

Permit Reference Number : WP3938SH

Operator : Wynnstay Group plc

Installation : Llansantffraid Mill

Form Number : A1

Reporting of Emissions to Air for the period from01/01/2013.....to.....31/12/2013.....

Emission Point	Substance / Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
A3	Particulate	50 mg/m ³ ^[6]	20.1	BS EN 13284	13/2/14 13.03	UKAS	+/- 0.6
A4	Particulate	90 mg/m ³ ^[6]	2.1	BS EN 13284	13/2/14 14.18	UKAS	+/- 0.6
A5	Particulate	50 mg/m ³ ^[6]	3.2	BS EN 13284	13/2/14 10.43	UKAS	+/- 0.4
A6	Particulate	35 mg/m ³ ^[6]	6.2	BS EN 13284	14/2/14 08.55	UKAS	+/- 0.6
A7	Particulate	Not applicable	3.1	BS EN 13284	14/2/14 10.59	UKAS	+/- 0.6

[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.

[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated, e.g. gas chromatography.

[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.

[4] The accreditation status of the equipment and/or the monitoring organisation, as appropriate, for the methods used for both sampling and analysis.

[5] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated. The following uncertainties are quoted on a different basis (basis as stated) – *{The basis of any other uncertainty figure needs to be stated. Where no figure is available the Agency will need to agree an appropriate uncertainty value.}*

[6] The emission limit values for particulate are expressed as a maximum individual value.

SignedS. Cipollaro.....
(authorised to sign as representative of the Operator)

Date.....03/03/14