

REFERENCE W1 Treated Effluent. 22nd July 2014.
Permit Reference Number: YP3539SX

Installation: Oakley Park Abattoir, Dolwen, Oakley Park, Llanidloes, Powys. SY18 6LX

Reporting of emissions to water (other than sewer) for the period from

Operator: Randall Parker Foods

Form Number: W1 Reference W1 Date - 22/7/2014

Time - 7.00am (lagoon sample)

Emission Point	Substance / Parameter	Emission Limit Value	Result [1]	Test Method [2]	Sample Date & Times [3]	Accreditation / Certification [4]	Uncertainty [5]
W1	BOD	40mg/l	4.75mg/l	BS EN 1899 - 1 (1998) ¹	22/7/2014 7.00am	UKAS 1349	- 11.4 %
W1	Suspended Solids	60mg/l	18mg/l	BS EN 872:1996, BS 6068 - 2.54:1996 ¹	22/7/2014 7.00am	UKAS 1349	- 9.8 %
W1	Ammoniacal Nitrogen (as N)	25mg/l	3.54mg/l	BS EN ISO 11732:1997 ¹	22/7/2014 7.00am	UKAS 1349	- 6.5 %
W1	Daily effluent flow rate	300 ³ m/day	No water discharge in July	To a relevant EN, BS, ISO standard as agreed in IC6	No discharge for July 2014	Mcerts	+/- 8%
W1	pH	6-10	6.56	BS 6068-2.50:1995 ISO 10523:1994	22/7/2014 7.00am	UKAS 1349	- 1.1 %

[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result given as the 'minimum - maximum' measured values.

[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated e.g. colorimetry.

[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements. Or flow/time proportional samples, the percentage of the process operating time covered by the monitoring is given.

[4] The accreditation status of the equipment and/or the monitoring organisation, as appropriate, for the methods used for both sampling and analysis.

[5] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated. The following uncertainties are quoted on a different basis (basis as stated).

Signed:John Eversfield..... Date: 22/7/2014
(authorised to sign as representative of the Operator)

Note -. No discharge to river from W1 - Centrifuge being carried out - lagoons all cleaned out and water stored after cleaning.

- 2 OCT 2014

REFERENCE W1 Treated Effluent. 21st August 2014
 Permit Reference Number: YP3539SX

Installation: Oakley Park Abattoir, Dolwen, Oakley Park, Llanidloes, Powys, SY18 6LX

Operator: Randall Parker Foods

Form Number: W1 Reference W1 Date - 21/8/2014

Reporting of emissions to water (other than sewer) for the period from

Time - 6.15am

Emission Point	Substance / Parameter	Emission Limit Value	Result [1]	Test Method [2]	Sample Date & Times [3]	Accreditation / Certification [4]	Uncertainty [5]
W1	BOD	40mg/l	5.3mg/l	BS EN 1899 - 1 (1998) ¹	21/8/2014 6.15am	UKAS 1349	- 11.4 %
W1	Suspended Solids	60mg/l	4mg/l	BS EN 872:1996, BS 6068 - 2.54:1996 ¹	21/8/2014 6.15am	UKAS 1349	- 9.8 %
W1	Ammoniacal Nitrogen (as N)	25mg/l	5.76mg/l	BS EN ISO 11732:1997 ¹	21/8/2014 6.15am	UKAS 1349	- 6.5 %
W1	Daily effluent flow rate	300 ³ m/day	148.963 ³ m/day Average daily flow.	To a relevant EN, BS, ISO standard as agreed in IC6	Average daily flow calculated on 25 discharges	Mcerts	+/- 8%
W1	pH	6-10	7.46	BS 6068-2.50:1995 ISO 10523:1994	21/8/2014 6.15am	UKAS 1349	- 1.1 %

[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result given as the 'minimum - maximum' measured values.

[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated e.g. colorimetry.

[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements. Or flow/time proportional samples, the percentage of the process operating time covered by the monitoring is given.

[4] The accreditation status of the equipment and/or the monitoring organisation, as appropriate, for the methods used for both sampling and analysis.

[5] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated. The following uncertainties are quoted on a different basis (basis as stated).

Signed:John Eversfield..... Date: 21/8/2014
 (authorised to sign as representative of the Operator)

Please also test for C.O.D.

REFERENCE W1 Treated Effluent. 11th September 2014

Permit Reference Number: YP35395X

Installation: Oakley Park Abattoir, Dolwen, Oakley Park, Llanidloes, Powys. SY18 6LX

Operator: Randall Parker Foods

Form Number: W1 Reference W1 Date - 11/9/2014

Reporting of emissions to water (other than sewer) for the period from

Time - 11:45am

Emission Point	Substance / Parameter	Emission Limit Value	Result [1]	Test Method [2]	Sample Date & Times [3]	Accreditation / Certification [4]	Uncertainty [5]
W1	BOD	40mg/l	4.3mg/l	BS EN 1899 - 1 (1998) ¹	11/9/2014	UKAS 1349	- 11.4 %
W1	Suspended Solids	60mg/l	>2mg/l	BS EN 872:1996, BS 6068 - 2.54:1996 ¹	11/9/2014	UKAS 1349	- 9.8 %
W1	Ammoniacal Nitrogen (as N)	25mg/l	8.24mg/l	BS EN ISO 11732:1997 ¹	11/9/2014	UKAS 1349	- 6.5 %
W1	Daily effluent flow rate	300 ³ m/day	178.92 ³ m/day average daily flow.	To a relevant EN, BS, ISO standard as agreed in IC6	Average daily flow calculated on 25 discharges	Mcerts	+/- 8%
W1	pH	6-10	7.36mg/l	BS 6068-2.50:1995 ISO 10523:1994	11/9/2014	UKAS 1349	- 1.1 %

[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result given as the 'minimum - maximum' measured values.

[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated e.g. colorimetry.

[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements. Or flow/time proportional samples, the percentage of the process operating time covered by the monitoring is given.

[4] The accreditation status of the equipment and/or the monitoring organisation, as appropriate, for the methods used for both sampling and analysis.

[5] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated. The following uncertainties are quoted on a different basis (basis as stated).

Signed:Gareth Gower..... Date: 11/9/2014
(authorised to sign as representative of the Operator)

Please also test for C.O.D.