

Schedule 5 - Notification

These pages outline the Information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

Part A

Permit Number	EPR/GP3235GH
Name of operator	Randall Parker Foods
Location of Facility	Dolwen ,Oakley Park,Llanidloes,Powys,SY18 6LX
Time and date of the detection	15/2/2016 at 9am

(a) Notification requirements for any activity that gives rise to an incident or accident which significantly affects or may significantly affect the environment	
To be notified Immediately	
Date and time of the event	15/02/16 9am
Reference or description of the location of the event	Small leak detected by refrigeration engineer.
Description of where any release into the environment took place	Small leak detected on oil separator associated with chiller plant RPF 01
Substances(s) potentially released	R404
Best estimate of the quantity or rate of release of substances	8kg
Measures taken, or intended to be taken, to stop any emission	Plant isolated and shut down. Refrigeration engineer on site carried out work,refilled system with 8kg R404 tested system and returned to service.
Description of the failure or accident.	Small leak detected on oil separator

(b) Notification requirements for the breach of a permit condition	
To be notified Immediately	
Emission point reference/ source	Chiller gas plant associated with RPFO1
Parameter(s)	
Limit	

Measured value and uncertainty	
Date and time of monitoring	
Measures taken, or intended to be taken, to stop the emission	Plant isolated and shut down. Refrigeration engineer on site carried out work, refilled system with 8kg R404 tested system and returned to service.

Time periods for notification following detection of a breach of a limit	
Parameter	Notification period

(c) In the event of a breach of permit condition which poses an immediate danger to human health or threatens to cause an immediate significant adverse effect on the environment:	
To be notified immediately	
Description of where the effect on the environment was detected	
Substances(s) detected	
Concentrations of substances detected	
Date of monitoring/sampling	

Part B - to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	
Measures taken, or intended to be taken, to prevent a recurrence of the incident	Plant isolated and shut down. Refrigeration engineer on site carried out work, refilled system with 8kg R404 tested system and returned to service.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	
The dates of any unauthorised emissions from the facility in the preceding 24 months.	29/6/2016 1/10/2016 13/2/2016

Name*	John Eversfield
Post	Technical Manager
Signature	
Date	18/2/2016

* authorised to sign on behalf of the operator