

GENERAL RESULTS LISTING

List of all results entered or expected for sample SM-24-FEB-2015-062993

Analysis ID	Component Name	Type	Result	Status
0007\$A/1	pH	N	7.83	E
0176\$OIL/1	Appearance (Pass = 1, Fail = 0)	N	1	E
0281\$D/1	Final weight of BOTTOM Filter	N	0.20510 g	E
0281\$D/1	Final weight of TOP Filter	N	0.20360 g	E
0281\$D/1	Initial weight of BOTTOM Filter	N	0.20510 g	E
0281\$D/1	Initial weight of TOP Filter	N	0.20250 g	E
0281\$D/1	Suspended solids	K	3.1 ppm_wt_v	E
0281\$D/1	Volume of water filtered	N	355 ml	E
0843\$ORG/1	Methanol	N	<3.00 ppm_wt_v	E
0843\$ORG/1	TMS	N	<1.00 ppm_wt_v	E

1100 ml³ emptied.