

20 MAY 2013

EMISSIONS MONITORING SURVEY

Prepared for:


**Bryn Posteg Landfill Site.
Llanidloes
Powys
SY18 6JJ**

Permit Number	: EPR/BU7766IC
Variation Number	: V004
Installation	: Landfill Flare
Visit Details	: Annual Compliance
Job Number	: P1560
Report Number	: R001
Report Issue Date	: 30th January 2013
Survey Dates	: 17th – 19th December 2012

Prepared by:

**Environmental Compliance Limited
Unit G1
Main Avenue
Treforest Industrial Estate
Pontypridd
CF37 5BF.**

**Tel: 01443 841760
Fax: 01443 841761**

Report Issue:		FINAL	
Report Prepared by:		Report Reviewed & Approved by MCERTS Level Two Technical Endorsements TE1, TE2, TE3 & TE4	
Name:	Jonathan Litterick	Name:	Andy Barnes
		MCERTS No:	MM 03 235
		Signature:	
Date:	28/01/13	Date:	30/01/13

This report is not to be used for contractual or engineering purposes unless this approval sheet is signed where indicated by the approver and the report is designated "FINAL".



Environmental Compliance Limited

Bryn Posteg Landfill Site
Permit No : EPR/BU77661C
Variation No : V004
Report Ref : P1560 : R001

Installation Name : Landfill Flare
Visit Details : Annual Compliance
Survey Dates : 17th – 19th December 2012
Report Issue Date : 30th January 2013

This report has been prepared by Environmental Compliance Limited (ECL) in their professional capacity as Environmental Consultants. The contents of the report reflect the conditions that prevailed and the information available or supplied at the time of its preparation. The report, and the information contained therein, is provided by ECL solely for use and reliance by the Client in performance of ECL's duties and liabilities under its contract with the Client. Until ECL has received payment in full as detailed in the quotation or contract the contents of this report remain the legal property of ECL. The contents of the report do not, in any way, purport to include any manner of legal advice or opinion.

Should the Client wish to release this report to a Third Party for the party's reliance, Environmental Compliance Ltd may, at its discretion, agree to such release provided that:

- Environmental Compliance Ltd gives written agreement prior to such release and ECL has received payment in full for all works/services undertaken;
- By release of the report to the Third Party, that Third Party does not acquire any rights, contractual or otherwise, whatsoever against Environmental Compliance Ltd and, accordingly, Environmental Compliance Ltd assume no duties, liabilities or obligations to that Third Party;
- Environmental Compliance Ltd accepts no responsibility for any loss or damage incurred by the Client or for any conflict of Environmental Compliance Ltd interests arising out of the Clients' release of this report to the Third Party.

In the event that a report is revised and re-issued, the client shall ensure that any earlier versions of the report, and any copies thereof, are void and such copies should be marked with the words "superseded and revised".

Opinions and Interpretation expressed within this report are outside the scope of the UKAS accreditation.

MCERTS requirements mean that comparison of results with emissions limit values is not permitted within this report.

TABLE OF CONTENTS

Section	Description	Page Number
	Document Control Sheet	
PART 1	EXECUTIVE SUMMARY	4
1	MONITORING OBJECTIVES	4
1.1	Monitoring Results	5
1.2	Operating Information	6
2	MONITORING DEVIATIONS	7
PART 2	SUPPORTING INFORMATION	8
3	SAMPLING STAFF DETAILS	8
4	SAMPLING PROTOCOLS / METHODOLOGIES	9
5	SAMPLE POINT DESCRIPTIONS	13
	EQUIPMENT IDs	14
	FIGURES	16
	TABLES	18
	VELOCITY TRAVERSE PROFILES	26
	FIELD CALIBRATION AND SAMPLING DATA	28
	LABORATORY ANALYSIS RESULTS	32
	UNCERTAINTY CALCULATIONS	41

PART 1 - EXECUTIVE SUMMARY

1 Monitoring Objectives

Environmental Compliance Ltd (ECL) was commissioned by **Bryn Posteg Landfill Site** to undertake an emission monitoring survey at their **Llanidloes**. This report presents the findings of the study.

The monitoring at this installation was carried out in accordance with our quotation reference **mdw/P1560/Q001**, for compliance check monitoring of emissions to air. The substances requested for monitoring at each emissions point are listed below:

Substances to be monitored	Emission Point Identification
	Landfill Flare Stack
Oxides of Nitrogen (as NO ₂)	• U
Sulphur Dioxide	• U
Carbon Monoxide	• U
Carbon Dioxide	• U
Oxygen	• U
Total Organic Carbon (TOC)	• U
Hydrogen Chloride	• U
Dioxins / Furans	• U
Non Methane VOC	• U

• Denotes the substances to be monitored.

U Denotes **UKAS accreditation is held for monitoring that substance, but does not mean that it has been claimed which will depend on whether the testing could be completed in accordance with the Standard Reference Method.**

Special Requirements: *"Normal Operation – Engine Not Running."*

Environmental Compliance Limited

Bryn Posteg Landfill Site
Permit No : EPR/BU77661C
Variation No : V004
Report Ref : P1560

: R001

Installation Name : Landfill Flare
Visit Details : Annual Compliance
Survey Dates : 17th - 19th December 2012
Report Issue Date : 30th January 2013

1.1 Monitoring Results

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty %	Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation for use of Method	Tick if non-conforming test (see Sections 2 & 5)	Operating Status
Flare Stack	Dioxin & Furans	...	0.035	ng/m ³	24	Dry & 3% O ₂	18/12/2012	13:30 - 17:30	BS EN 1948	UKAS / MCERTS	✓	Normal (Engine Not Running)
	TOCs as Carbon	10	4.65	mg/m ³	8		19/12/2012	12:05 - 13:05	BS EN 12619	UKAS / MCERTS		
	Oxides of Nitrogen (as NO ₂)	150	37.8	mg/m ³	2				BS EN 14792: 2005	UKAS / MCERTS		
	Carbon Monoxide	50	35.9	mg/m ³	3				BS EN 15058: 2006	UKAS / MCERTS		
	Sulphur Dioxide	...	58.4	mg/m ³	2		18/12/2012	14:00 - 16:59	EA TGN M21:V1.1 Jan 2010 (AM for BS EN 14791)	UKAS / MCERTS		
	Carbon Dioxide	...	6.75	%	4	Dry Gas			ISO 12039	UKAS / MCERTS		
	Oxygen	...	13.56	%	3				BS EN 14789: 2005	UKAS / MCERTS		
	Hydrogen Chloride	...	8.54	mg/m ³	13	Dry & 3% O ₂	19/12/2012	10:13 - 11:13	BS EN 1911	UKAS / MCERTS	✓	
	Non Methane VOC	5	4.57	mg/m ³	89		19/12/2012	12:05 - 13:05	BS EN 13649	NU	✓	

Notes

For CO & NO_x, the permit requires data to be reported as hourly averages.

The average figure presented for these parameters in Table 1.1, as well as for CO₂, SO₂ & O₂, is the maximum hourly average result during the 3hr sample period. All other hourly averages are presented in the tables section in the appendices of this report.

The uncertainty figures presented in Table 1.1 for NO_x, CO, SO₂, CO₂, O₂ & TOC are "measurement uncertainty" figures, which do not take into account the variability of the measured sample values. The "uncertainty of measurement results" figures, which do include this contribution, are presented in the appendices of the report for these determinands.

Emission Limit Value

Periodic Monitoring Result

Uncertainty

Reference Conditions

Monitoring Method Reference

Accreditation for use of Method

Operating Status

NU

NA

The emission limit value is that stated in the permit and will be expressed as a concentration or a mass emission. The result given is expressed in the same terms and units as the emission limit value.

The uncertainty associated with the quoted result is at the 95% confidence interval. The uncertainty results **DO NOT** take into account the effect of the sample location limitations.

All results are expressed at 273 K and 101.3kPa. The oxygen and moisture corrections are stated. The method stated is in accordance with the Environment Agency Technical Guidance Note M2, or other method approved by the Environment Agency.

The details indicate the accreditation for the use of the complete monitoring method, e.g. MCERTS, UKAS. If use of the method is not accredited "NA" is stated.

The details indicate the feedstock and the loading rate of the plant during monitoring.

Chemical Analysis on sample reagents was performed by an External Laboratory as detailed in Section 4

UKAS Accreditation Held but UKAS Accreditation cannot be claimed for the test as sampling did not comply with the Standard Reference Method (SRM), see section 2 & 5

Method is **NOT** UKAS Accredited.

Environmental Compliance Limited

Bryn Posteg Landfill Site
 Permit No : EPR/BU7766IC
 Variation No : V004
 Report Ref : P1560 : R001

Installation Name : Landfill Flare
 Visit Details : Annual Compliance
 Survey Dates : 17th - 18th December 2012
 Report Issue Date : 30th January 2013

1.2 Operating Information

Emission Point Reference	Process Type	Process Duration	Fuel	Feedstock	Abatement	Load	Comparison of Operator CEMS and Periodic Monitoring Results					
							Parameter	Date	Time	CEMS Results	Periodic Monitoring Results	Units
Flare Stack	Continuous	n/a	Gas	Landfill Gas	None	Normal	NP

Notes:

Process Type
 Process Duration
 Fuel
 Feedstock
 Abatement
 Load
 CEMS Data

State whether the process is a continuous or batch process.
 If a batch process, state the duration, frequency and details of the portion of the batch sampled. If continuous state "NA"
 If applicable, state the fuel type If not applicable state "NA"
 State the feedstock type
 State the type and whether operational during monitoring. If not applicable state "NA"
 State the normal load, throughput or rating of the plant
 Enter this data for each CEM installed if it is has been provided by operator otherwise state "NP" (NOT PROVIDED)

Bryn Posteg Landfill Site
Permit No : EPR/BU7766IC
Variation No : V004
Report Ref : P1560 : R001

Installation Name : Landfill Flare
Visit Details : Annual Compliance
Survey Dates : 17th – 19th December 2012
Report Issue Date : 30th January 2013

2 Monitoring Deviations

The objective of the survey was to measure the concentrations of pollutants from the processes / locations as detailed in Section 1. This survey meets the requirements of the site's **PPC Permit Number: EPR/BU7766IC** where UKAS and MCERTS accreditation has and could be claimed for the testing in the monitoring results table.

There was one modification to the sampling procedures (TPDs) listed in section 4. This was as follows:-

Non Methane VOC – ECL/TPD/84 is specifically for the monitoring of dry ambient gas. Testing of the flare stack required the modification of the TPD, to cool and dry the sample gas prior to passing it through the capture media (sorbent tube).

There was one substance deviation from the original and agreed emissions monitoring schedule:

Dioxins – Due to limited plant operation only 4 hours of sampling could be undertaken, rather than 6 hours as quoted.

Non-conforming tests are as follows:-

Due to the nature of the process and the limited access it was not possible to fully traverse the duct. All isokinetic sampling for **HCl & Dioxins** was undertaken at a single representative point, near the centre of the duct. Furthermore, the velocity was measured at a single point in the duct and was near to the lower limit of detection.

UKAS accreditation is not possible for the laboratory analysis stage of the **Non-Methane VOC** method.

The Uncertainty of the reported concentrations for these pollutant results DOES NOT take into account the effect of these non-conformities or sample location limitations.

Homogeneity tests have not been completed for pollutants at the flare stack and were not requested by client. Due to access limitations, it would not be safe to carry out such tests.

Environmental Compliance Limited

Bryn Posteg Landfill Site
Permit No : EPR/BU77661C
Variation No : V004
Report Ref : P1560 : R001

Installation Name : Landfill Flare
Visit Details : Annual Compliance
Survey Dates : 17th – 19th December 2012
Report Issue Date : 30th January 2013

PART 2 – SUPPORTING INFORMATION

3 SAMPLING STAFF DETAILS

Site Sampling Team

Names of Site Team	Dates on Site	MCERTS No.	LEVEL	Technical Endorsements
Jonathan Litterick	17 th – 19 th December 2012	MM 03 236	2	TE1, TE2, TE3, TE4
Matthew Broughton		MM 12 1196	Trainee	...

Report Reviewer

Name	MCERTS No.	LEVEL	Technical Endorsements
Andy Barnes	MM 03 235	2	TE1, TE2, TE3, TE4

Technical Endorsement Key:-

TE1 – Isokinetic Particulates, Temperature & Velocity Profiles, Oxygen.
TE2 – Isokinetic Extractive Pollutants:- Metals, Dioxin & Furans, PAHs, PCBs, HCl, HF.
TE3 – Non-Isokinetic Extractive Pollutants:- Speciated VOCs, HF, HCl, Cyanide.
TE4 – Continuous Analysers (Combustion Gases):- TOCs, CO, NOx, SO2.

Bryn Posteg Landfill Site
 Permit No : EPR/BU7766IC
 Variation No : V004
 Report Ref : P1560 : R001

Installation Name : Landfill Flare
 Visit Details : Annual Compliance
 Survey Dates : 17th – 19th December 2012
 Report Issue Date : 30th January 2013

4 SAMPLING PROTOCOLS / METHODOLOGIES

Any required modifications to the Technical Procedure Documents (TPDs) specified below will be detailed in section 2 of this report.

Combustion Gases (NO_x, SO₂, CO, O₂ & CO₂)

Measurements of combustion gases were carried out using an MCERTS Certified Horiba PG 250 portable stack analyser. Continuous monitoring of emissions was undertaken over each test period recording minute averaged data (one measurement every 60 seconds). The measurement techniques for each determinand are as follows:

<u>Determinand</u>	<u>Technique</u>	<u>SRM</u>
• NO _x	Chemiluminescence	BS EN 14792: 2005
• SO ₂	Non dispersive infrared	EA TGN M21
• CO	Non-dispersive infrared	BS EN 15058: 2006
• O ₂	Galvanic / Zirconia	BS EN 14789: 2005
• CO ₂	Non-dispersive infrared	ISO 12039

The analyser was set up with reference to the manufacturers operator handbook and the in-house technical procedure **ECL/TPD/033c**. The analyser was calibrated on site using certified gases which are traceable to ISO 17025. (with uncertainty <2%). Zero measurements were performed using Nitrogen. The analyser was calibrated directly into the sample inlet and then checked through the entire sampling system (including sampling probe, heated & unheated gas transport lines and gas drying/ conditioning system).

Data is presented graphically in the Figures Section, and the minute averaged data is given in the Tables Section.

Pressure, Temperature and Velocity

Testing was carried out using a sampling system in accordance with **BS EN 13284-1 & MID** and In-house technical procedure **ECL/TPD/022**.

Temperature was recorded using a thermocouple and digital temperature reader.

Velocity and pressure were recorded using an "L" type pitot and digital manometer, data being recorded in Pascals.

Environmental Compliance Limited

Bryn Posteg Landfill Site
Permit No : EPR/BU77661C
Variation No : V004
Report Ref : P1560 : R001

Installation Name : Landfill Flare
Visit Details : Annual Compliance
Survey Dates : 17th – 19th December 2012
Report Issue Date : 30th January 2013

TOCs as Carbon

Testing was carried out using an MCERTS Certified Signal 3030PM FID and heated gas sample line, with reference to the manufacturer's operation handbook **BS EN 12619** and in-house technical procedure **ECL/TPD/032**.

The analyser was calibrated on site using certified propane span gases which are traceable to ISO 17025 standard. (with uncertainty <2%). Zero measurements were performed using Nitrogen. The analyser was calibrated directly into the sample inlet and then checked through the entire sampling system (including sampling probe and heated gas transport lines). Data was corrected by molecular weight to TOCs as total carbon.

Data was recorded as minute averages over each test period. The data is presented in the Figures Section and the minute averaged data is detailed in the Tables Section.

The date of the last control gas mixture test on the FID was April 2012.

Hydrogen Chloride

Testing was carried out isokinetically, using a Universal Stack Sampling system in accordance with **BS EN 1911** and In-house technical procedure **ECL/TPD/036**. Non-isokinetic sampling can only take place if there are no droplets present in the stack gas.

In this method the stack gases are filtered to remove particulate matter then the gases are passed through a series of impingers. The first two or three impingers each containing 100ml of De-ionised Water and finally through an impinger containing a measured quantity of silica gel.

The impingers containing the de-ionised water are analysed for concentrations of Hydrogen Chloride by IC (Ion Chromatography).

Scientific Analysis Laboratories Ltd (SAL) who are situated in Manchester carried out the analysis of the samples. **SAL** are UKAS accredited for this analysis. In addition to the survey samples, appropriate field blanks and efficiency checks are submitted as part of the technical procedure.

Environmental Compliance Limited

Bryn Posteg Landfill Site
Permit No : EPR/BU77661C
Variation No : V004
Report Ref : P1560 : R001

Installation Name : Landfill Flare
Visit Details : Annual Compliance
Survey Dates : 17th – 19th December 2012
Report Issue Date : 30th January 2013

Dioxins & Furans - (Filter / Condenser Method)

Determination of **Dioxins & Furans** was carried out using a Universal Stack Sampling system in accordance with **BS EN 1948-1** and In-house technical procedure **ECL/TPD/031**.

In this method the stack gases are sampled via a heated titanium probe and are then filtered (110mm out-stack, heated quartz or GFA filter) to remove particulate matter. The filtered gases are then passed through a cooling condenser and spiked XAD absorber, a verification absorption stage is not used. The gases then pass through a condensate flask and a series of silica gel filled impingers.

The gases are cooled via the condenser where the cooled gases and condensate percolate through the XAD absorber accumulate in the condensate flask before being dried by the silica impingers.

Scientific Analysis Laboratories Ltd (SAL) who are situated in Manchester carried out the analysis of the samples. **SAL** are UKAS accredited for this analysis. In addition to the survey samples, appropriate field blanks are submitted as part of the technical procedure.

Prior to every sampling campaign, the sample train glassware (upstream of the silica impingers) is rinsed with solvents and then muffled at 450 °C for three hours, before being carefully capped for transport to site. If any of the glassware is re-used on site (for further samples) additional rinses of the glassware are taken prior to the re-use and kept for analysis in case of high results being obtained for the following sample.

The sorbent trap is filled with approx 70g of Amberlite XAD-2 resin, it is spiked with 0.4ng of 1,2,3,7,8-PeCDF & 1,2,3,7,8,9-HxCDF and 0.8ng of 1,2,3,4,7,8,9-HpCDF.

Water Vapour

Testing was carried out using a Universal Stack Sampling system in accordance with **BS EN 14790** and In-house technical procedure **ECL/TPD/082**.

In this method the stack gases are filtered (in-stack unheated filter or out-stack heated filter) to remove particulate matter. The gases are then passed through a **heated probe** and then to a cooled moisture trapping unit. All unheated parts of the sample train (outside the sample port) which come into contact with stack gas are weighed pre and post sampling in order to determine the weight gain.

After each test, a visual inspection of the last impinger is made to confirm that at least 50% of the silica gel column has not changed colour. This indicates satisfactory collection of water vapour.

Environmental Compliance Limited

Bryn Posteg Landfill Site
Permit No : EPR/BU7766IC
Variation No : V004
Report Ref : P1560 : R001

Installation Name : Landfill Flare
Visit Details : Annual Compliance
Survey Dates : 17th – 19th December 2012
Report Issue Date : 30th January 2013

Speciated VOC (Non-Methane VOC)

Non-continuous sampling for **Speciated VOC (Non-Methane VOC)** was carried out in based on **BS EN 13649** and In-house technical procedure **ECL/TPD/084**. In this method a metered volume of stack gas is extracted through a standard charcoal sorbent tube.

Scientific Analysis Laboratories Ltd (SAL) who are situated in Manchester carried out the analysis of the samples. **SAL** are **NOT UKAS** accredited for this analysis. In addition to the survey samples, appropriate field blanks and efficiency checks are submitted as part of the technical procedure.

Due to restrictions set out in BS EN 13649, MCERTS/UKAS accreditation can only be claimed when the target parameters are organic compounds, the sorbent tube used is a standard charcoal tube and when laboratory analysis is UKAS accredited and carried out by GC. If other tubes are used, or if analysis is by other means than GC, then usually only UKAS accreditation can be claimed, as long as the laboratory analysis is UKAS accredited. (MCERTS accreditation may still be claimed if prior approval is given for the modifications by the Environment Agency – details will be given in section 2 of this report).

Laboratory analysis **cannot** be UKAS accredited for "non-methane VOC", "Total VOC" or "TOP 10 compounds".

For the subcontract laboratory to claim UKAS accreditation for analysis, the internal recovery of a spiking compound (desorption efficiency from tube) needs to be above 80%. If it falls below 80% this will be noted on the analysis certificate.

Bryn Posteg Landfill Site
 Permit No : EPR/BU7766IC
 Variation No : V004
 Report Ref : P1560 : R001

Installation Name : Landfill Flare
 Visit Details : Annual Compliance
 Survey Dates : 17th – 19th December 2012
 Report Issue Date : 30th January 2013

5 SAMPLE POINT DESCRIPTION

The homogeneity test is applicable to combustion processes. This includes but is not restricted to, those regulated under the Waste Incineration Directive (WID) and the Large Combustion Plant Directive (LCPD).

Homogeneity testing has not been completed at this location.

The sample location that was monitored is detailed below:-

Flare Stack

The stack diameter is 2.3m and sampling was performed using one of the four ports located close to the exit of the stack.

As a result of the sampling point being located in close proximity to the exit of the stack the sampling location does not currently meet the requirements detailed in *Technical Guidance Note (Monitoring) M1 "Sampling requirements for stack-emission monitoring"* Environment Agency, January 2007, Version 4.1, and BS EN 13284-1.

Also, due to health and safety considerations, the flare was turned off in order to set up equipment and then turned back on again after the probe had been inserted into the stack and the monitoring team had descended from the sampling platform.

Due to the restricted access to the platform, all isokinetic samples were taken at a single point near to the centre of the duct, as they could not be taken from the designated number of sample points.

Access to the stack was gained by means of a temporary ladder secured to the side of temporary scaffolding complete with an in date scafftag.

A 240V power supply was available inside the engine room building directly below the sampling location.

Environmental Compliance Limited

Bryn Posteg Landfill Site
Permit No : **EPR/BU7766IC**
Variation No : **V004**
Report Ref : **P1560 : R001**

Installation Name : **Landfill Flare**
Visit Details : **Annual Compliance**
Survey Dates : **17th – 19th December 2012**
Report Issue Date : **30th January 2013**

EQUIPMENT IDs
(Pre site checklist from SSP)

Bryn Posteg Landfill Site
Permit No : **EPR/BU7766IC**
Varlation No : **V004**
Report Ref : **P1560** : **R001**

Installation Name : Landfill Flare
Visit Details : Annual Compliance
Survey Dates : 17th – 19th December 2012
Report Issue Date : 30th January 2013

(Completed before departure to site and when on site in full)

[illegible]Page 15 of 52

Environmental Compliance Limited

Bryn Posteg Landfill Site
Permit No : EPR/BU7766IC
Variation No : V004
Report Ref : P1560 : R001

Installation Name : Landfill Flare
Visit Details : Annual Compliance
Survey Dates : 17th – 19th December 2012
Report Issue Date : 30th January 2013

FIGURES

Environmental Compliance Limited

Bryn Posteg Landfill Site
Permit No : EPR/BU77661C
Variation No : V004
Report Ref : P1560 : R001

Installation Name : Landfill Flare
Visit Details : Annual Compliance
Survey Dates : 17th - 19th December 2012
Report Issue Date : 30th January 2013

Figure 1

TOC Continuous Emissions Data recorded from Bryn Posteg Landfill Flare
between 12:05 and 13:05, on 19/12/2012.

Reference Conditions (273K, 101.3kPa, 3% Oxygen & Dry Gas)





Figure 2

Combustion Gases Continuous Emissions Data recorded from Bryn Posteg Landfill Flare
between 14:00 and 16:59, on 18/12/2012.

Reference Conditions (273K, 101.3kPa, 3% Oxygen & Dry Gas)



Environmental Compliance Limited

Bryn Posteg Landfill Site
Permit No : EPR/BU7766IC
Variation No : V004
Report Ref : P1560 : R001

Installation Name : Landfill Flare
Visit Details : Annual Compliance
Survey Dates : 17th – 19th December 2012
Report Issue Date : 30th January 2013

TABLES

Environmental Compliance Limited

Bryn Posteg Landfill Site
 Permit No : EPR/BU7766IC
 Variation No : V004
 Report Ref : P1560 : R001

Installation Name : Landfill Flare
 Visit Details : Annual Compliance
 Survey Dates : 17th – 19th December 2012
 Report Issue Date : 30th January 2013

Table 1 - TOC

Data Recorded from Bryn Posteg Landfill Flare

Sample Period: 12:05 – 13:05 on the 19th December 2012

Volumetric Flowrate (Reference Conditions) = 2.90 m³/sec *

	Average	Emission Rate
	mg/m³	Kg/hr
TOCs (as carbon)*	4.65	0.049

*** Reference Conditions (273K, 101.3 kPa, 3% Oxygen & Dry Gas)**

Table 2 – Carbon Monoxide

Data Recorded from Bryn Posteg Landfill Flare

Sample Period: 14:00 – 16:59 on the 18th December 2012

Volumetric Flowrate (Reference Conditions) = 2.90 m³/sec *

	Average	Emission Rate
Carbon Monoxide*	mg/m³	Kg/hr
14:00 – 14:59	24.5	0.256
15:00 – 15:59	26.7	0.279
16:00 – 16:59	35.9	0.375

*** Reference Conditions (273K, 101.3 kPa, 3% Oxygen & Dry Gas)**

Environmental Compliance Limited

Bryn Posteg Landfill Site
 Permit No : EPR/BU7766IC
 Variation No : V004
 Report Ref : P1560 : R001

Installation Name : Landfill Flare
 Visit Details : Annual Compliance
 Survey Dates : 17th – 19th December 2012
 Report Issue Date : 30th January 2013

Table 3 – Oxides of Nitrogen (as NO₂)
Data Recorded from Bryn Posteg Landfill Flare

Sample Period: 14:00 – 16:59 on the 18th December 2012

Volumetric Flowrate (Reference Conditions) = 2.90 m³/sec *

	Average	Emission Rate
Oxides of Nitrogen*	mg/m³	Kg/hr
14:00 – 14:59	37.8	0.395
15:00 – 15:59	36.5	0.381
16:00 – 16:59	36.2	0.378

*** Reference Conditions (273K, 101.3 kPa, 3% Oxygen & Dry Gas)**

Table 4 – Sulphur Dioxide
Data Recorded from Bryn Posteg Landfill Flare

Sample Period: 14:00 – 16:59 on the 18th December 2012

Volumetric Flowrate (Reference Conditions) = 2.90 m³/sec *

	Average	Emission Rate
Sulphur Dioxide*	mg/m³	Kg/hr
14:00 – 14:59	58.4	0.610
15:00 – 15:59	49.6	0.622
16:00 – 16:59	47.7	0.498

*** Reference Conditions (273K, 101.3 kPa, 3% Oxygen & Dry Gas)**

Environmental Compliance Limited

Bryn Posteg Landfill Site
 Permit No : EPR/BU7766IC
 Variation No : V004
 Report Ref : P1560 : R001

Installation Name : Landfill Flare
 Visit Details : Annual Compliance
 Survey Dates : 17th – 19th December 2012
 Report Issue Date : 30th January 2013

**Table 5 – Carbon Dioxide
 Data Recorded from Bryn Posteg Landfill Flare**

Sample Period: 14:00 – 16:59 on the 18th December 2012

	Average	Emission Rate
Carbon Dioxide*	% (v/v)	Kg/hr
14:00 – 14:59	6.75	...
15:00 – 15:59	6.44	...
16:00 – 16:59	6.33	...

*** Reference Conditions (273K, 101.3k & Dry Gas)**

**Table 6 – Oxygen
 Data Recorded from Bryn Posteg Landfill Flare**

Sample Period: 14:00 – 16:59 on the 18th December 2012

	Average	Emission Rate
Oxygen*	% (v/v)	Kg/hr
14:00 – 14:59	12.96	...
15:00 – 15:59	13.39	...
16:00 – 16:59	13.56	...

*** Reference Conditions (273K, 101.3 kPa & Dry Gas)**

Environmental Compliance Limited

Bryn Posteg Landfill Site
 Permit No : EPR/BU7766IC
 Variation No : V004
 Report Ref : P1560 : R001

Installation Name : Landfill Flare
 Visit Details : Annual Compliance
 Survey Dates : 17th – 19th December 2012
 Report Issue Date : 30th January 2013

Table 7 – Hydrogen Chloride

Data Recorded from Flare - Landfill

Emission Parameter	Units	HCl	Blank
Stack Diameter	metres	2.30	...
Area of Sample Plane	m ²	4.155	...
Moisture Content	%	10.17	...
Oxygen Content	%	13.31	...
Stack Temperature	°C	959	...
Gas Velocity (as Measured)	m/sec	8.70	...
Gas Velocity (Reference Conditions)	m/sec*	0.70	...
Volumetric Flowrate (as Measured)	m ³ /sec	36.15	...
Volumetric Flowrate (Reference Conditions)	m ³ /sec*	2.911	...
Sample Date	...	19/12/2012	...
Sample Period	...	10:13 - 11:13	...
Sample Volume (reference Conditions)	m ³ *	0.325	0.325
Isokinetic Sampling Rate	%	112.24	...
Sample Reference (ECL ID)	ECL/12/	7532-33	7534
Mass of Hydrogen Chloride Collected	mg	2.78	0.02
Concentration of Hydrogen Chloride	mg/m ³ *	8.54	0.06
Emission Rate of Hydrogen Chloride	g/hr	89.43	...
Expanded Uncertainty (% Relative)	%	13	...

*Reference Conditions (273K, 101.3kPa, 3% Oxygen, Dry Gas)

Environmental Compliance Limited

Bryn Posteg Landfill Site
 Permit No : EPR/BU7766IC
 Variation No : V004
 Report Ref : P1560 : R001

Installation Name : Landfill Flare
 Visit Details : Annual Compliance
 Survey Dates : 17th - 19th December 2012
 Report Issue Date : 30th January 2013

Table 8 – Non Methane VOC

Bryn Posteg
 Llanidloes Flare

Emission Parameter	Units	Value
Stack Diameter	mm	2300
Area of Sample Plane	m ²	4.155
Moisture Content	%	10.51
Expanded Uncertainty of Moisture (%Relative)	%	13.40
Measured Oxygen (Dry)	%/vol	13.31
Meter Temperature	°C	9.50
Stack Temperature	°C	953.67
Sample Date	...	19/12/2012
Sample Period	...	12:05 - 13:05
Sample Volume (as Measured)	m ³	0.23
Sample Volume (reference Conditions)	m ³ *	0.22
Sample Tube Results		NM VOC
Sample Reference ECL/13/7537	Units	Concentration
Concentration of NM VOC	mg/m ³	4.57
		88.49%
		0.042

*Reference Conditions: 273 K, 101.3 kPa, 3% Oxygen & Dry Gas

Environmental Compliance Limited

Bryn Posteg Landfill Site
 Permit No : EPR/BU7766IC
 Variation No : V004
 Report Ref : P1560 : R001

Installation Name : Landfill Flare
 Visit Details : Annual Compliance
 Survey Dates : 17th – 19th December 2012
 Report Issue Date : 30th January 2013

Table 9 – Dioxin

Data Recorded from Landfill - Stack Flare

Emission Parameter	Units	Test DIOXIN		
Stack Diameter	metres	2.3		
-	-	-		
Area of sample plane	m ²	4.155		
Moisture Content	%	10.45		
Moisture Expanded Uncertainty	%(Relative)	5.32		
Stack Temperature	°C	890		
Oxygen Concentration	%	13.31		
Gas velocity (as Measured)	m/sec	8.31		
Gas velocity (Reference Conditions)	m/sec*	0.71		
Volumetric Flowrate (as Measured)	m ³ /sec	34.51		
Volumetric Flowrate (Reference	m ³ /sec*	2.96		
Sample Date	18/12/2012			
Sample Period	13:30 - 17:30			
Sample Reference	ECL/12/7525-7528			
Sample Volume (Reference Conditions)	m ³ *	1.32		
Isokinetic Sampling Rate	%	112.33		
Species	Sample Reference: ECL/12/7525-7528		Blank Reference: ECL/12/7529-7531	
	Conc. ng/m ³ *	TEQ ng/m ³ *	Conc. ng/m ³ *	TEQ ng/m ³ *
Dioxins 2,3,7,8 Isomers	0.17	0.020	0.073	0.012
Total Dioxins Non – Targeted	0.00	...	0.00	...
Furans 2,3,7,8 Isomers	0.13	0.015	0.030	0.0032
Total Furans Non – Targeted	0.00	...	0.00	...
TOTAL	...	0.035	...	0.015
Range	...	0.022 - 0.035
% Uncertainty	...	24

*Reference Conditions 273K, 101.3kPa, 3% Oxygen, Dry Gas

Environmental Compliance Limited

Bryn Posteg Landfill Site
Permit No : EPR/BU7766IC
Variation No : V004
Report Ref : P1560 : R001

Installation Name : Landfill Flare
Visit Details : Annual Compliance
Survey Dates : 17th - 19th December 2012
Report Issue Date : 30th January 2013

Table 10 – Dioxins

Data Recorded from Landfill - Stack Flare on the 18/12/12, 13:30 - 17:30

Species	Blank Reference: ECL/12/7529-7531 TEQ ng/m³*	EEC Toxic Equivalent Factor (TEF)	Sample Ref.: ECL/12/7525-7528		WHO Humans & Mammals (TEF)	Humans & Mammals TEQ ng/m³*	WHO Fish (TEF)	Fish TEQ ng/m³*	WHO Birds (TEF)	Birds TEQ ng/m³*
			Concentration ng/m³*	TEQ ng/m³*						
Dioxins - 2,3,7,8 Isomers										
2,3,7,8 - TCDD	0.0014	1	0.0050	0.0050	1	0.0050	1	0.0050	1	0.0050
1,2,3,7,8 - PeCDD	0.0099	0.5	0.027	0.014	1	0.027	1	0.027	1	0.027
1,2,3,4,7,8 - HxCDD	0.00017	0.1	0.0041	0.00041	0.1	0.00041	0.5	0.0021	0.05	0.00021
1,2,3,6,7,8 - HxCDD	0.00020	0.1	0.0046	0.00046	0.1	0.00046	0.01	0.000046	0.01	0.000046
1,2,3,7,8,9 - HxCDD	0.00020	0.1	0.0038	0.00038	0.1	0.00038	0.01	0.000038	0.1	0.00038
1,2,3,4,6,7,8 - HpCDD	0.000056	0.01	0.017	0.00017	0.01	0.00017	0.001	0.000017	0.001	0.000017
OCDD	0.000040	0.001	0.11	0.00011	0.0001	0.000011	0	***	0	***
Total Dioxins - Non - Targeted Isomers										
TCDD	***	0	0.000000	***	0	***	0	***	0	***
PeCDD	***	0	0.000000	***	0	***	0	***	0	***
HxCDD	***	0	0.000000	***	0	***	0	***	0	***
HpCDD	***	0	0.000000	***	0	***	0	***	0	***
Furans - 2,3,7,8 Isomers										
2,3,7,8 - TCDF	0.00027	0.1	0.024	0.0024	0.1	0.0024	0.05	0.0012	1	0.024
1,2,3,7,8 - PeCDF	0.00012	0.05	0.031	0.0016	0.05	0.0016	0.05	0.0016	0.1	0.0031
2,3,4,7,8 - PeCDF	0.0019	0.5	0.014	0.0072	0.5	0.0072	0.5	0.0072	1	0.014
1,2,3,4,7,8 - HxCDF	0.00017	0.1	0.014	0.0014	0.1	0.0014	0.1	0.0014	0.1	0.0014
1,2,3,6,7,8 - HxCDF	0.00020	0.1	0.011	0.0011	0.1	0.0011	0.1	0.0011	0.1	0.0011
2,3,4,6,7,8 - HxCDF	0.00029	0.1	0.0099	0.00099	0.1	0.00099	0.1	0.00099	0.1	0.00099
1,2,3,7,8,9 - HxCDF	0.00022	0.1	0.0024	0.00024	0.1	0.00024	0.1	0.00024	0.1	0.00024
1,2,3,4,6,7,8 - HpCDF	0.000036	0.01	0.014	0.00014	0.01	0.00014	0.01	0.00014	0.01	0.00014
1,2,3,4,7,8,9 - HpCDF	0.000036	0.01	0.0024	0.000024	0.01	0.000024	0.01	0.000024	0.01	0.000024
OCDF	0.000005	0.001	0.011	0.000011	0.0001	0.000001	0.0001	0.000001	0.0001	0.000001
Total Furans - Non - Targeted Isomers										
TCDF	***	0	0.000000	***	0	***	0	***	0	***
PeCDF	***	0	0.000000	***	0	***	0	***	0	***
HxCDF	***	0	0.000000	***	0	***	0	***	0	***
HpCDF	***	0	0.000000	***	0	***	0	***	0	***
TOTAL	0.015	***	***	0.035	***	0.049	***	0.048	***	0.079
Range	***	***	***	0.022 - 0.035	***	0.021 - 0.049	***	0.021 - 0.048	***	0.051 - 0.079
% Uncertainty	***	***	***	23.7	***	29.8	***	30.1	***	25.4

*Reference Conditions 273K, 101.3kPa, 3% Oxygen, Dry Gas

Environmental Compliance Limited

Bryn Posteg Landfill Site
Permit No : EPR/BU7766IC
Variation No : V004
Report Ref : P1560 : R001

Installation Name : Landfill Flare
Visit Details : Annual Compliance
Survey Dates : 17th – 19th December 2012
Report Issue Date : 30th January 2013

VELOCITY TRAVERSE PROFILES

Environmental Compliance Limited

Bryn Posteg Landfill Site
Permit No : EPR/BU7766IC
Variation No : V004
Report Ref : P1560 : R001

Installation Name : Landfill Flare
Visit Details : Annual Compliance
Survey Dates : 17th - 19th December 2012
Report Issue Date : 30th January 2013

Combustion Gases

		CO ppm	CO2 %	NO ppm	O2 %	SO2 ppm	
Formula ref	Analysers Range	500	25	500	25	3000	
	Repeatability at Zero	2.5	0.125	2.5	0.125	15	
A	Span Gas Concentration Applied	201.1	5.041	262.5	15.008	1017	
B	Zero Gas Concentration Applied	0	0	0	0	0	
	Direct Cal						
	Zero	0.113	0.010	0.013	0.009	0.148	
	Span	201.179	5.058	264.134	15.171	1019.729	
	Zero	0.653	0.010	0.013	0.006	16.349	
	Difference (Zero)	1.0661111	0	0.000556	0.074389	16.78778	
	<2*Repeatability @ Zero?	YES	YES	YES	YES	YES	
C	Pre Test						
D	Zero	0.005	0.010	0.013	0.000	3.350	
	Span	199.738	5.027	264.198	15.074	1011.333	
	Difference (Zero)	0.7377778	0	0.000556	0.073389	12.96944	
Drift	<2*Repeatability @ Zero?	YES	YES	YES	YES	YES	If Red CONTACT QM
Correction	Difference (Span)	1.4418661	0.029889	0.08425	0.09775	8.395833	
	<2% Relative	YES	YES	YES	YES	YES	If Red CONTACT QM
F	Post Test						
G	Zero	3.0136889	0.052361	1.077770	0.173611	3.361111	
	Span	198.45167	4.9615	257.42	15.02033	1011.3	
	Difference (Zero)	2.9288889	0.042361	1.064444	0.165778	0.011111	
	<2% of Span Value	YES	YES	YES	YES	YES	If Red apply Drift
	Difference (Span)	1.2858335	0.065	6.777914	0.053166	0.033333	
	<2% of Span Value	YES	YES	NO	YES	YES	If Red apply Drift
	Drift <5%?	YES	YES	YES	YES	YES	If Red CONTACT QM

TOC

		TOC ppm	
Analysers Range		40	
Repeatability at Zero		0.4	
Span Gas Concentration Applied		10.06	
Zero Gas Concentration Applied		0	
Direct Cal	Zero	0.00	
	Span	10.06	
	Zero	0.56	
Difference (Zero)		0.560436118	
<2*Repeatability @ Zero?		YES	
Pre Test			
	Zero	0.20	
	Span	9.82	
Difference (Zero)		0.36109788	
<5% (2% for O ₂) Relative to Direct Span		YES	If Red CONTACT QM
Difference (Span)		0.239015131	
<5% (2% for O ₂) Relative to Direct Span		YES	If Red CONTACT QM
Post Test			
	Zero	0.17	
	Span	9.92	
Difference (Zero)		0.026	
<2% of Analyser Range		YES	If Red apply Drift
Difference (Span)		0.095	
<2% of Analyser Range		YES	If Red apply Drift
Drift <5% of Analyser Range?		YES	If Red CONTACT QM

Environmental Compliance Limited

Bryn Posteg Landfill Site
Permit No : **EPR/BU7766IC**
Variation No : **V004**
Report Ref : **P1560** : **R001**

Installation Name : Landfill Flare
Visit Details : Annual Compliance
Survey Dates : 17th – 19th December 2012
Report Issue Date : 30th January 2013

Non Methane VOC

Environmental Compliance Limited						SAMPLE TUBE DATA SAMPLING PROFORMA							
Client		Bryn Ponies Landfills Site	Circular / rectangular / ellipse	Stack Diameter (mm)	2300	Barometer ID	351	Date of Test	19/12/2012				
Site						Balance ID	368	Sample Start Time	12:05				
Location		Landfill Site				Pump ID	u009	Sample End Time	13:05				
Stack ID		Flare	Stack Area (m ²)	4.155	Meter ID	u009		Duration	60				
Test No.		NM VOC	Barometric Pressure (mb)	958	DGM Yd or micount	1.0151		Measured O2	13.31				
Job No		P1560	Heated Line ID	---	tube condensation free for analysis sample (yin)			O2 Uncertainty %Vol	2.50				
ECL Site Staff		JL & MB	Impinger ID	559									
Notes													
SMT	IS Notes	Sample	Leak 1	Time (start and stop) Leak 1 (min:sec)	Leak 2	Time (start and stop) Leak 2 (min:sec)	Total						
		Start Volume	1674343.0	12:02:00	1674573.0	13:13:00		Start Weight (g)					
		Final Volume	1674573.0	12:03:00	1674573.0	13:14:00		End Weight (g)					
		Total Volume	235.0	0.0	0.0		230.0	Total weight (g)					
Time Point		0 to 10	10 to 20	20 to 30	30 to 40								
Heated Line Temp °C		---	---	---	---								
Tube Temp °C		8	9	8	8								
Stack Temp °C		958	951	964	954								
Meter Temp In °C		10	10	10	10								
Meter Temp Out °C		10	10	10	10								
Time Point		40 to 50	50 to 60										
Heated Line Temp °C		---	---										
Tube Temp °C		8	8										
Stack Temp °C		945	941										
Meter Temp In °C		9	8										
Meter Temp Out °C		9	8										
Time Point													
Heated Line Temp °C													
Tube Temp °C													
Stack Temp °C													
Meter Temp In °C													
Meter Temp Out °C													
Silica		(IF USED)											
~50% Spent at end?		YES											
Start Weight (g)		0											
End Weight (g)		20											
Total weight (g)		20											
Total		20											

Dioxins


[illegible]

Bryn Posteg Landfill Site
Permit No : EPR/BU77661C
Variation No : V004
Report Ref : P1560 : F

Installation Name : Landfill Flare
Visit Details : Annual Compliance
Survey Dates : 17th – 19th December 2012
Report Issue Date : 30th January 2013

Environmental Compliance Limited	Traverse Data Profoma	Date of Measurement	17/12/2012
---	------------------------------	----------------------------	-------------------

Company					
Bryn Posteg		Stack Diameter (mm)	2300		
Llanidloes		Port Length (mm)	90	Pilot Id	1
Land Fill Site		Duct Length (mm) A		Stack Thermocouple ID	488
Stack		Duct width (mm) B		Stack Temp Reader ID	466
Flare				Manometer ID	370
P1560		Barometric Pressure, (mb)	969	Barometer ID	356
Operators		Static Pressure, (mm H ₂ O)	1		351
JL & MB					

[illegible]

Average temp (K)	1223
------------------	------

Suitability of Sampling Position	Actual Stack Conditions
Permitted highest lowest flow pressure ratio = 9:1	1:1
Average deviation of flow from axis $<15^{\circ}$	OK
x-sectional area for stacks = πr^2	4.15 m ²
x-sectional area for ducts = L x B	0.000 m ²
Suitability of Position for Sampling	OK

Slack Moisture	10.2	%
Measured Oxygen	13.31	%
Measured Carbon Dioxide	6.75	%
Dry Gas Molecular Weight	29.6124	g/n mole

Gas Velocity (as Measured)	8.59	m/sec
Gas Velocity (Reference Conditions)	0.70	m/sec
Volumetric Flowrate (as Measured)	35.69	m ³ /sec
Volumetric Flowrate (Reference Conditions)	9.00	m ³ /sec

Reference Conditions: 273K, 101.3kPa, 3% Oxygen, Dry Gas

Page 27 of 52

Environmental Compliance Limited

Bryn Posteg Landfill Site
Permit No : EPR/BU7766IC
Variation No : V004
Report Ref : P1560 : R001

Installation Name : Landfill Flare
Visit Details : Annual Compliance
Survey Dates : 17th – 19th December 2012
Report Issue Date : 30th January 2013

FIELD CALIBRATION AND SAMPLING DATA

Environmental Compliance Limited

Bryn Posteg Landfill Site
Permit No : EPR/BU7766IC
Variation No : V004
Report Ref : P1560 : R001

Installation Name : Landfill Flare
Visit Details : Annual Compliance
Survey Dates : 17th - 19th December 2012
Report Issue Date : 30th January 2013

Hydrogen Chloride

Environmental Compliance Limited		PARTICULATE DATA SAMPLING PROFORMA		Date of Measurement		19/12/2012																																																																																																					
ECL/TPD/		34		Time taken to change Ports		8																																																																																																					
Start Time		10:13		End Time		11:13																																																																																																					
Client	Bryn Posteg Landfill Site	Stack Profile	Circular	Console id	U009	Barometer id	351																																																																																																				
Location	Landfill	Stack Area (m²)	4.15	Pump id	U009	Nozzle id	872																																																																																																				
Stack ID	Pire	Barometric Pressure (mb)	998	Probe id	H11EMP	Nozzle size	12.06																																																																																																				
Test No	W21	Stack Pres. (mm Hg)	0	OSHA Yd	1.2151	Filter No	488																																																																																																				
Test No	W21	Filter coefficient	1	AMP	50.36	Filter ID	488																																																																																																				
Job No	P1560	Probe Heater Settings (°C)	100	Impinger id	659	Print Box ID	134																																																																																																				
ECL Site Ref	21-MS	Hot Box Setting (°C)	100	Balance id	208																																																																																																						
If moisture was not measured see detailed notes below.																																																																																																											
Additional Moisture Weighings																																																																																																											
<table border="1"> <thead> <tr> <th>Impinger</th> <th>SOL</th> <th>Start Weight (g)</th> <th>End Weight (g)</th> <th>Total weight (g)</th> </tr> </thead> <tbody> <tr> <td>Impinger 1</td> <td>H₂O</td> <td>205.3</td> <td>205.3</td> <td>0</td> </tr> <tr> <td>Impinger 2</td> <td>H₂O</td> <td>205.3</td> <td>205.3</td> <td>0</td> </tr> <tr> <td>Impinger 3</td> <td>H₂O</td> <td>205.3</td> <td>205.3</td> <td>0</td> </tr> <tr> <td>Impinger 4</td> <td>Empty</td> <td>205.3</td> <td>205.3</td> <td>0</td> </tr> <tr> <td>Impinger 5</td> <td>Empty</td> <td>205.3</td> <td>205.3</td> <td>0</td> </tr> <tr> <td>Impinger 6</td> <td>Empty</td> <td>205.3</td> <td>205.3</td> <td>0</td> </tr> <tr> <td>Impinger 7</td> <td>Empty</td> <td>205.3</td> <td>205.3</td> <td>0</td> </tr> <tr> <td>Impinger 8</td> <td>Empty</td> <td>205.3</td> <td>205.3</td> <td>0</td> </tr> </tbody> </table>								Impinger	SOL	Start Weight (g)	End Weight (g)	Total weight (g)	Impinger 1	H ₂ O	205.3	205.3	0	Impinger 2	H ₂ O	205.3	205.3	0	Impinger 3	H ₂ O	205.3	205.3	0	Impinger 4	Empty	205.3	205.3	0	Impinger 5	Empty	205.3	205.3	0	Impinger 6	Empty	205.3	205.3	0	Impinger 7	Empty	205.3	205.3	0	Impinger 8	Empty	205.3	205.3	0																																																							
Impinger	SOL	Start Weight (g)	End Weight (g)	Total weight (g)																																																																																																							
Impinger 1	H ₂ O	205.3	205.3	0																																																																																																							
Impinger 2	H ₂ O	205.3	205.3	0																																																																																																							
Impinger 3	H ₂ O	205.3	205.3	0																																																																																																							
Impinger 4	Empty	205.3	205.3	0																																																																																																							
Impinger 5	Empty	205.3	205.3	0																																																																																																							
Impinger 6	Empty	205.3	205.3	0																																																																																																							
Impinger 7	Empty	205.3	205.3	0																																																																																																							
Impinger 8	Empty	205.3	205.3	0																																																																																																							
<table border="1"> <thead> <tr> <th>Sample</th> <th>Leak 1</th> <th>Leak 2</th> <th>Leak 3</th> <th>Leak 4</th> <th>Leak 5</th> <th>Total</th> </tr> </thead> <tbody> <tr> <td>Start Volume</td> <td>197458.0</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Final Volume</td> <td>197458.0</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Total Volume</td> <td>0.0</td> <td>0.0</td> <td>0.0</td> <td>0.0</td> <td>0.0</td> <td>0.0</td> </tr> </tbody> </table>								Sample	Leak 1	Leak 2	Leak 3	Leak 4	Leak 5	Total	Start Volume	197458.0						Final Volume	197458.0						Total Volume	0.0	0.0	0.0	0.0	0.0	0.0																																																																								
Sample	Leak 1	Leak 2	Leak 3	Leak 4	Leak 5	Total																																																																																																					
Start Volume	197458.0																																																																																																										
Final Volume	197458.0																																																																																																										
Total Volume	0.0	0.0	0.0	0.0	0.0	0.0																																																																																																					
<table border="1"> <thead> <tr> <th>Leak Check</th> <th>First</th> <th>Second</th> <th>Third</th> <th>Fourth</th> <th>Fifth</th> <th>Measured Cl₂ Atmosphere</th> <th>K Factor</th> </tr> </thead> <tbody> <tr> <td>Leak Check</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> <td>13.31</td> <td>18.2</td> </tr> <tr> <td>Measured Cl₂ Atmosphere</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> <td>13.31</td> <td>18.2</td> </tr> <tr> <td>Measured Carbon Dioxide %</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> <td>13.31</td> <td>18.2</td> </tr> <tr> <td>Measured Carbon Monoxide %</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> <td>13.31</td> <td>18.2</td> </tr> </tbody> </table>								Leak Check	First	Second	Third	Fourth	Fifth	Measured Cl ₂ Atmosphere	K Factor	Leak Check	0	0	0	0	0	13.31	18.2	Measured Cl ₂ Atmosphere	0	0	0	0	0	13.31	18.2	Measured Carbon Dioxide %	0	0	0	0	0	13.31	18.2	Measured Carbon Monoxide %	0	0	0	0	0	13.31	18.2																																																												
Leak Check	First	Second	Third	Fourth	Fifth	Measured Cl ₂ Atmosphere	K Factor																																																																																																				
Leak Check	0	0	0	0	0	13.31	18.2																																																																																																				
Measured Cl ₂ Atmosphere	0	0	0	0	0	13.31	18.2																																																																																																				
Measured Carbon Dioxide %	0	0	0	0	0	13.31	18.2																																																																																																				
Measured Carbon Monoxide %	0	0	0	0	0	13.31	18.2																																																																																																				
<table border="1"> <thead> <tr> <th>Transverse Point</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>Total</th> </tr> </thead> <tbody> <tr> <td>Time Point (mins)</td> <td>0-5</td> <td>5-10</td> <td>10-15</td> <td>15-20</td> <td>20-25</td> <td>25-30</td> <td>30-35</td> <td>35-40</td> <td></td> </tr> <tr> <td>Alt (mm H2O)</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> </tr> <tr> <td>K factor</td> <td>15.20</td> <td>15.20</td> <td>15.20</td> <td>15.20</td> <td>15.20</td> <td>15.20</td> <td>15.20</td> <td>15.20</td> <td>15.20</td> </tr> <tr> <td>Alt (O/Rifice)</td> <td>15.20</td> <td>15.20</td> <td>15.20</td> <td>15.20</td> <td>15.20</td> <td>15.20</td> <td>15.20</td> <td>15.20</td> <td>15.20</td> </tr> <tr> <td>Water (Tm in)</td> <td>8.00</td> <td>8.00</td> <td>8.00</td> <td>8.00</td> <td>8.00</td> <td>8.00</td> <td>8.00</td> <td>8.00</td> <td>8.00</td> </tr> <tr> <td>Water (Tm out)</td> <td>8.00</td> <td>8.00</td> <td>8.00</td> <td>8.00</td> <td>8.00</td> <td>8.00</td> <td>8.00</td> <td>8.00</td> <td>8.00</td> </tr> <tr> <td>Stack Temp (T_{st})</td> <td>880.00</td> <td>880.00</td> <td>880.00</td> <td>880.00</td> <td>880.00</td> <td>880.00</td> <td>880.00</td> <td>880.00</td> <td>880.00</td> </tr> <tr> <td>Impinger Y Outlet</td> <td>8.00</td> <td>8.00</td> <td>8.00</td> <td>8.00</td> <td>8.00</td> <td>8.00</td> <td>8.00</td> <td>8.00</td> <td>8.00</td> </tr> <tr> <td>Vacuum (T_{hg})</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> </tr> </tbody> </table>								Transverse Point	CP	CP	CP	CP	CP	CP	CP	CP	Total	Time Point (mins)	0-5	5-10	10-15	15-20	20-25	25-30	30-35	35-40		Alt (mm H2O)	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	K factor	15.20	15.20	15.20	15.20	15.20	15.20	15.20	15.20	15.20	Alt (O/Rifice)	15.20	15.20	15.20	15.20	15.20	15.20	15.20	15.20	15.20	Water (Tm in)	8.00	8.00	8.00	8.00	8.00	8.00	8.00	8.00	8.00	Water (Tm out)	8.00	8.00	8.00	8.00	8.00	8.00	8.00	8.00	8.00	Stack Temp (T _{st})	880.00	880.00	880.00	880.00	880.00	880.00	880.00	880.00	880.00	Impinger Y Outlet	8.00	8.00	8.00	8.00	8.00	8.00	8.00	8.00	8.00	Vacuum (T _{hg})	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
Transverse Point	CP	CP	CP	CP	CP	CP	CP	CP	Total																																																																																																		
Time Point (mins)	0-5	5-10	10-15	15-20	20-25	25-30	30-35	35-40																																																																																																			
Alt (mm H2O)	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00																																																																																																		
K factor	15.20	15.20	15.20	15.20	15.20	15.20	15.20	15.20	15.20																																																																																																		
Alt (O/Rifice)	15.20	15.20	15.20	15.20	15.20	15.20	15.20	15.20	15.20																																																																																																		
Water (Tm in)	8.00	8.00	8.00	8.00	8.00	8.00	8.00	8.00	8.00																																																																																																		
Water (Tm out)	8.00	8.00	8.00	8.00	8.00	8.00	8.00	8.00	8.00																																																																																																		
Stack Temp (T _{st})	880.00	880.00	880.00	880.00	880.00	880.00	880.00	880.00	880.00																																																																																																		
Impinger Y Outlet	8.00	8.00	8.00	8.00	8.00	8.00	8.00	8.00	8.00																																																																																																		
Vacuum (T _{hg})	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00																																																																																																		
<table border="1"> <thead> <tr> <th>Transverse Point</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>Total</th> </tr> </thead> <tbody> <tr> <td>Time Point (mins)</td> <td>40-45</td> <td>45-50</td> <td>50-55</td> <td>55-60</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Alt (mm H2O)</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td></td> <td></td> <td></td> <td></td> <td>1.00</td> </tr> <tr> <td>K factor</td> <td>15.20</td> <td>15.20</td> <td>15.20</td> <td>15.20</td> <td></td> <td></td> <td></td> <td></td> <td>15.20</td> </tr> <tr> <td>Alt (O/Rifice)</td> <td>15.20</td> <td>15.20</td> <td>15.20</td> <td>15.20</td> <td></td> <td></td> <td></td> <td></td> <td>15.20</td> </tr> <tr> <td>Water (Tm in)</td> <td>8.00</td> <td>8.00</td> <td>8.00</td> <td>8.00</td> <td></td> <td></td> <td></td> <td></td> <td>8.00</td> </tr> <tr> <td>Water (Tm out)</td> <td>8.00</td> <td>8.00</td> <td>8.00</td> <td>8.00</td> <td></td> <td></td> <td></td> <td></td> <td>8.00</td> </tr> <tr> <td>Stack Temp (T_{st})</td> <td>880.00</td> <td>880.00</td> <td>880.00</td> <td>880.00</td> <td></td> <td></td> <td></td> <td></td> <td>880.00</td> </tr> <tr> <td>Impinger Y Outlet</td> <td>8.00</td> <td>8.00</td> <td>8.00</td> <td>8.00</td> <td></td> <td></td> <td></td> <td></td> <td>8.00</td> </tr> <tr> <td>Vacuum (T_{hg})</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td></td> <td></td> <td></td> <td></td> <td>1.00</td> </tr> </tbody> </table>								Transverse Point	CP	CP	CP	CP	CP	CP	CP	CP	Total	Time Point (mins)	40-45	45-50	50-55	55-60						Alt (mm H2O)	1.00	1.00	1.00	1.00					1.00	K factor	15.20	15.20	15.20	15.20					15.20	Alt (O/Rifice)	15.20	15.20	15.20	15.20					15.20	Water (Tm in)	8.00	8.00	8.00	8.00					8.00	Water (Tm out)	8.00	8.00	8.00	8.00					8.00	Stack Temp (T _{st})	880.00	880.00	880.00	880.00					880.00	Impinger Y Outlet	8.00	8.00	8.00	8.00					8.00	Vacuum (T _{hg})	1.00	1.00	1.00	1.00					1.00
Transverse Point	CP	CP	CP	CP	CP	CP	CP	CP	Total																																																																																																		
Time Point (mins)	40-45	45-50	50-55	55-60																																																																																																							
Alt (mm H2O)	1.00	1.00	1.00	1.00					1.00																																																																																																		
K factor	15.20	15.20	15.20	15.20					15.20																																																																																																		
Alt (O/Rifice)	15.20	15.20	15.20	15.20					15.20																																																																																																		
Water (Tm in)	8.00	8.00	8.00	8.00					8.00																																																																																																		
Water (Tm out)	8.00	8.00	8.00	8.00					8.00																																																																																																		
Stack Temp (T _{st})	880.00	880.00	880.00	880.00					880.00																																																																																																		
Impinger Y Outlet	8.00	8.00	8.00	8.00					8.00																																																																																																		
Vacuum (T _{hg})	1.00	1.00	1.00	1.00					1.00																																																																																																		
<table border="1"> <thead> <tr> <th>Transverse Point</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>Total</th> </tr> </thead> <tbody> <tr> <td>Time Point (mins)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Alt (mm H2O)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>K factor</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Alt (O/Rifice)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Water (Tm in)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Water (Tm out)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp (T_{st})</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Impinger Y Outlet</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Vacuum (T_{hg})</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>								Transverse Point	CP	CP	CP	CP	CP	CP	CP	CP	Total	Time Point (mins)										Alt (mm H2O)										K factor										Alt (O/Rifice)										Water (Tm in)										Water (Tm out)										Stack Temp (T _{st})										Impinger Y Outlet										Vacuum (T _{hg})									
Transverse Point	CP	CP	CP	CP	CP	CP	CP	CP	Total																																																																																																		
Time Point (mins)																																																																																																											
Alt (mm H2O)																																																																																																											
K factor																																																																																																											
Alt (O/Rifice)																																																																																																											
Water (Tm in)																																																																																																											
Water (Tm out)																																																																																																											
Stack Temp (T _{st})																																																																																																											
Impinger Y Outlet																																																																																																											
Vacuum (T _{hg})																																																																																																											
<table border="1"> <thead> <tr> <th>Transverse Point</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>Total</th> </tr> </thead> <tbody> <tr> <td>Time Point (mins)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Alt (mm H2O)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>K factor</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Alt (O/Rifice)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Water (Tm in)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Water (Tm out)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp (T_{st})</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Impinger Y Outlet</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Vacuum (T_{hg})</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>								Transverse Point	CP	CP	CP	CP	CP	CP	CP	CP	Total	Time Point (mins)										Alt (mm H2O)										K factor										Alt (O/Rifice)										Water (Tm in)										Water (Tm out)										Stack Temp (T _{st})										Impinger Y Outlet										Vacuum (T _{hg})									
Transverse Point	CP	CP	CP	CP	CP	CP	CP	CP	Total																																																																																																		
Time Point (mins)																																																																																																											
Alt (mm H2O)																																																																																																											
K factor																																																																																																											
Alt (O/Rifice)																																																																																																											
Water (Tm in)																																																																																																											
Water (Tm out)																																																																																																											
Stack Temp (T _{st})																																																																																																											
Impinger Y Outlet																																																																																																											
Vacuum (T _{hg})																																																																																																											
<table border="1"> <thead> <tr> <th>Transverse Point</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>Total</th> </tr> </thead> <tbody> <tr> <td>Time Point (mins)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Alt (mm H2O)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>K factor</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Alt (O/Rifice)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Water (Tm in)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Water (Tm out)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp (T_{st})</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Impinger Y Outlet</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Vacuum (T_{hg})</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>								Transverse Point	CP	CP	CP	CP	CP	CP	CP	CP	Total	Time Point (mins)										Alt (mm H2O)										K factor										Alt (O/Rifice)										Water (Tm in)										Water (Tm out)										Stack Temp (T _{st})										Impinger Y Outlet										Vacuum (T _{hg})									
Transverse Point	CP	CP	CP	CP	CP	CP	CP	CP	Total																																																																																																		
Time Point (mins)																																																																																																											
Alt (mm H2O)																																																																																																											
K factor																																																																																																											
Alt (O/Rifice)																																																																																																											
Water (Tm in)																																																																																																											
Water (Tm out)																																																																																																											
Stack Temp (T _{st})																																																																																																											
Impinger Y Outlet																																																																																																											
Vacuum (T _{hg})																																																																																																											
<table border="1"> <thead> <tr> <th>Transverse Point</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>Total</th> </tr> </thead> <tbody> <tr> <td>Time Point (mins)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Alt (mm H2O)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>K factor</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Alt (O/Rifice)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Water (Tm in)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Water (Tm out)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp (T_{st})</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Impinger Y Outlet</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Vacuum (T_{hg})</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>								Transverse Point	CP	CP	CP	CP	CP	CP	CP	CP	Total	Time Point (mins)										Alt (mm H2O)										K factor										Alt (O/Rifice)										Water (Tm in)										Water (Tm out)										Stack Temp (T _{st})										Impinger Y Outlet										Vacuum (T _{hg})									
Transverse Point	CP	CP	CP	CP	CP	CP	CP	CP	Total																																																																																																		
Time Point (mins)																																																																																																											
Alt (mm H2O)																																																																																																											
K factor																																																																																																											
Alt (O/Rifice)																																																																																																											
Water (Tm in)																																																																																																											
Water (Tm out)																																																																																																											
Stack Temp (T _{st})																																																																																																											
Impinger Y Outlet																																																																																																											
Vacuum (T _{hg})																																																																																																											
<table border="1"> <thead> <tr> <th>Transverse Point</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>Total</th> </tr> </thead> <tbody> <tr> <td>Time Point (mins)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Alt (mm H2O)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>K factor</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Alt (O/Rifice)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Water (Tm in)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Water (Tm out)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp (T_{st})</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Impinger Y Outlet</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Vacuum (T_{hg})</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>								Transverse Point	CP	CP	CP	CP	CP	CP	CP	CP	Total	Time Point (mins)										Alt (mm H2O)										K factor										Alt (O/Rifice)										Water (Tm in)										Water (Tm out)										Stack Temp (T _{st})										Impinger Y Outlet										Vacuum (T _{hg})									
Transverse Point	CP	CP	CP	CP	CP	CP	CP	CP	Total																																																																																																		
Time Point (mins)																																																																																																											
Alt (mm H2O)																																																																																																											
K factor																																																																																																											
Alt (O/Rifice)																																																																																																											
Water (Tm in)																																																																																																											
Water (Tm out)																																																																																																											
Stack Temp (T _{st})																																																																																																											
Impinger Y Outlet																																																																																																											
Vacuum (T _{hg})																																																																																																											
<table border="1"> <thead> <tr> <th>Transverse Point</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>Total</th> </tr> </thead> <tbody> <tr> <td>Time Point (mins)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Alt (mm H2O)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>K factor</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Alt (O/Rifice)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Water (Tm in)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Water (Tm out)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp (T_{st})</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Impinger Y Outlet</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Vacuum (T_{hg})</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>								Transverse Point	CP	CP	CP	CP	CP	CP	CP	CP	Total	Time Point (mins)										Alt (mm H2O)										K factor										Alt (O/Rifice)										Water (Tm in)										Water (Tm out)										Stack Temp (T _{st})										Impinger Y Outlet										Vacuum (T _{hg})									
Transverse Point	CP	CP	CP	CP	CP	CP	CP	CP	Total																																																																																																		
Time Point (mins)																																																																																																											
Alt (mm H2O)																																																																																																											
K factor																																																																																																											
Alt (O/Rifice)																																																																																																											
Water (Tm in)																																																																																																											
Water (Tm out)																																																																																																											
Stack Temp (T _{st})																																																																																																											
Impinger Y Outlet																																																																																																											
Vacuum (T _{hg})																																																																																																											
<table border="1"> <thead> <tr> <th>Transverse Point</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>Total</th> </tr> </thead> <tbody> <tr> <td>Time Point (mins)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Alt (mm H2O)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>K factor</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Alt (O/Rifice)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Water (Tm in)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Water (Tm out)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp (T_{st})</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Impinger Y Outlet</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Vacuum (T_{hg})</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>								Transverse Point	CP	CP	CP	CP	CP	CP	CP	CP	Total	Time Point (mins)										Alt (mm H2O)										K factor										Alt (O/Rifice)										Water (Tm in)										Water (Tm out)										Stack Temp (T _{st})										Impinger Y Outlet										Vacuum (T _{hg})									
Transverse Point	CP	CP	CP	CP	CP	CP	CP	CP	Total																																																																																																		
Time Point (mins)																																																																																																											
Alt (mm H2O)																																																																																																											
K factor																																																																																																											
Alt (O/Rifice)																																																																																																											
Water (Tm in)																																																																																																											
Water (Tm out)																																																																																																											
Stack Temp (T _{st})																																																																																																											
Impinger Y Outlet																																																																																																											
Vacuum (T _{hg})																																																																																																											
<table border="1"> <thead> <tr> <th>Transverse Point</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>Total</th> </tr> </thead> <tbody> <tr> <td>Time Point (mins)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Alt (mm H2O)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>K factor</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Alt (O/Rifice)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Water (Tm in)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Water (Tm out)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp (T_{st})</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Impinger Y Outlet</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Vacuum (T_{hg})</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>								Transverse Point	CP	CP	CP	CP	CP	CP	CP	CP	Total	Time Point (mins)										Alt (mm H2O)										K factor										Alt (O/Rifice)										Water (Tm in)										Water (Tm out)										Stack Temp (T _{st})										Impinger Y Outlet										Vacuum (T _{hg})									
Transverse Point	CP	CP	CP	CP	CP	CP	CP	CP	Total																																																																																																		
Time Point (mins)																																																																																																											
Alt (mm H2O)																																																																																																											
K factor																																																																																																											
Alt (O/Rifice)																																																																																																											
Water (Tm in)																																																																																																											
Water (Tm out)																																																																																																											
Stack Temp (T _{st})																																																																																																											
Impinger Y Outlet																																																																																																											
Vacuum (T _{hg})																																																																																																											
<table border="1"> <thead> <tr> <th>Transverse Point</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>Total</th> </tr> </thead> <tbody> <tr> <td>Time Point (mins)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Alt (mm H2O)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>K factor</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Alt (O/Rifice)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Water (Tm in)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Water (Tm out)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp (T_{st})</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Impinger Y Outlet</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Vacuum (T_{hg})</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>								Transverse Point	CP	CP	CP	CP	CP	CP	CP	CP	Total	Time Point (mins)										Alt (mm H2O)										K factor										Alt (O/Rifice)										Water (Tm in)										Water (Tm out)										Stack Temp (T _{st})										Impinger Y Outlet										Vacuum (T _{hg})									
Transverse Point	CP	CP	CP	CP	CP	CP	CP	CP	Total																																																																																																		
Time Point (mins)																																																																																																											
Alt (mm H2O)																																																																																																											
K factor																																																																																																											
Alt (O/Rifice)																																																																																																											
Water (Tm in)																																																																																																											
Water (Tm out)																																																																																																											
Stack Temp (T _{st})																																																																																																											
Impinger Y Outlet																																																																																																											
Vacuum (T _{hg})																																																																																																											
<table border="1"> <thead> <tr> <th>Transverse Point</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>Total</th> </tr> </thead> <tbody> <tr> <td>Time Point (mins)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Alt (mm H2O)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>K factor</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Alt (O/Rifice)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Water (Tm in)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Water (Tm out)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp (T_{st})</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Impinger Y Outlet</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Vacuum (T_{hg})</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>								Transverse Point	CP	CP	CP	CP	CP	CP	CP	CP	Total	Time Point (mins)										Alt (mm H2O)										K factor										Alt (O/Rifice)										Water (Tm in)										Water (Tm out)										Stack Temp (T _{st})										Impinger Y Outlet										Vacuum (T _{hg})									
Transverse Point	CP	CP	CP	CP	CP	CP	CP	CP	Total																																																																																																		
Time Point (mins)																																																																																																											
Alt (mm H2O)																																																																																																											
K factor																																																																																																											
Alt (O/Rifice)																																																																																																											
Water (Tm in)																																																																																																											
Water (Tm out)																																																																																																											
Stack Temp (T _{st})																																																																																																											
Impinger Y Outlet																																																																																																											
Vacuum (T _{hg})																																																																																																											
<table border="1"> <thead> <tr> <th>Transverse Point</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>Total</th> </tr> </thead> <tbody> <tr> <td>Time Point (mins)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Alt (mm H2O)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>K factor</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Alt (O/Rifice)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Water (Tm in)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Water (Tm out)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp (T_{st})</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Impinger Y Outlet</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Vacuum (T_{hg})</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>								Transverse Point	CP	CP	CP	CP	CP	CP	CP	CP	Total	Time Point (mins)										Alt (mm H2O)										K factor										Alt (O/Rifice)										Water (Tm in)										Water (Tm out)										Stack Temp (T _{st})										Impinger Y Outlet										Vacuum (T _{hg})									
Transverse Point	CP	CP	CP	CP	CP	CP	CP	CP	Total																																																																																																		
Time Point (mins)																																																																																																											
Alt (mm H2O)																																																																																																											
K factor																																																																																																											
Alt (O/Rifice)																																																																																																											
Water (Tm in)																																																																																																											
Water (Tm out)																																																																																																											
Stack Temp (T _{st})																																																																																																											
Impinger Y Outlet																																																																																																											
Vacuum (T _{hg})																																																																																																											
<table border="1"> <thead> <tr> <th>Transverse Point</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>CP</th> <th>Total</th> </tr> </thead> <tbody> <tr> <td>Time Point (mins)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Alt (mm H2O)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>K factor</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Alt (O/Rifice)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Water (Tm in)</td> <td></td> <td></td> <td></td></tr></tbody></table>								Transverse Point	CP	CP	CP	CP	CP	CP	CP	CP	Total	Time Point (mins)										Alt (mm H2O)										K factor										Alt (O/Rifice)										Water (Tm in)																																																	
Transverse Point	CP	CP	CP	CP	CP	CP	CP	CP	Total																																																																																																		
Time Point (mins)																																																																																																											
Alt (mm H2O)																																																																																																											
K factor																																																																																																											
Alt (O/Rifice)																																																																																																											
Water (Tm in)																																																																																																											

Environmental Compliance Limited

Bryn Posteg Landfill Site
Permit No : EPR/BU77661C
Variation No : V004
Report Ref : P1580 : R001

Installation Name : Landfill Flare
Visit Details : Annual Compliance
Survey Dates : 17th – 19th December 2012
Report Issue Date : 30th January 2013

LABORATORY ANALYSIS RESULTS

Environmental Compliance Limited

Bryn Posteg Landfill Site
Permit No : EPR/BU7766IC
Variation No : V004
Report Ref : P1560 : R001

Installation Name : Landfill Flare
Visit Details : Annual Compliance
Survey Dates : 17th – 19th December 2012
Report Issue Date : 30th January 2013

Dioxins



Scientific Analysis Laboratories is a
limited company registered in England and
Wales (No 2514788) whose address is at
Hadfield House, Hadfield Street, Manchester M16 9FE

Scientific Analysis Laboratories Ltd Certificate of Analysis

Hadfield House
Hadfield Street
Combrook
Manchester
M16 9FE
Tel : 0161 874 2400
Fax : 0161 874 2404

Report Number: 309928-1

Date of Report: 15-Jan-2013

Customer: Environmental Compliance Ltd
Building 26
Bay 6
First Avenue
Penarct Trading Estate
Kingswinford
DY6 7TB

Customer Contact: Mr Jonathon Litterick

Customer Job Reference: P1560
Customer Purchase Order: E0956
Date Job Received at SAL: 24-Dec-2012
Date Analysis Started: 30-Dec-2012
Date Analysis Completed: 15-Jan-2013

The results reported relate to samples received in the laboratory
Opinions and interpretations expressed herein are outside the scope of UKAS accreditation
This report should not be reproduced except in full without the written approval of the laboratory
Tests covered by this certificate were conducted in accordance with SAL SOPs
All results have been reviewed in accordance with QP22



Report checked
and authorised by
Kayleigh McCann
Project Manager

Issued by :
Kayleigh McCann
Project Manager

Validity unknown

Digitally signed by Kayleigh
McCann
Date: 2013.01.15 11:07 GMT
Reason: Issue
Location: SAL

Page 1 of 6

Environmental Compliance Limited

Bryn Posteg Landfill Site
 Permit No : EPR/BU77661C
 Variation No : V004
 Report Ref : P1560 : R001

Installation Name : Landfill Flare
 Visit Details : Annual Compliance
 Survey Dates : 17th – 19th December 2012
 Report Issue Date : 30th January 2013

Summary Of Results

Composite (Filt, Trap, Wash)

Dioxins and Dioxin-like PCBs

SAL Reference	Customer Sample Reference	Analysis	Symbol	ITEQ Toxic Equivalents ng	
				Lower Bound	Upper Bound
309928 005	Combined ECU12/7527 + ECU12/7528 + ECU12/7525 + ECU12/7528	Dioxins and Furans (BS EN 1948:06)	U	0.028	0.046
309928 009	Combined ECU12/7529 + ECU12/7531 + ECU12/7530	Dioxins and Furans (BS EN 1948:06)	U	0.00053	0.020
309928 013	Combined METHOD BLANK TRAP + METHOD BLANK FILTER + METHOD BLANK WASH	Dioxins and Furans (BS EN 1948:06)	U	0.0	0.0064

Sampling Recoveries

SAL Reference	Customer Sample Reference	Determined	Sampling Recovery %
309928 005	Combined ECU12/7527 + ECU12/7528 + ECU12/7525 + ECU12/7528	1,2,3,7,8-PeCDF	107
		1,2,3,7,8,9-HxCDF	100
		1,2,3,4,7,8,9-HxCDF	97
309928 009	Combined ECU12/7529 + ECU12/7531 + ECU12/7530	1,2,3,7,8-PeCDF	101
		1,2,3,7,8,9-HxCDF	121
		1,2,3,4,7,8,9-HxCDF	122

Environmental Compliance Limited

Bryn Posteg Landfill Site
 Permit No : EPR/BU77661C
 Variation No : V004
 Report Ref : P1560 : R001

Installation Name : Landfill Fiere
 Visit Details : Annual Compliance
 Survey Dates : 17th – 19th December 2012
 Report Issue Date : 30th January 2013

Composite (Filt, Trap, Wash)

Customer Sample Reference : Combined ECU/12/7527 + ECU/12/7526 +
 ECU/12/7525 + ECU/12/7528
 SAL Sample Reference : 309928 005

Dioxins and Furans (BS EN 1948:06)

Technique : GC/MS (HR)

Determinand	Symbol	LOD ng	Result ng	Internal Recovery %	ITEQ Toxic Equivalents ng	
					Lower Bound	Upper Bound
2,3,7,8-TCDD	U	0.0015	0.0066	103	0.0066	0.0066
1,2,3,7,8-PeCDD	U	0.036	<0.036	90	0.0	0.018
1,2,3,4,7,8-HxCDD	U	0.0012	0.0054	130	0.0054	0.0054
1,2,3,6,7,8-HxCDD	U	0.0018	0.0061	96	0.0061	0.0061
1,2,3,7,8,9-HxCDD	U	0.0018	0.0060		0.0050	0.0060
1,2,3,4,6,7,8-HpCDD	U	0.0027	0.023	80	0.0023	0.0023
OCDD	U	0.0053	0.34	56	0.0014	0.0014
Dioxins Totals :					0.0066	0.027
2,3,7,8-TCDF	U	0.0014	0.032	109	0.0032	0.0032
1,2,3,7,8-PeCDF	U	0.0020	0.041		0.0021	0.0021
2,3,4,7,8-PeCDF	U	0.0028	0.019	74	0.0095	0.0095
1,2,3,4,7,8-HxCDF	U	0.0013	0.018	120	0.0018	0.0018
1,2,3,6,7,8-HxCDF	U	0.0015	0.044	111	0.0014	0.0014
2,3,4,6,7,8-HxCDF	U	0.0014	0.043	184	0.0013	0.0013
1,2,3,7,8,9-HxCDF	U	0.0023	0.032		0.0032	0.0032
1,2,3,4,6,7,8-HpCDF	U	0.0031	0.019	95	0.0019	0.0019
1,2,3,4,7,8,9-HpCDF	U	0.0051	<0.0011		0.0	0.00003
OCDF	U	0.0056	0.015	51	0.00001	0.00001
Furans Totals :					0.020	0.020
Totals :					0.028	0.046

Environmental Compliance Limited

Bryn Posteg Landfill Site
Permit No : EPR/BU77661C
Variation No : V004
Report Ref : P1560 : R001

Installation Name : Landfill Flare
Visit Details : Annual Compliance
Survey Dates : 17th – 19th December 2012
Report Issue Date : 30th January 2013

Composite (Filt, Trap, Wash)

Customer Sample Reference : Combined ECL/12/7529 + ECL/12/7531 +
ECL/12/7530
SAL Sample Reference : 309928 009

Dioxins and Furans (BS EN 1948:06)

Technique : GC/MS (HR)

Determinand	Symbol	LOD ng	Result ng	Internal Recovery %	ITEQ Toxic Equivalents ng	
					Lower Bound	Upper Bound
2,3,7,8-TCDD	U	0.0019	<0.0019	77	0.0	0.0019
1,2,3,7,8-PeCDD	U	0.026	<0.026	72	0.0	0.013
1,2,3,4,7,8-HxCDD	U	0.0022	<0.0022	124	0.0	0.00022
1,2,3,6,7,8-HxCDD	U	0.0026	<0.0026	94	0.0	0.00026
1,2,3,7,8,9-HxCDD	U	0.0026	<0.0026		0.0	0.00026
1,2,3,4,6,7,8-HpCDD	U	0.0031	0.0074	75	0.00007	0.00007
OCDD	U	0.0067	0.003	45	0.00005	0.00005
Dioxins Totals :					0.00013	0.016
2,3,7,8-TCDF	U	0.0017	0.0035	88	0.00035	0.00035
1,2,3,7,8-PeCDF	U	0.0032	<0.0032		0.0	0.00016
2,3,4,7,8-PeCDF	U	0.0049	<0.0049	51	0.0	0.0024
1,2,3,4,7,8-HxCDF	U	0.0022	<0.0022	124	0.0	0.00022
1,2,3,6,7,8-HxCDF	U	0.0026	<0.0026	93	0.0	0.00026
2,3,4,6,7,8-HxCDF	U	0.0038	<0.0038	54	0.0	0.00038
1,2,3,7,8,9-HxCDF	U	0.0029	<0.0029		0.0	0.00029
1,2,3,4,6,7,8-HpCDF	U	0.0047	0.0047	86	0.00005	0.00005
1,2,3,4,7,8,9-HpCDF	U	0.0047	<0.0047		0.0	0.00005
OCDF	U	0.0059	0.0008	51	0.00001	0.00001
Furans Totals :					0.00040	0.0042
Totals :					0.00053	0.020

Environmental Compliance Limited

Bryn Posteg Landfill Site
 Permit No : EPR/BU7766IC
 Variation No : V004
 Report Ref : P1560 : R001

Installation Name : Landfill Flare
 Visit Details : Annual Compliance
 Survey Dates : 17th – 19th December 2012
 Report Issue Date : 30th January 2013

Composite (Filt, Trap, Wash)

Customer Sample Reference : Combined METHOD BLANK TRAP +
 METHOD BLANK FILTER + METHOD
 BLANK WASH
 SAL Sample Reference : 309928 013

Dioxins and Furans (BS EN 1948:06)

Technique : GC/MS (HR)

Determinand	Symbol	LOD ng	Result ng	Internal Recovery %	ITEQ Toxic Equivalents ng	
					Lower Bound	Upper Bound
2,3,7,8-TCDD	U	0.0020	<0.0020	88	0.0	0.0020
1,2,3,7,8-PeCDD	U	0.0021	<0.0021	70	0.0	0.0010
1,2,3,4,7,8-HxCDD	U	0.0021	<0.0021	71	0.0	0.00021
1,2,3,6,7,8-HxCDD	U	0.0021	<0.0021	72	0.0	0.00021
1,2,3,7,8,9-HxCDD	U	0.0021	<0.0021		0.0	0.00021
1,2,3,4,6,7,8-HpCDD	U	0.0038	<0.0038	63	0.0	0.00004
OCDD	U	0.0072	<0.0072	42	0.0	0.00001
Dioxins Totals :					0.0	0.00037
2,3,7,8-TCDF	U	0.0024	<0.0024	83	0.0	0.00024
1,2,3,7,8-PeCDF	U	0.0024	<0.0024		0.0	0.00012
2,3,4,7,8-PeCDF	U	0.0024	<0.0024	61	0.0	0.0012
1,2,3,4,7,8-HxCDF	U	0.0021	<0.0021	70	0.0	0.00021
1,2,3,6,7,8-HxCDF	U	0.0023	<0.0023	66	0.0	0.00023
2,3,4,6,7,8-HxCDF	U	0.0022	<0.0022	68	0.0	0.00022
1,2,3,7,8,9-HxCDF	U	0.0035	<0.0035		0.0	0.00035
1,2,3,4,6,7,8-HpCDF	U	0.0048	<0.0048	63	0.0	0.00006
1,2,3,4,7,8,9-HxCDF	U	0.0048	<0.0048		0.0	0.00005
OCDF	U	0.0069	<0.0069	43	0.0	0.00001
Furans Totals :					0.0	0.0027
Totals :					0.0	0.0064

Environmental Compliance Limited

Bryn Posteg Landfill Site
Permit No : EPR/BU77681C
Variation No : V004
Report Ref : P1560 : R001

Installation Name : Landfill Flare
Visit Details : Annual Compliance
Survey Dates : 17th – 19th December 2012
Report Issue Date : 30th January 2013

Index to symbols used in 309928-1

Value	Description
AR	As Received
U	Analysis is UKAS accredited



Environmental Compliance Limited

Bryn Posteg Landfill Site
Permit No : EPR/BU77661C
Variation No : V004
Report Ref : P1560 : R001

Installation Name : Landfill Fiere
Visit Details : Annual Compliance
Survey Dates : 17th - 19th December 2012
Report Issue Date : 30th January 2013

Non Methane VOC & Hydrogen Chloride



Scientific Analysis Laboratories is a
limited company registered in England and
Wales (No 2514788) whose address is at
Hadfield House, Hadfield Street, Manchester M16 9FE

Scientific Analysis Laboratories Ltd Certificate of Analysis

Hadfield House
Hadfield Street
Combrook
Manchester
M16 9FE
Tel : 0161 874 2400
Fax : 0161 874 2404

Report Number: 309929-1

Date of Report: 07-Jan-2013

Customer: Environmental Compliance Ltd
Unit G1
Main Avenue
Treforest Industrial Estate
Pontypridd
CF37 5YL

Customer Contact: Mr Andrew Barnes

Customer Job Reference: P1560
Customer Purchase Order: E0956
Date Job Received at SAL: 24-Dec-2012
Date Analysis Started: 28-Dec-2012
Date Analysis Completed: 07-Jan-2013

The results reported relate to samples received in the laboratory
Opinions and interpretations expressed herein are outside the scope of UKAS accreditation
This report should not be reproduced except in full without the written approval of the laboratory
Tests covered by this certificate were conducted in accordance with SAL SOPs
All results have been reviewed in accordance with QP22



Report checked
and authorised by
Kayleigh McCann
Project Manager

Issued by :
Kayleigh McCann
Project Manager

Validity unknown
Digitally signed by Kayleigh
McCann
Date: 2013.01.07 12:32 GMT
Reason: Issue
Location: SAL

Page 1 of 2

Environmental Compliance Limited

Bryn Posteg Landfill Site
 Permit No : EPR/BU77661C
 Variation No : V004
 Report Ref : P1560 : R001

Installation Name : Landfill Flare
 Visit Details : Annual Compliance
 Survey Dates : 17th – 19th December 2012
 Report Issue Date : 30th January 2013

SAL Reference: 309929									
Customer Reference: P1560									
Impinger(DI water)					Analysed as Impinger(DI water)				
Miscellaneous									
SAL Reference					309929 001	309929 002	309929 003		
Customer Sample Reference					ECL/12/7632	ECL/12/7633	ECL/12/7634		
Test Sample					AR	AR	AR		
Determinand	Method	LOD	Units	Symbol					
Hydrogen Chloride	IC	0.05	mg/l	U	(10) 7.1	(12) <0.05	(11) <0.05		
Volume	Vol	1	ml	U	200	140	300		

SAL Reference: 309929									
Customer Reference: P1500									
Tube (Charcoal 226-09)					Analysed as Tube (Charcoal 226-09)				
Miscellaneous									
SAL Reference					309929 004	309929 005	309929 006	309929 007	
Customer Sample Reference					ECL/12/7635	ECL/12/7636	ECL/12/7637	ECL/12/7638	
Test Sample					AR	AR	AR	AR	
Determinand		Method	LOD	Units	Symbol				
Volatile Organic Compounds (Total)		GC/MS	2	µg	N	4400	13	420	9

Index to symbols used in 309929-1

Value	Description
AR	As Received
f3	Results have been blank corrected
U	Analysis is UKAS accredited
N	Analysis is not UKAS accredited

Environmental Compliance Limited

Bryn Posteg Landfill Site
Permit No : EPR/BU7766IC
Variation No : V004
Report Ref : P1560 : R001

Installation Name : Landfill Flare
Visit Details : Annual Compliance
Survey Dates : 17th – 19th December 2012
Report Issue Date : 30th January 2013

UNCERTAINTY CALCULATIONS

Environmental Compliance Limited

Bryn Posteg Landfill Site
 Permit No : EPR/BU77661C
 Variation No : V004
 Report Ref : P1560 : R001

Installation Name : Landfill Flare
 Visit Details : Annual Compliance
 Survey Dates : 17th – 19th December 2012
 Report Issue Date : 30th January 2013

Combustion Gases Uncertainty of Measurements

Uncertainty Calculations Part 1

Horiba PG250 Performance Characteristics	Standard Uncertainty (% of Range)	Distribution	Divisor	Minimum Certified Range (R)				
				NO 0 - 125 mg/m ³	SO ₂ 0 - 460 mg/m ³	CO 0 - 95 mg/m ³	O ₂ 0 - 25 %Vol	CO ₂ 0 - 20 %Vol
Lack of fit ⁽¹⁾	u_{kf}	Rectangular	$\sqrt{3}$	0.40	0.80	0.40	0.13	0.60
Span drift ⁽²⁾	u_{ds}			0.27	0.27	0.29	0.029	0.24
Losses / leakage in the sample system ⁽⁴⁾	u_{lss}			1.00	1.00	1.00	1.00	1.00
Temperature dependent span drift ⁽³⁾	u_t			0.18	0.15	0.090	0.070	0.040

Notes:

For rectangular distributions, $u(x_i) = \frac{u \times R}{\sqrt{3}}$

For $u(x_i) = \Delta x \sqrt{\frac{(x_{i,max} - x_{i,min})^2 + (x_{i,max} - x_{i,adj})(x_{i,min} - x_{i,adj}) + (x_{i,min} - x_{i,adj})^2}{3}}$, when $|x_{i,min} - x_{i,adj}| = |x_{i,max} - x_{i,adj}|$, then $u(x_i) = \frac{\Delta x}{\sqrt{3}}$

Where $u(x_i) = \frac{\sigma}{\sqrt{n}}$ (See note 6 below), $\sigma = \sqrt{\frac{\sum_{i=1}^n (x_i - \bar{x})^2}{n-1}}$

Horiba PG250 Performance Characteristics	Uncertainty (Units of final measurement)	Distribution	Divisor	NO 0 - 125 mg/m ³	SO ₂ 0 - 460 mg/m ³	CO 0 - 95 mg/m ³	O ₂ 0 - 25 %Vol	CO ₂ 0 - 20 %Vol
Lack of fit	u_{kf}	Rectangular	$\sqrt{3}$	0.29	2.12	0.22	0.019	0.069
Span drift	u_{ds}			0.20	0.72	0.16	0.0041	0.028
Temperature dependent span drift	u_t			0.34	1.05	0.073	0.027	0.0082
Interferents	u_i			0.67	3.98	1.59	0.091	—

Uncertainty Calculations Part 2

Horiba PG250 Performance Characteristics	Uncertainty (Units of final measurement)	Date & Time	NO 0 - 125 mg/m ³	SO ₂ 0 - 460 mg/m ³	CO 0 - 95 mg/m ³	O ₂ 0 - 25 %Vol	CO ₂ 0 - 20 %Vol
Losses / leakage in the sample system	u_{lss}	18/12/12 14:00 - 14:59	0.38	0.58	0.24	0.13	0.057
		18/12/12 15:00 - 15:59	0.37	0.50	0.27	0.13	0.064
		18/12/12 16:00 - 16:59	0.36	0.48	0.36	0.14	0.063
Standard Error of Measured Value	u_{SE}	18/12/12 14:00 - 14:59	0.086	0.30	0.18	0.030	0.024
		18/12/12 15:00 - 15:59	0.093	0.22	0.20	0.013	0.0085
		18/12/12 16:00 - 16:59	0.047	0.11	0.27	0.0065	0.0068
Uncertainty due to Oxygen Correction ⁽⁶⁾	u_{O_2}	18/12/12 14:00 - 14:59	0.14	0.22	0.083		
		18/12/12 15:00 - 15:59	0.065	0.088	0.047		
		18/12/12 16:00 - 16:59	0.042	0.055	0.042		

Where oxygen or moisture correction is required, uncertainty based on the standard error of the measured peripheral value is converted to units of final measurement using a sensitivity coefficient C,

$$\therefore u(x_i) = C \cdot u_i \text{ where } C_i = \frac{\partial f}{\partial x_i}$$

Uncertainty Calculations Part 3

Horiba PG250 Uncertainty	Date & Time	NO 0 - 125 mg/m ³	SO ₂ 0 - 460 mg/m ³	CO 0 - 95 mg/m ³	O ₂ 0 - 25 %Vol	CO ₂ 0 - 20 %Vol
Measured Concentration	18/12/12 14:00 - 14:59	37.81	58.39	24.47	12.96	6.75
Expanded Uncertainty as Percentage of Measured Concentration		5.7%	16.2%	13.5%	2.5%	3.1%
Measured Concentration	18/12/12 15:00 - 15:59	35.54	49.56	25.66	13.39	6.44
Expanded Uncertainty as Percentage of Measured Concentration		5.6%	18.1%	12.4%	2.4%	3.1%
Measured Concentration	18/12/12 16:00 - 16:59	35.15	47.68	35.88	13.56	6.33
Expanded Uncertainty as Percentage of Measured Concentration		5.9%	19.9%	9.3%	2.4%	3.1%

Combined Standard Uncertainty

$$u_c = \sqrt{u_{kf}^2 + u_{ds}^2 + u_{lss}^2 + u_{SE}^2 + u_{O_2}^2 + u_{t}^2 + u_{i}^2}$$

Expanded uncertainty (at 95% confidence) $U_{95} = 2 \times u_c$

- Expressed as a percentage of the analyser range
- Expressed as maximum drift per 24hr period
- Expressed in units of final measurement
- Expressed as a percentage of the final measured value
- Per one degree centigrade
- Where the uncertainty of Oxygen is taken as the standard error of the time averaged value used to correct to Reference Oxygen
- Where the uncertainty of Moisture is taken as the standard error of the time averaged value used to correct to Dry Conditions

Environmental Compliance Limited

Bryn Posteg Landfill Site
Permit No : EPR/BU7766IC
Variation No : V004
Report Ref : P1560 : R001

Installation Name : Landfill Flare
Visit Details : Annual Compliance
Survey Dates : 17th - 19th December 2012
Report Issue Date : 30th January 2013

Combustion Gases Measurement Uncertainty

Horiba PG 250 Performance Characteristics	Standard Uncertainty	Distribution	Minimum Certified Range (R)				
			NO 0 - 125 mg/m ³	SO ₂ 0 - 460 mg/m ³	CO 0 - 95 mg/m ³	O ₂ 0 - 25 %vol	CO ₂ 0 - 20 %vol
Lack of fit ⁽¹⁾	u_{lof}	Rectangular (Divisor = $\sqrt{3}$)	0.40	0.60	0.40	0.13	0.60
Span drift ⁽²⁾	u_{ds}	Rectangular (Divisor = $\sqrt{3}$)	0.27	0.27	0.29	0.029	0.24
Repeatability Standard Deviation (span)	u_r	Normal (Divisor = 1)	0.17	5.43	0.29	0.038	0.010
Losses / leakage in the sample system	u_{loss}	Rectangular (Divisor = $\sqrt{3}$)	2.00	2.00	2.00	2.00	2.00
Temperature dependent span drift ⁽³⁾	u_t	Rectangular (Divisor = $\sqrt{3}$)	0.18	0.15	0.050	0.070	0.040
Interferents ⁽⁴⁾	u_i	Rectangular (Divisor = $\sqrt{3}$)	1.20	1.50	2.80	0.56	---
Uncertainty of Reference Gas ⁽⁵⁾	u_{ref}	Rectangular (Divisor = $\sqrt{3}$)	5.39	29.08	2.51	0.076	0.038

Note:

$$\text{when } |(x_{i,max} - x_{i,adj})| = |(x_{i,min} - x_{i,adj})|, \text{ then } u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$$

- Expressed as a percentage of the analysis range
- Expressed as maximum drift per 24hr period
- Expressed in units of final measurement, dry gas
- Expressed as a percentage of the final measured value
- Per one degree celsius
- Expressed as standard uncertainty in units of measurement i.e. mg/m³ / %vol

Horiba PG-250 Performance Characteristics	Uncertainty	Value of Standard Uncertainty	NO 0 - 125 mg/m ³	SO ₂ 0 - 460 mg/m ³	CO 0 - 95 mg/m ³	O ₂ 0 - 25 %vol	CO ₂ 0 - 20 %vol	
Lack of fit	u_{lof}	$u(x_i) = \frac{u_{lof} \times R_i}{\sqrt{3}} =$	0.29	2.12	0.22	0.019	0.07	
Span drift	u_{ds}	$u(x_i) = \frac{u_{ds} \times R_i}{\sqrt{3}} =$	0.20	0.72	0.16	0.0041	0.0280	
Repeatability Standard Deviation (span)	u_r	$\sigma = \sqrt{\frac{\sum_{i=1}^n (x_i - \bar{x})^2}{n-1}} =$	0.17	5.43	0.29	0.038	0.01	
Losses / leakage in the sample system	u_{loss}	$u(x_i) = \frac{u_{loss} \times R_i}{\sqrt{3}} =$	1.99	26.92	2.50	0.16	0.06	
Temperature dependant span drift	u_t	$u(x_i) = \frac{u}{100} \times R_i \times \sqrt{\frac{(x_{i,max} - x_{i,min})^2 + (x_{i,max} - x_{i,adj})(x_{i,min} - x_{i,adj}) + (x_{i,min} - x_{i,adj})^2}{3}}$	0.13	0.40	0.027	0.010	0.005	
Interferents	u_i	$u(x_i) = \frac{u_i \times R_i}{\sqrt{3}} =$	0.67	3.98	1.59	0.081	---	
Uncertainty of Reference Gas	u_{ref}	$u(x_i) = \frac{u_{ref}}{\sqrt{3}} =$	3.11	16.78	1.45	0.044	0.02	
Combined Standard Uncertainty			$u_c = \sqrt{u_{lof}^2 + u_{ds}^2 + u_r^2 + u_{loss}^2 + u_t^2 + u_i^2 + u_{ref}^2}$	3.81	32.51	3.32	0.19	0.10
Expanded measurement uncertainty (at 95% confidence)			$U_{Exp} = 2 \times u_c$	7.63	65.02	6.64	0.38	0.20
Applied Span Concentration			539.06	2905.71	251.36	15.01	5.04	
Measured Span Concentration, STP Dry Gas			205.49	2913.51	251.47	15.17	5.06	
Expanded measurement uncertainty as % of Applied Span			1.4%	2.2%	2.6%	2.5%	3.9%	

Environmental Compliance Limited

Bryn Posteg Landfill Site
Permit No : EPR/BU7766IC
Variation No : V004
Report Ref : P1560 : R001

Installation Name : Landfill Flare
Visit Details : Annual Compliance
Survey Dates : 17th - 19th December 2012
Report Issue Date : 30th January 2013

TOC Uncertainty of Measurements

Uncertainty Calculations Part 1

Protir 204MFTIR & Signal 3030 FID Performance Characteristics	Standard Uncertainty (% of Range)	Distribution	Divisor	Minimum Certified Range (R)	
				O ₂ 0-21 %Vol	*TOC 0-15 mgC/m ³
Lack of fit ⁽¹⁾	u_{lof}	Rectangular	$\sqrt{3}$	1.80	0.40
Span drift ⁽²⁾	$u_{d,s}$			0.029	0.35
Losses / leakage in the sample system ⁽³⁾	u_{loss}			1.00	1.00
Temperature dependant span drift ⁽⁴⁾	u_t			0.30	0.30
Effect of Voltage Fluctuation ⁽⁵⁾	u_v			---	1.80

Notes:

For rectangular distributions, $u(x_i) = \frac{u \times R_i}{\sqrt{3}}$

For $u(x_i) = \Delta x_i \sqrt{\frac{(x_{i,max} - x_{i,adj})^2 + (x_{i,min} - x_{i,adj})^2 + (x_{i,max} - x_{i,min})^2}{3}}$, when $(x_{i,max} - x_{i,adj}) = (x_{i,min} - x_{i,adj})$, then $u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$

Where $u(x_i) = \frac{\sigma}{\sqrt{n}}$ (See note 6 below), $\sigma = \sqrt{\frac{\sum (x_i - \bar{x})^2}{n-1}}$

Protir 204MFTIR & Signal 3030 FID Performance Characteristics	Uncertainty (Units of final measurement)	Distribution	Divisor	O ₂ 0-21 %Vol	*TOC 0-15 mgC/m ³
Lack of fit	u_{lof}	Rectangular	$\sqrt{3}$	0.22	0.035
Span drift	$u_{d,s}$			0.0034	0.031
Temperature dependant span drift	u_t			0.00	0.00
Interferents	u_i			0.37	0.38
Effect of Voltage Fluctuation (See Note)	u_v			---	0.16

Uncertainty Calculations Part 2

Protir 204MFTIR & Signal 3030 FID Performance Characteristics	Uncertainty (Units of final measurement)	Date & Time	O ₂ 0-21 %Vol	*TOC 0-15 mgC/m ³
Losses / leakage in the sample system	u_{loss}	19/12/12 12:05 - 13:05	0.13	0.046
Standard Error of Measured Value	u_{SE}	19/12/12 12:05 - 13:05	1.15E-15	0.062
Uncertainty due to Oxygen Correction ⁽⁶⁾	u_{O_2}	19/12/12 12:05 - 13:05		4.44E-16
Uncertainty due to Moisture Correction ⁽⁶⁾	u_{H_2O}	19/12/12 12:05 - 13:05	0.74	0.26

Where oxygen or moisture correction is required, uncertainty based on the standard error of the measured peripheral value is converted to units of final measurement using a sensitivity coefficient C,

$$\therefore u(x_i) = C_i u_i \text{ where } C_i = \frac{\partial f}{\partial x_i}$$

Uncertainty Calculations Part 3

Protir 204MFTIR & Signal 3030 FID Uncertainty	Date & Time	O ₂ 0-21 %Vol	*TOC 0-15 mgC/m ³
Measured Concentration	19/12/12 12:05 - 13:05	13.31	4.65
Expanded Uncertainty as Percentage of Measured Concentration		13.1%	21.2%

Combined Standard Uncertainty $u_c = \sqrt{u_{SE}^2 + u_{loss}^2 + u_{O_2}^2 + u_{H_2O}^2 + u_i^2 + u_{d,s}^2 + u_t^2 + u_{lof}^2}$

Expanded uncertainty (at 95% confidence) $U_{Exp} = 2 \times u_c$

- Expressed as a percentage of the analyser range
- Expressed as maximum drift per 24hr period
- Expressed in units of final measurement
- Expressed as a percentage of the final measured value
- Per one degree centigrade
- Where the uncertainty of Oxygen is taken as the standard error of the time averaged value used to correct to Reference Oxygen
- Where the uncertainty of Moisture is taken from the manual extractive test calculations

Environmental Compliance Limited

Bryn Posteg Landfill Site
Permit No : EPR/BU77661C
Variation No : V004
Report Ref : P1560 : R001

Installation Name : Landfill Flare
Visit Details : Annual Compliance
Survey Dates : 17th – 19th December 2012
Report Issue Date : 30th January 2013

TOC Measurement Uncertainty

Signal 3030 FID Performance Characteristics	Standard Uncertainty	Distribution	Minimum Certified Range (R) *TOC 0 - 15 mgC/m ³
Lack of fit ⁽¹⁾	u_{lof}	Rectangular (Divisor = $\sqrt{3}$)	0.40
Span drift ⁽²⁾	$u_{d,s}$	Rectangular (Divisor = $\sqrt{3}$)	0.35
Repeatability Standard Deviation (span)	u_r	Normal (Divisor = 1)	0.20
Losses / leakage in the sample system ⁽³⁾	u_{loss}	Rectangular (Divisor = $\sqrt{3}$)	2.00
Temperature dependent span drift ⁽⁴⁾	u_t	Rectangular (Divisor = $\sqrt{3}$)	0.30
Interferents ⁽⁵⁾	u_i	Rectangular (Divisor = $\sqrt{3}$)	4.39
Uncertainty of Reference Gas ⁽⁶⁾	u_{ref}	Rectangular (Divisor = $\sqrt{3}$)	0.23
Effect of Voltage Fluctuation ⁽⁷⁾	u_v	Rectangular (Divisor = $\sqrt{3}$)	1.80
Effect of Oxygen Synergism ⁽⁷⁾	u_{syn}	Rectangular (Divisor = $\sqrt{3}$)	4.60

Note:

$$\text{when } |(x_{i,max} - x_{i,adj})| = |(x_{i,min} - x_{i,adj})|, \text{ then } u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$$

- Expressed as a percentage of the analyser range
- Expressed as maximum drift per 24hr period
- Expressed in units of final measurement, dry gas
- Expressed as a percentage of the final measured value
- Per one degree centigrade
- Expressed as standard uncertainty in units of measurement i.e. mg/m³ / %vol
- Applies to TOC analyser (*Signal 3030 FID) only

Signal 3030 FID Performance Characteristics	Uncertainty	Value of Standard Uncertainty	*TOC 0 - 15 mgC/m ³
Lack of fit	u_{lof}	$u(x_i) = \frac{u_{lof} \times R_i}{\sqrt{3}} =$	0.03
Span drift	$u_{d,s}$	$u(x_i) = \frac{u_{d,s} \times R_i}{\sqrt{3}} =$	0.031
Repeatability Standard Deviation (span)	u_r	$\sigma = \sqrt{\frac{\sum_{i=1}^n (x_i - \bar{x})^2}{n-1}} =$	0.20
Losses / leakage in the sample system	u_{loss}	$u(x_i) = \frac{u_{loss} \times R_i}{\sqrt{3}} =$	0.18
Temperature dependent span drift	u_t	$u(x_i) = \frac{u_t \times R_i \times \sqrt{(x_{i,max} - x_{i,adj})^2 + (x_{i,min} - x_{i,adj})^2 + (x_{i,max} - x_{i,min})^2}}{100 \times \sqrt{3}} =$	0.000
Interferents	u_i	$u(x_i) = \frac{u_i \times R_i}{\sqrt{3}} =$	0.38
Uncertainty of Reference Gas	u_{ref}	$u(x_i) = \frac{u_{ref}}{\sqrt{3}} =$	0.13
Effect of Voltage Fluctuation (See Note 7)	u_v	$u(x_i) = \frac{u_v \times R_i}{\sqrt{3}} =$	0.16
Effect of Oxygen Synergism (See Note 7)	u_{syn}	$u(x_i) = \frac{u_{syn} \times R_i}{\sqrt{3}} =$	0.40
Combined Standard Uncertainty		$u_c = \sqrt{u_{lof}^2 + u_{d,s}^2 + u_r^2 + u_{loss}^2 + u_t^2 + u_i^2 + u_{ref}^2}$	0.65
Expanded measurement uncertainty (at 95% confidence)		$U_{Exp} = 2 \times u_c$	1.30
Applied Span Concentration			16.17
Measured Span Concentration, STP Dry Gas			15.94
Expanded measurement uncertainty as % of Applied Span			8.0%

* Signal 3030 FID

Environmental Compliance Limited

Bryn Posteg Landfill Site
Permit No : EPR/BU7766IC
Variation No : V004
Report Ref : P1560 : R001

Installation Name : Landfill Flare
Visit Details : Annual Compliance
Survey Dates : 17th – 19th December 2012
Report Issue Date : 30th January 2013

Dioxins

Site: Llanidloes
Location: Flare

Dioxin	Recovered Mass ng	LOD ng	LAB Method Uncert (%) K=2 %age	as Mass (ng)	Standard Uncertainty Symbol	ng
2,3,7,8 - TCDD	0.00660	0.00190	50	0.00330	u2,3,7,8 - TCDD	0.00165
1,2,3,7,8 - PeCDD	0.0360	0.0260	50	0.0180	u1,2,3,7,8 - PeCDD	0.0090
1,2,3,4,7,8 - HxCDD	0.00540	0.00220	50	0.00270	u1,2,3,4,7,8 - HxCDD	0.0014
1,2,3,6,7,8 - HxCDD	0.00610	0.00260	50	0.00305	u1,2,3,6,7,8 - HxCDD	0.0015
1,2,3,7,8,9 - HxCDD	0.00500	0.00260	50	0.00250	u1,2,3,7,8,9 - HxCDD	0.0013
1,2,3,4,6,7,8 - HpCDD	0.0230	0.00740	50	0.0115	u1,2,3,4,6,7,8 - HpCDD	0.006
OCDD	0.140	0.0530	50	0.0700	uOCDD	0.035
2,3,7,8 - TCDF	0.0320	0.00350	50	0.0160	u2,3,7,8 - TCDF	0.0080
1,2,3,7,8 - PeCDF	0.0410	0.00320	30	0.0123	u1,2,3,7,8 - PeCDF	0.0062
2,3,4,7,8 - PeCDF	0.0190	0.00490	50	0.00950	u2,3,4,7,8 - PeCDF	0.0048
1,2,3,4,7,8 - HxCDF	0.0180	0.00220	50	0.00900	u1,2,3,4,7,8 - HxCDF	0.0045
1,2,3,6,7,8 - HxCDF	0.0140	0.00260	50	0.00700	u1,2,3,6,7,8 - HxCDF	0.0035
2,3,4,6,7,8 - HxCDF	0.0130	0.00380	50	0.00650	u2,3,4,6,7,8 - HxCDF	0.003
1,2,3,7,8,9 - HxCDF	0.00320	0.00290	50	0.00160	u1,2,3,7,8,9 - HxCDF	0.0008
1,2,3,4,6,7,8 - HpCDF	0.0190	0.00470	50	0.00950	u1,2,3,4,6,7,8 - HpCDF	0.005
1,2,3,4,7,8,9 - HpCDF	0.00310	0.00470	50	0.00155	u1,2,3,4,7,8,9 - HpCDF	0.0008
OCDF	0.0150	0.00660	50	0.00750	uOCDF	0.004

Measured Values			Standard Uncertainty @ 95%		
Sampled Volume (V _m)	3.399	m ³	uV _m	0.001	m ³
Meter Correction Factor (Y _d)	1.015
Meter Temperature (T _m)	292.938	K	uT _m	1.5	K
Average Differential Pressure (ΔH)	15.200	mmH ₂ O	uΔH	0.25	mmH ₂ O
Barometric Pressure (p _b)	726.807	mmHg	uP _b	3.8	mmHg
ΔH + p _b (P _m)	97.049	kPa
Oxygen content (O _{2,m})	13.307	% by volume	uO _{2,m} = σ / √n	0.02	% by volume
Moisture Content (H ₂ O)	10.450	% by volume	uH ₂ O	0.28	% by volume

Note: In the following calculations, the sensitivity coefficient (C) is estimated using:

$$C_i = \frac{\partial f}{\partial x_i}$$

(uΔH), measured stack pressure uncertainty component (uP_b) & measured temperature of dry gas uncertainty component (uT_m dry)

$$f_s = \frac{273}{760} \times \frac{P_b + \Delta H}{T_m} \times Y_d = 0.906$$

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{s, wet} = \frac{100}{(100 - H_2O)} = 1$$

	Maximum	Minimum	Sensitivity	u/f _s
uΔH	0.906	0.906	0.0000915	0.0000229
uP _b	0.911	0.901	0.00124	0.00467
uT _m	0.911	0.901	0.00309	0.00464
H ₂ O

$$\frac{u f_s}{f_s} = \sqrt{\left(\frac{u(\Delta H)^2 + (uP_b)^2}{(P_m/101.3)} \right)^2 + \left(\frac{uT_m}{(T_m/273.15)} \right)^2 + \left(\frac{uH_2O}{(100/(100-H_2O))} \right)^2} = 0.00590$$

Uncertainty in volume @ reference conditions due to volume correction factor uncertainty component (uV_{std}) & volume uncertainty component (uV_m)

$$V_{std} = V_{measured} \times f_s = 3.080$$

	Maximum m ³	Minimum m ³	Sensitivity	Standard Uncertainty m ³
Effect of uV _{std}	3.100	3.060	3.399	0.0201
Effect of uV _m	3.081	3.079	0.906	0.000906

Combined Standard Uncertainty

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uV_{std}}{f_s} \right)^2 + \left(\frac{uV_m}{V_m} \right)^2} = 0.0682$$

Uncertainty of correction factor to reference oxygen due to measured oxygen uncertainty component (uO₂)

$$f_{O_2} = \frac{20.9\% - O_{2, ref}}{20.9\% - O_{2, measured}} = 1.300$$

	Maximum	Minimum	Sensitivity	Standard Uncertainty
u f _{O₂}	1.304	1.296	0.169	0.00374

Environmental Compliance Limited

Bryn Posteg Landfill Site

Permit No : EPR/BU7766IC

Variation No : V004

Report Ref : P1560 : R001

Installation Name

: Landfill Flare

Visit Details

: Annual Compliance

Survey Dates

: 17th – 19th December 2012

Report Issue Date

: 30th January 2013

Uncertainty in final dioxin measurement @ reference conditions due to mass uncertainty component (uM)

Dioxin	Maximum ng/Nm ³	Minimum ng/Nm ³	Sensitivity	uM ng/Nm ³
2,3,7,8 - TCDD	0.00348	0.00209	0.422	0.000696
1,2,3,7,8 - PeCDD	0.0190	0.0114	0.422	0.00380
1,2,3,4,7,8 - HxCDD	0.00285	0.00171	0.422	0.000570
1,2,3,6,7,8 - HxCDD	0.00322	0.00193	0.422	0.000644
1,2,3,7,8,9 - HxCDD	0.00264	0.00158	0.422	0.000528
1,2,3,4,6,7,8 - HpCDD	0.0121	0.00728	0.422	0.00243
OCDD	0.0739	0.0443	0.422	0.0148
2,3,7,8 - TCDF	0.0169	0.0101	0.422	0.00338
1,2,3,7,8 - PeCDF	0.0199	0.0147	0.422	0.00260
2,3,4,7,8 - PeCDF	0.0100	0.00601	0.422	0.00200
1,2,3,4,7,8 - HxCDF	0.00950	0.00570	0.422	0.00190
1,2,3,6,7,8 - HxCDF	0.00739	0.00443	0.422	0.00148
2,3,4,6,7,8 - HxCDF	0.00686	0.00412	0.422	0.00137
1,2,3,7,8,9 - HxCDF	0.00169	0.00101	0.422	0.000338
1,2,3,4,6,7,8 - HpCDF	0.0100	0.00601	0.422	0.00200
1,2,3,4,7,8,9 - HpCDF	0.00164	0.000981	0.422	0.000327
OCDF	0.00791	0.00475	0.422	0.00158

Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss in the sample system (uL)

Dioxin	uL ng/Nm ³
2,3,7,8 - TCDD	0.0000322
1,2,3,7,8 - PeCDD	0.000175
1,2,3,4,7,8 - HxCDD	0.0000263
1,2,3,6,7,8 - HxCDD	0.0000297
1,2,3,7,8,9 - HxCDD	0.0000244
1,2,3,4,6,7,8 - HpCDD	0.000112
OCDD	0.000682
2,3,7,8 - TCDF	0.000156
1,2,3,7,8 - PeCDF	0.000200
2,3,4,7,8 - PeCDF	0.0000926
1,2,3,4,7,8 - HxCDF	0.0000877
1,2,3,6,7,8 - HxCDF	0.0000682
2,3,4,6,7,8 - HxCDF	0.0000634
1,2,3,7,8,9 - HxCDF	0.0000156
1,2,3,4,6,7,8 - HpCDF	0.0000926
1,2,3,4,7,8,9 - HpCDF	0.0000151
OCDF	0.0000731

Uncertainty in final measurement @ reference conditions due to oxygen correction uncertainty component (u_{O₂})

Dioxin	Maximum ng/Nm ³	Minimum ng/Nm ³	Sensitivity	u _{O₂} ng/Nm ³
2,3,7,8 - TCDD	0.00279	0.00278	0.00214	8.005E-06
1,2,3,7,8 - PeCDD	0.0152	0.0152	0.0117	0.0000437
1,2,3,4,7,8 - HxCDD	0.00229	0.00227	0.00175	6.549E-06
1,2,3,6,7,8 - HxCDD	0.00258	0.00257	0.00198	7.398E-06
1,2,3,7,8,9 - HxCDD	0.00212	0.00210	0.00162	6.064E-06
1,2,3,4,6,7,8 - HpCDD	0.00974	0.00968	0.00747	0.0000279
OCDD	0.0593	0.0589	0.0455	0.000170
2,3,7,8 - TCDF	0.0135	0.0135	0.0104	0.0000388
1,2,3,7,8 - PeCDF	0.0174	0.0173	0.0133	0.0000497
2,3,4,7,8 - PeCDF	0.00804	0.00800	0.00617	0.0000230
1,2,3,4,7,8 - HxCDF	0.00782	0.00758	0.00584	0.0000218
1,2,3,6,7,8 - HxCDF	0.00593	0.00589	0.00455	0.0000170
2,3,4,6,7,8 - HxCDF	0.00550	0.00547	0.00422	0.0000158
1,2,3,7,8,9 - HxCDF	0.00135	0.00135	0.00104	3.881E-06
1,2,3,4,6,7,8 - HpCDF	0.00804	0.00800	0.00617	0.0000230
1,2,3,4,7,8,9 - HpCDF	0.00131	0.00130	0.00101	3.760E-06
OCDF	0.00635	0.00631	0.00487	0.0000182

Uncertainty in final measurement @ Reference Conditions due to uVap

Dioxin	Maximum ng/Nm ³	Minimum ng/Nm ³	Sensitivity	uVap ng/Nm ³
2,3,7,8 - TCDD	0.00285	0.00273	0.000905	0.0000617
1,2,3,7,8 - PeCDD	0.0155	0.0149	0.00494	0.000337
1,2,3,4,7,8 - HxCDD	0.00233	0.00223	0.000740	0.0000505
1,2,3,6,7,8 - HxCDD	0.00263	0.00252	0.000838	0.0000571
1,2,3,7,8,9 - HxCDD	0.00216	0.00208	0.000886	0.0000468
1,2,3,4,6,7,8 - HpCDD	0.00993	0.00950	0.00315	0.0000215
OCDD	0.0604	0.0578	0.0192	0.00131
2,3,7,8 - TCDF	0.0138	0.0132	0.00439	0.000299
1,2,3,7,8 - PeCDF	0.0177	0.0169	0.00562	0.000383
2,3,4,7,8 - PeCDF	0.00820	0.00785	0.00261	0.000178
1,2,3,4,7,8 - HxCDF	0.00777	0.00743	0.00247	0.000168
1,2,3,6,7,8 - HxCDF	0.00604	0.00578	0.00192	0.000131
2,3,4,6,7,8 - HxCDF	0.00561	0.00537	0.00178	0.000122
1,2,3,7,8,9 - HxCDF	0.00138	0.00132	0.000439	0.0000299
1,2,3,4,6,7,8 - HpCDF	0.00820	0.00785	0.00261	0.000178
1,2,3,4,7,8,9 - HpCDF	0.00134	0.00128	0.000425	0.0000290
OCDF	0.00647	0.00619	0.00206	0.000140

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (u_{O_2})^2 + (u_{Vap})^2}$$

Dioxin	Combined Uncertainty ng/Nm ³	Expanded Uncertainty ng/Nm ³	Measured Concentration ng/Nm ³	% of Measured Concentration
2,3,7,8 - TCDD	0.000700	0.00140	0.00279	50.3
1,2,3,7,8 - PeCDD	0.00382	0.00764	0.0152	50.3
1,2,3,4,7,8 - HxCDD	0.000573	0.00115	0.00228	50.3
1,2,3,6,7,8 - HxCDD	0.000647	0.00129	0.00257	50.3
1,2,3,7,8,9 - HxCDD	0.000530	0.00106	0.00211	50.3
1,2,3,4,6,7,8 - HpCDD	0.00244	0.00488	0.00971	50.3
OCDD	0.0148	0.0297	0.0591	50.3
2,3,7,8 - TCDF	0.00339	0.00679	0.0135	50.3
1,2,3,7,8 - PeCDF	0.00263	0.00526	0.0173	30.4
2,3,4,7,8 - PeCDF	0.00201	0.00403	0.00802	50.3
1,2,3,4,7,8 - HxCDF	0.00191	0.00382	0.00760	50.3
1,2,3,6,7,8 - HxCDF	0.00148	0.00297	0.00591	50.3
2,3,4,6,7,8 - HxCDF	0.00138	0.00276	0.00549	50.3
1,2,3,7,8,9 - HxCDF	0.000339	0.000679	0.00135	50.3
1,2,3,4,6,7,8 - HpCDF	0.00201	0.00403	0.00802	50.3
1,2,3,4,7,8,9 - HpCDF	0.000329	0.000658	0.00131	50.3
OCDF	0.00159	0.00318	0.00633	50.3

Total (ng/Nm³)

0.169

19.8

Environmental Compliance Limited

Bryn Posteg Landfill Site
Permit No : EPR/BU7766IC
Variation No : V004
Report Ref : P1560 : R001

Installation Name : Landfill Flare
Visit Details : Annual Compliance
Survey Dates : 17th – 19th December 2012
Report Issue Date : 30th January 2013

Uncertainty - Adjusted for TEQ / TEF												
Dioxin	TEQ ng/m³	Uncertainty ng/Nm³	Conc ng/Nm³	WHO Humans & Mammals (TEF)	Uncertainty ng/Nm³	Conc ng/Nm³	WHO Fish (TEF)	Uncertainty ng/Nm³	Conc ng/Nm³	WHO Birds (TEF)	Uncertainty ng/Nm³	Conc ng/Nm³
2,3,7,8 - TCDD	1	0.00140	0.00279	1	0.00140	0.00279	1	0.00140	0.00279	1	0.00140	0.00279
1,2,3,7,8 - PeCDD	0.5	0.00382	0.00760	1	0.00764	0.0152	1	0.00764	0.0152	1	0.00764	0.0152
1,2,3,4,7,8 - HxCDD	0.1	0.000115	0.000228	0.1	0.000115	0.000228	0.5	0.000573	0.00114	0.05	0.000573	0.00114
1,2,3,6,7,8 - HxCDD	0.1	0.000129	0.000257	0.1	0.000129	0.000257	0.01	0.000129	0.000257	0.01	0.000129	0.000257
1,2,3,7,8,9 - HxCDD	0.1	0.000106	0.000211	0.1	0.000106	0.000211	0.01	0.000106	0.000211	0.1	0.000106	0.000211
1,2,3,4,6,7,8 - HpCDD	0.01	0.000486	0.000971	0.01	0.000486	0.000971	0.001	4.875E-06	9.707E-06	0.001	4.875E-06	9.707E-06
OCDD	0.001	0.0000297	0.0000594	0.0001	2.969E-06	5.909E-06						
2,3,7,8 - TCDF	0.1	0.000679	0.00135	0.1	0.000679	0.00135	0.05	0.000339	0.000678	1	0.000679	0.00135
1,2,3,7,8 - PeCDF	0.05	0.000263	0.000526	0.05	0.000263	0.000526	0.05	0.000263	0.000526	0.1	0.000263	0.000526
2,3,4,7,8 - PeCDF	0.5	0.00201	0.00401	0.5	0.00201	0.00401	0.5	0.00201	0.00401	1	0.00201	0.00401
1,2,3,4,7,8 - HxCDF	0.1	0.000382	0.000760	0.1	0.000382	0.000760	0.1	0.000382	0.000760	0.1	0.000382	0.000760
1,2,3,6,7,8 - HxCDF	0.1	0.000297	0.000594	0.1	0.000297	0.000594	0.1	0.000297	0.000594	0.1	0.000297	0.000594
2,3,4,6,7,8 - HxCDF	0.1	0.000276	0.000549	0.1	0.000276	0.000549	0.1	0.000276	0.000549	0.1	0.000276	0.000549
1,2,3,7,8,9 - HxCDF	0.1	0.000679	0.00135	0.1	0.000679	0.00135	0.1	0.000679	0.00135	0.1	0.000679	0.00135
1,2,3,4,6,7,8 - HpCDF	0.01	0.000403	0.000802	0.01	0.000403	0.000802	0.01	0.000403	0.000802	0.01	0.000403	0.000802
1,2,3,4,7,8,9 - HpCDF	0.01	6.575E-06	0.000131	0.01	6.575E-06	0.000131	0.01	6.575E-06	0.000131	0.01	6.575E-06	0.000131
OCDF	0.001	3.181E-06	6.361E-06	0.0001	3.181E-07	6.361E-07	0.0001	3.181E-07	6.361E-07	0.0001	3.181E-07	6.361E-07
TOTAL		0.00454	0.0196		0.00908	0.0271		0.00907	0.0269		0.0111	0.0437
% Uncertainty			23.7			28.8			30.1			25.4

Uncertainty - Adjusted for TEF									
PCB	WHO Humans & Mammals (TEF)	Uncertainty ng/Nm³	Conc ng/Nm³	WHO Fish (TEF)	Uncertainty ng/Nm³	Conc ng/Nm³	WHO Birds (TEF)	Uncertainty ng/Nm³	Conc ng/Nm³
	0.0001			0.000005			0.0001		
	0.0005			0.000005			0.0001		
	0.0001			0.000005			0.00001		
	0.0001			0.000005			0.00001		
	0.1			0.005			0.1		
	0.0005			0.000005			0.0001		
	0.0005			0.000005			0.0001		
	0.00001			0.000005			0.00001		
	0.01			0.00005			0.001		
	0.0001			0.000005			0.00001		
	0.0001			0.0001			0.05		
	0.0001			0.0005			0.1		
TOTAL	***	0.00	0.00	***	0.00	0.00	***	0.00	0.00
% Uncertainty	***	***	0.0	***	***	0.0	***	***	0.0

Environmental Compliance Limited

Bryn Posteg Landfill Site
 Permit No : EPR/BU77661C
 Variation No : V004
 Report Ref : P1560 : R001

Installation Name : Landfill Flare
 Visit Details : Annual Compliance
 Survey Dates : 17th – 19th December 2012
 Report Issue Date : 30th January 2013

Uncertainty in final measurement @ reference conditions due to mass uncertainty component (uM)

Determinand	HCl:				...2			
	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	uM mg/Nm ³	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	uM mg/Nm ³
Hydrogen Chloride	9.09	7.98	3.07	0.55				

Uncertainty in final measurement @ reference conditions due to uncertainty component arising from peak area or loss (assumed 2% max) in the sample system (uL)

Determinand	HCl:	...2
	uL mg/Nm ³	uL mg/Nm ³
Hydrogen Chloride	0.0986	

Uncertainty in final measurement @ reference conditions due to oxygen correction uncertainty component (uO₂)

Determinand	HCl:				...2			
	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	uO ₂ mg/Nm ³	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	uO ₂ mg/Nm ³
Hydrogen Chloride	8.55	8.52	3.65	0.0136				

Uncertainty in final measurement @ Reference Conditions due to uV_{stp}

Determinand	HCl:				...2			
	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	uV _{stp} mg/Nm ³	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	uV _{stp} mg/Nm ³
Hydrogen Chloride	8.59	8.49	11.22	0.0499				

Combined Uncertainty

$$u_{combined} = \sqrt{(u_M)^2 + (u_L)^2 + (u_{O_2})^2 + (u_{V_{stp}})^2}$$

Determinand	HCl:				...2			
	Combined Uncertainty mg/Nm ³	Expanded Uncertainty mg/Nm ³	Measured Concentration mg/Nm ³	Percent of Measured Concentration	Combined Uncertainty mg/Nm ³	Expanded Uncertainty mg/Nm ³	Measured Concentration mg/Nm ³	Percent of Measured Concentration
Hydrogen Chloride	0.57	1.13	8.54	13.26				

Environmental Compliance Limited

Bryn Posteg Landfill Site
Permit No : EPR/BU77661C
Variation No : V004
Report Ref : P1560 : R001

Installation Name : Landfill Flare
Visit Details : Annual Compliance
Survey Dates : 17th - 19th December 2012
Report Issue Date : 30th January 2013

Non Methane VOC

Site: Bryn Posteg, Llanidloes
Location: Landfill Site, Stack ID:Flare

				Standard Uncertainty @ 95%			
Sampled Volume	V _m	0.23000	m ³	uV _m	0.000	m ³	
Meter Correction Factor or ml/count	Yd	1.0151	
Meter Temperature	T _m	282.50	K	uT _m	1.5	K	
Barometric Pressure	P _b	966.00	mBar		10.0	mBar	
Oxygen content	O _{2,m}	13.31	%Vol	uO _{2,m}	2.50	%Vol	
Moisture	H ₂ O	10.51	%Vol	uH ₂ O	1.41	%Vol	

Tubes							
Determinand	Recovered Mass			Standard Uncertainty			
NM VOC	420.00	μg		uM	21.00	μg	

Note: In the following calculations, the sensitivity coefficient (C) is estimated using $\frac{\partial}{\partial x_i}$

For each factor, uncertainty is then calculated by $C \cdot u$ where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. i=uV_m, uT_m etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{d,wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (uP_b), measured temperature of dry gas uncertainty component (uT_m) & measured moisture (uH₂O)

$$f_s = \frac{273}{T_m} \times \frac{P}{101.3} = 0.92$$

	Maximum	Minimum	Sensitivity	u _{f_s}
uP _b	0.47	0.46	0.000485	0.00485
uT _m	0.93	0.92	0.00326	0.00489
uH ₂ O

$$\frac{u f_s}{f_s} = \sqrt{\left(\frac{u P_b}{(P_b/101.3)}\right)^2 + \left(\frac{u T_m}{(T_m/273.15)}\right)^2 + \left(\frac{u H_2O}{(100/(100 - H_2O))}\right)^2} = 0.00640$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV_{std}) & volume uncertainty component (uV_m)

$$V_{std} = V_{measured} \times f_s = 0.22$$

	Maximum m ³	Minimum m ³	Sensitivity	Standard Uncertainty m ³
Effect of u _{f_s}	0.22	0.21	0.23	0.00149
Effect of uV _m	0.22	0.22	0.94	9.355E-06

$$\frac{u V_{std}}{V_{std}} = \sqrt{\left(\frac{u f_s}{f_s}\right)^2 + \left(\frac{u V_m}{V_m}\right)^2} = 0.0502$$

Uncertainty of correction factor to reference oxygen due to measured oxygen uncertainty component (uO₂) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

$$f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 2.34$$

	Maximum	Minimum	Sensitivity	Standard Uncertainty
u _{f_{O₂}}	3.47	1.77	0.34	0.85

$$uL = \frac{Conc \times \frac{2}{100}}{\sqrt{3}}$$

	Tubes uL mg/Nm ³	Condensate uL mg/Nm ³
NM VOC	0.0528	...

Environmental Compliance Limited

Bryn Posteg Landfill Site
 Permit No : EPR/BU7766IC
 Variation No : V004
 Report Ref : P1560 : R001

Installation Name : Landfill Flare
 Visit Details : Annual Compliance
 Survey Dates : 17th – 19th December 2012
 Report Issue Date : 30th January 2013

$$Conc = \frac{M_{Recovered}}{V_m \times f_s \times f_{O_2}}$$

Uncertainty in final measurement @ Reference Conditions due to $uM_{Recovered}$

Charcoal Tube Results				
	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	Standard Uncertainty mg/Nm ³
NM VOC	4.80	4.34	10.88	0.23
Condensate Results				
	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	Standard Uncertainty mg/Nm ³
NM VOC				

Uncertainty in final measurement @ Reference Conditions due to uV_{STD}

Charcoal Tube Results				
	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	Standard Uncertainty mg/Nm ³
NM VOC	5.96	3.70	22.46	1.13

Uncertainty in final measurement @ Reference Conditions due to $u f_{O_2}$

Charcoal Tube Results				
	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	Standard Uncertainty mg/Nm ³
NM VOC	6.23	2.91	1.95	1.66

Combined Uncertainty

$$u_{combined} = \sqrt{(u_M)^2 + (u_L)^2 + (u f_{O_2})^2 + (u V_{std})^2}$$

Charcoal Tubes: Determinand	Combined Uncertainty mg/Nm ³	Expanded Uncertainty mg/Nm ³	Measured Concentration mg/Nm ³	Percent of Measured Concentration
NM VOC	2.02	4.04	4.57	88.5%