

RELEASES TO AIR
 QUARTERLY RETURN
 MONTHLY MEAN, MAXIMUM DAILY MEAN AND ANNUAL PERCENTILE CONCENTRATIONS (a),(b),(c)
 OPERATING MODE:

Operator: Siemens O&M for Calon Energy
 Location: Severn CCGT A1, Unit 10
 Permit/Variation Number: EPR/HP3737UE/V005

Form: IED CON2

Version: 1.0, 15 Dec 2015

Huw Edwards

22 FEB 2017

EHS Manager

Huw Edwards

LCP 324: UNIT 10											
Year: 2016	Month	NOx (mg/m3)				CO (mg/m3)				95% of hourly means	
		Monthly Mean	Max Daily Mean	Part Load Max Daily Mean	Max Hourly Average	Monthly Mean	Max Daily Mean	Part Load Max Daily Mean			
	January	24.62	26.98	29.26	29.97	2.16	2.75	5.01	3.1		
	February	27.40	33.32	36.46	40.28	2.47	4.14	4.14	2.4		
	March	26.72	32.86	36.11	88.68	2.55	3.72	7.67	2.9		
	April	26.89	30.46	35.70	67.14	2.80	3.93	5.67	3.0		
	May	27.75	32.60	32.49	40.25	2.67	3.27	7.77			
	June	24.76	29.95	30.98	39.67	2.80	3.36	4.93	5.7		
	July	25.62	31.56	31.30	40.76	2.96	3.96	6.03	5.9		
	August	26.63	29.63	29.40	37.31	3.12	5.24	5.92	5.0		
	September	27.20	31.84	31.59	66.50	3.12	5.01	9.25	4.5		
	October	22.98	26.71	40.49	60.96	3.09	5.58	22.33	4.5		
	November	25.55	30.21	30.10	36.21	3.06	4.36	5.43	4.7		
	December	23.14	28.79	29.07	73.99	2.98	4.33	5.25	3.6		
	Monthly ELY Daily ELY (t)	50.	50.	50.	100.	100.	110.	110.	N/A		
	Annual 95th Percentile (g)	33.12	30.63			4.67	3.93				
	Annual Percentile ELY (t)	75.				100.					

Hu Edwards

RELEASES TO AIR
 QUARTERLY RETURN
 MONTHLY MEAN, MAXIMUM DAILY MEAN AND ANNUAL PERCENTILE CONCENTRATIONS (a),(b),(c)
 OPERATING MODE:

Operator: Siemens O&M for Calon Energy
 Location: Severn CCGT A2, Unit 20
 Permit/Variation Number: EPR/HP3737UE/V005
 Form: IED CON2
 Version/Date: v10.9.Dic.2015

LCP 325: UNIT 20											
Year: 2016	NOx (mg/m3)						CO (mg/m3)				
	Monthly Mean	Max Daily Mean	Part Load Max Daily Mean	Max Hourly Average	Monthly Mean	Max Daily Mean	Part Load Max Daily Mean	95% of hourly means	Max Daily Mean	Part Load Max Daily Mean	95% of hourly means
January	23.99	31.08	29.60	32.20	0.80	1.60	7.18	1.3	1.60	7.18	1.3
February	22.09	28.90	32.51	30.08	1.02	3.44	19.16	2.9	3.44	19.16	2.9
March	20.92	26.02	32.59	30.01	1.17	11.90	14.45	0.8	11.90	14.45	0.8
April	22.28	27.48	31.49	31.78	0.72	1.14	3.06	1.8	1.14	3.06	1.8
May	22.24	26.75	26.50	37.73	0.86	1.43	8.83	*	1.43	8.83	*
June	18.95	23.30	23.55	32.06	0.82	2.74	5.71	0.8	2.74	5.71	0.8
July	19.62	22.86	23.26	28.31	0.92	1.56	5.81	2.1	1.56	5.81	2.1
August	19.07	22.30	22.02	48.63	0.99	2.12	9.33	1.4	2.12	9.33	1.4
September	20.95	24.39	25.52	30.81	0.99	1.80	10.00	1.5	1.80	10.00	1.5
October	17.91	21.34	21.51	30.87	1.01	1.95	8.08	4.0	1.95	8.08	4.0
November	19.23	30.59	30.59	30.59	1.03	2.42	20.29	1.4	2.42	20.29	1.4
December	18.48	22.22	25.80	26.68	0.76	2.80	6.93	1.8	2.80	6.93	1.8
Monthly ELV Daily ELV (t)	50.	50.	50.	100.	100.	110.	110.	N/A	110.	110.	N/A
Annual 95th Percentile (g)	26.68	25.34			2.15	1.76					
Annual Percentile ELV (t)	75.				100.						

RELEASES TO AIR
ANNUAL RETURN
OPERATING HOURS

Operator: Siemens

Location: Severn Power

Permit/Variation Number: EPR/HP3737/V005

Form:

IED HR1

Version/date:

V.11 Mar 2016

Year:	LCP1 (324) (hours)	Bypass (hours)	LCP2 (325) (hours)	Bypass (hours)	LCP3 (hours)	Bypass (hours)	LCP4 (hours)	Bypass (hours)
Annual Operating Hours ^{(a), (b)}	6,094	N/A	5,830	N/A	N/A	N/A	N/A	N/A
Cumulative Operating Hours ^{(c), (d)}		N/A		N/A	N/A	N/A	N/A	N/A
Derogated annual hours ^(e)		N/A		N/A	N/A	N/A	N/A	N/A
Five year rolling average ^(f)		N/A		N/A	N/A	N/A	N/A	N/A

NOTES:

- (a) Annual operating hours for every LCP from 1-Jan in calendar year. (For gas turbines with a Bypass stack, include the Bypass stack operating hours during normal operation even though these are reported separately).
- (b) For gas turbines with a Bypass stack, report Bypass operating hours from 1-Jan in calendar year, excluding Start-Up and Shut-down, in the adjacent column (labelled Bypass) which may be deleted if not applicable.
- (c) Cumulative operating hours from 1-Jan-2016 for LCP subject to a Limited Lifetime Derogation or a 10,000h monitoring derogation. (For gas turbines with a Bypass stack, include the Bypass stack operating hours during normal operation even though these are reported separately).
- (d) For gas turbines with a Bypass stack, report Bypass Cumulative operating hours from 1-Jan-2016 if subject to a separate 10,000h monitoring derogation, in the adjacent column (labelled Bypass).
- (e) Annual operating hours in calendar year from entry date (in first year as applicable) or from 1-Jan in calendar year, for each 1,500h ELV derogated Unit/LCP only.
- (f) Five year running average from entry date for each 1,500h derogated Unit/LCP only.
- (g) General note: hours are reported as a decimal number to two decimal places.

Signed on behalf of the Operator by: Huw Edwards

Date of return: 27/01/2017

Huw Edwards

22 FEB 2017

EHS Manager



Permit Number: EPR/HP3737UE

Operator: Siemens plc

Facility: Severn Power Station

Form Number: Water1 / 10/03/10

Reporting of emissions to water (other than to sewer) and land for year commencing January 2016

Handwritten signature: H. Edwards

Month	Emissions Point	Parameter	Emissions Limit Value	Reference Period	Result	Test Method	Sample Date and Time	Disposability
January	W1	Total ammonia	No limit set	Monthly spot	Tankered away from site	BS EN ISO 11732:2005	N/A	
	W1	pH	6-9	Continuous. Pumps operate when pH is between 6 and 9	6-9	pH Probe	N/A	
	W2	pH	No limit set	Monthly spot	8.6	pH Probe	10 th 14:51	
	W3	pH	No limit set	Monthly spot	6.7	pH Probe	10 th 14:51	
February	W1	Total ammonia	No limit set	Monthly spot	Tankered away from site	BS EN ISO 11732:2005	N/A	
	W1	pH	6-9	Continuous. Pumps operate when pH is between 6 and 9	6-9	pH Probe	N/A	
	W2	pH	No limit set	Monthly spot	8.5	pH Probe	14 th 01:28	
	W3	pH	No limit set	Monthly spot	7.5	pH Probe	14 th 01:28	
March	W1	Total ammonia	No limit set	Monthly spot	Tankered away from site	BS EN ISO 11732:2005	N/A	
	W1	pH	6-9	Continuous. Pumps operate when pH is between 6 and 9	6-9	BS6068-2:50	N/A	
	W2	pH	No limit set	Monthly spot	8.6	pH Probe	12 th 11:00	
	W3	pH	No limit set	Monthly spot	8.6	pH Probe	12 th 11:00	

Month	Emissions Point	Parameter	Emission Limit Value	Reference Period	Result (1)	Test Method (2)	Sample Date and Times (3)	Uncertainty (4)
April	W1	Total ammonia	No limit set	Monthly spot	Tankered away from site	BS EN ISO 11732:2005	N/A	
	W1	pH	6-9	Constant (pumps operate only when pH is 6 to 9)	6-9	pH Probe	N/A	
	W2	pH	No limit set	Monthly spot	8.6	pH Probe	15 th 22:37	
	W3	pH	No limit set	Monthly spot	7.5	pH Probe	15 th 22:37	
May	W1	Total ammonia	No limit set	Monthly spot	Tankered away from site	BS EN ISO 11732:2005	N/A	
	W1	pH	6-9	Constant (pumps operate only when pH is 6 to 9)	6-9	pH Probe	N/A	
	W2	pH	No limit set	Monthly spot	7.5	pH Probe	10 th 05:00	
June	W3	pH	No limit set	Monthly spot	8.7	pH Probe	10 th 05:00	
	W1	Total ammonia	No limit set	Monthly spot	Tankered away from site	BS EN ISO 11732:2005	N/A	
	W1	pH	6-9	Constant (pumps operate only when pH is 6 to 9)	6-9	pH Probe	N/A	
	W2	pH	No limit set	Monthly spot	8.7	pH Probe	6 th 05:09	
	W3	pH	No limit set	Monthly spot	7.0	pH Probe	6 th 05:09	

Huw Edwards

22 FEB 2017

EHS Manager



Month	Emissions Point	Parameter	Emission Limit Value	Reference Period	Result (1)	Test Method (2)	Sample Date and Times (3)	Uncertainty (4)
July	W1	Total ammonia	No limit set	Monthly spot	Tankered away from site	BS EN ISO 11732:2005	N/A	
	W1	pH	6-9	Constant (pumps operate only when pH is 6 to 9)	6-9	pH Probe	N/A	
	W2	pH	No limit set	Monthly spot	7.6	pH Probe	23 rd 04:21	
	W3	pH	No limit set	Monthly spot	6.0	pH Probe	23 rd 04:21	
August	W1	Total ammonia	No limit set	Monthly spot	Tankered away from site	BS EN ISO 11732:2005	N/A	
	W1	pH	6-9	Constant (pumps operate only when pH is 6 to 9)	6-9	pH Probe	N/A	
	W2	pH	No limit set	Monthly spot	7.3	pH Probe	22 nd 17:02	
	W3	pH	No limit set	Monthly spot	7.9	pH Probe	22 nd 17:02	
September	W1	Total ammonia	No limit set	Monthly spot	Tankered away from site	BS EN ISO 11732:2005	N/A	
	W1	pH	6-9	Constant (pumps operate only when pH is 6 to 9)	6-9	BS6068-2.50	N/A	
	W2	pH	No limit set	Monthly spot	7.6	pH Probe	24 th 23:28	
	W3	pH	No limit set	Monthly spot	6.3	pH Probe	24 th 23:28	

Huw Edwards

22 FEB 2017

EHS Manager



Month	Emissions Point	Parameter	Emissions Limit Value	Reference Point	Reliability	Test Method(s)	Sample Date and Times	Frequency
October	W1	Total ammonia	No limit set	Monthly spot	Tankerred away from site	BS EN ISO 11732:2005	N/A	
	W1	pH	6-9	Constant (pumps operate only when pH is 6 to 9)	6-9	pH Probe	N/A	
	W2	pH	No limit set	Monthly spot	8.8	pH Probe	21 st 14:12	
	W3	pH	No limit set	Monthly spot	5.9	pH Probe	21 st 14:12	
November	W1	Total ammonia	No limit set	Monthly spot	Tankerred away from site	BS EN ISO 11732:2005	N/A	
	W1	pH	6-9	Constant (pumps operate only when pH is 6 to 9)	6-9	pH Probe	N/A	
	W2	pH	No limit set	Monthly spot	8.4	pH Probe	15 th 14:23	
	W3	pH	No limit set	Monthly spot	6.1	pH Probe	15 th 14:23	
December	W1	Total ammonia	No limit set	Monthly spot	Tankerred away from site	BS EN ISO 11732:2005	N/A	
	W1	pH	6-9	Constant (pumps operate only when pH is 6 to 9)	6-9	pH Probe	N/A	
	W2	pH	No limit set	Monthly spot	7.0	pH Probe	18 th 02:02	
	W3	pH	No limit set	Monthly spot	6.6	pH Probe	18 th 02:02	

21 Feb 2007

H. Edwards

[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum - maximum' measured values.

[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated, e.g. gas chromatography.

[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.

[4] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

Signed
(Authorised to sign as representative of Operator)

Date... 22/02/17

Huw Edwards
22 FEB

EHS Manager

