

Permit Number: EPR/HP3737UE
Installation: Severn Power Station

Operator: Siemens plc
Form Number: Air – 5_2

LCPD MONTHLY AND CUMULATIVE RELEASES ¹ (TONNES) FROM EACH LCP FOR THE YEAR 2015 GAS TURBINE NUMBER ² A2

Reporting period	Sulphur dioxide		Oxides of nitrogen		Dust (Particulate matter)	
	Actual	Year to date	Actual	Year to date	Actual	Year to date
01 (Jan)	0.163	0.163	20.076	20.076	0.469	0.469
02 (Feb)	0.078	0.241	9.677	29.754	0.226	0.695
03 (Mar)	0.047	0.288	5.795	35.549	0.135	0.830
04 (Apr)	0.090	0.378	11.116	46.665	0.260	1.090
05 (May)	0.074	0.452	9.129	55.794	0.213	1.303
06 (Jun)	0.033	0.485	4.091	59.885	0.096	1.398
07 (Jul)	0.050	0.535	6.188	66.073	0.144	1.543
08 (Aug)	0.096	0.631	11.890	77.963	0.278	1.820
09 (Sep)	0.231	0.862	28.496	106.459	0.665	2.486
10 (Oct)	0.078	0.940	9.628	116.087	0.225	2.711
11 (Nov)	0.058	0.998	7.208	123.295	0.168	2.879
12 (Dec)	0.039	1.037	4.795	128.090	0.112	2.991

¹ Excluding start-up and shut-down


² Form Air 3 must be completed separately for each gas turbine at the Facility

Operator comments: **This combined cycle unit operated during every month in 2015.**

Huw Edwards

27 MAY 2015

EHS Manager

Signed on behalf of Siemens plc by:  Date of return:

Revised to
Correct typo. error
