

CAULMERT LIMITED

Engineering, Environmental & Planning
Consultancy Services

Bryn Posteg Landfill Site

Potters Waste Management

Annual Monitoring Review

January - December 2017

Prepared by:

Caulmert Limited

InTec, Parc Menai, Bangor, Gwynedd, LL57 4FG

Tel: 01248 672666

Fax: 01248 672601

Email: dianabrookshaw@caulmert.com

Web: www.caulmert.com

Doc ref: 3033-CAU-XX-XX-RP-V-0306.A0-C1

February 2018





APPROVAL RECORD

Site: Bryn Posteg Landfill Site

Client: Potters Waste Management

Document Title: Annual Monitoring Review (January – December 2017)

Document Ref: 3033-CAU-XX-XX-RP-V-0306

Report Status: Final

Project Director: Andy Stocks

Project Manager: Diana Brookshaw

Caulmert Limited: Intec, Parc Menai, Bangor, Gwynedd, LL57 4FG

Tel: 01248 672666

Author	Sean O'Brien	Date	28/02/2018
Reviewer	Diana Brookshaw	Date	28/02/2018
Approved	Diana Brookshaw	Date	07/03/2018

DISCLAIMER

This report has been prepared by Caulmert Limited with all reasonable skill, care and diligence in accordance with the instruction of the above named client and within the terms and conditions of the Contract with the Client.

The report is for the sole use of the above named Client and Caulmert Limited shall not be held responsible for any use of the report or its content for any purpose other than that for which it was prepared and provided to the Client.

Caulmert Limited accepts no responsibility of whatever nature to any third parties who may have been made aware of or have acted in the knowledge of the report or its contents.

No part of this document may be copied or reproduced without the prior written approval of Caulmert Limited.

TABLE OF CONTENTS

1. INTRODUCTION	1
1.0 Background	1
1.1 Site Location and Surrounding Land-use	1
1.2 Environmental Context	1
2. LANDFILL GAS	3
2.1 Perimeter Gas Monitoring Results.....	3
2.2 Trace Gas Monitoring.....	3
2.3 Engine and Flare Emission Monitoring	3
2.4 Landfill Gas from Capped Surfaces	3
3. GROUNDWATER	4
3.1 Groundwater Levels.....	4
3.2 Groundwater Quality	4
4. LEACHATE	6
4.1 Leachate Levels	6
4.3 Leachate Quality	6
4.4 Treated Leachate	7
5. SURFACE WATER.....	9
5.1 Surface Water Quality.....	9
6. DUST	10
6.1 Monitoring	10
7. ANNUAL PRODUCTION / TREATMENT	11
7.1 Introduction	11
8. PERFORMANCE PARAMETERS	12
8.1 Introduction	12
9. TOPOGRAPHICAL SURVEY	13
10. SUMMARY.....	14
10.1 Landfill Gas.....	14
10.2 Groundwater.....	14
10.3 Leachate	14
10.4 Surface Water	15
10.5 Dust.....	15

APPENDICES

- Appendix 1: Drawing: 2601.EMP.01 - Location of Monitoring Points
- Appendix 2: Landfill gas
- Appendix 3: Groundwater
- Appendix 4: Leachate
- Appendix 5: Surface water
- Appendix 6: Dust

1. INTRODUCTION

1.0 Background

1.1.1 This report has been compiled in compliance with the Environmental Permit (EP) (formerly PPC Permit) BU7766, Variation Notice Number EPR/BU7766IC/V004 for Bryn Posteg Landfill Site, which requires that the monitoring data collected at the site, is reviewed annually. The data reviewed by this report was collected from 1st January – 31st December 2017.

1.1.2 This report records and reviews monitoring data for landfill gas, leachate, groundwater and surface water and discusses this data in relation to emission limits set in the latest EP variations. The report includes a summary of performance parameters including dust monitoring, topographic survey of the site and production and treatment figures for leachate and gas.

1.1 Site Location and Surrounding Land-use

1.2.2 Bryn Posteg Landfill Site is located approximately 3 km south east of Llanidloes in Powys and is centered at National Grid Reference SN 971 822.

1.2.3 The landfill site was developed from the surface void of a former lead mine. Controlled landfilling has taken place since 1982.

1.2.4 The site is accessed via the B4518, Llanidloes to Tylwch road. The B4518 runs parallel with the western site boundary.

1.2.5 Bryn Posteg is situated amongst predominantly agricultural land. There are seven residential receptors located within approximately 450 m of the waste mass, these are:

- Valley View, 100 m to the north west;
- Rhoswen, 200 m to the east;
- Pant, 250 m to the east;
- Bryn Posteg Farm, 250 to the west;
- Penbryn Du, 300 m to the north
- Maes-Socyn, 350 m to the south-west
- Talcen-Llwydiarth, 450 m to the south-east

1.2 Environmental Context

Geology

1.2.1 According to ground investigations, the site is underlain by clay. The clay is predominantly grey, with various quantities of sand and mudstone gravel. This gravel is interpreted as being the weathering product of the underlying mudstone bedrock.

- 1.2.2 Geological maps indicated that the region is underlain by strata of the Upper Llandovery Groups of Silurian age. These strata comprise mudstone, slates and sandstones. There are a number of faults through the region, two of which underlie the site. One fault is oriented east-west across the north of the site and the other is oriented south-west to north-east, approximately along the stream on the south side of the site.

Hydrology

- 1.2.3 The site is within the catchment area of the River Severn. The Afon Dulas runs 3 km north-west of the site. Prior to development of this site the area was partly occupied by marshlands.
- 1.2.4 Due to the mining activities and later the landfilling activities at the site, the surface water regime around the site has been altered. Surface waters are discharged into the Nant-y-Bradnant to the east of the site and into the unnamed tributary of the Dulas on the western perimeter of the site.

Hydrogeology

- 1.2.5 The EA Groundwater Vulnerability Sheet No.20 indicates that the strata at the site are classified as a non-aquifer with negligible permeability. Groundwater is controlled by fracture flow within the Llandovery Mudstones.

2. LANDFILL GAS

2.1 Perimeter Gas Monitoring Results

- 2.1.1 Routine landfill gas (LFG) monitoring around the site perimeter is carried out on a weekly basis at 36 boreholes. Concentrations of methane (CH₄) and carbon dioxide (CO₂) are measured alongside oxygen (O₂), relative pressure and atmospheric pressure on each visit.
- 2.1.2 CH₄ concentrations exceeded the EP limit of 1.0 %¹ on at least one occasion at every location. Maximum concentrations in the boreholes ranged between 1.1 % (at 4 locations) and 84.6 % in G20.
- 2.1.3 Of these exceedances, sixteen of the locations where a breach was recorded were only slightly above the compliance limit. Eleven perimeter locations did however contain average methane concentrations at a significant concentration, above 10 %, during 2017.
- 2.1.4 CO₂ concentrations exceeded the trigger level value of 1.5 % on at least one occasion at 31 monitoring locations. Average concentrations in these boreholes ranged between 0% (G16) and a maximum of 32.1 % in G19. Locations G2, G8, G16, G17 and G32 remained below the trigger limit throughout the review period.
- 2.1.5 A summary table and time series graphs displaying all landfill gas monitoring data collected during this period are included in Appendix 2.

2.2 Trace Gas Monitoring

- 2.2.1 Trace gas monitoring was carried out on the 11th January. Monitoring reports are enclosed in Appendix 2.

2.3 Engine and Flare Emission Monitoring

- 2.3.1 Monitoring of the emissions from the flare and landfill gas engines was carried out on the 10th and 11th January 2018. Monitoring reports are enclosed in Appendix 2. None of the recorded emissions exceeded their respective limits for the flare or the engines.

2.4 Landfill Gas from Capped Surfaces

- 2.4.1 No surface emissions surveys were undertaken during 2017. A Flame Ionisation Detector (FID) walkover survey and flux box survey of the landfill is due to be carried out in 2018 and will be submitted separately.

¹ All gas concentrations are expressed as % v/v

3. GROUNDWATER

3.1 Groundwater Levels

- 3.1.1 Groundwater levels are recorded weekly. Levels remained stable throughout the year.

3.2 Groundwater Quality

- 3.2.1 Groundwater is sampled at locations W1 – W9 as required by Table S4.5 in the EP. W10 was not sampled as it is not currently safe to monitor and is due to be extended to ground level. Groundwater samples are analysed monthly for ammoniacal nitrogen, chloride, cyanide, pH, electrical conductivity and sulphate. In March, June and September, groundwater samples were analysed for the monthly and quarterly suites. In December, samples were also analysed for an additional annual suite. All monitoring data is included in Appendix 3.
- 3.2.2 Ammoniacal nitrogen concentrations remained below the 2 mg/L EP limit in all groundwater locations throughout 2017, with the exception of W4. Maximum concentrations of 2.49 mg/L, 2.35 mg/L and 3.13 mg/L were detected at W4 during August, October and November respectively.
- 3.2.3 pH ranged between a minimum of 5.5 in W5, and a maximum of 7.8 in W2. Electrical conductivity ranged between a minimum of 58.8 $\mu\text{S}/\text{cm}$ in W6 and a maximum of 890 $\mu\text{S}/\text{cm}$ in W1. Sulphate concentrations ranged between <4.4 mg/L in W2, W3 and W6 to 59.8 mg/L in W3.
- 3.2.4 Chloride concentrations were higher than the EP limit of 69 mg/L throughout the review period at W1. The average chloride concentration in W1 was 203 mg/L. Chloride concentration within W1 reduced over the review period to a minimum of 105 mg/L during October.
- 3.2.5 W1 is situated very close to the B4518 Llanidloes to Tylwch Road. In previous annual reviews it was noted that the groundwater quality within this borehole may be influenced by the application of road salt during the winter months. The chloride concentration within W1 shows no correlation to ammoniacal nitrogen, but does show strong correlation to sodium concentration. This was investigated in the Caulmert letter report 3033-CAU-XX-XX-CO-V-9101.A0-C1 which was submitted to NRW on the 24th April 2017. The results of this investigation suggest that the chloride concentrations at W1 are not related to landfill, but are instead reflective of a localised source of salt.
- 3.2.6 No 2, 4 –D, ethyl benzene or xylenes were detected in any of the groundwater monitoring locations.
- 3.2.7 Mecoprop was detected above the compliance limit at W5 during the second and third quarters with a concentration of 0.11 $\mu\text{g}/\text{l}$. Mecoprop was also detected below the

compliance limit at W5 in the fourth quarter of 2017 and during the third and fourth quarters at W4.

- 3.2.8 Concentrations of metals cadmium, nickel and zinc remained below their respective EP limits in all locations, throughout the review period.
- 3.2.9 In December, a full annual suite was undertaken, including a hazardous substances suite. Three parameters were detected in the groundwater and are detailed below in Table 1. No volatile organic compounds (VOCs) or semi volatile organic compounds (SVOCs) were detected. Full annual suite results are included in Appendix 3.

Table 1: Annual Groundwater Hazardous substances suite – detected parameters

Parameter	Unit	GW 1	GW 2	GW 3	GW 4	GW 5	GW 6	GW 7	GW 8	GW 9
EH >C16 - C24	ug/l	<40	101	<20	<40	<10	<10	<10	<10	<10
EH >C24 - C40	ug/l	<40	337	58	<40	<10	<10	<10	<10	<10
EH >C6 - C40	ug/l	<40	438	58	<40	<10	<10	<10	<10	<10

4. LEACHATE

4.1 Leachate Levels

- 4.2.1 Leachate levels are measured monthly at LCP1 (Sump 1), LCP2 (Sump 2), LCP3 (Sump 3), LCP7 (Sump 4), LCP8 (Sump 5), RMLP9C (Sump 9c) and RMLP9D (Sump 9d). LC6, RMLP9A and RMLP9B are sealed to improve the gas management on site. Level data and time series graphs are presented in Appendix 4.
- 4.2.2 Leachate levels in LCP1 remained below the 1 m EP limit throughout 2017.
- 4.2.3 Leachate levels in LCP2 and LCP3 were above the compliance limit for the first quarter of 2017. For the remainder of the year LCP2 was compliant and LCP3 was compliant between May and December. Average values for leachate above the base were 0.7 m and 1.0 m respectively.
- 4.2.4 LCP7 and LCP8 leachate levels were highest during the first quarter with maximums of 1.05 m and 1.65 m respectively, this is significantly lower than the previous year maximums which were 8.66 m and 6.89 m. From May onwards LCP7 and LCP8 were below the permitted limit of 1m above base.
- 4.2.5 RMLP9C and RMLP9D had the most elevated leachate levels in 2017 with levels around 10 m above base in both sumps for the first 3 months of the year. Levels in RMLP9C range between 10.01 m and 10.11 m in the first quarter and in RMLP9D levels were between 10.06 m and 10.36 m. From April onwards leachate levels in these sumps comply with the 1m permitted limit. These levels have been under review as part of ongoing improvement measures to increase leachate extraction rates. More efficient extraction and removal of leachate from site via tanker facilitated a reduction in levels across the site during 2017.

4.3 Leachate Quality

- 4.3.1 Leachate was analysed monthly for pH and ammoniacal nitrogen at LCP1 (Sump 1), LCP2 (Sump 2), LCP3 (Sump 3), LCP7 (Sump 4), LCP8 (Sump 5), RMLP9C (Sump 9c) and RMLP9D (Sump 9d). Samples from these locations were previously referred to as Leachate 1 – 7 respectively. In this report, and all future reports, the leachate results will be referred to as they are presented in the Permit.
- 4.3.2 LCP3 was sampled once during 2017. RMLP9C was sampled on 5 occasions, and RMLP9D was sampled on 7 occasions in 2017. Treated leachate (final discharge) was tested monthly for pH, ammoniacal nitrogen, sulphate, suspended solids, COD, and a TPH range (C6 – C40).
- 4.3.3 Highest ammoniacal nitrogen concentrations were detected in LCP2 during 2017, as in 2016. Concentrations in this sump ranged between 21.7 mg/L and 3690 mg/L.
- 4.3.4 Ammoniacal nitrogen concentrations at LCP7 (average concentration of 1210 mg/L) and LCP8 (average concentration of 1490 mg/L) followed a similar trend, increasing towards June 2017 then decreasing slightly towards the end of the year.

- 4.3.5 pH in the leachate ranged between a minimum of 5.2 in RMLP9D to a maximum of 8.2 in LCP2.
- 4.3.6 Landfill leachate was also analysed for a larger hazardous substances annual suite in December. 9 parameters were detected in the leachate chambers and are presented in Table 2 below. This is significantly less than in 2016 when 31 were detected.

Table 2: Landfill Leachate Hazardous substances suite – detected parameters

Sample Matrix	Unit	LCP1	LCP2	LCP7	LCP8
Lead , Total as Pb	mg/L	<0.006	0.182	0.007	<0.006
Nickel, Total as Ni	mg/L	0.022	0.334	0.125	0.155
Zinc, Total as Zn	mg/L	0.225	2.24	0.2	0.12
Mecoprop	ug/L	2.32	77.1	25.8	38.4
EH >C6 - C40	ug/L	977	2740	1320	555
EH >C8 - C10	ug/L	59	235	177	<100
EH >C16 - C24	ug/L	<40	271	201	140
EH >C24 - C40	ug/L	50	871	342	177
EH >C10 - C16	ug/L	868	1370	595	238

4.4 Treated Leachate

- 4.4.1 Approximately 28,844 m³ of leachate was discharged, under discharge consent to Severn Trent for further treatment between the 1st of January and the 31st of December 2017.
- 4.4.2 Additionally to the leachate processed on site at the leachate treatment plant, 6975 m³ of leachate was tankered off site during 2017 to maximize extraction from the site and lower leachate levels.
- 4.4.3 Potters Waste Management undertake daily in-situ testing of treated leachate in order to assess its suitability for discharge. Treated leachate is not discharged if compliance level exceedances are recorded. A summary of this data is included in Table 4 below as requested by NRW:

Table 3: Treated leachate daily monitoring summary (January - December 2017)

DATE	pH (METER)	pH (STRIP)	Ammoniacal Nitrogen (mg/l)	Dissolved Oxygen (mg/l)	Temperature (°C)
Min	5.5	10.0	6.9	0.9	10.1
Max	8.3	150.0	6.9	9.6	20.5
Average	7.2	70.3	6.9	4.6	15.6
Count	62	62	62	62	62

- 4.4.4 Several exceedances were recorded during the review period within the treated leachate. Concentrations of ammoniacal nitrogen did not exceed the EP limit of 150 mg/L in 2017.

This is a significant improvement on the quality of treated leachate from 2016, when six ammoniacal nitrogen concentration exceedances were recorded.

- 4.4.5 The concentration of suspended solids within the treated leachate exceeded the EP limit between May and August with a maximum of 7650 mg/L. The average for the year was 1087 mg/l, this is above the limit of 500 mg/L. Suspended solids concentrations have increased on average when compared to 2016 (1470 mg/L average), however the total number of exceedances has decreased. There were four exceedances for suspended solids during 2017, as opposed to nine exceedances during 2016.
- 4.4.6 COD concentrations ranged between 374 mg/L in December and a maximum of 2660 mg/L in January 2017. Average concentrations were 1196 mg/L which is slightly above the limit of 1000 mg/L and significantly lower than the 2016 average of 2071 mg/L. There were also only four months in which an exceedance was detected during 2017, as opposed to the eleven exceedances of 2016. The DAF is currently operational and is expected to continue improving the COD concentration in the treated leachate.
- 4.4.7 Concentrations of TPH were detected on all of the monitoring rounds, exceeding the compliance limit of 'nil'. Concentrations ranged between 301 µg/L and 6100 µg/L. Average TPH concentration during 2017 was 2068.8 mg/L. This is significantly higher than that detected in 2016 (986 mg/L).
- 4.4.8 A biomass boiler and heat exchange system was commissioned at Bryn Posteg during 2017, which aids in maintaining the temperature of the leachate treatment lagoon within the optimum range for the biological treatment process. With the exception of TPH, this has improved the quality of the treated leachate, particularly during the winter months.
- 4.4.9 During June and December the Final Discharge was analysed for a 6 monthly suite. December samples were also analysed for additional hazardous substances. Table 4 below displays the detected parameters.

Table 4: Treated Leachate Hazardous substances suite – detected parameters

Parameter	Units	June	December
Cyanide	mg/L	0.85	<0.009
Dicamba	µg/L	<5.00	0.32
EH >C6 - C40	µg/L	2220	301
EH >C10 - C16	µg/L	2220	232
EH >C16 - C24	µg/L	<100	69
Mercury	mg/L	0.00019	<0.0001
Chloromethane	µg/L	22	<20.0
Bromomethane	µg/L	17.2	<20.0

5. SURFACE WATER

5.1 Surface Water Quality

- 5.1.1 Surface water samples were collected at SW1 (P1) and SW2 (P2) during the review period. Surface water monitoring data and time series graphs are included in Appendix 5.
- 5.1.2 Concentrations of ammoniacal nitrogen do not exceed the compliance limit of 0.25 mg/L in SW1 in 2017. In SW2 concentrations of ammoniacal nitrogen reach a maximum of 0.83mg/L in December 2017. Ammoniacal nitrogen in SW2 is compliant for 75% of the year, with an average concentration of 0.2 mg/L.
- 5.1.3 Suspended solids concentration exceeded the trigger limit on average in SW2 at 230 mg/L, this is higher than the previous year where the maximum was 180 mg/L. An average of 53 mg/l is noted at SW2, which is slightly above the limit of 50 mg/L. However in SW1 the concentrations did not exceed the permitted limit of 50 mg/L.
- 5.1.4 The pH remained within the EP limit range of 6 – 9 at SW1 and SW2 throughout the review.
- 5.1.5 No hazardous substances were detected in the surface water locations as part of the suites in June and December. This is a notable decrease compared to three substances detected in 2016.

6. DUST

6.1 Monitoring

6.1.1 Dust monitoring at the site was carried out on 3 occasions in 2017. The results are summarized below:

Table 5: Dust Monitoring Results

Dust	Concentration (mg/m ² /day)
Period	17/05/2017 – 30/05/2017
BP 1	26
BP 2	41
BP 3	31
Period	27/06/2017 -31/07/2017
BP 1	46
BP 2	69
BP 3	37
Period	12/11/2017 – 16/12/2017
BP 1	<10
BP 2	<10
BP 3	23

6.1.2 Dust concentrations remained below the EP limit of 200 mg/m²/day at all locations during 2017.

7. ANNUAL PRODUCTION / TREATMENT

7.1 Introduction

7.1.1 Annual production/treatment at Bryn Posteg during the period 1st January to 31st December 2016 is reported in accordance with Table S5.2 in the EP, see Table 7 below:

Table 6: Annual Production/Treatment

Annual production/treatment	
Leachate:	Cubic metres/year:
Disposed of off-site (sewer);	28,844
Disposed of to any offsite effluent treatment plant;	6975
Recirculated into the waste mass.	Nil
Surface water and/or groundwater:	Cubic metres/year:
Disposed of off-site;	Nil
Disposed of to any onsite effluent treatment plant.	Nil
Landfill gas:	Normalised cubic metres/year:
Combustion in flares;	0.15 million*
Combustion in gas engines;	4.8 million*
Other methods of gas utilisation.	Nil

* estimated

8. PERFORMANCE PARAMETERS

8.1 Introduction

- 8.1.1 Performance parameters are reported in line with requirements in the EP. Data is presented in Table 7 below, which is a reproduction of Table S5.3 in the permit.

Table 7: Performance Parameters

Parameter	Frequency of assessment	Annual total	Unit
Energy Used (including for leachate treatment)	Annually	130*	MWh of Electricity

* estimated

- 8.1.2 It should be noted that 8793 MWh of energy was exported from the site during the same time period.

9. TOPOGRAPHICAL SURVEY

- 9.0.1 An investigation into the current landfill form is ongoing in relation to the Statutory Notice R61 dated 18th January 2018. An updated Stability Risk Assessment will be submitted separately to include a current topographical survey, restoration profiles and remaining void figures.

10. SUMMARY

10.1 Landfill Gas

- 10.1.1 Methane concentrations exceeded the EP limit of 1.0 %¹ on at least one occasion all monitoring locations.
- 10.1.2 CO₂ concentrations exceeded the trigger level value of 1.5 % on at least one occasion at all monitoring locations.
- 10.1.3 Landfill gas concentration detected in the perimeter boreholes in this review period are similar to those detected in 2016.

10.2 Groundwater

- 10.2.1 Groundwater levels remained stable throughout the review period in all locations.
- 10.2.2 The EP limit for chloride was exceeded in location W1 throughout the review period. It is likely that this locations is influenced by road salt, used on the B4518 during the winter months, which would explain the seasonality seen in the results.
- 10.2.3 Three parameters from the bi-annual suite were detected in the groundwater in low concentrations.

10.3 Leachate

- 10.3.1 Leachate levels in LCP1 remained below the 1 m EP limit throughout the review. Leachate levels in LCP2 and LCP3 were above the compliance limit for the first quarter of 2017. For the remainder of the year LCP2 was compliant and LCP3 was compliant between May and December. LCP7 leachate levels were above the compliance limit in February alone, while LCP8 levels were in exceedance of the compliance limit for January through April.
- 10.3.2 RMLP9C and RMLP9D were above the leachate level compliance limit during the first quarter of 2017, then decreased to below the compliance limit for the remainder of 2017.
- 10.3.3 Highest ammoniacal nitrogen concentrations were detected in LCP2 during 2017. Nine parameters were detected in the annual hazardous substances suite.
- 10.3.4 In the final discharge (treated leachate) quality data, exceedances of the EP limits for suspended solids, COD and TPH were recorded. Treated leachate is not discharged if EP limit exceedances are recorded. A total of eight parameters from the hazardous substances suite were detected during 2017.
- 10.3.5 Approximately 28,844 m³ of treated leachate was discharged to sewer (under discharge consent) and 6975 m³ of leachate was tankered off site for treatment.

10.4 Surface Water

10.4.1 Concentrations of all parameters remained below their respective EP limits in the monthly and quarterly analysis, except ammoniacal nitrogen and suspended solids.

10.4.2 Ammoniacal nitrogen concentration did not exceed the EP limit during 2017 at SW1, however three slight exceedances were detected at SW2. Suspended solids concentrations exceeded the EP limit on six occasions in SW2 alone.

10.4.3 No hazardous substances were detected in SW1 or SW2 as part of the annual suite in December.

10.5 Dust


10.5.1 Dust concentrations remained below the EP limit at all locations during 2017.



Appendix 1

© COPYRIGHT CAULMERT LIMITED - NOT TO BE COPIED OR REPRODUCED IN ANY WAY OR FORM WITHOUT PRIOR WRITTEN CONSENT FROM CAULMERT LIMITED

CAD FILE REF: \\caulmert.local\cmmore\Files\CAD\Projects\2306 Bryn Posteg\Drawings\Current Working Drawings\2306.EMP.01.dwg



NOTES

1. SURVEY INFORMATION PROVIDED BY POTTERS WASTE MANAGEMENT. SURVEY DATED 12.01.2016
2. ALL LEVELS IN METRES ABOVE ORDNANCE DATUM.
3. DO NOT SCALE FROM THIS DRAWING

LEGEND

- IN WASTE GAS WELL
- GAS MONITORING BOREHOLE
- GROUNDWATER MONITORING BOREHOLE
- GAS MONITORING BOREHOLE WITH GROUNDWATER MONITORING BOREHOLE
- EXISTING LEACHATE COLLECTION POINT

- IN WASTE GAS WELL
- APPROXIMATE POSITION OF SURFACE WATER MONITORING POINT
- APPROXIMATE POSITION OF DUST MONITORING POINT

SURFACE WATER MONITORING POINTS

- P1 NANT-Y-BRADNANT
- P2 AFON DULAS

DUST MONITORING POINTS

- DMP1 VALLEY VIEW
- DMP2 RHOSWEN AND PANT
- DMP3 PENBRYNDU

REV	MODIFICATIONS	BY	RE	AP	DATE
-----	---------------	----	----	----	------

POTTERS WASTE
MANAGEMENT

BRYN POSTEG LANDFILL
SITE

ENVIRONMENTAL
MONITORING PLAN

DRAWN BY	RWG	DATE	12.02.2016
----------	-----	------	------------

REVIEWED BY	JMC	SCALE	A1 1:1250
-------------	-----	-------	--------------


AUTHORISED BY	JMC	ISSUE	P	REVISION	P1
---------------	-----	-------	---	----------	----

DRAWING NUMBER	2601.EMP.01
----------------	-------------

Caulmert
Engineering, Environmental and Planning

WWW.CAULMERT.COM

Registered Office: Intec, Parc Menai, Bangor, Gwynedd, LL57 4EG Company Registered No: 06716319









Appendix 2




APPENDIX 2 – LANDFILL GAS




Table 1: Landfill Gas monitoring data (% v/v) – Exceedances highlighted yellow




ID	Methane (% v/v)			Carbon Dioxide (% v/v)			Oxygen (%v/v)			Count
	Min	Max	Ave	Min	Max	Ave	Min	Max	Ave	
G01	0.0	21.7	2.5	0.0	4.0	1.1	4.7	20.5	17.3	33
G02	0.0	11.2	0.4	0.0	1.2	0.2	20.0	22.1	20.7	33
G03	0.0	1.1	0.1	0.1	3.2	1.3	13.6	21.0	18.2	33
G07	0.0	1.2	0.1	0.0	3.6	1.6	12.8	22.0	19.5	33
G08	0.0	1.2	0.1	0.0	1.7	0.3	14.2	21.8	19.7	34
G09	0.0	1.2	0.1	0.0	0.9	0.1	20.5	22.2	21.1	33
G10	0.0	1.2	0.2	0.0	8.9	3.5	13.0	21.6	18.0	34
G11	0.0	45.2	1.5	0.0	3.5	0.9	7.7	22.9	20.2	33
G12	33.4	92.4	57.6	2.6	4.9	3.6	0.2	11.2	5.6	33
G13	0.0	1.2	0.1	0.0	2.6	0.2	19.0	22.6	21.1	33
G14	0.0	1.2	0.1	1.1	4.0	2.5	16.0	20.7	18.4	34
G15	0.0	1.2	0.1	0.4	6.5	1.8	6.2	20.4	17.6	33
G16	0.0	1.2	0.1	0.0	0.1	0.0	20.6	22.8	21.4	33
G17	0.0	1.2	0.1	0.0	0.7	0.1	20.6	22.7	21.4	33
G18	0.0	1.2	0.1	0.0	1.8	0.1	20.4	22.8	21.3	33
G19	44.8	81.6	68.7	23.0	38.3	32.1	0.2	6.6	0.8	33
G20	61.4	84.6	71.0	8.2	39.2	26.9	0.1	7.4	1.0	33
G21	1.2	75.6	54.5	0.0	25.4	14.8	0.1	21.2	2.3	33
G22	52.9	75.9	71.6	16.6	31.3	23.3	0.1	5.7	0.4	33
G23	0.9	56.9	14.8	4.8	21.1	9.8	0.1	8.6	0.8	32
G24	0.0	52.0	12.0	0.0	24.4	5.2	5.1	22.1	16.7	33
G25	14.7	62.7	38.2	6.8	22.3	15.0	0.2	11.7	2.0	34
G26	0.0	1.2	0.1	0.6	4.2	2.3	15.4	20.8	18.8	33
G27	0.0	64.5	8.1	0.0	31.6	5.5	1.0	22.7	17.6	34
G29	0.0	7.1	1.3	0.0	8.1	1.8	1.8	23.1	16.9	33
G30	0.0	19.0	5.2	0.0	3.9	1.6	10.6	22.7	17.8	33
G31	0.0	21.9	2.4	1.0	9.8	3.8	5.3	21.6	17.0	33
G32	0.0	1.1	0.1	0.0	1.3	0.3	20.0	22.7	21.2	33
G35	0.0	74.3	47.1	0.0	37.1	22.4	0.1	21.6	6.1	34
G36	0.0	39.5	3.4	0.1	7.7	1.5	5.2	22.2	18.6	34
G37	0.0	1.1	0.1	0.1	3.6	1.7	15.6	21.5	20.3	32
G38	18.1	73.9	55.2	16.4	35.5	29.3	0.1	8.0	0.8	34
G39	0.0	1.1	0.1	0.0	5.4	1.1	14.8	22.7	20.2	33
G40	0.0	69.5	19.3	0.0	33.5	14.1	0.1	22.3	9.3	33
G41	0.0	36.4	4.1	0.0	28.7	6.7	0.3	22.1	9.9	34
G42	0.0	1.1	0.1	0.0	3.4	0.4	18.1	22.9	21.2	31














Concept Reference: 708572

Customer Reference: P3334

Tube (Tenax/Carbon/Molecular Sieve) Analysed as Tube (Tenax/Carbon/Molecular Sieve)

Trace Landfill Gas Suite

Concept Reference					708572 018	708572 021	708572 022
Customer Sample Reference					ECL/18/0086	ECL/18/0089	ECL/18/0090
Test Sample					AR	AR	AR
Volume l					0.238		
Date Sampled					11-JAN-2018	11-JAN-2018	11-JAN-2018
Determinand	Method	LOD	Units	Symbol			
1 Pentene	GC/MS (TD SIR)	10	ng	U	(68) 46	(68) 30	(68) 23
	Calc	Calc	mg/m3	N	0.19		
	Calc	Calc	ppm	N	0.067		
1,1-Dichloroethane	GC/MS (TD SIR)	10	ng	U	<10	<10	<10
	Calc	Calc	mg/m3	N	<0.042		
	Calc	Calc	ppm	N	<0.010		
1,1-Dichloroethylene	GC/MS (TD SIR)	10	ng	U	280	240	<10
	Calc	Calc	mg/m3	N	1.2		
	Calc	Calc	ppm	N	0.30		
1,2-Dichloroethane	GC/MS (TD SIR)	10	ng	N	(175) 1600	<10	<10
	Calc	Calc	mg/m3	N	6.7		
	Calc	Calc	ppm	N	1.7		
1,2-Dichloroethylene	GC/MS (TD SIR)	30	ng	U	<30	<30	300
	Calc	Calc	mg/m3	N	<0.13		
	Calc	Calc	ppm	N	<0.032		
1,3-Butadiene	GC/MS (TD SIR)	10	ng	U	(68) <10	(68) <10	(68) 82
	Calc	Calc	mg/m3	N	<0.042		
	Calc	Calc	ppm	N	<0.019		
1,4 epoxy 1,3-butadiene	GC/MS (TD SIR)	10	ng	N	<10	<10	<10
	Calc	Calc	mg/m3	N	<0.042		
	Calc	Calc	ppm	N	<0.015		
1-Propanethiol	GC/MS (TD SIR)	10	ng	U	<10	<10	<10
	Calc	Calc	mg/m3	N	<0.042		
	Calc	Calc	ppm	N	<0.013		
2-butoxyethanol	GC/MS (TD SIR)	10	ng	N	<10	<10	<10
	Calc	Calc	mg/m3	N	<0.042		
	Calc	Calc	ppm	N	<0.0087		
Benzene	GC/MS (TD SIR)	10	ng	U	(175) 5900	(175) 2100	<10
	Calc	Calc	mg/m3	N	25		
	Calc	Calc	ppm	N	7.8		
Butyric acid	GC/MS (TD SIR)	10	ng	N	<10	<10	<10
	Calc	Calc	mg/m3	N	<0.042		
	Calc	Calc	ppm	N	<0.012		
Carbon disulphide	GC/MS (TD SIR)	10	ng	N	440	<10	<10
	Calc	Calc	mg/m3	N	1.8		
	Calc	Calc	ppm	N	0.59		
Carbon tetrachloride	GC/MS (TD SIR)	10	ng	U	<10	<10	<10
	Calc	Calc	mg/m3	N	<0.042		
	Calc	Calc	ppm	N	<0.0067		
Chloroethane	GC/MS (TD SIR)	30	ng	N	<30	<30	<30
	Calc	Calc	mg/m3	N	<0.13		
	Calc	Calc	ppm	N	<0.048		
Dichloromethane	GC/MS (TD SIR)	10	ng	N	(175) 5300	<10	<10
	Calc	Calc	mg/m3	N	22		
	Calc	Calc	ppm	N	6.4		
Dimethyl disulphide	GC/MS (TD SIR)	10	ng	N	320	<10	<10
	Calc	Calc	mg/m3	N	1.3		
	Calc	Calc	ppm	N	0.35		
Dimethyl sulphide	GC/MS (TD SIR)	10	ng	U	750	12	21
	Calc	Calc	mg/m3	N	3.2		
	Calc	Calc	ppm	N	1.2		
Ethyl butyrate	GC/MS (TD SIR)	25	ng	N	<25	<25	<25
	Calc	Calc	mg/m3	N	<0.11		
	Calc	Calc	ppm	N	<0.022		
Ethyl Mercaptan	GC/MS (TD SIR)	10	ng	N	<10	<10	<10
	Calc	Calc	mg/m3	N	<0.042		
	Calc	Calc	ppm	N	<0.017		
Hydrogen sulphide	GC/MS (TD SIR)	60	ng	N	<60	<60	<60

Concept Reference: 708572							
Customer Reference: P3334							
Tube (Tenax/Carbon/Molecular Sieve) Analysed as Tube (Tenax/Carbon/Molecular Sieve)							
Trace Landfill Gas Suite							
Concept Reference					708572 018	708572 021	708572 022
Customer Sample Reference					ECL/18/0086	ECL/18/0089	ECL/18/0090
Test Sample					AR	AR	AR
Volume l					0.238		
Date Sampled					11-JAN-2018	11-JAN-2018	11-JAN-2018
Determinand	Method	LOD	Units	Symbol			
	Calc	Calc	mg/m3	N	<0.25		
	Calc	Calc	ppm	N	<0.18		
Methyl Mercaptan	GC/MS (TD SIR)	30	ng	N	<30	<30	<30
	Calc	Calc	mg/m3	N	<0.13		
	Calc	Calc	ppm	N	<0.064		
N-Butyl Mercaptan	GC/MS (TD SIR)	10	ng	U	<10	<10	<10
	Calc	Calc	mg/m3	N	<0.042		
	Calc	Calc	ppm	N	<0.011		
Styrene	GC/MS (TD SIR)	10	ng	N	260	<10	<10
	Calc	Calc	mg/m3	N	1.1		
	Calc	Calc	ppm	N	0.26		
Toluene	GC/MS (TD SIR)	10	ng	N	(27) 12000	31	<10
	Calc	Calc	mg/m3	N	50		
	Calc	Calc	ppm	N	13		
Trichloroethylene	GC/MS (TD SIR)	10	ng	U	730	250	<10
	Calc	Calc	mg/m3	N	3.1		
	Calc	Calc	ppm	N	0.57		
Vinyl chloride monomer	GC/MS (TD SIR)	10	ng	U	(68) <10	(68) <10	(68) <10
	Calc	Calc	mg/m3	N	<0.042		
	Calc	Calc	ppm	N	<0.016		

Concept Reference: 708572 Customer Reference: P3334 Tube (Charcoal) Analysed as Tube (Charcoal 226-01) Siloxanes							
Concept Reference				708572 025	708572 026		
Customer Sample Reference				ECL/18/0093	ECL/18/0094		
Test Sample				AR	AR		
Date Sampled				11-JAN-2018	11-JAN-2018		
Determinand	Method	LOD	Units	Symbol			
Decamethylcyclopentasiloxane	GC/MS (Solvent Desorption)	1	µg	U	<1	<1	
Decamethyltetrasiloxane	GC/MS (Solvent Desorption)	1	µg	U	<1	<1	
Hexamethylcyclotrisiloxane	GC/MS (Solvent Desorption)	1	µg	U	<1	<1	
Hexamethyldisiloxane	GC/MS (Solvent Desorption)	1	µg	U	<1	<1	
Octamethylcyclotetrasiloxane	GC/MS (Solvent Desorption)	1	µg	U	<1	<1	
Octamethyltrisiloxane	GC/MS (Solvent Desorption)	1	µg	U	<1	<1	

Index to symbols used in Supplement to 708572-1

Value	Description
AR	As Received
27	Result should be considered as a minimum due to detector saturation.
13	Results have been blank corrected.
175	Results should be viewed with caution due to being outside of the instrument calibration range
68	Outside scope of UKAS accreditation
U	Analysis is UKAS accredited
N	Analysis is not UKAS accredited
C	Calculation

Notes

Supplemental report issued to include air concentration units for Sample 018 as this was missing from the original report.
The results for 1 Pentene, 1,3-Butadiene & Vinyl Chloride Monomer are outside the scope of our UKAS accreditation as the standards expired on the 13/01/18.

EMISSIONS MONITORING SURVEY

Prepared for:


**Potters Waste
Brynposteg Landfill Site
Llandidloes
SY18 6JJ**

Permit Number	: TP3736SQ
Variation Number	: ...
Installation	: Engine 1 & 2
Visit Details	: Annual Compliance
Job Number	: P3334
Report Number	: R001
Report Issue Date	: 31st January 2018
Survey Dates	: 10th & 11th January 2018

Prepared by:

Environmental Compliance Limited

Unit G1
Main Avenue
Treforest Industrial Estate
Pontypridd
CF37 5BF.
Tel: 01443 841760
Fax: 01443 841761

Report Issue:		FINAL	
Report Prepared by:		Report Reviewed & Approved by MCERTS Level Two Technical Endorsements TE1, TE2, TE3 & TE4	
Name:	Mike Mullett	Name:	Sam Brookes
		MCERTS No:	MM 06 755
		Signature:	
Date:	29/01/2018	Date:	31/01/2018

This report is not to be used for contractual or engineering purposes unless this approval sheet is signed where indicated by the approver and the report is designated "FINAL".



Environmental Compliance Limited

Potters Waste
Permit No : TP3736SQ
Variation No : ...
Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

This report has been prepared by Environmental Compliance Limited (ECL) in their professional capacity as Environmental Consultants. The contents of the report reflect the conditions that prevailed and the information available or supplied at the time of its preparation. The report, and the information contained therein, is provided by ECL solely for use and reliance by the Client in performance of ECL's duties and liabilities under its contract with the Client. Until ECL has received payment in full as detailed in the quotation or contract the contents of this report remain the legal property of ECL. The contents of the report do not, in any way, purport to include any manner of legal advice or opinion.

This report should not be reproduced, (except in full) without the written approval of the laboratory.

Should the Client wish to release this report to a Third Party for the party's reliance, Environmental Compliance Ltd may, at its discretion, agree to such release provided that:

- Environmental Compliance Ltd gives written agreement prior to such release and ECL has received payment in full for all works/services undertaken;
- By release of the report to the Third Party, that Third Party does not acquire any rights, contractual or otherwise, whatsoever against Environmental Compliance Ltd and, accordingly, Environmental Compliance Ltd assume no duties, liabilities or obligations to that Third Party;
- Environmental Compliance Ltd accepts no responsibility for any loss or damage incurred by the Client or for any conflict of Environmental Compliance Ltd interests arising out of the Client's release of this report to the Third Party.

In the event that a report is revised and re-issued, the client shall ensure that any earlier versions of the report, and any copies thereof, are void and such copies should be marked with the words "superseded and revised".

Opinions and Interpretation expressed within this report are outside the scope of the UKAS accreditation.

MCERTS requirements mean that comparison of results with emissions limit values is not permitted within this report.

Potters Waste
 Permit No : TP3736SQ
 Variation No : ...
 Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
 Visit Details : Annual Compliance
 Survey Dates : 10th & 11th January 2018
 Report Issue Date : 31st January 2018

TABLE OF CONTENTS

Section	Description	Page Number
	Document Control Sheet	
PART 1	EXECUTIVE SUMMARY	4
1	MONITORING OBJECTIVES	4
1.1	Monitoring Results	5
1.2	Operating Information	7
2	MONITORING DEVIATIONS	8
PART 2	SUPPORTING INFORMATION	9
3	SAMPLING STAFF DETAILS	9
4	SAMPLING PROTOCOLS / METHODOLOGIES	10
5	SAMPLE POINT DESCRIPTIONS	14
	EQUIPMENT IDs	16
	FIGURES	18
	TABLES	21
	VELOCITY TRAVERSE PROFILES	28
	FIELD CALIBRATION AND SAMPLING DATA	31
	LABORATORY ANALYSIS RESULTS	42
	UNCERTAINTY CALCULATIONS	47

Potters Waste
 Permit No : TP3736SQ
 Variation No : ...
 Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
 Visit Details : Annual Compliance
 Survey Dates : 10th & 11th January 2018
 Report Issue Date : 31st January 2018

PART 1 - EXECUTIVE SUMMARY

1 Monitoring Objectives

Environmental Compliance Ltd (ECL) was commissioned by **Potters Waste** to undertake an emission monitoring survey at their **Brynposteg Landfill site**. This report presents the findings of the study.

The monitoring at this installation was carried out in accordance with our quotation reference **DHFB/P3334/Q001**, for compliance check monitoring of emissions to air. The substances requested for monitoring at each emissions point are listed below:

Substances to be monitored	Emission Point Identification	
	Ref No:	Ref No:
	Engine 1	Engine 2
Velocity / Flowrate	● U	● U
Oxides of Nitrogen (as NO ₂)	● U	● U
Sulphur Dioxide	● U	● U
Carbon Monoxide	● U	● U
Oxygen	● U	● U
Carbon Dioxide	● U	● U
Total Organic Carbon (TVOC)	● U	● U
Non-methane VOCs	● U	● U

- Denotes the substances to be monitored.

U

Denotes UKAS accreditation is held for monitoring that substance, but does not mean that it has been claimed which will depend on whether the testing could be completed in accordance with the Standard Reference Method.

Special Requirements: "Normal operating conditions."

Environmental Compliance Limited

Potters Waste
Permit No : TP3736SQ
Variation No : ...
Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

1.1 Monitoring Results

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty %	Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation for use of Method	Tick if non-conforming test (see Sections 2 & 5)	Operating Status
Engine 1	Volumetric Flowrate	...	4.45007	m³/sec	4	Stack Conditions	10/01/2018	12:28 – 12:38	BS EN 16911-1:2013 & MID	NU	✓	Normal
	Volumetric Flowrate	...	1.10789	m³/sec	8	Dry & 5% O₂		12:51 – 13:50		BS EN 12619:2013	NU	
	TVOC as Carbon	1750	1639.12	mgC/m³	3			12:30 – 13:29	BS EN 14792: 2017	UKAS / MCERTS	✓	
	Oxides of Nitrogen (as NO₂)	441.18	439.21	mg/m³	3				BS EN 15058: 2017	UKAS / MCERTS	✓	
	Carbon Monoxide	1500	1062.54	mg/m³	4				BS EN 14789: 2017	UKAS / MCERTS	✓	
	Oxygen (Zirconia Cell)	...	7.18	%	6	Dry		ISO 12039:2001	UKAS / MCERTS	✓		
	Carbon Dioxide	1448.7	11.51	%	3	Dry		13:56 – 14:36	CEN/TS 13649:2014	NU	✓	
	Non-Methane VOC ^{\$}	150	0.73	mg/m³	20	Dry & 5% O₂		12:43 – 13:43	BS EN 14791:2017	NU	✓	
	Sulphur Dioxide ^{\$}	...	72.11	mg/m³	13							

The volumetric flowrate shown above is that from the initial pitot traverse.

Any other flow measurements made during isokinetic sampling and/ or repeat traverses are shown later in the tables section.

For additional Notes see page 6.

Environmental Compliance Limited

Potters Waste
Permit No : TP3736SQ
Variation No : ...
Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty %	Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation for use of Method	Tick if non-conforming test (see Sections 2 & 5)	Operating Status	
Engine 2	Volumetric Flowrate	...	4.62948	m³/sec	5	Stack Conditions	10/01/2018	15:00 – 15:20	BS EN 16911-1:2013 & MID	UKAS / MCERTS		Normal	
	Volumetric Flowrate	...	1.18792	m³/sec	9	Dry & 5% O₂					UKAS / MCERTS		
	TVOC as Carbon	1750	1648.33	mgC/m³	3			16:23 – 17:22	BS EN 12619:2013	UKAS / MCERTS			
	Oxides of Nitrogen (as NO₂)	441.18	430.48	mg/m³	3				BS EN 14792: 2017	UKAS / MCERTS			
	Carbon Monoxide	1500	1061.30	mg/m³	4				BS EN 15058: 2017	UKAS / MCERTS			
	Oxygen (Zirconia Cell)	...	8.08	%	6	Dry		16:23 – 17:22	BS EN 14789: 2017	UKAS / MCERTS			
	Carbon Dioxide	1448.7	10.24	%	3	Dry			ISO 12039:2001	UKAS / MCERTS			
	Non-Methane VOC ^{\$}	150	0.20	mg/m³	18	Dry & 5% O₂		16:23 – 17:23	CEN/TS 13649:2014	NU	✓		
	Sulphur Dioxide ^{\$}	...	93.72	mg/m³	13			15:14 – 16:14	BS EN 14791:2017	UKAS / MCERTS			

The volumetric flowrate shown above is that from the initial pitot traverse.

Any other flow measurements made during isokinetic sampling and/ or repeat traverses are shown later in the tables section.

Notes

The uncertainty figures presented in Table 1.1 for NO_x, CO, SO₂, O₂ & TVOC are “measurement uncertainty” figures, which do not take into account the variability of the measured sample values. The “uncertainty of measurement results” figures, which do include this contribution, are presented in the appendices of the report for these determinands.

Emission Limit Value
Periodic Monitoring Result
Uncertainty
Reference Conditions
Monitoring Method Reference
Accreditation for use of Method
Operating Status
^{\$}

The emission limit value is that stated in the permit and will be expressed as a concentration or a mass emission.
The result given is expressed in the same terms and units as the emission limit value.
The uncertainty associated with the quoted result is at the 95% confidence interval. The Uncertainty results **DO NOT** take into account the effect of the sample location limitations.
All results are expressed at 273 K and 101.3kPa. The oxygen and moisture corrections are stated.
The method stated is in accordance with the Environment Agency Technical Guidance Note M2, or other method approved by the Environment Agency.
The details indicate the accreditation for the use of the complete monitoring method, e.g. MCERTs, UKAS. If use of the method is not accredited " NA" is stated.
The details indicate the feedstock and the loading rate of the plant during monitoring.
Chemical Analysis on sample reagents was performed by an External Laboratory as detailed in Section 4
UKAS Accreditation Held but UKAS Accreditation cannot be claimed for the test as sampling did not comply with the Standard Reference Method (SRM), see section 2 & 5
Method is NOT UKAS Accredited.

NU
NA

Environmental Compliance Limited

Potters Waste
Permit No : TP3736SQ
Variation No : ...
Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

1.2 Operating Information

Emission Point Reference	Process Type	Process Duration	Fuel	Feedstock	Abatement	Load	Comparison of Operator CEMS and Periodic Monitoring Results					
							Parameter	Date	Time	CEMS Results	Periodic Monitoring Results	Units
Engine 1	Continuous	Dependent on gas supply	Landfill Gas	N/A	N/A	85%	NP
Engine 2	Continuous		Landfill Gas	N/A	N/A	100%	NP

Notes:

Process Type State whether the process is a continuous or batch process.
Process Duration If a batch process, state the duration, frequency and details of the portion of the batch sampled. If continuous state "NA"
Fuel If applicable, state the fuel type If not applicable state "NA"
Feedstock State the feedstock type
Abatement State the type and whether operational during monitoring. If not applicable state "NA"
Load State the normal load, throughput or rating of the plant
CEMS Data Enter this data for each CEM installed if it is has been provided by operator otherwise state "NP" (NOT PROVIDED)

Potters Waste
Permit No : TP3736SQ
Variation No : ...
Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

2 Monitoring Deviations

The objective of the survey was to measure the concentrations of pollutants from the processes / locations as detailed in Section 1. This survey meets the requirements of the site's **PPC Permit Number: TP3736SQ** where UKAS and MCERTS accreditation has and could be claimed for the testing in the monitoring results table.

There was a modification to the sampling procedures (TPDs) listed in Section 4 as follows:

- **Non Methane VOC** – ECL/TPD/84 is specifically for the monitoring of dry ambient gas. Testing of the flare stack required the modification of the TPD, to cool and dry the sample gas prior to passing it through the capture media (sorbent tube). Due to the high stack temperature, and the modifications required to facilitate sampling, all Non-Methane VOC tests are non-conforming and UKAS/MCERTS accreditation has not been claimed.

There were no substance deviations from the original and agreed emissions monitoring schedule.

Non-conforming tests are as follows:

- All extractive tests and the volumetric flowrate tests on Gas Engine 1 are non-conforming as they were sampled on the stack exit. Please note that no alternative sample location is currently available.
- In order to facilitate sampling, a sample extension line (un-heated PTFE line) was used from the back of the filtered probe to the impinger train during the wet chemistry SO₂ test on Gas Engine 1. Consequently, the moisture test is not in compliance with ECL/TPD/082 and not accredited.
- Analytical laboratory Concept Life Sciences (CLS) do not hold UKAS accreditation for the analysis of total NMVOCs. Consequently, all Non-Methane VOC tests are non-conforming and UKAS/MCERTS accreditation has not been claimed.

The Uncertainty of the reported concentrations for these pollutant results DOES NOT take into account the effect of non-conformities or sample location limitations.

Homogeneity tests have not been completed for pollutants at the following locations:

- Gas Engine 1 - Not applicable to this location as the duct area is < 1m².
- Gas Engine 2 - Not applicable to this location as the duct area is < 1m².

Potters Waste
Permit No : TP3736SQ
Variation No : ...
Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

PART 2 – SUPPORTING INFORMATION

3 SAMPLING STAFF DETAILS

Site Sampling Team

Names of Site Team	Dates on Site	MCERTS No.	LEVEL	Technical Endorsements
Sam Brookes	10-11/01/2018	MM 06 775	2	TE1, TE2, TE3, TE4
Peter Brockway		MM 17 1459	Trainee	...

Report Reviewer

Name	MCERTS No.	LEVEL	Technical Endorsements
Sam Brookes	MM 06 775	2	TE1, TE2, TE3, TE4

Technical Endorsement Key:-

TE1 – Isokinetic Particulates, Temperature & Velocity Profiles, Oxygen.
TE2 – Isokinetic Extractive Pollutants:- Metals, Dioxin & Furans, PAHs, PCBs, HCl, HF.
TE3 – Non-Isokinetic Extractive Pollutants:- Speciated VOCs, HF, HCl, Cyanide.
TE4 – Continuous Analysers (Combustion Gases):- TVOC, CO, NO_x, SO₂.

Potters Waste
Permit No : TP3736SQ
Variation No : ...
Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

4 SAMPLING PROTOCOLS / METHODOLOGIES

Any required modifications to the Technical Procedure Documents (TPDs) specified below will be detailed in section 2 of this report.

Stand alone velocity measurements and those made to support isokinetic sampling are conducted using BS EN 16911-1:2013 & MID.

Pressure, Temperature and Velocity

Testing was carried out using a sampling system in accordance with BS EN ISO 16911-1:2013 & MID and In-house technical procedure ECL/TPD/022A.

Temperature was recorded using a thermocouple and digital temperature reader.

Velocity and pressure were recorded using an "L" pitot and digital manometer, data being recorded in Pascals.

Water Vapour

Testing was carried out using a Universal Stack Sampling system in accordance with BS EN 14790:2017 and In-house technical procedure ECL/TPD/082.

In this method the stack gases are filtered (in-stack unheated filter or out-stack heated filter) to remove particulate matter. The gases are then passed through a **heated probe** and then to a cooled moisture trapping unit. All unheated parts of the sample train (outside the sample port) which come into contact with stack gas are weighed pre and post sampling in order to determine the weight gain.

After each test, a visual inspection of the last impinger is made to confirm that at least 50% of the silica gel column has not changed colour. This indicates satisfactory collection of water vapour.

Potters Waste
Permit No
Variation No
Report Ref

: TP3736SQ
: ...
: P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Combustion Gases (NO_x, CO & CO₂)

Measurements of combustion gases were carried out using an MCERTS Certified **Horiba PG 250** stack gas analyser. Continuous monitoring of emissions was undertaken over each test period recording minute averaged data (one measurement every 60 seconds). The measurement techniques for each determinand are as follows:

<u>Determinand</u>	<u>Technique</u>	<u>SRM</u>
• NO _x	Chemiluminescence	BS EN 14792: 2017
• CO	Non-dispersive infrared	BS EN 15058: 2017
• CO ₂	Non-dispersive infrared	ISO 12039:2001

The analyser was set up with reference to the manufacturer's operator handbook and the in-house technical procedure **ECL/TPD/033c**. The analyser was calibrated on site using certified gases which are traceable to ISO 17025 (with uncertainty < 2%). Zero measurements were performed using Nitrogen. The analyser was calibrated directly into the sample inlet and then checked through the entire sampling system (including sampling probe, heated & unheated gas transport lines and gas drying/ conditioning system).

Data is presented graphically in the Figures Section, and the minute averaged data is given in the Tables Section.

Oxygen

Measurements of Oxygen were carried out using a Testo 350XL electrochemical cell combustion gas analyser which has been validated to meet the performance requirements of **BS EN 14789:2017**. Continuous monitoring of emissions was undertaken over each test period recording minute averaged data.

The analyser was set up with reference to the manufacturer's operator handbook and the in-house technical procedure **ECL/TPD/086**. The analyser was calibrated on-site using certified gases which are traceable to ISO 17025 (with uncertainty < 2%), (for emissions streams where oxygen is above 15%, dry ambient air can be used to calibrate the analyser). Zero measurements were performed using Nitrogen. The analyser was calibrated directly into the sample inlet (which is up-stream of the built-in chiller system) and then checked through the entire sampling system (including sampling probe, short heated/ unheated gas transport lines and external gas conditioning systems as required).

Potters Waste
Permit No
Variation No
Report Ref

: TP3736SQ
: ...
: P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

TVOC as Carbon

Testing was carried out using an MCERTS Certified Signal 3030PM FID and heated gas sample line, with reference to the manufacturer's operation handbook, **BS EN 12619:2013** and in-house technical procedure **ECL/TPD/032A**.

The analyser was calibrated on site using certified propane span gases, (made up in synthetic air) which are traceable to ISO 17025 standard (with uncertainty < 2%).

Zero measurements were performed using synthetic air zero gas, with TVOC content less than 0.2 mg/m³ (or purity greater than 99.998%).

The analyser was calibrated directly into the sample inlet and then checked through the entire sampling system (including sampling probe, heated filter and heated gas transport lines). Data was corrected by molecular weight to TVOCs as total carbon.

Data was recorded as minute averages over each test period. The data is presented in the Figures Section and the minute averaged data is detailed in the Tables Section.

Sulphur Dioxide

Testing was carried out non-isokinetically using a Universal Stack Sampling system in accordance with **BS EN 14791:2017** and In-house technical procedure **ECL/TPD/039**. Non-isokinetic sampling can only take place if there are no droplets present in the stack gas.

In this method the stack gases are filtered to remove particulate matter then the gases are passed through a series of impingers. The first three impingers each contain 140ml of 3% Hydrogen Peroxide (3% H₂O₂). The fourth impinger is left empty and the final impinger contains a measured quantity of silica gel.

The first three impingers containing the 3% Hydrogen Peroxide are analysed for concentrations of Sulphur Dioxide by IC (Ion Chromatography).

Concept Life Sciences Ltd (CLS) who are situated in Manchester carried out the analysis of the samples. **CLS** is UKAS accredited for this analysis. In addition to the survey samples, appropriate field blanks and efficiency checks are submitted as part of the technical procedure.

Potters Waste
Permit No
Variation No
Report Ref

: TP3736SQ
: ...
: P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Non-Methane VOC

Non-continuous sampling for **Non-Methane VOC** was carried out in accordance with **CEN/TS 13649:2014** and In-house technical procedure **ECL/TPD/084**. In this method a metered volume of stack gas is extracted through a standard charcoal sorbent tube.

Concept Life Sciences Ltd (CLS) who are situated in Manchester carried out the analysis of the samples. **CLS** are **not UKAS accredited** for this analysis. In addition to the survey samples, appropriate field blanks and efficiency checks are submitted as part of the technical procedure.

Due to restrictions set out in CEN/TS 13649:2014, MCERTS/UKAS accreditation can only be claimed when the target parameters are organic compounds, the sorbent tube used is a standard charcoal tube/ thermal desorption tube and when laboratory analysis is UKAS accredited and carried out by GC. If other tubes are used, or if analysis is by other means than GC, then usually only UKAS accreditation can be claimed, as long as the laboratory analysis is UKAS accredited. (MCERTS accreditation may still be claimed if prior approval is given for the modifications by the Environment Agency – details will be given in section 2 of this report).

Laboratory analysis cannot be UKAS accredited for “Total VOC” or “TOP 10 compounds”.

For the subcontract laboratory to claim UKAS accreditation for analysis, the internal recovery of a spiking compound (desorption efficiency from tube) needs to be above 80%. If it falls below 80% this will be noted on the analysis certificate.

If greater than 5% of the total amount of any of the target species is found in the back up portion of the sorbent tube, this will be noted on the analysis certificate.

Potters Waste
Permit No
Variation No
Report Ref

: TP3736SQ
: ...
: P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

5 SAMPLE POINT DESCRIPTIONS

The homogeneity test is applicable to combustion processes. This includes but is not restricted to, those regulated under the Waste Incineration Directive (**WID**) and the Large Combustion Plant Directive (**LCPD**).

Homogeneity testing has not been completed at these locations in accordance with the mandatory requirements of the regulatory authority.

The test is not usually required for stacks with sampling plane areas of $< 1\text{m}^2$ (below 1.13m in diameter for circular ducts).

The sample locations that were monitored are detailed below:-

Landfill Gas Engine 1

The exhaust diameter is 0.3m and sampling was performed from the exit of the duct approximately 1.25m above the Engine Room roof.

As a result of the sampling point being on the exit of the duct and immediately after a bend it does not currently meet the requirements detailed in *Technical Guidance Note (Monitoring) M1 "Sampling requirements for stack-emission monitoring"* Environment Agency, and BS EN 13284-1. The sampling probes were inserted down into the duct exit and positioned at a central location within the ducting.

Access to the sample location was attained by means of temporary scaffolding complete with an in date scafftag accessed from outside the engine one control building. The scaffolding provided 1.8m of width back from the stack exit to facilitate sampling.

A 240V power supply was available inside the engine one control room building directly below the sampling location.

All tests are non-conforming as they had to be conducted on the stack exit.

In addition and in order to facilitate sampling, a sample extension line (unheated PTFE line) was used from the back of the filtered probe to the impinger train during the wet chemistry SO₂ test. Consequently, the moisture test is not in compliance with ECL/TPD/082 and not accredited.

The Uncertainty of the reported concentrations for these pollutant results DOES NOT take into account the effect of these non-conformities or sample location limitations.

Potters Waste
Permit No : TP3736SQ
Variation No : ...
Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Landfill Gas Engine 2

The sampling platform does not currently meet the requirements detailed in *Technical Guidance Note (Monitoring) M1 "Sampling requirements for stack-emission monitoring"* Environment Agency, and BS EN 13284-1 due to a lack of space however both ports could be accessed in this survey and no isokinetic tests were required.

The stack diameter is 0.4m and the sample platform width back from the sample port is only 0.4m.

Two sample ports are located on the stack at 90 degrees to each other and are located on the same plane.

These sample ports are located at a height of approximately 1.15m from the working sample platform.

Access to the sample location was attained by means of temporary scaffolding complete with an in date scafftag accessed from outside the engine two control building.

A 240V power supply was available inside the engine two control room building directly below the sampling location.

The Uncertainty of the reported concentrations for these pollutant results DOES NOT take into account the effect of non-conformities or sample location limitations.

Environmental Compliance Limited

Potters Waste
Permit No : TP3736SQ
Variation No : ...
Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

**EQUIPMENT IDs
(Pre site checklist from SSP)**

Potters Waste
 Permit No : TP3736SQ
 Variation No : ...
 Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
 Visit Details : Annual Compliance
 Survey Dates : 10th & 11th January 2018
 Report Issue Date : 31st January 2018

PRE SITE EQUIPMENT CHECKLIST/ EQUIPMENT USED

(Completed before departure to site and when on site in full)

Equipment	Equip. Type	ID No:	ID No:	ID No:	ID No:	ID No:	ID No:	ID No:	ID No:
MST console/pump	E001	U001							
MST Nozzle set									
MST "S" Type Pitot									
MST Probe									
MST Hot Box		978							
MST Impinger Arm		401							
		660							
Barometer		627							
Site Balance		088							
Site Check weights		276							
		277							
Horiba	E002	511							
Heated Probe / Filter		920							
Chiller		972							
Sonimix / MFC									
Heated Line		1013	1014						
FID	E003	269							
Heated Line		517	518						
Heated Probe / Filter		919							
Testo	E004	350							
FTIR	E005								
Heated Probe / Filter									
Heated Line									
Stackmite	E006								
"L" Type Pitot		489							
Digital Manometer		421							
Stack Thermocouple		866							
Thermocouple Reader		1112							
Nozzle Set									
Workhorse Pumps	E007								
Low Flow Pumps									
Tube Thermocouple		1041							

Quantity of Ice Required / Used for Survey

6

Bags (2kg bags)

Environmental Compliance Limited

Potters Waste			Installation Name	: Engine 1 & 2
Permit No	: TP3736SQ		Visit Details	: Annual Compliance
Variation No	: ...		Survey Dates	: 10th & 11th January 2018
Report Ref	: P3334	: R001	Report Issue Date	: 31st January 2018

FIGURES

Potters Waste
Permit No : TP3736SQ
Variation No : ...
Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Figure 1: Engine 1 TVOCs





Figure 2: Engine 1 Combustion Gases



Potters Waste
 Permit No : TP3736SQ
 Variation No : ...
 Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
 Visit Details : Annual Compliance
 Survey Dates : 10th & 11th January 2018
 Report Issue Date : 31st January 2018

Figure 3: Engine 2 TVOCs





Figure: Engine 2 Combustion Gases



Environmental Compliance Limited

Potters Waste			Installation Name	: Engine 1 & 2
Permit No	: TP3736SQ		Visit Details	: Annual Compliance
Variation No	: ...		Survey Dates	: 10th & 11th January 2018
Report Ref	: P3334	: R001	Report Issue Date	: 31st January 2018

TABLES

Potters Waste
Permit No : TP3736SQ
Variation No : ...
Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Table 1 – TVOC
Data Recorded Engine 1
Sample Period: 12:51 – 13:50 on the 10th January 2018

Volumetric Flowrate (Reference Conditions) = 1.10789 m³/sec *

	Average	Emission Rate
	mg/m ³	Kg/hr
TVOC (as carbon)*	1639.12	6.537

* Reference Conditions (273K, 101.3 kPa, 5% Oxygen & Dry Gas)

Table 2 – Gases
Data Recorded from Engine 1
Sample Period: 12:30 – 13:29 on the 10th January 2018

Volumetric Flowrate (Reference Conditions) = 1.10789 m³/sec *

	Average	Emission Rate
	mg/m ³	Kg/hr
Oxides of Nitrogen (as NO ₂) *	439.21	1.752
Carbon Monoxide *	1062.54	4.238
Carbon Dioxide (%) **	11.51	...
Oxygen (%) **	7.18	...

* Reference Conditions (273K, 101.3 kPa, 5% Oxygen & Dry Gas)

** Dry Gas

Environmental Compliance Limited

Potters Waste
Permit No : TP3736SQ
Variation No : ...
Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Table 3 – SO₂

Data Recorded from Engine 1 - Landfill

Emission Parameter	Units	One - SO ₂	Blank
Stack Diameter	metres	0.40	
Area of Sample Plane	m ²	0.126	
Moisture Content	%	13.25	
Oxygen Content	%	7.23	
Stack Temperature	°C	505	
Gas Velocity (as Measured)	m/sec	62.96	
Gas Velocity (Reference Conditions)	m/sec*	15.68	
Volumetric Flowrate (as Measured)	m ³ /sec	7.91	
Volumetric Flowrate (Reference Conditions)	m ³ /sec*	1.97	
Dry Gas Molecular Weight	g/gmole	30.13540327	
Sample Date	...	10/01/2018	
Sample Period	...	12:43 - 13:43	
Sample Volume (reference Conditions)	m ³ *	0.339	0.339
Sample Reference	ECL/18/	0070 & 0071	0072
Mass of Sulphur Dioxide Collected	mg	24.42	0.14
Concentration of Sulphur Dioxide	mg/m ³ *	72.11	0.41
Emission Rate of Sulphur Dioxide	kg/hr	0.51	...
Expanded Uncertainty (% Relative)	%	13	...
Impinger Collection Efficiency	%	99	...

*Reference Conditions (273K, 101.3kPa, 5% Oxygen, Dry Gas)

Potters Waste
 Permit No : TP3736SQ
 Variation No : ...
 Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
 Visit Details : Annual Compliance
 Survey Dates : 10th & 11th January 2018
 Report Issue Date : 31st January 2018

Table 4 – Non-Methane TVOCs

Potters Waste Brynposteg Landfill Engine 1

Emission Parameter	Units	Value		
Stack Diameter	mm	300		
Area of Sample Plane	m ²	0.071		
Moisture Content	%	10.15		
Expanded Uncertainty of Moisture (%Relative)	%	14.57		
Measured Oxygen (Dry)	%Vol	7.19		
Meter Temperature	°C	10.33		
StackTemperature	°C	509.17		
Sample Date	...	10/01/2018		
Sample Period	...	13:56 - 14:56		
Sample Volume (as Measured)	m ³	0.10		
Sample Volume (reference Conditions)	m ³ *	0.081		
Sample Tube Results		One		Blank
Sample Reference ECL/18/80	Units	Concentration*	Uncertainty	Concentration
Concentration of Non Methane VOCs	mg/m ³	0.73	19.97%	0.012

*Reference Conditions: 273 K, 101.3 kPa, 5% Oxygen & Dry Gas

Potters Waste
 Permit No : TP3736SQ
 Variation No : ...
 Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
 Visit Details : Annual Compliance
 Survey Dates : 10th & 11th January 2018
 Report Issue Date : 31st January 2018

Table 5 – TVOC
Data Recorded from Engine 2
Sample Period: 15:33 - 16:32 on the 10th January 2018

Volumetric Flowrate (Reference Conditions) = 1.18792 m³/sec *

	Average	Emission Rate
	mg/m ³	Kg/hr
TVOC (as carbon)*	1648.33	6.59

* Reference Conditions (273K, 101.3 kPa, 5% Oxygen & Dry Gas)

Table 6 – Gases
Data Recorded from Engine 2
Sample Period: 16:23 – 17:22 on the 10th January 2018

Volumetric Flowrate (Reference Conditions) = 1.18792 m³/sec *

	Average	Emission Rate
	mg/m ³	Kg/hr
Oxides of Nitrogen (as NO ₂) *	430.48	1.841
Carbon Monoxide *	1061.30	4.539
Carbon Dioxide (%) **	10.24	...
Oxygen (%) **	8.08	...

* Reference Conditions (273K, 101.3 kPa, 5% Oxygen & Dry Gas)

** Dry Gas

Environmental Compliance Limited

Potters Waste
Permit No : TP3736SQ
Variation No : ...
Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Table 7 – SO₂

Data Recorded from Engine 2 - Landfill

Emission Parameter	Units	One - SO ₂	Blank
Stack Diameter	metres	0.40	
Area of Sample Plane	m ²	0.126	
Moisture Content	%	10.31	
Oxygen Content	%	8.07	
Stack Temperature	°C	459	
Gas Velocity (as Measured)	m/sec	36.82	
Gas Velocity (Reference Conditions)	m/sec*	9.45	
Volumetric Flowrate (as Measured)	m ³ /sec	4.63	
Volumetric Flowrate (Reference Conditions)	m ³ /sec*	1.19	
Dry Gas Molecular Weight	g/gmole	29.95981639	
Sample Date	...	10/01/2018	
Sample Period	...	15:14 - 16:14	
Sample Volume (reference Conditions)	m ³ *	0.265	0.265
Sample Reference	ECL/18/	0073 & 0074	0075
Mass of Sulphur Dioxide Collected	mg	24.84	0.15
Concentration of Sulphur Dioxide	mg/m ³ *	93.72	0.58
Emission Rate of Sulphur Dioxide	kg/hr	0.40	...
Expanded Uncertainty (% Relative)	%	13	...
Impinger Collection Efficiency	%	100	...

*Reference Conditions (273K, 101.3kPa, 5% Oxygen, Dry Gas)

Potters Waste
 Permit No : TP3736SQ
 Variation No : ...
 Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
 Visit Details : Annual Compliance
 Survey Dates : 10th & 11th January 2018
 Report Issue Date : 31st January 2018

Table 8 – Non-Methane TVOCs

Potters Waste Brynposteg Landfill Engine 2

Emission Parameter	Units	Value
Stack Diameter	mm	400
Area of Sample Plane	m ²	0.126
Moisture Content	%	6.60
Expanded Uncertainty of Moisture (%Relative)	%	16.73
Measured Oxygen (Dry)	%Vol	8.08
Meter Temperature	°C	10.17
Stack Temperature	°C	460.00
Sample Date	...	10/01/2018
Sample Period	...	16:23 - 17:23
Sample Volume (as Measured)	m ³	0.099
Sample Volume (reference Conditions)	m ³ *	0.073
Sample Tube Results		One - NMVOC
Sample Reference ECL/18/81	Units	Concentration*
Concentration of Non Methane VOC	mg/m ³	0.20
		Uncertainty
		18.30%
		Blank
		Concentration
		0.014

*Reference Conditions: 273 K, 101.3 kPa, 5% Oxygen & Dry Gas


Environmental Compliance Limited

Potters Waste			Installation Name	: Engine 1 & 2
Permit No	: TP3736SQ		Visit Details	: Annual Compliance
Variation No	: ...		Survey Dates	: 10th & 11th January 2018
Report Ref	: P3334	: R001	Report Issue Date	: 31st January 2018

VELOCITY TRAVERSE PROFILES

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

*Reference Conditions: 273K, 101.3kPa, 5% Oxygen, Dry Gas NOTE: Velocity / volume flowrate calculations exclude contributions from the measurement point(s) where swirl > 15°



Potters Waste
Permit No : TP3736SQ
Variation No : ...
Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Company	Potters Waste	Stack Diameter Port A (mm)	400	Average Stack Diameter (mm)	400	Pitot tube coefficient	0.99
Site	Brynposteg	Stack Diameter Port B (mm)	400	Port Length (mm)	90	Pitot Id	489
Location	Landfill	Duct Length Port A (mm)		Average Duct Length (mm) L		Stack Thermocouple ID	866
Stack	Engine 2	Duct Length Port B (mm)		Duct width (mm) B		Stack Temp Reader ID	1112
Job No	P3334	Duct Length Port C (mm)		Barometric Pressure, (mb)	964	Manometer ID	421
Operators	SEB + PB	Duct Length Port D (mm)		Ave Static Press, (mm H ₂ O)	-7.65	Barometer ID	627

Pre - Traverse Checks Carried Out	Time	Pass/ Fail
Pre - Traverse PITOT <u>Visual Inspection</u>	15:00:00	Pass
Pre - Traverse PITOT <u>Leak Check</u>	15:02:00	Pass

Smooth Walls

Static Pressure Readings (Pascals)			
Port A	Port B	Port C	Port D
-75.00	-75.00		

[illegible]

Post - Traverse Checks Carried Out	Time	Pass/ Fail
Post - Traverse <u>Visual Inspection</u>	15:18:00	Pass
Post - Traverse PITOT Leak Check	15:20:00	Pass

Stagnation Check (S-type Pitot Only)	Time	Reading
Static Pressure Via Positive Leg (Pa)	.	.
Static Pressure Via Negative Leg (Pa)	.	.
Difference (Pa) < 10Pa ?		#VALUE!




Average temp (K)	732.167
--------------------	---------

Suitability of Sampling Position	Actual Stack Conditions
Highest:lowest flow pressure ratio < 9:1?	1.08:1
Maximum deviation of flow from axis < 15°?	10
X-sectional area for stacks = πr^2	0.13 m ²
X-sectional area for ducts = L x B	1 m ²
Suitability of Position for Sampling	OK

Stack Moisture	10.31	%	Gas Velocity (as Measured) Adjusted for Smooth Walls	36.84027	m/sec
Measured Oxygen	8.07	%	Gas Velocity (Reference Conditions) Adjusted for Smooth Walls	9.45320	m/sec*
Measured Carbon Dioxide	10.23	%	Volumetric Flowrate (as Measured) Adjusted for Smooth Walls	4.62948	m ³ /sec
Dry Gas Molecular Weight	29.95960	g/g mole	Volumetric Flowrate (Ref Cond) Adjusted for Smooth Walls	1.18792	m ³ /sec*

*Reference Conditions: 273K, 101.3kPa, 5% Oxygen, Dry Gas

NOTE: Velocity / volume flowrate calculations exclude contributions from the measurement point(s) where swirl $\geq 15^\circ$



Notes

Including expected or actual deviations from procedures / non-conformities

100% load

Narrow platform but both ports can be reached

[illegible]

Height of sample ports from Platform	1.15m
Number of sample ports	5
Width of platform (port back to handrail)	0.4m

Nearest downstream disturbance	exit	2.0m
Nearest upstream disturbance	bend	1.5m

Disturbances are classed as bends, fans or diameter variations

Environmental Compliance Limited

Potters Waste
Permit No : TP3736SQ
Variation No : ...
Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

FIELD CALIBRATION AND SAMPLING DATA

Potters Waste
 Permit No : TP3736SQ
 Variation No : ...
 Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
 Visit Details : Annual Compliance
 Survey Dates : 10th & 11th January 2018
 Report Issue Date : 31st January 2018

Engine 1 - Combustion Gases

Units

Mean Initial Direct Zero
 Mean Confirmation Direct Zero
 Difference in Direct Zero
 Repeatability at Zero
 <2 x Repeatability at Zero?

Mean Pre Test Zero
 % of Measurement Range?
 Detection Limit (LOD)

Actual Applied Span Concentration

Mean Pre Test System Zero
 Difference $\leq \pm 2\%$ of Span Value (5% for SO₂)?

Mean Post Test Zero
 % of Certified Range?
 Zero Drift $\leq \pm 5\%$ of Applied Span?

Mean Pre Test System Span
 Difference $\leq \pm 2\%$ of Span Value (5% for SO₂)?

Mean Post Test Span
 Span Drift $\leq \pm 5\%$ Span Value?

Horiba PG 250 Measurement Ranges:			
NO as			
NO ₂	CO	O ₂	CO ₂
1025	2500	25	20
mg/m ³	mg/m ³	%Vol	%Vol
Zero Values (Direct)			
0.30	0.00	-0.01	0.00
0.28	0.24	-0.03	0.00
0.02	0.24	0.02	0.00
4.10	2.50	0.20	0.20
YES	YES	YES	YES
Pre Zero Values (System)			
0.24	-0.03	-0.03	0.00
0.02%	0.00%	-0.13%	0.00%
0.16	0.12	0.20	0.00
Applied Span:			
NO	CO	O ₂	CO ₂
526.44	1271.25	14.84	17.73
Pre Test System Zero Values			
0.24	-0.03	-0.03	0.00
0.05%	0.00%	0.22%	0.00%
Post Test Zero Values			
1.06	1.53	-0.04	0.02
0.10%	0.06%	-0.16%	0.10%
0.15%	0.12%	0.20%	0.11%
Pre Test System Span Values			
520.19	1262.67	14.86	17.63
1.19%	0.67%	0.13%	0.55%
Post Test Span Values			
508.92	1222.29	14.67	17.58
3.33%	3.85%	1.12%	0.83%

3.33% 3.85% 1.12% 0.83%

See Note 2 See Note 2 See Note 3 See Note 3

NOTE 1: Data Invalid! Contact Quality Manager!

NOTE 2: Correct test data for drift!

NOTE 3: No drift correction required.

NB: NO_x and CO data drift corrected prior to calculation of periodic monitoring results

Potters Waste
Permit No
Variation No
Report Ref

: TP3736SQ
: ...
: P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Engine 1 - TVOCs Calibrations Summary

TVOC - FIELD DATA SHEET

Client	Potters Waste	Barometric Pressure mb	964
Site	Brynposteg	Barometer ID	ECL/ID/ 627
Date	10/01/2018	Analyser ID	ECL/ID/ 269
Location	Landfill	Sonimix/ MFC ID	ECL/ID/
Stack ID	Engine 1	Heated Line/ Controller ID	ECL/ID/ 517 + 518
Stack Temp °C	923	Heated Line Set Temp °C	180 YES
Ambient Temp (sampling)	1 = 11 2 = 13 3 = 15	Heated Line Length	10 m
Ambient Temp (sampling)	4 = 17 5 = 16 6 = 15	Heated Probe Filter ID	ECL/ID/ 919
Job No	P3334	Heated Filter Set Temp °C	180 YES
Operators	SEB + PB	Logger ID	926

Calibration Gas Details

Calibration Gas	Gas Bottle ID	Gas Value	Uncertainty of Gas (k=2)	Analyser Range	Span Gas value used
Zero Gas (Synthetic Air)	Gas/ 1771	Propane	4000 ppm 924.8 ppm
Hydrogen / Helium	Gas/ 1869		
Propane (In Air)	Gas/ 1770	924.8 ppm	1%		

Analyser Range should be not less than the expected peak emissions.

Span Gas Values should be either *approximately the half-hourly ELV* **OR** *50% to 90% of the Selected Analyser Range.*

Direct Calibration (Rear of Analyser)						
Zero Cal		Span Gas Cal		Zero Check		
Start Time	End Time	Start Time	End Time	Start Time	End Time	
ZERO /SPAN/ ZERO	11:05 11:10	11:15 11:20		11:22 11:27		

NOTE: RESPONSE TIME

Response Time to be carried out at the same time as "Span Check" on system verification (via the sample probe)
Start Time = when gas turned on. 90% Time = when analyser displays 90% of span gas value used. Response must be within 200 seconds.

Pre-Cal Ambient Temp °C		PRE System Verification Check (Down Line)				Response Time		
Max	Min	Zero Check		Span Check		SYSTEM Span Gas Cal		
9	8	Start Time	End Time	Start Time	End Time	Start Time	90% Time	less than 200s (Y/N)
ZERO / SPAN		11:29	11:34	11:36	11:41	11:35:00	11:35:12	Y

	Start Time	End Time	Location	Production Details
Sample Period	12:00	14:56	Engine 1	Normal
Sample Period				
Sample Period				
Sample Period				
Sample Period				
Sample Period				

Post-Cal Ambient Temp °C		POST System Verification Check (Down Line)			
Max	Min	Zero Check		Span Check	
10	6	Start Time	End Time	Start Time	End Time
ZERO / SPAN		17:32	17:34	17:37	17:39

Process Details / Comments

Potters Waste
Permit No
Variation No
Report Ref

: TP3736SQ
: ...
: P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Engine 1 - TVOCs Data Sheet

Calibration Summary		TVOC ppm
Analyser Range		4000
Repeatability at Zero		2
Span Gas Concentration Applied		924.8
Zero Gas Concentration Applied		0
Direct Cal	Zero	0.00
	Span	924.8
	Zero	-0.12
Difference (Zero)		0.1249
< 2 × Repeatability @ Zero?		YES
Pre Test (System)	Zero	0.00
	Span	926.9
Difference (Zero)		0.0000
< 2% Relative to Direct Span		YES
Difference (Span)		2.0927
< 2% Relative to Direct Span		YES
Post Test (System)	Zero	2.92
	Span	908.9
Difference (Zero)		2.9152
Zero Drift < 2% of Applied Span?		YES
Difference (Span)		17.9600
Span Drift < 2% of Applied Span?		YES
Zero and Span Drift < 5% of Applied Span?		YES

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

If moisture was not measured see detailed notes below.

Environmental Compliance Limited

Potters Waste
Permit No : TP3736SQ
Variation No : ...
Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Engine 1 - Non-methane TVOCs Field Data Sheet

Environmental Compliance Limited				SAMPLE TUBE DATA SAMPLING PROFORMA	
Client	Potters Waste	<input checked="" type="radio"/> Circular <input type="radio"/> Rectangular <input type="radio"/> Elipse	Pump ID	n/a	
Site	Brynposteg	Stack Diameter (mm)	Meter ID	U001	
Location	Landfill		MST Probe ID	Sinter in-stack	
Stack ID	Engine 1	Stack Area (m ²)	MST Probe Heating Temp (C)	180	
Test No	One	Barometric Pressure (mb)	DGM Yd or ml/count	0.9746	
Job No	P3334	Stack Thermocouple ID	MST Hot Box ID	978	
ECL Site Staff	SEB + PB	Tube Thermocouple ID	MST Hot Box Heating Temp (C)	180	
Barometer ID	627	Meter Thermocouple ID	Workhorse Set Sample Rate (%)	n/a	
		In-Stack Sinter Used (Y/N)	MST Delta H Sampling Rate	0.5 - 1	

Meter Units <input type="radio"/> ml <input checked="" type="radio"/> litres	Sample	Leak 1	Time (start/ end) (minimum 1 minute)	Leak 2	Time (start/ end) (minimum 1 minute)	Total
Start Volume	2851334.2	2851324.2	13:53:00	2851449.2	14:58:00	
Final Volume	2851440.0	2851324.2	13:54:00	2851449.2	14:59:00	
Total Volume	104.6	0.0		0.0		104.6
Sample Train Internal Volume	1.2447	Litres				

Sample Point	A1	A1	A1	A1
Time/ point (mins)	0-10	10 -- 20	20-30	30-40
Tube Temp °C	11	11	12	13
Stack Temp °C	507	508	510	510
Meter Temp In °C	10	10	11	11
Meter Temp Out °C	10	10	10	10

Sample Point	A1	A1		
Time/ point (mins)	40-50	50-60		
Tube Temp °C	14	15		
Stack Temp °C	510	510		
Meter Temp In °C	11	11		
Meter Temp Out °C	10	10		

Sample Point				
Time/ point (mins)				
Tube Temp °C				
Stack Temp °C				
Meter Temp In °C				
Meter Temp Out °C				

Impinger 1	Empty
Start Weight (g)	526.7
End Weight (g)	534.6
Total weight (g)	7.9

Impinger 2	Empty
Start Weight (g)	617.8
End Weight (g)	618.4
Total weight (g)	0.6

Impinger3	Silica
Start Weight (g)	761.4
End Weight (g)	761.6
Total weight (g)	0.2

Silica	(IF USED)
<50% Spent at end Y/N?	YES
Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	no

NB: Non-conforming test due to high temperature and moisture, see Section 2 "Monitoring Deviations".

Potters Waste
 Permit No : TP3736SQ
 Variation No : ...
 Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
 Visit Details : Annual Compliance
 Survey Dates : 10th & 11th January 2018
 Report Issue Date : 31st January 2018

Engine 2 - Combustion Gases

Units

Mean Initial Direct Zero
 Mean Confirmation Direct Zero
 Difference in Direct Zero
 Repeatability at Zero
 <2 x Repeatability at Zero?

Mean Pre Test Zero
 % of Measurement Range?
 Detection Limit (LOD)

Actual Applied Span Concentration

Mean Pre Test System Zero
 Difference $\leq \pm 2\%$ of Span Value (5% for SO₂)?

Mean Post Test Zero
 % of Certified Range?
 Zero Drift $\leq \pm 5\%$ of Applied Span?

Mean Pre Test System Span
 Difference $\leq \pm 2\%$ of Span Value (5% for SO₂)?

Mean Post Test Span
 Span Drift $\leq \pm 5\%$ Span Value?

Horiba PG 250 Measurement Ranges:				
NO as				
NO ₂	CO	O ₂	CO ₂	
1025	2500	25	20	
mg/m ³	mg/m ³	%Vol	%Vol	
Zero Values (Direct)				
0.30	0.00	-0.01	0.00	
0.28	0.24	-0.03	0.00	
0.02	0.24	0.02	0.00	
4.10	2.50	0.20	0.20	
YES	YES	YES	YES	
Pre Zero Values (System)				
0.24	-0.03	-0.03	0.00	
0.02%	0.00%	-0.13%	0.00%	
0.16	0.12	0.20	0.00	
Applied Span:				
NO	CO	O ₂	CO ₂	
526.44	1271.25	14.84	17.73	
Pre Test System Zero Values				
0.24	-0.03	-0.03	0.00	
0.05%	0.00%	0.22%	0.00%	
Post Test Zero Values				
1.06	1.53	-0.04	0.02	
0.10%	0.06%	-0.16%	0.10%	
0.15%	0.12%	0.20%	0.11%	
Pre Test System Span Values				
520.19	1262.67	14.86	17.63	
1.19%	0.67%	0.13%	0.55%	
Post Test Span Values				
508.92	1222.29	14.67	17.58	
3.33%	3.85%	1.12%	0.83%	

3.33% 3.85% 1.12% 0.83%

See Note 2 See Note 2 See Note 3 See Note 3

NOTE 1: Data Invalid! Contact Quality Manager!

NOTE 2: Correct test data for drift!

NOTE 3: No drift correction required.

NB: NO_x and CO data drift corrected prior to calculation of periodic monitoring results

Environmental Compliance Limited

Potters Waste
Permit No
Variation No
Report Ref

: TP3736SQ
: ...
: P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Engine 2 - TVOCs Calibrations Summary

TVOC - FIELD DATA SHEET

Client	Potters Waste	Barometric Pressure mb	964
Site	Brynposteg	Barometer ID	ECL/ID/ 627
Date	10/01/2018	Analyser ID	ECL/ID/ 269
Location	Landfill	Sonimix/ MFC ID	ECL/ID/
Stack ID	Engine 2	Heated Line/ Controller ID	ECL/ID/ 517 + 518
Stack Temp °C	923	Heated Line Set Temp °C	180 YES
Ambient Temp (sampling)	1 = 11 2 = 13 3 = 15	Heated Line Length	10 m
Ambient Temp (sampling)	4 = 17 5 = 16 6 = 15	Heated Probe Filter ID	ECL/ID/ 919
Job No	P3334	Heated Filter Set Temp °C	180 YES
Operators	SEB + PB	Logger ID	926

Calibration Gas Details

Calibration Gas	Gas Bottle ID	Gas Value	Uncertainty of Gas (k=2)	Analyser Range	Span Gas value used
Zero Gas (Synthetic Air)	Gas/ 1771	Propane	4000 ppm
Hydrogen / Helium	Gas/ 1869		924.8 ppm
Propane (In Air)	Gas/ 1770	924.8 ppm	1%		

Analysers Range should be not less than the expected peak emissions.

Span Gas Values should be either approximately the half-hourly ELV OR 50% to 90% of the Selected Analyser Range.

Direct Calibration (Rear of Analyser)

	Zero Cal		Span Gas Cal		Zero Check	
	Start Time	End Time	Start Time	End Time	Start Time	End Time
ZERO /SPAN/ ZERO	11:05	11:10	11:15	11:20	11:22	11:27

NOTE: RESPONSE TIME

Response Time to be carried out at the same time as "Span Check" on system verification (via the sample probe)
Start Time = when gas turned on. 90% Time = when analyser displays 90% of span gas value used. Response must be within 200 seconds.

Pre-Cal Ambient Temp °C		PRE <u>System</u> Verification Check (Down Line)			
Max	Min	Zero Check		Span Check	
9	8	Start Time	End Time	Start Time	End Time
ZERO / SPAN		11:29	11:34	11:36	11:41

Response Time SYSTEM Span Gas Cal		
Start Time	90% Time	less than 200s (Y/N)
11:35:00	11:35:12	Y

	Start Time	End Time	Location	Production Details
Sample Period	15:30	17:25	Enigne 2	Normal
Sample Period				
Sample Period				
Sample Period				
Sample Period				
Sample Period				

Post-Cal Ambient Temp °C		POST <u>System</u> Verification Check (Down Line)			
Max	Min	Zero Check		Span Check	
10	6	Start Time	End Time	Start Time	End Time
ZERO / SPAN		17:32	17:34	17:37	17:39

Process Details/ Comments

Potters Waste
Permit No
Variation No
Report Ref

: TP3736SQ
: ...
: P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Engine 1 - TVOCs data Sheet

Calibration Summary		TVOC ppm
Analyser Range		4000
Repeatability at Zero		2
Span Gas Concentration Applied		924.8
Zero Gas Concentration Applied		0
Direct Cal	Zero	0.00
	Span	924.8
	Zero	-0.12
Difference (Zero)		0.1249
< 2 × Repeatability @ Zero?		YES
Pre Test (System)	Zero	0.00
	Span	926.9
Difference (Zero)		0.0000
< 2% Relative to Direct Span		YES
Difference (Span)		2.0927
< 2% Relative to Direct Span		YES
Post Test (System)	Zero	2.92
	Span	908.9
Difference (Zero)		2.9152
Zero Drift < 2% of Applied Span?		YES
Difference (Span)		17.9600
Span Drift < 2% of Applied Span?		YES
Zero and Span Drift < 5% of Applied Span?		YES

Environmental Compliance Limited

Potters Waste
Permit No : TP3736SQ
Variation No : ...
Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Engine 2 - SO2 Field Data Sheet

Environmental Compliance Limited		NON ISOKINETIC SAMPLING PROFORMA		Date of Measurement		10/01/2018	
ECL/TPD	39	Time taken to change Ports?		0		Start Time	15:14
						Test Duration	60 mins
Client	Potters Waste	Stack Profile	Circular	Console id	U001	Barometer id	627
Site	Brynposteg	Stack Area (m²)	0.13	Pump id	U001	Nozzle Id	n/a
Location	Landfill	Barometric Pressure (mb)	964	Probe id	Sinter probe	Nozzle size	n/a
Stack ID	Engine 2	Static Pres. (mm H ₂ O)	-7.645259939	DGM Yd	0.9746	Filter Id	Sinter in-stack
Test No.	One - SO2	Pilot coefficient	n/a	ΔH@	38.2	Pilot ID	n/a
Job No	P3334	Probe Heater Setting (°C)	n/a	Impinger Id	660	Hot Box ID	978
ECL Site Staff	SEB + PB	Hot Box Setting (°C)	120	Balance Id	88		
						Required Sample Flowrate l/min	Suggested ΔH Entered Below
						3	1
						6	3
						10	10
						15	25
						25	50
Sample	Leak 1	Leak 2	Leak 3	Leak 4	Leak 5	Total	
Start Volume	2851723.4						
Final Volume	2852090.6						
Total Volume	367.2	0.0	0.0	0.0	0.0	0.0	367.2
Leak Check	First	Second	Third	Fourth	Fifth		
Leak rate l/min	0				0	Dry O ₂ <input type="checkbox"/> Atmospheric	8.07
Vaccum °Hg	8				13	Dry Carbon Dioxide %	10.23
Time of Check	15:10				16:19	Dry Carbon Monoxide ppm	
Set Rate l/min	6				6.12	Reference Oxygen Percentage	5
Leak <2%?	YES				YES		
Traverse Point	A1	A1	A1	A1	A1	A1	Total
Time/Point (mins)	0 - 10	10 - 20	20 - 30	30 - 40	40 - 50	50 - 60	
ΔP (mm H2O)	n/a	n/a	n/a	n/a	n/a	n/a	n/a
K factor	n/a	n/a	n/a	n/a	n/a	n/a	n/a
ΔH (Orifice)	3.00	3.00	3.00	3.00	3.00	3.00	3.00
Meter (Tm in)	12.00	12.00	11.00	11.00	10.00	10.00	11.00
Meter (Tm out)	11.00	11.00	10.00	10.00	9.00	9.00	10.00
Stack Temp (Ts)	458.00	460.00	459.00	460.00	460.00	459.00	459.33
Impinger T Outlet	10.00	10.00	10.00	11.00	10.00	9.00	10.00
Vaccum (° Hg)	12.00	12.00	12.00	12.00	12.00	12.00	12.00
Traverse Point							Total
Time/Point(mins)							
ΔP (mm H2O)	n/a	n/a	n/a	n/a	n/a	n/a	n/a
K factor	n/a	n/a	n/a	n/a	n/a	n/a	n/a
ΔH (Orifice)							
Meter (Tm in)							
Meter (Tm out)							
Stack Temp (Ts)							
Impinger T Outlet							
Vaccum (° Hg)							
Traverse Point							Total
Time/Point(mins)							
ΔP (mm H2O)	n/a	n/a	n/a	n/a	n/a	n/a	n/a
K factor	n/a	n/a	n/a	n/a	n/a	n/a	n/a
ΔH (Orifice)							
Meter (Tm in)							
Meter (Tm out)							
Stack Temp (Ts)							
Impinger T Outlet							
Vaccum (° Hg)							
Traverse Point							Total
Time/Point(mins)							
ΔP (mm H2O)	n/a	n/a	n/a	n/a	n/a	n/a	n/a
K factor	n/a	n/a	n/a	n/a	n/a	n/a	n/a
ΔH (Orifice)							
Meter (Tm in)							
Meter (Tm out)							
Stack Temp (Ts)							
Impinger T Outlet							
Vaccum (° Hg)							
Impinger 1	3% H2O2						
SOL/	3362						
Start Weight (g)	731.4						
End Weight (g)	756.7						
Total weight (g)	25.3						
Impinger 2	3% H2O2						
SOL/	3362						
Start Weight (g)	751.8						
End Weight (g)	840.6						
Total weight (g)	88.8						
Impinger3	3% H2O2						
SOL/	3362						
Start Weight (g)	765.8						
End Weight (g)	679.4						
Total weight (g)	-86.4						
Impinger 4	Empty						
SOL/	...						
Start Weight (g)	491.3						
End Weight (g)	491.7						
Total weight (g)	0.4						
Impinger 5	Silica						
SOL/	...						
Start Weight (g)	909.7						
End Weight (g)	911.9						
Total weight (g)	2.2						
Impinger 6							
SOL/							
Start Weight (g)							
End Weight (g)							
Total weight (g)	0						
Impinger 7							
SOL/							
Start Weight (g)							
End Weight (g)							
Total weight (g)	0						
Impinger 8							
SOL/							
Start Weight (g)							
End Weight (g)							
Total weight (g)	0						
Total (g)	30.30						
Silica < 50% used at End of Test? Y/N	YES						
<p>If moisture was not measured see detailed notes below.</p> <p>Rinse Solutions used</p> <p>Solution SOL NO</p> <p>DI Water 3356</p> <p>Acetone ...</p> <p>3% H2O2 3362</p>							
<p>If moisture was not measured and gas was dried before entering the gas meter, impinger weights must be included to produce the moisture concentration used in the isokinetic calculations. If the gas was not dried before it entered the gas meter then impinger weights may be included to produce a nominal 0.1% moisture value.</p>							

Environmental Compliance Limited

Potters Waste
Permit No : TP3736SQ
Variation No : ...
Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Engine 2 - Non-methane TVOCs Field Data Sheet

Environmental Compliance Limited				SAMPLE TUBE DATA SAMPLING PROFORMA	
Client	Potters Waste	<input checked="" type="radio"/> Circular <input type="radio"/> Rectangular <input type="radio"/> Elipse	Pump ID	n/a	
Site	Brynposteg	Stack Diameter (mm)	Meter ID	U001	
Location	Landfill		MST Probe ID	n/a	
Stack ID	Engine 2	Stack Area (m ²)	MST Probe Heating Temp (C)	Sinter in-stack	
Test No	One - NMVOC	Barometric Pressure (mb)	DGM Yd or ml/count	0.9746	
Job No	P3334	Stack Thermocouple ID	MST Hot Box ID	978	
ECL Site Staff	SEB + PB	Tube Thermocouple ID	MST Hot Box Heating Temp (C)	180	
Barometer ID	627	Meter Thermocouple ID	Workhorse Set Sample Rate (%)	n/a	
		In-Stack Sinter Used (Y/N)	MST Delta H Sampling Rate	0.5 - 1	

Meter Units <input type="radio"/> ml <input checked="" type="radio"/> litres	Sample	Leak 1	Time (start/ end) (minimum 1 minute)	Leak 2	Time (start/ end) (minimum 1 minute)	Total
Start Volume	2852118.0	2852117.0	16:21:00	2852222.2	17:26:00	
Final Volume	2852221.0	2852117.0	16:22:00	2852222.2	17:27:00	
Total Volume	101.8	0.0		0.0		101.8
Sample Train Internal Volume	1.2447	Litres				

Sample Point	A1	A1	A1	A1
Time/ point (mins)	0-10	10--20	20-30	30-40
Tube Temp °C	17	16	16	17
Stack Temp °C	460	460	460	460
Meter Temp In °C	9	10	10	11
Meter Temp Out °C	9	10	10	11

Sample Point	A1	A1		
Time/ point (mins)	40-50	50-60		
Tube Temp °C	17	18		
Stack Temp °C	460	460		
Meter Temp In °C	11	10		
Meter Temp Out °C	11	10		

Sample Point				
Time/ point (mins)				
Tube Temp °C				
Stack Temp °C				
Meter Temp In °C				
Meter Temp Out °C				

Impinger 1	Empty
Start Weight (g)	526.7
End Weight (g)	529.7
Total weight (g)	3

Impinger 2	Empty
Start Weight (g)	618.4
End Weight (g)	618.9
Total weight (g)	0.5

Impinger3	Silica
Start Weight (g)	761.6
End Weight (g)	763.4
Total weight (g)	1.8

Silica	(IF USED)
<50% Spent at end Y/N?	Yes
Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	no

Environmental Compliance Limited

Potters Waste
Permit No : TP3736SQ
Variation No : ...
Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

LABORATORY ANALYSIS RESULTS

Environmental Compliance Limited

Potters Waste
Permit No
Variation No
Report Ref

: TP3736SQ
: ...
: P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018



Concept Life Sciences is a trading name of
Concept Life Sciences Analytical & Development
Services Limited registered in England and
Wales (No: 2514788)

Concept Life Sciences Certificate of Analysis

Hadfield House
Hadfield Street
Combrook
Manchester
M16 9FE
Tel : 0161 874 2400
Fax : 0161 874 2404

Report Number: 708572-1

Date of Report: 24-Jan-2018

Customer: Environmental Compliance Ltd
Unit G1
Main Avenue
Treforest Industrial Estate
Pontypridd
CF37 5BF

Customer Contact: Mr Sam Brookes

Customer Job Reference: P3334
Customer Purchase Order: E7497
Date Job Received at Concept: 15-Jan-2018
Date Analysis Started: 15-Jan-2018
Date Analysis Completed: 24-Jan-2018

The results reported relate to samples received in the laboratory and may not be representative of a whole batch.

Opinions and interpretations expressed herein are outside the scope of UKAS accreditation

This report should not be reproduced except in full without the written approval of the laboratory

Tests covered by this certificate were conducted in accordance with Concept Life Sciences SOPs

All results have been reviewed in accordance with Section 25 of the Concept Life Sciences, Analytical Services Quality Manual



Report checked
and authorised by :
Kathryn Gleaves
Customer Service Advisor

Issued by :
Emma Spear
Customer Service Advisor

Page 1 of 4
708572-1

Environmental Compliance Limited

Potters Waste
Permit No
Variation No
Report Ref

: TP3736SQ
: ...
: P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Concept Reference: 708572					
Customer Reference: P3334					
Impinger(peroxide) Analysed as Impinger(peroxide)					
Sulphur Dioxide & Volume					
Concept Reference	708572 001	708572 002	708572 003	708572 004	708572 005
Customer Sample Reference	ECL/18/0070	ECL/18/0071	ECL/18/0072	ECL/18/0073	ECL/18/0074
Test Sample	AR	AR	AR	AR	AR
Date Sampled	10-JAN-2018	10-JAN-2018	10-JAN-2018	10-JAN-2018	10-JAN-2018
Determinand	Method	LOD	Units	Symbol	
Sulphur Dioxide	IC	0.05	mg/l	U	(13) 64 (13) 0.54 (13) 0.48 (13) 55 (13) 0.59
Volume	Vol	1	ml	U	460 230 300 450 180

Concept Reference: 708572					
Customer Reference: P3334					
Impinger(peroxide) Analysed as Impinger(peroxide)					
Sulphur Dioxide & Volume					
Concept Reference	708572 006	708572 007	708572 008	708572 009	
Customer Sample Reference	ECL/18/0075	ECL/18/0076	ECL/18/0077	ECL/18/0078	
Test Sample	AR	AR	AR	AR	
Date Sampled	10-JAN-2018	11-JAN-2018	11-JAN-2018	11-JAN-2018	
Determinand	Method	LOD	Units	Symbol	
Sulphur Dioxide	IC	0.05	mg/l	U	(13) 0.43 (13) 0.78 (13) 0.38 (13) 0.78
Volume	Vol	1	ml	U	390 420 220 280

Concept Reference: 708572					
Customer Reference: P3334					
Tube (Charcoal 228-08) Analysed as Tube (Charcoal 228-09)					
VOC (Total)					
Concept Reference	708572 011	708572 012	708572 013	708572 014	708572 015
Customer Sample Reference	ECL/18/0080	ECL/18/0081	ECL/18/0082	ECL/18/0083	ECL/18/0084
Test Sample	AR	AR	AR	AR	AR
Date Sampled	10-JAN-2018	10-JAN-2018	10-JAN-2018	11-JAN-2018	11-JAN-2018
Determinand	Method	LOD	Units	Symbol	
Volatile Organic Compounds (Total)	GC/MS	1	µg	N	69 16 <1 3 <1

Environmental Compliance Limited

Potters Waste
Permit No
Variation No
Report Ref

: TP3736SQ
: ...
: P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Concept Reference: 708572						
Customer Reference: P3334						
Tube (Tenax/Carbon/Molecular Sieve) Analysed as Tube (Tenax/Carbon/Molecular Sieve)						
Trace Landfill Gas Suite						
Concept Reference		708572 018	708572 021	708572 022		
Customer Sample Reference		ECL/18/0088	ECL/18/0088	ECL/18/0088		
Test Sample		AR	AR	AR		
Date Sampled		11-JAN-2018	11-JAN-2018	11-JAN-2018		
Determinand	Method	LOD	Units	Symbol		
1-Pentene	GC/MS (TD SIR)	10	ng	U	(RR) 48	(RR) 30
1,1-Dichloroethane	GC/MS (TD SIR)	10	ng	U	<10	<10
1,1-Dichloroethylene	GC/MS (TD SIR)	10	ng	U	280	240
1,2-Dichloroethane	GC/MS (TD SIR)	10	ng	N	(175) 1600	<10
1,2-Dichloroethylene	GC/MS (TD SIR)	30	ng	U	<30	<30
1,3-Butadiene	GC/MS (TD SIR)	10	ng	U	(RR) <10	(RR) <10
1,4-isopropyl-2-butadiene	GC/MS (TD SIR)	10	ng	N	<10	<10
1-Propanethiol	GC/MS (TD SIR)	10	ng	U	<10	<10
2-butoxyethanol	GC/MS (TD SIR)	10	ng	N	<10	<10
Benzene	GC/MS (TD SIR)	10	ng	U	(175) 6800	(175) 2100
Butyric acid	GC/MS (TD SIR)	10	ng	N	<10	<10
Carbon disulphide	GC/MS (TD SIR)	10	ng	N	440	<10
Carbon tetrachloride	GC/MS (TD SIR)	10	ng	U	<10	<10
Chloroethane	GC/MS (TD SIR)	30	ng	N	<30	<30
Dichloromethane	GC/MS (TD SIR)	10	ng	N	(175) 6300	<10
Dimethyl disulphide	GC/MS (TD SIR)	10	ng	N	320	<10
Dimethyl sulphide	GC/MS (TD SIR)	10	ng	U	760	12
Ethyl butyrate	GC/MS (TD SIR)	25	ng	N	<25	<25
Ethyl Mercaptan	GC/MS (TD SIR)	10	ng	N	<10	<10
Hydrogen sulphide	GC/MS (TD SIR)	60	ng	N	<60	<60
Methyl Mercaptan	GC/MS (TD SIR)	30	ng	N	<30	<30
N-Butyl Mercaptan	GC/MS (TD SIR)	10	ng	U	<10	<10
Styrene	GC/MS (TD SIR)	10	ng	N	280	<10
Toluene	GC/MS (TD SIR)	10	ng	N	(27) 12000	31
Trichloroethylene	GC/MS (TD SIR)	10	ng	U	730	260
Vinyl chloride monomer	GC/MS (TD SIR)	10	ng	U	(RR) <10	(RR) <10

Concept Reference: 708572						
Customer Reference: P3334						
Tube (Charcoal) Analysed as Tube (Charcoal 226-01)						
Siloxanes						
Concept Reference		708572 025	708572 028			
Customer Sample Reference		ECL/18/0088	ECL/18/0088			
Test Sample		AR	AR			
Date Sampled		11-JAN-2018	11-JAN-2018			
Determinand	Method	LOD	Units	Symbol		
Decamethylcyclotrisiloxane	GC/MS (Solvent Desorption)	1	ug	U	<1	<1
Decamethyltetrasiloxane	GC/MS (Solvent Desorption)	1	ug	U	<1	<1
Hexamethylcyclotrisiloxane	GC/MS (Solvent Desorption)	1	ug	U	<1	<1
Hexamethyldisiloxane	GC/MS (Solvent Desorption)	1	ug	U	<1	<1
Octamethylcyclotrisiloxane	GC/MS (Solvent Desorption)	1	ug	U	<1	<1
Octamethyltrisiloxane	GC/MS (Solvent Desorption)	1	ug	U	<1	<1

Index to symbols used in 708572-1

Value	Description
AR	As Received
27	Result should be considered as a minimum due to detector saturation.
13	Results have been blank corrected.
68	Outside scope of UKAS accreditation
175	Results should be viewed with caution due to being outside of the instrument calibration range
U	Analysis is UKAS accredited
N	Analysis is not UKAS accredited

Environmental Compliance Limited

Potters Waste
Permit No : TP3736SQ
Variation No : ...
Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Notes

The results for 1 Pentene, 1,3-Butadiene & Vinyl Chloride Monomer are outside the scope of our UKAS accreditation as the standards expired on the 13/01/18.



Environmental Compliance Limited

Potters Waste
Permit No : TP3736SQ
Variation No : ...
Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

UNCERTAINTY CALCULATIONS

Potters Waste
Permit No
Variation No
Report Ref

: TP3736SQ
: ...
: P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Engine 1 - Volumetric Flowrate Uncertainty

Measurement Uncertainty Calculations - Velocity at Stack Conditions

Contribution From	Standard u/c (Pa)	
Pitot Calibration Uncertainty Contribution	4.34	A
Manometer Calibration Uncertainty Contribution	4.34166667	B
Variation in Actual Pitot reading at sample points	3.00	C
Combined u/c (Pa) = SQRT (A/ $\sqrt{3}$) ² + (B/ $\sqrt{3}$) ² + (C/ $\sqrt{3}$) ²)	3.95	
Expanded Uncertainty of Flow Measurements Pa	7.89	
	Standard u/c (K)	
Temperature Calibration (K)	3.91	D
Variation in Actual Temp reading at sample points	0.00	E
Combined u/c of Temp (K) SQRT ((D/ $\sqrt{3}$) ² + (E/ $\sqrt{3}$) ²)	2.25	
Expanded Uncertainty of Temp Measurements (K)	4.51	
Measured Average Velocity (m/s) at Stack Conds	63.27	
Maximum Average Velocity (m/s) at Stack Conds	63.74	
Standard Uncertainty Velocity at Stack Conditions (%)	0.74	
Expanded Uncertainty Velocity (at Stack Conditions)	1.49 (%)	

Measurement Uncertainty Calculations - Flowrate at Stack Conditions

Contribution From	Standard u/c (m ²)
Area (m2)	0.00071
Measured Average Flowrate (m ³ /s) at Stack Conds	4.47
Maximum Average Flowrate (m ³ /s) at Stack Conds	4.55
Standard Uncertainty Flowrate (m ³ /s) at Stack Conditions (%)	1.75
Expanded Uncertainty Flowrate (m³/s) at Stack Conditions	3.50 (%)

Measurement Uncertainty Calculations - Flowrate at STP & Wet Gas

Contribution From	Standard u/c (%)
Temperature Calibration (K)	0.5
Barometer Calibration	0.5
Measured Average Flowrate (m ³ /s) at STP Wet	1.49
Maximum Average Flowrate (m ³ /s) at STP Wet	1.52
Standard Uncertainty Flowrate (m ³ /s) at STP Wet	1.93
Expanded Uncertainty Flowrate (m³/s) at STP Wet	3.86 (%)

Measurement Uncertainty Calculations - Flowrate at STP & Dry Gas

Contribution From	Standard u/c (%)
Moisture Uncertainty (% v/v)	0.24
Measured Average Flowrate (m ³ /s) at STP Dry	1.29
Maximum Average Flowrate (m ³ /s) at STP Dry	1.32
Standard Uncertainty Flowrate (m ³ /s) at STP Dry	2.21
Expanded Uncertainty Flowrate (m³/s) at STP Dry	4.42 (%)

Measurement Uncertainty Calculations - Flowrate at STP, Dry Gas & Ref Oxygen

Contribution From	Standard u/c (%)
Oxygen Uncertainty (% v/v)	0.217
Measured Average Flowrate (m ³ /s) at STP Dry & Ref Oxygen	1.11
Maximum Average Flowrate (m ³ /s) at STP Dry & Ref Oxygen	1.15
Standard Uncertainty Flowrate (m ³ /s) at STP Dry & Ref Oxygen	3.82
Expanded Uncertainty Flowrate (m³/s) at STP Dry & Ref O₂	7.64 (%)

Environmental Compliance Limited

Potters Waste
Permit No : TP3736SQ
Variation No : ...
Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Engine 1 Combustion Gases Uncertainty of Measurement

Uncertainty of Measurement Results - Calculations Part 1

Horiba PG 250 Performance Characteristics	Standard Uncertainty (% of Range)	Distribution	Divisor	Minimum Certified Range (R _i)			
				NO 0 - 125 mg/m ³	CO 0 - 95 mg/m ³	O ₂ 0 - 25 %Vol	CO ₂ 0 - 20 %Vol
Lack of fit ⁽¹⁾	u_{lof}	Rectangular	$\sqrt{3}$	0.40	0.40	0.13	0.60
Span drift ⁽²⁾	$u_{d,s}$			0.27	0.29	0.029	0.24
Losses / leakage in the sample system ⁽⁴⁾	u_{loss}			5.00	9.03	0.080	0.49
Temperature dependant span drift ⁽³⁾	u_t			0.18	0.050	0.070	0.040

Notes:

For rectangular distributions, $u(x_i) = \frac{u \times R_i}{\sqrt{3}}$

For $u(x_i) = \Delta x_i \sqrt{\frac{(x_{i,max} - x_{i,adj})^2 + (x_{i,min} - x_{i,adj})^2 + (x_{i,max} - x_{i,adj})(x_{i,min} - x_{i,adj})}{3}}$, when $|x_{i,max} - x_{i,adj}| = |x_{i,min} - x_{i,adj}|$, then $u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$

Where $u(x_i) = \frac{\sigma}{\sqrt{n}}$ (See note 6 below), $\sigma = \sqrt{\frac{\sum (x_i - \bar{x})^2}{n-1}}$

Horiba PG 250 Performance Characteristics	Uncertainty (Units of final measurement)	Distribution	Divisor	NO 0 - 125 mg/m ³	CO 0 - 95 mg/m ³	O ₂ 0 - 25 %Vol	CO ₂ 0 - 20 %Vol
Lack of fit	u_{lof}	Rectangular	$\sqrt{3}$	0.29	0.22	0.019	0.069
Span drift	$u_{d,s}$			0.20	0.16	0.0041	0.028
Temperature dependant span drift	u_t			1.41	0.30	0.11	0.0092
Interferents	u_i			0.87	1.59	0.081	...

Uncertainty of Measurement Results - Calculations Part 2

Horiba PG 250 Performance Characteristics	Uncertainty (Units of final measurement)	Date & Time	NO 0 - 125 mg/m ³	CO 0 - 95 mg/m ³	O ₂ 0 - 25 %Vol	CO ₂ 0 - 20 %Vol
Losses / leakage in the sample system	u_{loss}	10/01/18 12:30 - 13:29	21.97	94.85	0.0057	0.056
Standard Error of Measured Value	u_{SE}	10/01/18 12:30 - 13:29	2.23	1.79	0.0078	0.0099

Effect on Uncertainty Caused by Oxygen

$$u_{Corr_{O_2}} = \frac{20.9\% - O_{2,ref}}{(20.9\% - O_{2,measured}) \times (20.9\% - O_{2,measured})} \times \text{Uncertainty of } O_2 \text{ Measurement} = 0.025$$

$$f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 2.2131 \quad u_{f_{O_2}} = \frac{u_{Corr_{O_2}}}{f_{O_2}} \times 100 = 1.15 \%$$

The effect of oxygen on the overall uncertainties (below) is incorporated using the following equation:-

$$u_{combined} = \sqrt{\sum (u_{f_{O_2}})^2 + (\text{Uncertainty of Measurement of Determinand})^2}$$

Where oxygen or moisture correction is required, uncertainty based on the standard error of the measured peripheral value is converted to units of final measurement using a sensitivity coefficient C,

$$\therefore u(x_i) = C_i u_i \text{ where } C_i = \frac{\partial f}{\partial x_i}$$

Uncertainty of Measurement Results - Calculations Part 3

Horiba PG 250 Uncertainty	Date & Time	NOx (as NO2) 0 - 125 mg/m ³	CO 0 - 95 mg/m ³	O ₂ 0 - 25 %Vol	CO ₂ 0 - 20 %Vol
Measured Concentration	10/01/18 12:30 - 13:29	439.21	1062.54	7.18	11.51
Expanded Uncertainty as Percentage of Measured Concentration		10%	18%	4%	2%

Combined Standard Uncertainty $u_c = \sqrt{u_{NO_2}^2 + u_{CO}^2 + u_{O_2}^2 + u_{CO_2}^2 + u_t^2 + u_{ref}^2 + u_{dyn}^2}$

Expanded uncertainty (at 95% confidence) $U_{95\%} = 2 \times u_c$

- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range as maximum drift per 24hr period
- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range per one degree centigrade
- Where the uncertainty of Moisture is taken as the standard error of the time averaged value used to correct to Dry Conditions
- If no value for uncertainty is presented above, the uncertainty is considered to be > 100%

Environmental Compliance Limited

Potters Waste
Permit No : TP3736SQ
Variation No : ...
Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Engine 1 - Combustion Gases Measurement Uncertainty

Measurement Uncertainty Calculations Part 1

Horiba PG 250 Performance Characteristics	Standard Uncertainty (% of Range)	Distributioun	Minimum Certified Range (R _i)			
			NO 0 - 125 mg/m ³	CO 0 - 95 mg/m ³	O ₂ 0 - 25 %Vol	CO ₂ 0 - 20 % Vol
Lack of fit ⁽¹⁾	u_{lof}	Rectangular (Divisor = $\sqrt{3}$)	0.40	0.40	0.13	0.60
Span drift ⁽²⁾	$u_{d,s}$	Rectangular (Divisor = $\sqrt{3}$)	0.27	0.29	0.029	0.24
Repeatability Standard Deviation (span) ⁽³⁾	u_r	Normal (Divisor = 1)	4.95	23.31	0.42	0.14
Losses / leakage in the sample system ⁽⁴⁾	u_{loss}	Rectangular (Divisor = $\sqrt{3}$)	5.00	9.03	0.080	0.49
Temperature dependant span drift ⁽⁵⁾	u_t	Rectangular (Divisor = $\sqrt{3}$)	0.18	0.050	0.070	0.040
Interferents ⁽¹⁾	u_i	Rectangular (Divisor = $\sqrt{3}$)	1.20	2.90	0.56	0.010
Uncertainty of Reference Gas ⁽⁶⁾	u_{ref}	Rectangular (Divisor = $\sqrt{3}$)	9.12	22.02	0.15	0.31

Note:

$$\text{when } |(x_{i,\max} - x_{i,\text{adj}})| = |(x_{i,\min} - x_{i,\text{adj}})|, \text{ then } u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$$

- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range as maximum drift per 24hr period
- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range per one degree centigrade
- Expressed as standard uncertainty in units of measurement i.e. mg/m³ / %Vol inc additional uncertainty of 2% for gas blending
- Data not available so not included

Measurement Uncertainty Calculations Part 2

Horiba PG 250 Performance Characteristics	Uncertainty	Value of Standard Uncertainty	NO 0 - 125 mg/m ³	CO 0 - 95 mg/m ³	O ₂ 0 - 25 %Vol	CO ₂ 0 - 20 % Vol
Lack of fit	u_{lof}	$u(x_i) = \frac{u_{lof} \times R_i}{\sqrt{3}} =$	0.29	0.22	0.019	0.07
Span drift	$u_{d,s}$	$u(x_i) = \frac{u_{d,s} \times R_i}{\sqrt{3}} =$	0.20	0.16	0.0041	0.0280
Repeatability Standard Deviation (span)	u_r	$\sigma = \sqrt{\frac{\sum_{i=1}^n (x_i - \bar{x})^2}{n-1}} =$	4.95	23.31	0.42	0.14
Losses / leakage in the sample system	u_{loss}	$u(x_i) = \frac{u_{loss} \times R_i}{\sqrt{3}} =$	3.61	4.95	0.012	0.06
Temperature dependant span drift	u_t	$u(x_i) = \frac{u_t}{100} \times R_i \times \sqrt{\frac{(x_{j,\max} - x_{adj})^2 + (x_{j,\min} - x_{adj})(x_{j,\max} - x_{adj}) + (x_{j,\min} - x_{adj})^2}{3}}$	0.26	0.055	0.020	0.009
Interferents	u_i	$u(x_i) = \frac{u_i \times R_i}{\sqrt{3}} =$	0.87	1.59	0.081	0.01
Uncertainty of Reference Gas	u_{ref}	$u(x_i) = \frac{u_{ref}}{\sqrt{3}} =$	5.26	12.71	0.086	0.18
Combined Standard Uncertainty		$u_c = \sqrt{u_{lof}^2 + u_{d,s}^2 + u_r^2 + u_{loss}^2 + u_t^2 + u_i^2 + u_{ref}^2}$	8.14	27.05	0.43	0.25
Expanded measurement uncertainty (at 95% confidence)		$U_{EXP} = 2 \times u_c$	16.27	54.11	0.87	0.49
Applied Span Concentration			526.44	1271.25	14.84	17.73
Measured Span Concentration, STP Dry Gas			514.55	1242.48	14.77	17.61
Expanded measurement uncertainty as % of Applied Span			3%	4%	6%	3%

Potters Waste
Permit No : TP3736SQ
Variation No : ...
Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Engine 1 - TVOCs Uncertainty of Measurement

Engine 1 - TVOC - Uncertainty of Measurement Results - Calculations Part 1

Performance Characteristics	Standard Uncertainty (% of Range)	Distribution	Divisor	Min Certified Range	
				O ₂ 0 - 25 %Vol	TVOC 0 - 15 mgC/m ³
Lack of fit ⁽¹⁾	u_{lof}	Rectangular	$\sqrt{3}$	0.13	0.73
Span drift ⁽²⁾	$u_{d,s}$			0.029	0.35
Losses / leakage in the sample system ⁽⁴⁾	u_{loss}			1.00	0.23
Temperature dependant span drift ⁽⁵⁾	u_t			0.070	0.30
Interferents ⁽¹⁾	u_i			0.56	4.39
Effect of Voltage Fluctuation ⁽⁷⁾	u_v			...	1.80
Effect of Oxygen Synergism ⁽⁷⁾	u_{syn}			...	

Notes:

For rectangular distributions, $u(x_i) = \frac{u \times R_i}{\sqrt{3}}$

For $u(x_i) = \Delta x_i \sqrt{\frac{(x_{i,max} - x_{i,adj})^2 + (x_{i,min} - x_{i,adj})^2 + (x_{i,max} - x_{i,min})^2}{3}}$, when $|x_{i,max} - x_{i,adj}| = |x_{i,min} - x_{i,adj}|$, then $u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$

Where $u(x_i) = \frac{\sigma}{\sqrt{n}}$ (See note 6 below), $\sigma = \sqrt{\frac{\sum_{i=1}^n (x_i - \bar{x})^2}{n-1}}$

Performance Characteristics	Uncertainty (Units of final measurement)	Distribution	Divisor	O ₂ 0 - 25 %Vol	TVOC 0 - 15 mgC/m ³
Lack of fit	u_{lof}	Rectangular	$\sqrt{3}$	0.019	0.064
Span drift	$u_{d,s}$			0.0041	0.031
Temperature dependant span drift	u_t			0.053	0.14
Interferents	u_i			0.081	0.38
Effect of Voltage Fluctuation (See Note)	u_v			...	0.16

Engine 1 - TVOC - Uncertainty of Measurement Results - Calculations Part 2

Performance Characteristics	Uncertainty (Units of final measurement)	Date & Time	O ₂ 0 - 25 %Vol	TVOC 0 - 15 mgC/m ³
Losses / leakage in the sample system	u_{loss}	10/01/18 12:51 - 13:50	0.072	3.71
Standard Error of Measured Value	u_{SE}	10/01/18 12:51 - 13:50	0.015	5.63

Effect on Uncertainty Caused by Oxygen

$$u_{Corr_{O_2}} = \frac{20.9\% - O_{2,ref}}{(20.9\% - O_{2,measured})(20.9\% - O_{2,measured})} \times \text{Uncertainty of O}_2 \text{ Meas} =$$

0.03

$$f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 1.1624$$

$$u_{f_{O_2}} = \frac{u_{Corr_{O_2}}}{f_{O_2}} \times 100 = 2.19 \%$$

The effect of oxygen on the overall uncertainties (below) is incorporated using the following equation:-

$$u_{combined} = \sqrt{\sum (u_{f_{O_2}})^2 + (\text{Uncertainty of Measurement of Determinand})^2}$$

Where oxygen or moisture correction is required, uncertainty based on the standard error of the measured peripheral value is converted to units of final measurement using a sensitivity coefficient C,

$$\therefore u(x_i) = C_i u_i \text{ where } C_i = \frac{\partial f}{\partial x_i}$$

Engine 1 - TVOC - Uncertainty of Measurement Results - Calculations Part 3

Uncertainty	Date & Time	O ₂ 0 - 25 %Vol	*TVOC 0 - 15 mgC/m ³
Measured Concentration	10/01/18 12:51 - 13:50	7.22	1639.12
Expanded Uncertainty as Percentage of Measured Concentration		3 %	2 %

Combined Standard Uncertainty $u_c = \sqrt{u_{lof}^2 + u_{d,s}^2 + u_{loss}^2 + u_t^2 + u_i^2 + u_{ref}^2 + u_v^2 + u_{syn}^2}$

Expanded uncertainty (at 95% confidence) $U_{Exp} = 2 \times u_c$

- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range as maximum drift per 24hr period
- Expressed as a percentage of the certified range
- Expressed as a percentage of the applied span concentration
- Expressed as a percentage of the certified range per one degree centigrade
- Where the uncertainty of moisture is taken from the manual extract test calculations.
- Expressed as a percentage of the certified range
- Where no uncertainty is presented above, the uncertainty is > 100%

Environmental Compliance Limited

Potters Waste
Permit No : TP3736SQ
Variation No : ...
Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Engine 1 - TVOCs Measurement Uncertainty

Engine 1 - TVOC - Measurement Uncertainty - Uncertainty Calculations Table 1

Performance Characteristics	Standard Uncertainty (% of Range)	Distribution	Min Certified Ranges
			TVOC 0 - 15 mgC/m ³
Lack of fit ⁽¹⁾	u_{lof}	Rectangular (Divisor = $\sqrt{3}$)	0.73
Span drift ⁽²⁾	$u_{d,s}$	Rectangular (Divisor = $\sqrt{3}$)	0.35
Repeatability Standard Deviation (span) ⁽³⁾	u_r	Normal (Divisor = 1)	82.16
Losses / leakage in the sample system ⁽⁴⁾	u_{loss}	Rectangular (Divisor = $\sqrt{3}$)	13.95
Temperature dependant span drift ⁽⁵⁾	u_t	Rectangular (Divisor = $\sqrt{3}$)	0.30
Interferents ⁽¹⁾	u_i	Rectangular (Divisor = $\sqrt{3}$)	4.39
Uncertainty of Reference Gas ⁽⁶⁾	u_{ref}	Rectangular (Divisor = $\sqrt{3}$)	25.74
Effect of Voltage Fluctuation ⁽⁷⁾	u_v	Rectangular (Divisor = $\sqrt{3}$)	1.80
Effect of Oxygen Synergism ⁽⁷⁾	u_{syn}	Rectangular (Divisor = $\sqrt{3}$)	4.60

Note:

$$\text{when } |(x_{i,max} - x_{i,adj})| = |(x_{i,min} - x_{i,adj})|, \text{ then } u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$$

- Expressed as a percentage of the certified range
- Expressed as maximum drift per 24hr period as percentage of the certified range
- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range per one degree centigrade
- Expressed as standard uncertainty in units of measurement i.e. mg/m³ / %Vol taking account of an additional uncertainty of 2% for gas blending
- Expressed as a percentage of the certified range

Engine 1 - TVOC - Measurement Uncertainty - Uncertainty Calculations Table 2

Performance Characteristics	Uncertainty	Value of Standard Uncertainty	*TVOC 0 - 15 mgC/m ³
Lack of fit	u_{lof}	$u(x_i) = \frac{u_{lof} \times R_i}{\sqrt{3}} =$	0.064
Span drift	$u_{d,s}$	$u(x_i) = \frac{u_{d,s} \times R_i}{\sqrt{3}} =$	0.031
Repeatability Standard Deviation (span)	u_r	$\sigma = \sqrt{\frac{\sum_{i=1}^n (x_i - \bar{x})^2}{n-1}} =$	12.32
Losses / leakage in the sample system	u_{loss}	$u(x_i) = \frac{u_{loss} \times R_i}{\sqrt{3}} =$	1.21
Temperature dependant span drift	u_t	$u(x_i) = \frac{u_t}{100} \times R_i \times \sqrt{\frac{(x_{i,max} - x_{i,adj})^2 + (x_{i,min} - x_{i,adj})^2 + (x_{i,max} - x_{i,min})^2}{3}} =$	0.052
Interferents	u_i	$u(x_i) = \frac{u_i \times R_i}{\sqrt{3}} =$	0.38
Uncertainty of Reference Gas	u_{ref}	$u(x_i) = \frac{u_{ref}}{\sqrt{3}} =$	14.86
Effect of Voltage Fluctuation	u_v	$u(x_i) = \frac{u_v \times R_i}{\sqrt{3}} =$	0.16
Effect of Oxygen Synergism	u_{syn}	$u(x_i) = \frac{u_{syn} \times R_i}{\sqrt{3}} =$	0.40
Combined Standard Uncertainty		$u_c = \sqrt{u_{lof}^2 + u_{d,s}^2 + u_r^2 + u_{loss}^2 + u_t^2 + u_i^2 + u_{ref}^2}$	19.35
Expanded measurement uncertainty (at 95% confidence)		$U_{EXP} = 2 \times u_c$	38.71
Applied Span Concentration			1486.15
Measured Span Concentration, STP Dry Gas			1480.90
Expanded measurement uncertainty as % of Applied Span			3 %

* Signal 3030 FID

Environmental Compliance Limited

Potters Waste
Permit No
Variation No
Report Ref

: TP3736SQ
: ...
: P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Engine 1 - SO2 Uncertainty

Site: Brynposteg
Location: Engine 1

$$u_{mass} = \sqrt{\sum (u_{filter})^2 + (u_{solution})^2}$$

Determinand	Filter mg	Solution mg	Recovered Mass mg	LAB Method Filter mg	Uncert (%) K=2 Solution mg	Standard Uncertainty Filter mg	Solution mg	Combined Uncertainty mg
One - SO2								
...
...
Sulphur Dioxide	...	24.42	24.42	...	3.18	...	1.59	1.59
...

...
...
...
...

	One - SO2		Standard Uncertainty @ 95%	
Sampled Volume (V _m)	0.44	m ³	uV _m 0.001	m ³
Meter Correction Factor (Y _d)	0.98
Meter Temperature (T _m)	282.42	k	uT _m 1.5	k
Average Differential Pressure (ΔH)	3.00	mmH ₂ O	uΔH 0.25	mmH ₂ O
Barometric Pressure (p _b)	723.06	mmHg	up _b 3.8	mmHg
ΔH + ps (p _m)	96.43	kPa
Oxygen content (O _{2,m})	7.23	% by volume	uO _{2,m} = σ/√n 0.0146	% by volume
Moisture Content (H ₂ O)	13.25	% by volume	uH ₂ O 0.48	% by volume

Note: In the following calculations, the sensitivity coefficient (C) is estimated using: $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by $C_i u_i$ where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. $i = uV_m, uT_m$ etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

One - SO2:

$$f_{s, wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured ΔH uncertainty component (uΔH), measured stack pressure uncertainty component (up_b) & measured temperature of dry gas uncertainty component (uT_{m, dry})

One - SO2:

$$f_s = \frac{273}{760} \times \frac{P_b + \frac{\Delta H}{13.6}}{T_m} \times Y_d = 0.898$$

	Maximum	Minimum	Sensitivity	ufstp
uΔH	0.90	0.90	0.0000913	0.0000228
up _b	0.90	0.89	0.00124	0.00466
uT _m	0.90	0.89	0.00318	0.00477
H ₂ O

$$\frac{uf_s}{f_s} = \sqrt{\left(\frac{\sqrt{(u\Delta H)^2 + (uP_b)^2}}{(P_m/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{100/(100-H_2O)}\right)^2} = 0.00604$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV_{std}) & volume uncertainty component (uV_m)

One - SO2:

$$V_{std} = V_{measured} \times f_s = 0.393$$

	Maximum m ³	Minimum m ³	Sensitivity	Standard Uncertainty (m ³)
Effect of uV _{std}	0.40	0.39	0.44	0.00265
Effect of uV _m	0.39	0.39	0.90	0.000898

Combined Standard Uncertainty

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uV_{std}}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.00141$$

Uncertainty of Oxygen Correction Factor (%):-

One - SO2:

$$f_{O_2} = \frac{20.9\% - O_{2, ref}}{20.9\% - O_{2, measured}} = 1.16$$

$$uCorr_{O_2} = \frac{20.9\% - O_{2, ref}}{(20.9\% - O_{2, measured}) \times (20.9\% - O_{2, measured})} \times \text{Uncertainty of } O_2 \text{ Measurement} = 0.0255$$

$$uf_{O_2} = \frac{uCorr_{O_2}}{f_{O_2}} \times 100 = 2.19\%$$

Environmental Compliance Limited

Potters Waste

Permit No : TP3736SQ

Variation No : ...

Report Ref : P3334 : R001

Installation Name

Visit Details : Annual Compliance

Survey Dates : 10th & 11th January 2018

Report Issue Date : 31st January 2018

Uncertainty in final measurement @ reference conditions due to mass uncertainty component (uM)

Determinand	one:			
	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	uM mg/Nm ³
...
...
Sulphur Dioxide	76.88	67.49	2.96	4.69
...

Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

Determinand	one:
	uL mg/Nm ³
...	...
...	...
Sulphur Dioxide	0.83
...	...

Uncertainty in final measurement @ Reference Conditions due to uVstp

Determinand	one:			
	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	uVstp mg/Nm ³
...
...
Sulphur Dioxide	72.45	71.93	183.48	0.26
...

Combined Uncertainty excluding oxygen contribution

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (u_{Vstp})^2}$$

Determinand	one:			
	Combined Uncertainty mg/Nm ³	Expanded Uncertainty mg/Nm ³	Measured Concentration mg/Nm ³	Percent of Measured Concentration
...
...
Sulphur Dioxide	4.77	9.55	72.19	13.22
...

Combined Uncertainty including oxygen contribution

$$u_{combined} = \sqrt{\sum (u_{f_{O_2}})^2 + (Uncertainty\ of\ Measurement\ of\ Determinand)^2}$$

Determinand	Measurement Uncertainty of Determinand	Measurement Uncertainty of Oxygen Corr Factor	Overall Measurement Uncertainty inc O ₂ Corr ² factor (Ucombined)
...
...
Sulphur Dioxide	13.22	2.19	13.40
...

Environmental Compliance Limited

Potters Waste
Permit No : TP3736SQ
Variation No : ...
Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Engine 1 - Non-methane TVOCs Uncertainty

Site: Potters Waste, Brynposteg
Location: Landfill, Stack ID:Engine 1

				Standard Uncertainty @ 95%		
Sampled Volume	V_m	0.10456	m ³	uV_m	0.000	m ³
Meter Correction Factor or ml/count	Y_d	0.9746
Meter Temperature	T_m	283.33	K	uT_m	1.5	K
Barometric Pressure	P_b	964.00	mBar		10.0	mBar
Oxygen content	$O_{2,m}$	7.19	%Vol	$uO_{2,m}$	0.43	%Vol
Moisture	H_2O	10.15	%Vol	uH_2O	1.48	%Vol

Tubes					
Determinand	Recovered Mass	Standard Uncertainty			
Engine 1	59.00 µg	uM	5.90	µg	

Note: In the following calculations, the sensitivity coefficient (C) is estimated using: $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by $C_i u_i$ where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. $i = uV_m, uT_m$ etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from meter:

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (uP_b), measured temperature of dry gas uncertainty component (uT_m) & measured moisture (uH_2O) where required

$$f_s = \frac{273}{T_m} \times \frac{P}{101.3} = 0.92$$

	Maximum	Minimum	Sensitivity	ufstp
uP_b	0.47	0.46	0.000484	0.00484
uT_m	0.92	0.91	0.00324	0.00485
uH_2O

$$\frac{uf_s}{f_s} = \sqrt{\left(\frac{uP_b}{(P_b/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{100/(100 - H_2O)}\right)^2} = 0.00634$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV_{std}) & volume uncertainty component (uV_m)

$$V_{std} = V_{measured} \times f_s = 0.0934$$

	Maximum m ³	Minimum m ³	Sensitivity	Standard Uncertainty m ³
Effect of uf_s	0.0941	0.0928	0.10	0.000646
Effect of uV_m	0.0934	0.0934	0.89	8.936E-06

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uf_s}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.00952$$

Uncertainty of correction factor to reference conditions (excluding oxygen contribution) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

$$uL = \frac{Conc \times \frac{2}{100}}{\sqrt{3}}$$

	Tubes uL mg/Nm ³	Condensate uL mg/Nm ³
Engine 1	0.00729	...

Environmental Compliance Limited

Potters Waste
Permit No : TP3736SQ
Variation No : ...
Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

$$Conc = \frac{M_{Recovered}}{V_m \times f_s \times f_{O_2}}$$

Uncertainty in final measurement @ Reference Conditions due to $uM_{Recovered}$

Charcoal Tube Results				
	Maximum	Minimum	Sensitivity	Standard Uncertainty
	mg/Nm ³	mg/Nm ³		mg/Nm ³
Non Methane VOCs	0.66	0.60	10.70	0.0316
Condensate Results				
	Maximum	Minimum	Sensitivity	Standard Uncertainty
	mg/Nm ³	mg/Nm ³		mg/Nm ³
Non Methane VOCs				

Uncertainty in final measurement @ Reference Conditions due to uV_{STD}

Charcoal Tube Results				
	Maximum	Minimum	Sensitivity	Standard Uncertainty
	mg/Nm ³	mg/Nm ³		mg/Nm ³
Non Methane VOCs	0.70	0.57	6.83	0.0650

Combined Uncertainty (excluding Oxygen contribution)

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (uV_{std})^2}$$

Charcoal Tubes: Determinand	Combined Uncertainty mg/Nm ³	Expanded Uncertainty mg/Nm ³	Measured Concentration mg/Nm ³	Percent of Measured Concentration
Non Methane VOCs	0.0726	0.15	0.73	19.85

Potters Waste
Permit No
Variation No
Report Ref

: TP3736SQ
: ...
: P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Engine 2 - Volumetric Flowrate Uncertainty

Measurement Uncertainty Calculations - Velocity at Stack Conditions

Contribution From	Standard u/c (Pa)	
Pitot Calibration Uncertainty Contribution	1.59	A
Manometer Calibration Uncertainty Contribution	1.590416667	B
Variation in Actual Pitot reading at sample points	7.00	C
Combined u/c (Pa) = SQRT (A/ $\sqrt{3}$) ² + (B/ $\sqrt{3}$) ² + (C/ $\sqrt{3}$) ²)	4.24	
Expanded Uncertainty of Flow Measurements Pa	8.49	
	Standard u/c (K)	
Temperature Calibration (K)	3.66	D
Variation in Actual Temp reading at sample points	0.25	E
Combined u/c of Temp (K) SQRT ((D/ $\sqrt{3}$) ² + (E/ $\sqrt{3}$) ²)	2.12	
Expanded Uncertainty of Temp Measurements (K)	4.24	
Measured Average Velocity (m/s) at Stack Conds	37.01	
Maximum Average Velocity (m/s) at Stack Conds	37.60	
Standard Uncertainty Velocity at Stack Conditions (%)	1.62	
Expanded Uncertainty Velocity (at Stack Conditions)	3.24 (%)	

Measurement Uncertainty Calculations - Flowrate at Stack Conditions

Contribution From	Standard u/c (m ³)
Area (m ²)	0.00126
Measured Average Flowrate (m ³ /s) at Stack Conds	4.65
Maximum Average Flowrate (m ³ /s) at Stack Conds	4.77
Standard Uncertainty Flowrate (m ³ /s) at Stack Conditions (%)	2.63
Expanded Uncertainty Flowrate (m³/s) at Stack Conditions	5.27 (%)

Measurement Uncertainty Calculations - Flowrate at STP & Wet Gas

Contribution From	Standard u/c (%)
Temperature Calibration (K)	0.5
Barometer Calibration	0.5
Measured Average Flowrate (m ³ /s) at STP Wet	1.65
Maximum Average Flowrate (m ³ /s) at STP Wet	1.70
Standard Uncertainty Flowrate (m ³ /s) at STP Wet	2.83
Expanded Uncertainty Flowrate (m³/s) at STP Wet	5.65 (%)

Measurement Uncertainty Calculations - Flowrate at STP & Dry Gas

Contribution From	Standard u/c (%)
Moisture Uncertainty (% v/v)	0.25
Measured Average Flowrate (m ³ /s) at STP Dry	1.48
Maximum Average Flowrate (m ³ /s) at STP Dry	1.53
Standard Uncertainty Flowrate (m ³ /s) at STP Dry	3.11
Expanded Uncertainty Flowrate (m³/s) at STP Dry	6.22 (%)

Measurement Uncertainty Calculations - Flowrate at STP, Dry Gas & Ref Oxygen

Contribution From	Standard u/c (%)
Oxygen Uncertainty (% v/v)	0.179
Measured Average Flowrate (m ³ /s) at STP Dry & Ref Oxygen	1.12
Maximum Average Flowrate (m ³ /s) at STP Dry & Ref Oxygen	1.17
Standard Uncertainty Flowrate (m ³ /s) at STP Dry & Ref Oxygen	4.64
Expanded Uncertainty Flowrate (m³/s) at STP Dry & Ref O₂	9.28 (%)

Environmental Compliance Limited

Potters Waste
Permit No : TP3736SQ
Variation No : ...
Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Engine 2 - Combustion Gases Uncertainty of Measurement

Uncertainty of Measurement Results - Calculations Part 1

Horiba PG 250 Performance Characteristics	Standard Uncertainty (% of Range)	Distribution	Divisor	Minimum Certified Range (R _i)			
				NO 0 - 125 mg/m ³	CO 0 - 95 mg/m ³	O ₂ 0 - 25 %Vol	CO ₂ 0 - 20 %Vol
Lack of fit ⁽¹⁾	u_{lof}	Rectangular	$\sqrt{3}$	0.40	0.40	0.13	0.60
Span drift ⁽²⁾	$u_{d,s}$			0.27	0.29	0.029	0.24
Losses / leakage in the sample system ⁽⁴⁾	u_{loss}			5.00	9.03	0.080	0.49
Temperature dependant span drift ⁽³⁾	u_t			0.18	0.050	0.070	0.040

Notes:

For rectangular distributions, $u(x_i) = \frac{u \times R_i}{\sqrt{3}}$

For $u(x_i) = \Delta x_i \sqrt{\frac{(x_{i,max} - x_{i,adj})^2 + (x_{i,min} - x_{i,adj})(x_{i,max} - x_{i,adj}) + (x_{i,min} - x_{i,adj})^2}{3}}$, when $|x_{i,max} - x_{i,adj}| = |x_{i,min} - x_{i,adj}|$, then $u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$

Where $u(x_i) = \frac{\sigma}{\sqrt{n}}$ (See note 6 below), $\sigma = \sqrt{\frac{\sum_{i=1}^n (x_i - \bar{x})^2}{n-1}}$

Horiba PG 250 Performance Characteristics	Uncertainty (Units of final measurement)	Distribution	Divisor	NO 0 - 125 mg/m ³	CO 0 - 95 mg/m ³	O ₂ 0 - 25 %Vol	CO ₂ 0 - 20 %Vol
Lack of fit	u_{lof}	Rectangular	$\sqrt{3}$	0.29	0.22	0.019	0.069
Span drift	$u_{d,s}$			0.20	0.16	0.0041	0.028
Temperature dependant span drift	u_t			1.41	0.30	0.11	0.0092
Interferents	u_i			0.87	1.59	0.081	...

Uncertainty of Measurement Results - Calculations Part 2

Horiba PG 250 Performance Characteristics	Uncertainty (Units of final measurement)	Date & Time	NO 0 - 125 mg/m ³	CO 0 - 95 mg/m ³	O ₂ 0 - 25 %Vol	CO ₂ 0 - 20 %Vol
Losses / leakage in the sample system	u_{loss}	10/01/18 16:23 - 17:22	21.98	92.34	0.0065	0.050
Standard Error of Measured Value	u_{SE}	10/01/18 16:23 - 17:22	8.98	4.07	0.0079	0.0059

Effect on Uncertainty Caused by Oxygen

$$u_{Corr_{O_2}} = \frac{20.9\% - O_{2,ref}}{(20.9\% - O_{2,measured}) \times (20.9\% - O_{2,measured})} \times \text{Uncertainty of } O_2 \text{ Measurement} = 0.029$$

$$f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 1.9681 \quad u_{f_{O_2}} = \frac{u_{Corr_{O_2}}}{f_{O_2}} \times 100 = 1.47\%$$

The effect of oxygen on the overall uncertainties (below) is incorporated using the following equation:-

$$u_{combined} = \sqrt{\sum (u_{f_{O_2}})^2 + (\text{Uncertainty of Measurement of Determinand})^2}$$

Where oxygen or moisture correction is required, uncertainty based on the standard error of the measured peripheral value is converted to units of final measurement using a sensitivity coefficient C,

$$\therefore u(x_i) = C_i u_i \text{ where } C_i = \frac{\partial f}{\partial x_i}$$

Uncertainty of Measurement Results - Calculations Part 3

Horiba PG 250 Uncertainty	Date & Time	NOx (as NO2) 0 - 125 mg/m ³	CO 0 - 95 mg/m ³	O ₂ 0 - 25 %Vol	CO ₂ 0 - 20 %Vol
Measured Concentration	10/01/18 16:23 - 17:22	430.48	1061.30	8.08	10.24
Expanded Uncertainty as Percentage of Measured Concentration		11%	18%	4%	2%

$$u_c = \sqrt{u_{lof}^2 + u_{d,s}^2 + u_t^2 + u_{loss}^2 + u_i^2 + u_{ref}^2 + u_{syn}^2}$$

$$\text{Expanded uncertainty (at 95\% confidence)} \quad U_{Exp} = 2 \times u_c$$

- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range as maximum drift per 24hr period
- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range per one degree centigrade
- Where the uncertainty of Moisture is taken as the standard error of the time averaged value used to correct to Dry Conditions
- If no value for uncertainty is presented above, the uncertainty is considered to be > 100%

Environmental Compliance Limited

Potters Waste
Permit No : TP3736SQ
Variation No : ...
Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Engine 2 - Combustion Gases Measurement Uncertainty

Measurement Uncertainty Calculations Part 1

Horiba PG 250 Performance Characteristics	Standard Uncertainty (% of Range)	Distributioun	Minimum Certified Range (R _i)			
			NO 0 - 125 mg/m ³	CO 0 - 95 mg/m ³	O ₂ 0 - 25 %Vol	CO ₂ 0 - 20 %Vol
Lack of fit ⁽¹⁾	U_{lof}	Rectangular (Divisor = $\sqrt{3}$)	0.40	0.40	0.13	0.60
Span drift ⁽²⁾	$U_{d,s}$	Rectangular (Divisor = $\sqrt{3}$)	0.27	0.29	0.029	0.24
Repeatability Standard Deviation (span) ⁽³⁾	U_r	Normal (Divisor = 1)	4.95	23.31	0.42	0.14
Losses / leakage in the sample system ⁽⁴⁾	U_{loss}	Rectangular (Divisor = $\sqrt{3}$)	5.00	9.03	0.080	0.49
Temperature dependant span drift ⁽⁵⁾	U_t	Rectangular (Divisor = $\sqrt{3}$)	0.18	0.050	0.070	0.040
Interferents ⁽¹⁾	U_i	Rectangular (Divisor = $\sqrt{3}$)	1.20	2.90	0.56	0.010
Uncertainty of Reference Gas ⁽⁶⁾	U_{ref}	Rectangular (Divisor = $\sqrt{3}$)	9.12	22.02	0.15	0.31

Note:

$$\text{when } |(x_{i,max} - x_{i,adj})| = |(x_{i,min} - x_{i,adj})|, \text{ then } u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$$

- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range as maximum drift per 24hr period
- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range per one degree centigrade
- Expressed as standard uncertainty in units of measurement i.e. mg/m³ / %Vol inc additional uncertainty of 2% for gas blending
- Data not available so not included

Measurement Uncertainty Calculations Part 2

Horiba PG 250 Performance Characteristics	Uncertainty	Value of Standard Uncertainty	NO 0 - 125 mg/m ³	CO 0 - 95 mg/m ³	O ₂ 0 - 25 %Vol	CO ₂ 0 - 20 %Vol
Lack of fit	U_{lof}	$u(x_i) = \frac{u_{lof} \times R_i}{\sqrt{3}} =$	0.29	0.22	0.019	0.07
Span drift	$U_{d,s}$	$u(x_i) = \frac{u_{d,s} \times R_i}{\sqrt{3}} =$	0.20	0.16	0.0041	0.0280
Repeatability Standard Deviation (span)	U_r	$\sigma = \sqrt{\frac{\sum_{i=1}^n (x_i - \bar{x})^2}{n-1}} =$	4.95	23.31	0.42	0.14
Losses / leakage in the sample system	U_{loss}	$u(x_i) = \frac{u_{loss} \times R_i}{\sqrt{3}} =$	3.61	4.95	0.012	0.06
Temperature dependant span drift	U_t	$u(x_i) = \frac{u_t}{100} \times R_i \times \sqrt{\frac{(x_{i,max} - x_{i,adj})^2 + (x_{i,min} - x_{i,adj})^2 + (x_{i,max} - x_{i,min})^2}{3}}$	0.26	0.055	0.020	0.009
Interferents	U_i	$u(x_i) = \frac{u_i \times R_i}{\sqrt{3}} =$	0.87	1.59	0.081	0.01
Uncertainty of Reference Gas	U_{ref}	$u(x_i) = \frac{u_{ref}}{\sqrt{3}} =$	5.26	12.71	0.086	0.18
Combined Standard Uncertainty		$u_c = \sqrt{u_{lof}^2 + u_{d,s}^2 + u_r^2 + u_{loss}^2 + u_t^2 + u_i^2 + u_{ref}^2}$	8.14	27.05	0.43	0.25
Expanded measurement uncertainty (at 95% confidence)		$U_{EXP} = 2 \times u_c$	16.27	54.11	0.87	0.49
Applied Span Concentration			526.44	1271.25	14.84	17.73
Measured Span Concentration, STP Dry Gas			514.55	1242.48	14.77	17.61
Expanded measurement uncertainty as % of Applied Span			3%	4%	6%	3%

Environmental Compliance Limited

Potters Waste
Permit No
Variation No
Report Ref

: TP3736SQ
: ...
: P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Engine 2 - TVOCs Uncertainty of Measurement

Engine 2 - TVOC - Uncertainty of Measurement Results - Calculations Part 1

Performance Characteristics	Standard Uncertainty (% of Range)	Distribution	Divisor	Min Certified Range	
				O ₂ 0 - 25 %Vol	TVOC 0 - 15 mgC/m ³
Lack of fit ⁽¹⁾	u_{lof}	Rectangular	$\sqrt{3}$	0.13	0.73
Span drift ⁽²⁾	$u_{d,s}$			0.029	0.35
Losses / leakage in the sample system ⁽⁴⁾	u_{loss}			1.00	0.23
Temperature dependant span drift ⁽⁵⁾	u_t			0.070	0.30
Interferents ⁽¹⁾	u_i			0.56	4.39
Effect of Voltage Fluctuation ⁽⁷⁾	u_v			...	1.80
Effect of Oxygen Synergism ⁽⁷⁾	u_{syn}			...	

Notes:

For rectangular distributions, $u(x_i) = \frac{u \times R_i}{\sqrt{3}}$

For $u(x_i) = \Delta x_i \sqrt{\frac{(x_{i,max} - x_{i,adj})^2 + (x_{i,min} - x_{i,adj})^2 + (x_{i,max} - x_{i,adj})^2 + (x_{i,min} - x_{i,adj})^2}{3}}$, when $|x_{i,max} - x_{i,adj}| = |x_{i,min} - x_{i,adj}|$, then $u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$

Where $u(x_i) = \frac{\sigma}{\sqrt{n}}$ (See note 6 below), $\sigma = \sqrt{\frac{\sum_{i=1}^n (x_i - \bar{x})^2}{n-1}}$

Performance Characteristics	Uncertainty (Units of final measurement)	Distribution	Divisor	O ₂ 0 - 25 %Vol	TVOC 0 - 15 mgC/m ³
Lack of fit	u_{lof}	Rectangular	$\sqrt{3}$	0.019	0.064
Span drift	$u_{d,s}$			0.0041	0.031
Temperature dependant span drift	u_t			0.053	0.14
Interferents	u_i			0.081	0.38
Effect of Voltage Fluctuation (See Note)	u_v			...	0.16

Engine 2 - TVOC - Uncertainty of Measurement Results - Calculations Part 2

Performance Characteristics	Uncertainty (Units of final measurement)	Date & Time	O ₂ 0 - 25 %Vol	TVOC 0 - 15 mgC/m ³
Losses / leakage in the sample system	u_{loss}	10/01/18 15:33 - 16:32	0.081	3.73
Standard Error of Measured Value	u_{SE}	10/01/18 15:33 - 16:32	0.0069	13.55

Effect on Uncertainty Caused by Oxygen

$$u_{Corr_{O_2}} = \frac{20.9\% - O_{2,ref}}{(20.9\% - O_{2,measured}) \times (20.9\% - O_{2,measured})} \times \text{Uncertainty of } O_2 \text{ Meas} =$$

0.03

$$f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 1.2377$$

$$u_{f_{O_2}} = \frac{u_{Corr_{O_2}}}{f_{O_2}} \times 100 = 2.34 \%$$

The effect of oxygen on the overall uncertainties (below) is incorporated using the following equation:-

$$u_{combined} = \sqrt{\sum (u_{f_{O_2}})^2 + (\text{Uncertainty of Measurement of Determinand})^2}$$

Where oxygen or moisture correction is required, uncertainty based on the standard error of the measured peripheral value is converted to units of final measurement using a sensitivity coefficient C,

$$\therefore u(x_i) = C_i u_i \text{ where } C_i = \frac{\partial f}{\partial x_i}$$

Engine 2 - TVOC - Uncertainty of Measurement Results - Calculations Part 3

Uncertainty	Date & Time	O ₂ 0 - 25 %Vol	*TVOC 0 - 15 mgC/m ³
Measured Concentration	10/01/18 15:33 - 16:32	8.05	1648.33
Expanded Uncertainty as Percentage of Measured Concentration		3 %	3 %

Combined Standard Uncertainty $u_c = \sqrt{u_{lof}^2 + u_{d,s}^2 + u_{loss}^2 + u_t^2 + u_i^2 + u_{v}^2 + u_{syn}^2}$

Expanded uncertainty (at 95% confidence) $U_{Exp} = 2 \times u_c$

- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range as maximum drift per 24hr period
- Expressed as a percentage of the certified range
- Expressed as a percentage of the applied span concentration
- Expressed as a percentage of the certified range per one degree centigrade
- Where the uncertainty of moisture is taken from the manual extract test calculations.
- Expressed as a percentage of the certified range
- Where no uncertainty is presented above, the uncertainty is > 100%

Environmental Compliance Limited

Potters Waste
Permit No : TP3736SQ
Variation No : ...
Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Engine 2 - TVOCs Measurement Uncertainty

Engine 2 - TVOC - Measurement Uncertainty - Uncertainty Calculations Table 1

Performance Characteristics	Standard Uncertainty (% of Range)	Distribution	Min Certified Ranges
			TVOC 0 - 15 mgC/m ³
Lack of fit ⁽¹⁾	u_{lof}	Rectangular (Divisor = $\sqrt{3}$)	0.73
Span drift ⁽²⁾	$u_{d,s}$	Rectangular (Divisor = $\sqrt{3}$)	0.35
Repeatability Standard Deviation (span) ⁽³⁾	u_r	Normal (Divisor = 1)	82.16
Losses / leakage in the sample system ⁽⁴⁾	u_{loss}	Rectangular (Divisor = $\sqrt{3}$)	13.95
Temperature dependant span drift ⁽⁵⁾	u_t	Rectangular (Divisor = $\sqrt{3}$)	0.30
Interferents ⁽¹⁾	u_i	Rectangular (Divisor = $\sqrt{3}$)	4.39
Uncertainty of Reference Gas ⁽⁶⁾	u_{ref}	Rectangular (Divisor = $\sqrt{3}$)	25.74
Effect of Voltage Fluctuation ⁽⁷⁾	u_v	Rectangular (Divisor = $\sqrt{3}$)	1.80
Effect of Oxygen Synergism ⁽⁷⁾	u_{syn}	Rectangular (Divisor = $\sqrt{3}$)	4.60

Note:

$$\text{when } |(x_{i,max} - x_{i,adj})| = |(x_{i,min} - x_{i,adj})|, \text{ then } u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$$

- Expressed as a percentage of the certified range
- Expressed as maximum drift per 24hr period as percentage of the certified range
- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range per one degree centigrade
- Expressed as standard uncertainty in units of measurement i.e. mg/m³ / %Vol taking account of an additional uncertainty of 2% for gas blending
- Expressed as a percentage of the certified range

Engine 2 - TVOC - Measurement Uncertainty - Uncertainty Calculations Table 2

Performance Characteristics	Uncertainty	Value of Standard Uncertainty	*TVOC 0 - 15 mgC/m ³
Lack of fit	u_{lof}	$u(x_i) = \frac{u_{lof} \times R_i}{\sqrt{3}} =$	0.064
Span drift	$u_{d,s}$	$u(x_i) = \frac{u_{d,s} \times R_i}{\sqrt{3}} =$	0.031
Repeatability Standard Deviation (span)	u_r	$\sigma = \sqrt{\frac{\sum_{i=1}^n (x_i - \bar{x})^2}{n-1}} =$	12.32
Losses / leakage in the sample system	u_{loss}	$u(x_i) = \frac{u_{loss} \times R_i}{\sqrt{3}} =$	1.21
Temperature dependant span drift	u_t	$u(x_i) = \frac{u_t}{100} \times R_i \times \sqrt{\frac{(x_{i,max} - x_{i,adj})^2 + (x_{i,min} - x_{i,adj})^2 + (x_{i,max} - x_{i,min})^2}{3}}$	0.052
Interferents	u_i	$u(x_i) = \frac{u_i \times R_i}{\sqrt{3}} =$	0.38
Uncertainty of Reference Gas	u_{ref}	$u(x_i) = \frac{u_{ref}}{\sqrt{3}} =$	14.86
Effect of Voltage Fluctuation	u_v	$u(x_i) = \frac{u_v \times R_i}{\sqrt{3}} =$	0.16
Effect of Oxygen Synergism	u_{syn}	$u(x_i) = \frac{u_{syn} \times R_i}{\sqrt{3}} =$	0.40
Combined Standard Uncertainty		$u_c = \sqrt{u_{lof}^2 + u_{d,s}^2 + u_r^2 + u_{loss}^2 + u_t^2 + u_i^2 + u_{ref}^2}$	19.35
Expanded measurement uncertainty (at 95% confidence)		$U_{EXP} = 2 \times u_c$	38.71
Applied Span Concentration			1486.15
Measured Span Concentration, STP Dry Gas			1480.90
Expanded measurement uncertainty as % of Applied Span			3 %

* Signal 3030 FID

Environmental Compliance Limited

Potters Waste
Permit No
Variation No
Report Ref

: TP3736SQ
: ...
: P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Engine 2 - SO2 Uncertainty

Site: Brynposteg
Location: Engine 2

$$u_{\text{mass}} = \sqrt{\sum (u_{\text{filter}})^2 + (u_{\text{solution}})^2}$$

Determinand	Filter mg	Solution mg	Recovered Mass mg	LAB Method Filter mg	Uncert (%) K=2 Solution mg	Standard Uncertainty Filter mg	Solution mg	Combined Uncertainty mg
One - SO2								
...
...
Sulphur Dioxide	...	24.84	24.84	...	3.23	...	1.61	1.61
...
...
...
...

One - SO2			Standard Uncertainty @ 95%		
Sampled Volume (V _m)	0.37	m ³	uV _m	0.001	m ³
Meter Correction Factor (Y _d)	0.97
Meter Temperature (T _m)	283.50	k	uT _m	1.5	k
Average Differential Pressure (ΔH)	3.00	mmH ₂ O	uΔH	0.25	mmH ₂ O
Barometric Pressure (p _b)	723.06	mmHg	u _{p_b}	3.8	mmHg
ΔH + p _s (p _m)	96.43	kPa
Oxygen content (O _{2,m})	8.07	% by volume	uO _{2,m} = σ/√n	0.00823	% by volume
Moisture Content (H ₂ O)	10.31	% by volume	uH ₂ O	0.50	% by volume

Note: In the following calculations, the sensitivity coefficient (C) is estimated using:

$$C_i = \frac{\partial f}{\partial x_i}$$

For each factor, uncertainty is then calculated by $C_i u_i$ where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. $i = uV_m, uT_m$ etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

One - SO2 :

$$f_{s, \text{wet}} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured ΔH uncertainty component (uΔH), measured stack pressure uncertainty component (u_p) & measured temperature of dry gas uncertainty component (uT_{m Dry})

One - SO2 :

$$f_s = \frac{273}{760} \times \frac{P_b + \frac{\Delta H}{13.6}}{T_m} \times Y_d = 0.893$$

	Maximum	Minimum	Sensitivity	u _{STP}
uΔH	0.89	0.89	0.0000908	0.0000227
u _{p_b}	0.90	0.89	0.00123	0.00463
uT _m	0.90	0.89	0.00315	0.00473
H ₂ O

$$\frac{u f_s}{f_s} = \sqrt{\left(\frac{\sqrt{(u\Delta H)^2 + (uP_b)^2}}{(P_m/101.3)} \right)^2 + \left(\frac{uT_m}{(T_m/273.15)} \right)^2 + \left(\frac{uH_2O}{(100/(100 - H_2O))} \right)^2} = 0.00595$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV_{std}) & volume uncertainty component (uV_m)

One - SO2 :

$$V_{std} = V_{measured} \times f_s = 0.328$$

	Maximum m ³	Minimum m ³	Sensitivity	Standard Uncertainty (m ³)
Effect of uV _{std}	0.33	0.33	0.37	0.00219
Effect of uV _m	0.33	0.33	0.89	0.000893

Combined Standard Uncertainty

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uV_{std}}{f_s} \right)^2 + \left(\frac{uV_m}{V_m} \right)^2} = 0.00113$$

Uncertainty of Oxygen Correction Factor (%):-

One - SO2 :

$$f_{O_2} = \frac{20.9\% - O_{2, \text{ref}}}{20.9\% - O_{2, \text{measured}}} = 1.24$$

$$u_{\text{Corr } O_2} = \frac{20.9\% - O_{2, \text{ref}}}{(20.9\% - O_{2, \text{measured}}) \times (20.9\% - O_{2, \text{measured}})} \times \text{Uncertainty of } O_2 \text{ Measurement} = 0.0290$$

$$u f_{O_2} = \frac{u_{\text{Corr } O_2}}{f_{O_2}} \times 100 = 2.34 \%$$

Environmental Compliance Limited

Potters Waste
Permit No : TP3736SQ
Variation No : ...
Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Uncertainty in final measurement @ reference conditions due to mass uncertainty component (uM)

Determinand	one:			
	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	uM mg/Nm ³
...
...
Sulphur Dioxide	99.81	87.63	3.77	6.09
...

Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

Determinand	one:	
	uL mg/Nm ³	
...	...	
...	...	
Sulphur Dioxide	1.08	
...	...	

Uncertainty in final measurement @ Reference Conditions due to uVstp

Determinand	one:			
	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	uVstp mg/Nm ³
...
...
Sulphur Dioxide	94.04	93.40	285.76	0.32
...

Combined Uncertainty excluding oxygen contribution

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (u_{V_{stp}})^2}$$

Determinand	one:			
	Combined Uncertainty mg/Nm ³	Expanded Uncertainty mg/Nm ³	Measured Concentration mg/Nm ³	Percent of Measured Concentration
...
...
Sulphur Dioxide	6.20	12.39	93.72	13.22
...

Combined Uncertainty including oxygen contribution

$$u_{combined} = \sqrt{\sum (u_{f_{O_2}})^2 + (Uncertainty\ of\ Measurement\ of\ Determinand)^2}$$

Determinand	Measurement Uncertainty of Determinand	Measurement Uncertainty of Oxygen Corr'n Factor	Overall Measurement Uncertainty inc O ₂ Corr'n factor (Uncorrected)
...
...
Sulphur Dioxide	13.22	2.33	13.43
...

Environmental Compliance Limited

Potters Waste		Installation Name	: Engine 1 & 2
Permit No	: TP3736SQ	Visit Details	: Annual Compliance
Variation No	: ...	Survey Dates	: 10th & 11th January 2018
Report Ref	: P3334 : R001	Report Issue Date	: 31st January 2018

Engine 2 - Non-methane TVOCs Uncertainty

Site: Potters Waste, Brynposteg
Location: Landfill, Stack ID:Engine 2

				Standard Uncertainty @ 95%		
Sampled Volume	V_m	0.10176	m^3	uV_m	0.000	m^3
Meter Correction Factor or ml/count	Y_d	0.9746
Meter Temperature	T_m	283.17	K	uT_m	1.5	K
Barometric Pressure	p_b	964.00	$mBar$		10.0	$mBar$
Oxygen content	$O_{2,m}$	8.10	%Vol	$uO_{2,m}$	0.49	%Vol
Moisture	H_2O	4.21	%Vol	uH_2O	0.89	%Vol

Tubes		
Determinand	Recovered Mass	Standard Uncertainty
Engine 2	15.00 μg	uM 1.50 μg

Environmental Compliance Limited

Potters Waste		Installation Name	: Engine 1 & 2
Permit No	: TP3736SQ	Visit Details	: Annual Compliance
Variation No	: ...	Survey Dates	: 10th & 11th January 2018
Report Ref	: P3334 : R001	Report Issue Date	: 31st January 2018

Note: In the following calculations, the sensitivity coefficient (C) is estimated using: $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by $C_i u_i$ where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. $i = uV_m, uT_m$ etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from dry to wet:

$$f_{s, wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (uP_b), measured temperature of dry gas uncertainty component (uT_m) & measured moisture (uH_2O) where required

$$f_s = \frac{273}{T_m} \times \frac{P}{101.3} = 0.92$$

	Maximum	Minimum	Sensitivity	uf_{stp}
uP_b	0.47	0.46	0.000485	0.00485
uT_m	0.92	0.91	0.00324	0.00486
uH_2O

$$\frac{uf_s}{f_s} = \sqrt{\left(\frac{uP_b}{(P_b/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{(100/(100 - H_2O))}\right)^2} = 0.00635$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV_{std}) & volume uncertainty component (uV_m)

$$V_{std} = V_{measured} \times f_s = 0.0910$$

	Maximum m^3	Minimum m^3	Sensitivity	Standard Uncertainty m^3
Effect of uf_s	0.0916	0.0904	0.0992	0.000630
Effect of uV_m	0.0910	0.0910	0.89	8.942E-06

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uf_s}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.00902$$

Uncertainty of correction factor to reference conditions (excluding oxygen contribution) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

$$uL = \frac{Conc \times \frac{2}{100}}{\sqrt{3}}$$

	Tubes uL mg/Nm^3	Condensate uL mg/Nm^3
Engine 2	0.00190	...

Environmental Compliance Limited

Potters Waste
Permit No : TP3736SQ
Variation No : ...
Report Ref : P3334 : R001

Installation Name : Engine 1 & 2
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

$$Conc = \frac{M_{Recovered}}{V_m \times f_s \times f_{O_2}}$$

Uncertainty in final measurement @ Reference Conditions due to $uM_{Recovered}$

Charcoal Tube Results				
	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	Standard Uncertainty mg/Nm ³
Non Methane VOC	0.17	0.16	10.99	0.00824
Condensate Results				
	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	Standard Uncertainty mg/Nm ³
Non Methane VOC				

Uncertainty in final measurement @ Reference Conditions due to uV_{STD}

Charcoal Tube Results				
	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	Standard Uncertainty mg/Nm ³
Non Methane VOC	0.18	0.15	1.83	0.0165

Combined Uncertainty (excluding Oxygen contribution)

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (uV_{stp})^2}$$

Charcoal Tubes: Determinand	Combined Uncertainty mg/Nm ³	Expanded Uncertainty mg/Nm ³	Measured Concentration mg/Nm ³	Percent of Measured Concentration
Non Methane VOC	0.0186	0.0371	0.20	18.15

EMISSIONS MONITORING SURVEY

Prepared for:


**Potters Waste
Brynposteg Landfill Site
Llandidloes
SY18 6JJ**

Permit Number	: BU7766IC
Variation Number	: EPR/BU7766IC/V004
Installation	: Flare Stack
Visit Details	: Annual Compliance
Job Number	: P3334
Report Number	: R002
Report Issue Date	: 31st January 2018
Survey Dates	: 10th & 11th January 2018

Prepared by:

Environmental Compliance Limited

Unit G1
Main Avenue
Treforest Industrial Estate
Pontypridd
CF37 5BF.
Tel: 01443 841760
Fax: 01443 841761

Report Issue:		FINAL	
Report Prepared by:		Report Reviewed & Approved by MCERTS Level Two Technical Endorsements TE1, TE2, TE3 & TE4	
Name:	Mike Mullett	Name:	Sam Brookes
		MCERTS No:	MM 06 755
		Signature:	
Date:	29/01/2018	Date:	31/01/2018

This report is not to be used for contractual or engineering purposes unless this approval sheet is signed where indicated by the approver and the report is designated "FINAL".



Environmental Compliance Limited

Potters Waste		Installation Name	: Flare Stack
Permit No	: BU77661C	Visit Details	: Annual Compliance
Variation No	: EPR/BU77661C/V004	Survey Dates	: 10th & 11th January 2018
Report Ref	: P3334 : R002	Report Issue Date	: 31st January 2018

This report has been prepared by Environmental Compliance Limited (ECL) in their professional capacity as Environmental Consultants. The contents of the report reflect the conditions that prevailed and the information available or supplied at the time of its preparation. The report, and the information contained therein, is provided by ECL solely for use and reliance by the Client in performance of ECL's duties and liabilities under its contract with the Client. Until ECL has received payment in full as detailed in the quotation or contract the contents of this report remain the legal property of ECL. The contents of the report do not, in any way, purport to include any manner of legal advice or opinion.

This report should not be reproduced, (except in full) without the written approval of the laboratory.

Should the Client wish to release this report to a Third Party for the party's reliance, Environmental Compliance Ltd may, at its discretion, agree to such release provided that:

- Environmental Compliance Ltd gives written agreement prior to such release and ECL has received payment in full for all works/services undertaken;
- By release of the report to the Third Party, that Third Party does not acquire any rights, contractual or otherwise, whatsoever against Environmental Compliance Ltd and, accordingly, Environmental Compliance Ltd assume no duties, liabilities or obligations to that Third Party;
- Environmental Compliance Ltd accepts no responsibility for any loss or damage incurred by the Client or for any conflict of Environmental Compliance Ltd interests arising out of the Clients' release of this report to the Third Party.

In the event that a report is revised and re-issued, the client shall ensure that any earlier versions of the report, and any copies thereof, are void and such copies should be marked with the words "superseded and revised".

Opinions and Interpretation expressed within this report are outside the scope of the UKAS accreditation.

MCERTS requirements mean that comparison of results with emissions limit values is not permitted within this report.

Potters Waste
 Permit No : BU77661C
 Variation No : EPR/BU77661C/V004
 Report Ref : P3334 : R002

Installation Name : Flare Stack
 Visit Details : Annual Compliance
 Survey Dates : 10th & 11th January 2018
 Report Issue Date : 31st January 2018

TABLE OF CONTENTS

Section	Description	Page Number
	Document Control Sheet	
PART 1	EXECUTIVE SUMMARY	4
1	MONITORING OBJECTIVES	4
1.1	Monitoring Results	5
1.2	Operating Information	6
2	MONITORING DEVIATIONS	7
PART 2	SUPPORTING INFORMATION	8
3	SAMPLING STAFF DETAILS	8
4	SAMPLING PROTOCOLS / METHODOLOGIES	9
5	SAMPLE POINT DESCRIPTIONS	13
	EQUIPMENT IDs	14
	FIGURES	16
	TABLES	18
	VELOCITY TRAVERSE PROFILES	22
	FIELD CALIBRATION AND SAMPLING DATA	24
	LABORATORY ANALYSIS RESULTS	29
	UNCERTAINTY CALCULATIONS	34

PART 1 - EXECUTIVE SUMMARY

1 Monitoring Objectives

Environmental Compliance Ltd (ECL) was commissioned by **Potters Waste** to undertake an emission monitoring survey at their **Brynposteg Landfill site**. This report presents the findings of the study.

The monitoring at this installation was carried out in accordance with our quotation reference **DHFB/P3334/Q001**, for compliance check monitoring of emissions to air. The substances requested for monitoring at each emissions point are listed below:

Substances to be monitored	Emission Point Identification
	Ref No:
	Flare Stack
Velocity / Flowrate	● U
Oxides of Nitrogen (as NO ₂)	● U
Sulphur Dioxide	● U
Carbon Monoxide	● U
Oxygen	● U
Carbon Dioxide	● U
Total Organic Carbon (TVOC)	● U
Non-methane VOCs	● U

- Denotes the substances to be monitored.

U

Denotes UKAS accreditation is held for monitoring that substance, but does not mean that it has been claimed which will depend on whether the testing could be completed in accordance with the Standard Reference Method.

Special Requirements: "Normal operating conditions"

Environmental Compliance Limited

Potters Waste
Permit No : BU7766IC
Variation No : EPR/BU7766IC/V004
Report Ref : P3334 : R002

Installation Name : Flare Stack
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

1.1 Monitoring Results

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty %	Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation for use of Method	Tick if non-conforming test (see Sections 2 & 5)	Operating Status
Flare Stack	Volumetric Flowrate	...	36.16668	m³/sec	17	Stack Conditions	11/01/2018	10:35 – 10:46	BS EN 16911-1:2013 & MID	UKAS / MCERTS	✓	Normal
	Volumetric Flowrate	...	4.74322	m³/sec	23	STP Dry 3% O₂		13:38 – 14:37	BS EN 12619:2013	UKAS / MCERTS	✓	
	TVOC as Carbon	10	4.60	mgC/m³	5			13:54 – 14:53	BS EN 14792: 2017	UKAS / MCERTS		
	Oxides of Nitrogen (as NO₂)	150	78.19	mg/m³	2				BS EN 15058: 2017	UKAS / MCERTS		
	Carbon Monoxide	50	49.12	mg/m³	3				BS EN 14789: 2017	UKAS / MCERTS		
	Oxygen (Testo)	...	9.87	%	6	Dry			ISO 12039:2001	UKAS / MCERTS		
	Carbon Dioxide (Horiba)	...	8.67	%	3			BS 14791:2017	UKAS / MCERTS	✓		
	Sulphur Dioxide	...	2.81	mg/m³	13	STP Dry 3% O₂		13:12 – 14:12	BS 14791:2017	UKAS / MCERTS	✓	
	Non-methane VOCs	5	0.092	mg/m³	10			14:24 – 15:24	CEN/TS 13649:2014	NU	✓	

Notes

The volumetric flowrate shown above is that from the initial pitot traverse.

Any other flow measurements made during isokinetic sampling and/ or repeat traverses are shown later in the tables section.

The uncertainty figures presented in Table 1.1 for NO_x, CO, O₂, CO₂ & TVOC are “measurement uncertainty” figures, which do not take into account the variability of the measured sample values. The “uncertainty of measurement results” figures, which do include this contribution, are presented in the appendices of the report for these determinands.

Emission Limit Value
Periodic Monitoring Result
Uncertainty
Reference Conditions
Monitoring Method Reference
Accreditation for use of Method
Operating Status

The emission limit value is that stated in the permit and will be expressed as a concentration or a mass emission.
The result given is expressed in the same terms and units as the emission limit value.
The uncertainty associated with the quoted result is at the 95% confidence interval. The Uncertainty results **DO NOT** take into account the effect of the sample location limitations.
All results are expressed at 273 K and 101.3kPa. The oxygen and moisture corrections are stated.
The method stated is in accordance with the Environment Agency Technical Guidance Note M2, or other method approved by the Environment Agency.
The details indicate the accreditation for the use of the complete monitoring method, e.g. MCERTs, UKAS. If use of the method is not accredited “NA” is stated.
The details indicate the feedstock and the loading rate of the plant during monitoring.
Chemical Analysis on sample reagents was performed by an External Laboratory as detailed in Section 4
UKAS Accreditation Held but UKAS Accreditation cannot be claimed for the test as sampling did not comply with the Standard Reference Method (SRM), see section 2 & 5
Method is NOT UKAS Accredited.

NU
NA

Environmental Compliance Limited

Potters Waste
Permit No : BU7766IC
Variation No : EPR/BU7766IC/V004
Report Ref : P3334 : R002

Installation Name : Flare Stack
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

1.2 Operating Information

Emission Point Reference	Process Type	Process Duration	Fuel	Feedstock	Abatement	Load	Comparison of Operator CEMS and Periodic Monitoring Results					
							Parameter	Date	Time	CEMS Results	Periodic Monitoring Results	Units
Flare Stack	Batch	N/A	Gas	Landfill Gas	None	Normal	NP

Notes:

Process Type State whether the process is a continuous or batch process.
Process Duration If a batch process, state the duration, frequency and details of the portion of the batch sampled. If continuous state "NA"
Fuel If applicable, state the fuel type If not applicable state "NA"
Feedstock State the feedstock type
Abatement State the type and whether operational during monitoring. If not applicable state "NA"
Load State the normal load, throughput or rating of the plant
CEMS Data Enter this data for each CEM installed if it is has been provided by operator otherwise state "NP" (NOT PROVIDED)

2 Monitoring Deviations

The objective of the survey was to measure the concentrations of pollutants from the processes / locations as detailed in Section 1. This survey meets the requirements of the site's **PPC Permit Number: BU77661C** where UKAS and MCERTS accreditation has and could be claimed for the testing in the monitoring results table.

There was a modification to the sampling procedures (TPDs) listed in Section 4:

- **Non Methane VOC** – ECL/TPD/84 is specifically for the monitoring of dry ambient gas. Testing of the flare stack required the modification of the TPD, to cool and dry the sample gas prior to passing it through the capture media (sorbent tube). Due to the high stack temperature, and the modifications required to facilitate sampling, UKAS accreditation has not been claimed for Non-Methane VOCs.

There were no substance deviation from the original and agreed emissions monitoring schedule.

Non-conforming tests are as follows:

- Due to Health & Safety restrictions only a single sampling point was traversed, see also Section 5. Due to the high stack temperatures and the limited access, it was not possible to fully traverse the duct. Consequently, all flowrate measurements are non-conforming.
- Impinger collection efficiency is less than 95% for the Sulphur Dioxide tests. However, please note that there is no ELV in place. If an ELV of 50mg/m³ is used (the same as CO) then the concentration is less than 30% of the ELV and the impinger collection efficiency is not applicable.

The Uncertainty of the reported concentrations for these pollutant results DOES NOT take into account the effect of non-conformities or sample location limitations.

Homogeneity tests have not been completed for pollutants at the following locations:

- Flare stack – Not requested by client

Potters Waste
Permit No
Variation No
Report Ref

: BU77661C
: EPR/BU77661C/V004
: P3334 : R002

Installation Name : Flare Stack
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

PART 2 – SUPPORTING INFORMATION

3 SAMPLING STAFF DETAILS

Site Sampling Team

Names of Site Team	Dates on Site	MCERTS No.	LEVEL	Technical Endorsements
Sam Brookes	10-11/01/2018	MM 06 775	2	TE1, TE2, TE3, TE4
Peter Brockway		MM 17 1459	Trainee	...

Report Reviewer

Name	MCERTS No.	LEVEL	Technical Endorsements
Sam Brookes	MM 06 775	2	TE1, TE2, TE3, TE4

Technical Endorsement Key:-

TE1 – Isokinetic Particulates, Temperature & Velocity Profiles, Oxygen.
TE2 – Isokinetic Extractive Pollutants:- Metals, Dioxin & Furans, PAHs, PCBs, HCl, HF.
TE3 – Non-Isokinetic Extractive Pollutants:- Speciated VOCs, HF, HCl, Cyanide.
TE4 – Continuous Analysers (Combustion Gases):- TVOC, CO, NO_x, SO₂.

4 SAMPLING PROTOCOLS / METHODOLOGIES

Any required modifications to the Technical Procedure Documents (TPDs) specified below will be detailed in section 2 of this report.

Stand alone velocity measurements and those made to support isokinetic sampling are conducted using BS EN 16911-1:2013 & MID.

Pressure, Temperature and Velocity

Testing was carried out using a sampling system in accordance with BS EN ISO 16911-1:2013 & MID and In-house technical procedure ECL/TPD/022A.

Temperature was recorded using a thermocouple and digital temperature reader.

Velocity and pressure were recorded using an "L" type and digital manometer, data being recorded in Pascals.

Water Vapour

Testing was carried out using a Universal Stack Sampling system in accordance with BS EN 14790:2017 and In-house technical procedure ECL/TPD/082.

In this method the stack gases are filtered (in-stack unheated filter or out-stack heated filter) to remove particulate matter. The gases are then passed through a **heated probe** and then to a cooled moisture trapping unit. All unheated parts of the sample train (outside the sample port) which come into contact with stack gas are weighed pre and post sampling in order to determine the weight gain.

After each test, a visual inspection of the last impinger is made to confirm that at least 50% of the silica gel column has not changed colour. This indicates satisfactory collection of water vapour.

Potters Waste
Permit No
Variation No
Report Ref

: BU77661C
: EPR/BU77661C/V004
: P3334 : R002

Installation Name : Flare Stack
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Combustion Gases (NO_x, CO & CO₂)

Measurements of combustion gases were carried out using an MCERTS Certified **Horiba PG 250** stack gas analyser. Continuous monitoring of emissions was undertaken over each test period recording minute averaged data (one measurement every 60 seconds). The measurement techniques for each determinand are as follows:

<u>Determinand</u>	<u>Technique</u>	<u>SRM</u>
• NO _x	Chemiluminescence	BS EN 14792: 2017
• CO	Non-dispersive infrared	BS EN 15058: 2017
• CO ₂	Non-dispersive infrared	ISO 12039:2001

The analyser was set up with reference to the manufacturer's operator handbook and the in-house technical procedure **ECL/TPD/033c**. The analyser was calibrated on site using certified gases which are traceable to ISO 17025 (with uncertainty < 2%). Zero measurements were performed using Nitrogen. The analyser was calibrated directly into the sample inlet and then checked through the entire sampling system (including sampling probe, heated & unheated gas transport lines and gas drying/ conditioning system).

Data is presented graphically in the Figures Section, and the minute averaged data is given in the Tables Section.

Oxygen

Measurements of Oxygen were carried out using a Testo 350XL electrochemical cell combustion gas analyser which has been validated to meet the performance requirements of **BS EN 14789:2017**. Continuous monitoring of emissions was undertaken over each test period recording minute averaged data.

The analyser was set up with reference to the manufacturer's operator handbook and the in-house technical procedure **ECL/TPD/086**. The analyser was calibrated on-site using certified gases which are traceable to ISO 17025 (with uncertainty < 2%). (for emissions streams where oxygen is above 15%, dry ambient air can be used to calibrate the analyser). Zero measurements were performed using Nitrogen. The analyser was calibrated directly into the sample inlet (which is up-stream of the built-in chiller system) and then checked through the entire sampling system (including sampling probe, short heated/ unheated gas transport lines and external gas conditioning systems as required).

Potters Waste
Permit No
Variation No
Report Ref

: BU77661C
: EPR/BU77661C/V004
: P3334 : R002

Installation Name : Flare Stack
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

TVOC as Carbon

Testing was carried out using an MCERTS Certified Signal 3030PM FID and heated gas sample line, with reference to the manufacturer's operation handbook, **BS EN 12619:2013** and in-house technical procedure **ECL/TPD/032A**.

The analyser was calibrated on site using certified propane span gases, (made up in synthetic air) which are traceable to ISO 17025 standard (with uncertainty < 2%).

Zero measurements were performed using synthetic air zero gas, with TVOC content less than 0.2 mg/m³ (or purity greater than 99.998%).

The analyser was calibrated directly into the sample inlet and then checked through the entire sampling system (including sampling probe, heated filter and heated gas transport lines). Data was corrected by molecular weight to TVOCs as total carbon.

Data was recorded as minute averages over each test period. The data is presented in the Figures Section and the minute averaged data is detailed in the Tables Section.

Sulphur Dioxide

Testing was carried out non-isokinetically using a Universal Stack Sampling system in accordance with **BS EN 14791:2017** and In-house technical procedure **ECL/TPD/039**. Non-isokinetic sampling can only take place if there are no droplets present in the stack gas.

In this method the stack gases are filtered to remove particulate matter then the gases are passed through a series of impingers. The first three impingers each contain 140ml of 3% Hydrogen Peroxide (3% H₂O₂). The fourth impinger is left empty and the final impinger contains a measured quantity of silica gel.

The first three impingers containing the 3% Hydrogen Peroxide are analysed for concentrations of Sulphur Dioxide by IC (Ion Chromatography).

Concept Life Sciences Ltd (CLS) who are situated in Manchester carried out the analysis of the samples. **CLS** is UKAS accredited for this analysis. In addition to the survey samples, appropriate field blanks and efficiency checks are submitted as part of the technical procedure.

Potters Waste
Permit No
Variation No
Report Ref

: BU77661C
: EPR/BU77661C/V004
: P3334 : R002

Installation Name : Flare Stack
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Non-methane VOCs

Non-continuous sampling for **Non-methane VOCs** was carried out in accordance with **CEN/TS 13649:2014** and In-house technical procedure **ECL/TPD/084**. In this method a metered volume of stack gas is extracted through a standard charcoal sorbent tube/ thermal desorption tube.

Concept Life Sciences Ltd (CLS) who are situated in Manchester carried out the analysis of the samples. **CLS are not UKAS** accredited for this analysis. In addition to the survey samples, appropriate field blanks and efficiency checks are submitted as part of the technical procedure.

Due to restrictions set out in CEN/TS 13649:2014, MCERTS/UKAS accreditation can only be claimed when the target parameters are organic compounds, the sorbent tube used is a standard charcoal tube/ thermal desorption tube and when laboratory analysis is UKAS accredited and carried out by GC. If other tubes are used, or if analysis is by other means than GC, then usually only UKAS accreditation can be claimed, as long as the laboratory analysis is UKAS accredited. (MCERTS accreditation may still be claimed if prior approval is given for the modifications by the Environment Agency – details will be given in section 2 of this report).

Laboratory analysis **cannot** be UKAS accredited for “Total VOC” or “TOP 10 compounds”.

For the subcontract laboratory to claim UKAS accreditation for analysis, the internal recovery of a spiking compound (desorption efficiency from tube) needs to be above 80%. If it falls below 80% this will be noted on the analysis certificate.

If greater than 5% of the total amount of any of the target species is found in the back up portion of the sorbent tube, this will be noted on the analysis certificate.

5 SAMPLE POINT DESCRIPTIONS

The homogeneity test is applicable to combustion processes. This includes but is not restricted to, those regulated under the Waste Incineration Directive (**WID**) and the Large Combustion Plant Directive (**LCPD**).

Homogeneity testing has not been completed at this location in accordance with the mandatory requirements of the regulatory authority.

The test is not usually required for stacks with sampling plane areas of $< 1\text{m}^2$ (below 1.13m in diameter for circular ducts).

The sample location that was monitored is detailed below:-

Flare Stack

As a result of the sampling point being located in close proximity to the exit of the stack the sampling location does not currently meet the requirements detailed in *Technical Guidance Note (Monitoring) M1 "Sampling requirements for stack-emission monitoring"* Environment Agency, January 2007, Version 4.1, and BS EN 13284-1 but there is no alternative sampling location.

In addition, due to health and safety considerations, the flare was turned off in order to set up equipment and then turned back on again after the probe had been inserted into the stack and the monitoring team had descended from the sampling platform.

The stack diameter is 2.3m and sampling was performed using one of the four 4-inch flange ports located close to the exit of the stack.

These ports are positioned at a height of 0.3m above the scaffold platform and the distance back from the port is 1m.

Access to the stack was gained by means of three temporary ladders secured to the side of temporary scaffolding complete with an in-date scaffold tag.

Due to Health & Safety restrictions only a single sampling point was traversed, see also Section 5. Due to the high stack temperatures and the limited access, it was not possible to fully traverse the duct. Furthermore, the velocity that was measured at a single point in the duct was near to the lower limit of detection. Consequently, all flowrate measurements are non-conforming.

The Uncertainty of the reported concentrations for these pollutant results DOES NOT take into account the effect of non-conformities or sample location limitations.

Environmental Compliance Limited

Potters Waste

Permit No

: BU77661C

Variation No

: EPR/BU77661C/V004

Report Ref

: P3334 : R002

Installation Name

: Flare Stack

Visit Details

: Annual Compliance

Survey Dates

: 10th & 11th January 2018

Report Issue Date

: 31st January 2018

**EQUIPMENT IDs
(Pre site checklist from SSP)**

Potters Waste
 Permit No : BU77661C
 Variation No : EPR/BU77661C/V004
 Report Ref : P3334 : R002

Installation Name : Flare Stack
 Visit Details : Annual Compliance
 Survey Dates : 10th & 11th January 2018
 Report Issue Date : 31st January 2018

PRE SITE EQUIPMENT CHECKLIST/ EQUIPMENT USED

(Completed before departure to site and when on site in full)

Equipment	Equip. Type	ID No:	ID No:	ID No:	ID No:	ID No:	ID No:	ID No:	ID No:
MST console/pump	E001	U001							
MST Nozzle set									
MST "S" Type Pitot									
MST Probe									
MST Hot Box		978							
MST Impinger Arm		401							
		660							
Barometer		627							
Site Balance		088							
Site Check weights		276							
		277							
Horiba	E002	511							
Heated Probe / Filter		920							
Chiller		972							
Sonimix / MFC									
Heated Line		1013	1014						
FID	E003	269							
Heated Line		517	518						
Heated Probe / Filter		919							
Testo	E004	350							
FTIR	E005								
Heated Probe / Filter									
Heated Line									
Stackmite	E006								
"L" Type Pitot		489							
Digital Manometer		421							
Stack Thermocouple		866							
Thermocouple Reader		1112							
Nozzle Set									
Workhorse Pumps	E007								
Low Flow Pumps									
Tube Thermocouple		1041							

Quantity of Ice Required / Used for Survey	6	Bags (2kg bags)
--	---	-----------------

Environmental Compliance Limited

Potters Waste		Installation Name	: Flare Stack
Permit No	: BU77661C	Visit Details	: Annual Compliance
Variation No	: EPR/BU77661C/V004	Survey Dates	: 10th & 11th January 2018
Report Ref	: P3334 : R002	Report Issue Date	: 31st January 2018

FIGURES

Potters Waste
Permit No
Variation No
Report Ref

: BU77661C
: EPR/BU77661C/V004
: P3334 : R002

Installation Name : Flare Stack
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Figure 1 – Flare Stack Combustion Gases





Figure 2 – Flare Stack TVOCs



Environmental Compliance Limited

Potters Waste		Installation Name	: Flare Stack
Permit No	: BU77661C	Visit Details	: Annual Compliance
Variation No	: EPR/BU77661C/V004	Survey Dates	: 10th & 11th January 2018
Report Ref	: P3334 : R002	Report Issue Date	: 31st January 2018

TABLES

Potters Waste
 Permit No : BU77661C
 Variation No : EPR/BU77661C/V004
 Report Ref : P3334 : R002

Installation Name : Flare Stack
 Visit Details : Annual Compliance
 Survey Dates : 10th & 11th January 2018
 Report Issue Date : 31st January 2018

Table 1 – TVOC
Data Recorded from Flare Stack
Sample Period: 13:38 – 14:47 on the 11th January 2018

Volumetric Flowrate (Reference Conditions) = 4.74322 m³/sec *

	Average	Emission Rate
	mg/m ³	Kg/hr
TVOC (as carbon)*	4.60	0.0785

* Reference Conditions (273K, 101.3 kPa, 3% Oxygen & Dry Gas)

Table 2 – Combustion Gases
Data Recorded from Flare Stack
Sample Period: 13:54 – 14:53 on the 11th January 2018

Volumetric Flowrate (Reference Conditions) = 4.74322 m³/sec *

	Average	Emission Rate
	mg/m ³	Kg/hr
Oxides of Nitrogen (as NO₂) *	78.19	1.335
Carbon Monoxide *	49.12	0.839
Carbon Dioxide (%) **	8.67	...
Oxygen (%) **	9.87	...

* Reference Conditions (273K, 101.3 kPa, 3% Oxygen & Dry Gas)

** Dry Gas

Environmental Compliance Limited

Potters Waste
Permit No
Variation No
Report Ref

: BU77661C
: EPR/BU77661C/V004
: P3334 : R002

Installation Name : Flare Stack
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Table 3 – SO₂

Data Recorded from Flare - Landfill

Emission Parameter	Units	One	Blank
Stack Diameter	metres	2.30	
Area of Sample Plane	m ²	4.155	
Moisture Content	%	7.55	
Oxygen Content	%	9.40	
Stack Temperature	°C	930	
Gas Velocity (as Measured)	m/sec	8.66	
Gas Velocity (Reference Conditions)	m/sec*	1.14	
Volumetric Flowrate (as Measured)	m ³ /sec	35.99	
Volumetric Flowrate (Reference Conditions)	m ³ /sec*	4.72	
Dry Gas Molecular Weight	g/gmole	29.82680874	
Sample Date	...	11/01/2018	
Sample Period	...	13:12 - 14:12	
Sample Volume (reference Conditions)	m ³ *	0.143	0.143
Sample Reference	ECL/18/	0076 0077	0078
Mass of Sulphur Dioxide Collected	mg	0.40	0.21
Concentration of Sulphur Dioxide	mg/m ³ *	2.81	1.48
Emission Rate of Sulphur Dioxide	kg/hr	0.05	...
Expanded Uncertainty (% Relative)	%	13	...
Impinger Collection Efficiency	%	79	...

*Reference Conditions (273K, 101.3kPa, 3% Oxygen, Dry Gas)

NB: No ELV for SO₂, please note if 50mg/m³ ELV used then the concentration is < 30% ELV and therefore impinger collection efficiency is not applicable.

Potters Waste
Permit No
Variation No
Report Ref

: BU77661C
: EPR/BU77661C/V004
: P3334 : R002

Installation Name : Flare Stack
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Table 4 – NMVOCs

Potters Waste
Brynposteg Landfill Flare

Emission Parameter	Units	Value		
Stack Diameter	mm	2300		
Area of Sample Plane	m ²	4.155		
Moisture Content	%	9.20		
Expanded Uncertainty of Moisture (%Relative)	%	17.99		
Measured Oxygen (Dry)	%Vol	9.82		
Meter Temperature	°C	13.25		
Stack Temperature	°C	925.50		
Sample Date	...	11/01/2018		
Sample Period	...	14:24 - 15:24		
Sample Volume (as Measured)	m ³	0.057		
Sample Volume (reference Conditions)	m ³ *	0.033		
Sample Tube Results		One		Blank
Sample Reference ECL/18/83	Units	Concentration*	Uncertainty	Concentration
Concentration of Non Methane VOC	mg/m ³	0.092	9.65%	0.031

*Reference Conditions: 273 K, 101.3 kPa, 3% Oxygen & Dry Gas

Environmental Compliance Limited

Potters Waste

Permit No

Variation No

Report Ref

: BU77661C

: EPR/BU77661C/V004

: P3334 : R002

Installation Name

Visit Details

Survey Dates

Report Issue Date

: Flare Stack

: Annual Compliance

: 10th & 11th January 2018

: 31st January 2018

VELOCITY TRAVERSE PROFILES

**Potters Waste
Permit No
Variation No
Report Ref**

: BU7766IC
: EPR/BU7766IC/V004
: P3334 : R002

Installation Name : Flare Stack
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Environmental Compliance Limited	Traverse Data Profoma	Date of Measurement	11/01/2018
----------------------------------	-----------------------	---------------------	------------

Company	Potters Waste	Stack Diameter Port A (mm)	2300	Average Stack Diameter (mm)	2300	Pitot tube coefficient	0.98
Site	Brynposteg	Stack Diameter Port B (mm)		Port Length (mm)	90	Pitot Id	489
Location	Landfill	Duct Length Port A (mm)		Average Duct Length (mm) L		Stack Thermocouple ID	866
Stack	Flare	Duct Length Port B (mm)		Duct width (mm) B		Stack Temp Reader ID	1112
Job No	P3334	Duct Length Port C (mm)		Barometric Pressure. (mb)	980	Manometer ID	421
Operators	SEB + PB	Duct Length Port D (mm)		Ave Static Press. (mm H ₂ O)	-0.82	Barometer ID	627

Pre - Traverse Checks Carried Out	Time	Pass/ Fail
Pre - Traverse PITOT Visual Inspection	10:35:00	Pass
Pre - Traverse PITOT Leak Check	10:37:00	Pass

Smooth Walls	Static Pressure Readings (Pa inside)			
	Port A	Port B	Port C	Port D
-8.00				

Port/ Point	Distance to Point (mm)	Time	Temperature Readings (°C)			(ΔP) Pitot Readings (Pa)			Average Temp. (°C)	Average (ΔP) (Pa)	Swirl Test ° From Reference
			1	2	3	1	2	3			
A1	1150	10:40:00	923.0	923.0	923.0	10.1	12.9	11.1	923.0	11.4	1

Post - Traverse Checks Carried Out	Time	Pass/ Fail
Post - Traverse <u>Visual Inspection</u>	10:44:00	Pass
Post - Traverse PITOT Leak Check	10:46:00	Pass

Stagnation Check (S-type Pitot Only)	Time	Reading
Static Pressure Via Positive Leg (Pa)		.
Static Pressure Via Negative Leg (Pa)		.
Difference (Pa) < 10Pa }		#VALUE!

Average temp (K)	1196.000
--------------------	----------


Suitability of Sampling Position	Actual Stack Conditions
Highest:lowest flow pressure ratio < 9:1?	1.13:1
Maximum deviation of flow from axis < 15°?	1
X-sectional area for stacks = πr^2	4.15 m ²
X-sectional area for ducts = L x B	m ²
Suitability of Position for Sampling	OK

Stack Moisture	7.55	%	Gas Velocity (as Measured) Adjusted for Smooth Walls	8.70489	m/sec
Measured Oxygen	9.4	%	Gas Velocity (Reference Conditions) Adjusted for Smooth Walls	1.14164	m/sec*
Measured Carbon Dioxide	9.07	%	Volumetric Flowrate (as Measured) Adjusted for Smooth Walls	36.16668	m ³ /sec
Dry Gas Molecular Weight	29.82720	g/g mole	Volumetric Flowrate (Ref Cond) Adjusted for Smooth Walls	4.74322	m ³ /sec*

*Reference Conditions: 273K, 101.3kPa, 3% Oxygen, Dry Gas

NOTE: Velocity / volume flowrate calculations exclude contributions from the measurement point(s) where swirl $> 15^\circ$

Diagram/ Description of Cross Section of Stack/Duct



Notes

Including expected or actual deviations from procedures / non-conformities

Only one point measured due to access and temperature

Site thermocouple readings 1026C

Compliance With Positional Requirements?

Height of sample ports from Platform	03.m
Number of sample ports	4
Width of platform (port back to handrail)	1m

Nearest downstream disturbance	exit	0.5m
Nearest upstream disturbance	bend	5m

Disturbances are classed as bends, fans or diameter variations

Environmental Compliance Limited

Potters Waste

Permit No

Variation No

Report Ref

: BU77661C

: EPR/BU77661C/V004

: P3334 : R002

Installation Name

Visit Details

Survey Dates

Report Issue Date

: Flare Stack

: Annual Compliance

: 10th & 11th January 2018

: 31st January 2018

FIELD CALIBRATION AND SAMPLING DATA

Potters Waste
Permit No : BU77661C
Variation No : EPR/BU77661C/V004
Report Ref : P3334 : R002

Installation Name : Flare Stack
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Combustion Gases Field Calibration Sheet

Units

Mean Initial Direct Zero
Mean Confirmation Direct Zero
Difference in Direct Zero
Repeatability at Zero
<2 x Repeatability at Zero?

Mean Pre Test Zero
% of Measurement Range?
Detection Limit (LOD)

Actual Applied Span Concentration

Mean Pre Test System Zero
Difference $\leq \pm 2\%$ of Span Value (5% for SO₂)?

Mean Post Test Zero
% of Certified Range?
Zero Drift $\leq \pm 5\%$ of Applied Span?

Mean Pre Test System Span
Difference $\leq \pm 2\%$ of Span Value (5% for SO₂)?

Mean Post Test Span
Span Drift $\leq \pm 5\%$ Span Value?

Horiba PG 250 Measurement Ranges:			
NO as			
NO ₂	CO	O ₂	CO ₂
1025	625	25	20
mg/m ³	mg/m ³	%Vol	%Vol
Zero Values (Direct)			
0.20	-0.59	-0.01	0.02
0.30	-0.44	-0.02	0.02
0.10	0.15	0.01	0.00
4.10	2.50	0.20	0.20
YES	YES	YES	YES
Pre Zero Values (System)			
-0.20	0.82	-0.01	0.02
-0.02%	0.13%	-0.04%	0.11%
0.05	0.11	0.20	0.01
Applied Span:			
NO	CO	O ₂	CO ₂
526.44	252.75	14.84	17.73
Pre Test System Zero Values			
-0.20	0.82	-0.01	0.02
0.04%	0.32%	0.07%	0.13%
Post Test Zero Values			
-0.21	0.66	-0.02	0.02
-0.02%	0.11%	-0.09%	0.10%
0.08%	0.49%	0.11%	0.00%
Pre Test System Span Values			
521.25	253.49	14.87	17.67
0.99%	0.29%	0.19%	0.33%
Post Test Span Values			
519.94	251.51	14.67	17.74
1.24%	0.49%	1.15%	0.04%

1.24% 0.49% 1.15% 0.04%

See Note 3 See Note 3 See Note 3 See Note 3

NOTE 1: Data Invalid! Contact Quality Manager!

NOTE 2: Correct test data for drift!

NOTE 3: No drift correction required.

Environmental Compliance Limited

Potters Waste
Permit No
Variation No
Report Ref

: BU77661C
: EPR/BU77661C/V004
: P3334 : R002

Installation Name : Flare Stack
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

TVOC - FIELD DATA SHEET

Client	Potters Waste	Barometric Pressure mb	980
Site	Brynposteg	Barometer ID	ECL/ID/ 627
Date	11/01/2018	Analyser ID	ECL/ID/ 269
Location	Landfill	Sonimix/ MFC ID	ECL/ID/
Stack ID	Flare	Heated Line/ Controller ID	ECL/ID/ 517 518
Stack Temp °C	1000	Heated Line Set Temp °C	180 YES
Ambient Temp (sampling)	1 = 6 2 = 7 3 = 8	Heated Line Length	10 m
Ambient Temp (sampling)	4 = 8 5 = 8 6 = 7	Heated Probe Filter ID	ECL/ID/ 919
Job No	P3334	Heated Filter Set Temp °C	180 YES
Operators	SEB + PB	Logger ID	926

Calibration Gas Details

Calibration Gas	Gas Bottle ID	Gas Value	Uncertainty of Gas (k=2)	Analyser Range	Span Gas value used
Zero Gas (Synthetic Air)	Gas/ 1771	Propane	40 ppm 29.91 ppm
Hydrogen / Helium	Gas/ 1869		
Propane (In Air)	Gas/ 1895	29.91 ppm	1%		

Analysers Range should be not less than the expected peak emissions.

Span Gas Values should be either approximately the half-hourly ELV OR 50% to 90% of the Selected Analyser Range.

Direct Calibration (Rear of Analyser)						
	Zero Cal		Span Gas Cal		Zero Check	
	Start Time	End Time	Start Time	End Time	Start Time	End Time
ZERO /SPAN/ ZERO	09:20	09:25	09:21	09:36	09:41	09:46

NOTE: RESPONSE TIME

Response Time to be carried out at the same time as "Span Check" on system verification (via the sample probe)
Start Time = when gas turned on. 90% Time = when analyser displays 90% of span gas value used. Response must be within 200 seconds.

Pre-Cal Ambient Temp °C		PRE System Verification Check (Down Line)				Response Time		
Max	Min	Zero Check		Span Check		SYSTEM Span Gas Cal		
6	5	Start Time	End Time	Start Time	End Time	Start Time	90% Time	less than 200s (Y/N)
ZERO / SPAN		10:43	10:48	10:50	10:55	10:49:00	10:49:18	Y

	Start Time	End Time	Location	Production Details
Sample Period	10:21	15:07	Flare	Normal
Sample Period				
Sample Period				
Sample Period				
Sample Period				

Post-Cal Ambient Temp °C		POST System Verification Check (Down Line)			
Max	Min	Zero Check		Span Check	
7	7	Start Time	End Time	Start Time	End Time
ZERO / SPAN		15:34	15:39	15:41	15:46

Process Details / Comments

Potters Waste
Permit No
Variation No
Report Ref

: BU77661C
: EPR/BU77661C/V004
: P3334 : R002

Installation Name : Flare Stack
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

TVOCs Field Calibration Sheet

Calibration Summary		TVOC ppm
Analyser Range		40
Repeatability at Zero		0.8
Span Gas Concentration Applied		29.91
Zero Gas Concentration Applied		0
Direct Cal	Zero	0.00
	Span	29.9
	Zero	0.14
Difference (Zero)		0.1425
< 2 × Repeatability @ Zero?		YES
Pre Test (System)	Zero	0.52
	Span	29.9
Difference (Zero)		0.5157
< 2% Relative to Direct Span		YES
Difference (Span)		0.0440
< 2% Relative to Direct Span		YES
Post Test (System)	Zero	0.25
	Span	30.2
Difference (Zero)		0.2620
Zero Drift < 2% of Applied Span?		YES
Difference (Span)		0.3228
Span Drift < 2% of Applied Span?		YES
Zero and Span Drift < 5% of Applied Span?		YES

Installation Name : Flare Stack
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Environmental Compliance Limited		NON ISOKINETIC SAMPLING PROFORMA				Date of Measurement		11/01/2018		If moisture was not measured see detailed notes below.	
ECU/PPD		39		Time taken to change Port/s		0		Start Time		13:12	
Client		Patterson Waste		Stack Profile		Circular		Console id		U/001	
Site		Brynysteg		Stack Area (m ²)		4.15		Pump id		U/001	
Location		Landfill		Barometric Pressure (mb)		980		Probe id		Sinter probe	
Stack ID		Flare		Static Pres. (mm Hg)		4.8		DCV id		0.9746	
Test No.		One		Pilot coefficient		n/a		ΔP		38.2	
Job No		P3334		Probe Heater Setting (°C)		n/a		Impinger id		660	
ECI Site Staff		SEB + PB		Hot Box Setting (°C)		120		Balance id		88	
Sample		Leak 1		Leak 2		Leak 3		Leak 4		Leak 5	
Start Volume		2852245.0									
End Volume		2852488.0									
Total Volume		243.0		0.0		0.0		0.0		0.0	
Leak Check		First		Second		Third		Fourth		Fifth	
Leak rate l/min		0									
Vacuum %Hg		8				16		Dry Carbon Dioxide %		0.07	
Time of Check		13:10				14:17		Dry Carbon Monoxide ppm		9.40	
Set Rate Units		6		4				Reference Oxygen Percentage		25	
Leak < 2%?		YES				YES				Initial ΔH	
Traverse Point		A1		A1		A1		A1		A1	
TimePoint (mins)		0 - 10		10 - 20		20 - 30		30 - 40		40 - 50	
AP (mm H2O)		n/a		n/a		n/a		n/a		n/a	
K factor		n/a		n/a		n/a		n/a		n/a	
AR (Orifice)		3.00		3.00		3.00		3.00		3.00	
Meter (Tm in)		7.00		7.00		8.00		8.00		9.00	
Meter (Tm out)		7.00		7.00		8.00		8.00		9.00	
Stack Temp (Tn)		923.00		926.00		928.00		930.00		934.00	
Impinger 1 Outlet		6.00		6.00		7.00		7.00		9.00	
Vacuum (° Hg)		14.00		12.00		12.00		12.00		12.00	
Traverse Point										Total	
TimePoint(mins)											
AP (mm H2O)		n/a		n/a		n/a		n/a		n/a	
K factor		n/a		n/a		n/a		n/a		n/a	
AR (Orifice)		n/a		n/a		n/a		n/a		n/a	
Meter (Tm in)		n/a		n/a		n/a		n/a		n/a	
Meter (Tm out)		n/a		n/a		n/a		n/a		n/a	
Stack Temp (Tn)		n/a		n/a		n/a		n/a		n/a	
Impinger 1 Outlet		n/a		n/a		n/a		n/a		n/a	
Vacuum (° Hg)		n/a		n/a		n/a		n/a		n/a	
Traverse Point										Total	
TimePoint(mins)											
AP (mm H2O)		n/a		n/a		n/a		n/a		n/a	
K factor		n/a		n/a		n/a		n/a		n/a	
AR (Orifice)		n/a		n/a		n/a		n/a		n/a	
Meter (Tm in)		n/a		n/a		n/a		n/a		n/a	
Meter (Tm out)		n/a		n/a		n/a		n/a		n/a	
Stack Temp (Tn)		n/a		n/a		n/a		n/a		n/a	
Impinger 1 Outlet		n/a		n/a		n/a		n/a		n/a	
Vacuum (° Hg)		n/a		n/a		n/a		n/a		n/a	
Traverse Point										Total	
TimePoint(mins)											
AP (mm H2O)		n/a		n/a		n/a		n/a		n/a	
K factor		n/a		n/a		n/a		n/a		n/a	
AR (Orifice)</											

Environmental Compliance Limited					SAMPLE TUBE DATA SAMPLING PROFORMA																																														
Client		Potters Waste	≈ Circular	◁ Rectangular	◁ Ellipse	Pump ID		n/a	Date of Test	11/01/2018																																									
Site		Brynposteg	Stack Diameter (mm)		2300	Meter ID		U001	Sample Start Time		14:24																																								
Location		Landfill				MST Probe ID		n/a	Sample End Time		15:24																																								
Stack ID		Flare	Stack Area (m²)		4.155	MST Probe Heating Temp (°C)		180	Duration		60																																								
Test No		0ne	Barometric Pressure (mb)		980	DGM Yd or ml/cmcount		0.9746	Measured O2		9.82																																								
Job No		P3334	Stack Thermocouple ID		866	MST Hot Box ID		978	O2 Uncertainty %Vol		0.59																																								
ECI Site Staff		SEB - + PB	Tube Thermocouple ID		1041	MST Hot Box Heating Temp (°C)		180																																											
Barometer ID		627	Meter Thermocouple ID		U001	Workhorse Set Sample Rate (%)		n/a																																											
			In-Stack Sinter Used (Y/N)		Y	MST Delta H Sampling Rate		0.5																																											
<table border="1"> <thead> <tr> <th>Motor Units C ml</th> <th>≈ litres</th> <th>Sample</th> <th>Leak 1</th> <th>Time (start/end minimum 1 minute)</th> <th>Leak 2</th> <th>Time (start/end minimum 1 minute)</th> <th>Total</th> </tr> </thead> <tbody> <tr> <td></td> <td></td> <td>2852464.0</td> <td>2852454.9</td> <td>14:21:00</td> <td>2852532.1</td> <td>15:30:00</td> <td></td> </tr> <tr> <td></td> <td></td> <td>2852523.8</td> <td>2852454.9</td> <td>14:22:00</td> <td>2852532.1</td> <td>15:31:00</td> <td></td> </tr> <tr> <td></td> <td></td> <td>58.6</td> <td>0.0</td> <td></td> <td>0.0</td> <td></td> <td>58.6</td> </tr> <tr> <td colspan="2">Sample Train Interval Volume</td> <td>1.2447</td> <td colspan="5">Litres</td> </tr> </tbody> </table>												Motor Units C ml	≈ litres	Sample	Leak 1	Time (start/end minimum 1 minute)	Leak 2	Time (start/end minimum 1 minute)	Total			2852464.0	2852454.9	14:21:00	2852532.1	15:30:00				2852523.8	2852454.9	14:22:00	2852532.1	15:31:00				58.6	0.0		0.0		58.6	Sample Train Interval Volume		1.2447	Litres				
Motor Units C ml	≈ litres	Sample	Leak 1	Time (start/end minimum 1 minute)	Leak 2	Time (start/end minimum 1 minute)	Total																																												
		2852464.0	2852454.9	14:21:00	2852532.1	15:30:00																																													
		2852523.8	2852454.9	14:22:00	2852532.1	15:31:00																																													
		58.6	0.0		0.0		58.6																																												
Sample Train Interval Volume		1.2447	Litres																																																
<table border="1"> <thead> <tr> <th>Sample Point</th> <th>A1</th> <th>A1</th> <th>A1</th> </tr> </thead> <tbody> <tr> <td>Time/ point (mins)</td> <td>0-10</td> <td>10-20</td> <td>20-30</td> </tr> <tr> <td>Tube Temp °C</td> <td>11</td> <td>11</td> <td>11</td> </tr> <tr> <td>Stack Temp °C</td> <td>917</td> <td>923</td> <td>927</td> </tr> <tr> <td>Meter Temp In °C</td> <td>16</td> <td>16</td> <td>15</td> </tr> <tr> <td>Meter Temp Out °C</td> <td>11</td> <td>11</td> <td>12</td> </tr> </tbody> </table>								Sample Point	A1	A1	A1	Time/ point (mins)	0-10	10-20	20-30	Tube Temp °C	11	11	11	Stack Temp °C	917	923	927	Meter Temp In °C	16	16	15	Meter Temp Out °C	11	11	12	Impinger 1		Empty																	
Sample Point	A1	A1	A1																																																
Time/ point (mins)	0-10	10-20	20-30																																																
Tube Temp °C	11	11	11																																																
Stack Temp °C	917	923	927																																																
Meter Temp In °C	16	16	15																																																
Meter Temp Out °C	11	11	12																																																
<table border="1"> <tbody> <tr> <td>Start Weight (g)</td> <td>527.7</td> </tr> <tr> <td>End Weight (g)</td> <td>529.7</td> </tr> <tr> <td>Total weight (g)</td> <td>2</td> </tr> </tbody> </table>								Start Weight (g)	527.7	End Weight (g)	529.7	Total weight (g)	2																																						
Start Weight (g)	527.7																																																		
End Weight (g)	529.7																																																		
Total weight (g)	2																																																		
<table border="1"> <thead> <tr> <th>Sample Point</th> <th>A1</th> <th>A1</th> <th>A1</th> </tr> </thead> <tbody> <tr> <td>Time/ point (mins)</td> <td>40-50</td> <td>50-60</td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td>12</td> <td>13</td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td>930</td> <td>927</td> <td></td> </tr> <tr> <td>Meter Temp In °C</td> <td>14</td> <td>14</td> <td></td> </tr> <tr> <td>Meter Temp Out °C</td> <td>12</td> <td>11</td> <td></td> </tr> </tbody> </table>								Sample Point	A1	A1	A1	Time/ point (mins)	40-50	50-60		Tube Temp °C	12	13		Stack Temp °C	930	927		Meter Temp In °C	14	14		Meter Temp Out °C	12	11		Impinger 2		Empty																	
Sample Point	A1	A1	A1																																																
Time/ point (mins)	40-50	50-60																																																	
Tube Temp °C	12	13																																																	
Stack Temp °C	930	927																																																	
Meter Temp In °C	14	14																																																	
Meter Temp Out °C	12	11																																																	
<table border="1"> <tbody> <tr> <td>Start Weight (g)</td> <td>617.1</td> </tr> <tr> <td>End Weight (g)</td> <td>618</td> </tr> <tr> <td>Total weight (g)</td> <td>0.9</td> </tr> </tbody> </table>								Start Weight (g)	617.1	End Weight (g)	618	Total weight (g)	0.9																																						
Start Weight (g)	617.1																																																		
End Weight (g)	618																																																		
Total weight (g)	0.9																																																		
<table border="1"> <thead> <tr> <th>Sample Point</th> <th>A1</th> <th>A1</th> <th>A1</th> </tr> </thead> <tbody> <tr> <td>Time/ point (mins)</td> <td>40-50</td> <td>50-60</td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td>12</td> <td>13</td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td>930</td> <td>927</td> <td></td> </tr> <tr> <td>Meter Temp In °C</td> <td>14</td> <td>14</td> <td></td> </tr> <tr> <td>Meter Temp Out °C</td> <td>12</td> <td>11</td> <td></td> </tr> </tbody> </table>								Sample Point	A1	A1	A1	Time/ point (mins)	40-50	50-60		Tube Temp °C	12	13		Stack Temp °C	930	927		Meter Temp In °C	14	14		Meter Temp Out °C	12	11		Impinger3		Silca																	
Sample Point	A1	A1	A1																																																
Time/ point (mins)	40-50	50-60																																																	
Tube Temp °C	12	13																																																	
Stack Temp °C	930	927																																																	
Meter Temp In °C	14	14																																																	
Meter Temp Out °C	12	11																																																	
<table border="1"> <tbody> <tr> <td>Start Weight (g)</td> <td>760.4</td> </tr> <tr> <td>End Weight (g)</td> <td>761.9</td> </tr> <tr> <td>Total weight (g)</td> <td>1.5</td> </tr> </tbody> </table>								Start Weight (g)	760.4	End Weight (g)	761.9	Total weight (g)	1.5																																						
Start Weight (g)	760.4																																																		
End Weight (g)	761.9																																																		
Total weight (g)	1.5																																																		
<table border="1"> <thead> <tr> <th>Sample Point</th> <th>A1</th> <th>A1</th> <th>A1</th> </tr> </thead> <tbody> <tr> <td>Time/ point (mins)</td> <td>40-50</td> <td>50-60</td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td>12</td> <td>13</td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td>930</td> <td>927</td> <td></td> </tr> <tr> <td>Meter Temp In °C</td> <td>14</td> <td>14</td> <td></td> </tr> <tr> <td>Meter Temp Out °C</td> <td>12</td> <td>11</td> <td></td> </tr> </tbody> </table>								Sample Point	A1	A1	A1	Time/ point (mins)	40-50	50-60		Tube Temp °C	12	13		Stack Temp °C	930	927		Meter Temp In °C	14	14		Meter Temp Out °C	12	11		Silica		(IF USED)																	
Sample Point	A1	A1	A1																																																
Time/ point (mins)	40-50	50-60																																																	
Tube Temp °C	12	13																																																	
Stack Temp °C	930	927																																																	
Meter Temp In °C	14	14																																																	
Meter Temp Out °C	12	11																																																	
<table border="1"> <tbody> <tr> <td>Start Weight (g)</td> <td>760.4</td> </tr> <tr> <td>End Weight (g)</td> <td>761.9</td> </tr> <tr> <td>Total weight (g)</td> <td>1.5</td> </tr> </tbody> </table>								Start Weight (g)	760.4	End Weight (g)	761.9	Total weight (g)	1.5	<table border="1"> <tbody> <tr> <td>≤ 50% Spent at end V/N1</td> <td>Yes</td> </tr> <tr> <td>Sample train upstream of scrubber before condensation line for entire sample (Y/N)</td> <td>no</td> </tr> </tbody> </table>		≤ 50% Spent at end V/N1	Yes	Sample train upstream of scrubber before condensation line for entire sample (Y/N)	no																																
Start Weight (g)	760.4																																																		
End Weight (g)	761.9																																																		
Total weight (g)	1.5																																																		
≤ 50% Spent at end V/N1	Yes																																																		
Sample train upstream of scrubber before condensation line for entire sample (Y/N)	no																																																		

Page 28 of 44

Environmental Compliance Limited

Potters Waste

Permit No

: BU77661C

Variation No

: EPR/BU77661C/V004

Report Ref

: P3334 : R002

Installation Name

: Flare Stack

Visit Details

: Annual Compliance

Survey Dates

: 10th & 11th January 2018

Report Issue Date

: 31st January 2018

LABORATORY ANALYSIS RESULTS

Environmental Compliance Limited

Potters Waste
Permit No
Variation No
Report Ref

: BU77661C
: EPR/BU77661C/V004
: P3334 : R002

Installation Name : Flare Stack
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018



Concept Life Sciences Certificate of Analysis

Hadfield House
Hadfield Street
Combrook
Manchester
M16 9FE
Tel : 0161 874 2400
Fax : 0161 874 2404

Report Number: 708572-1

Date of Report: 24-Jan-2018

Customer: Environmental Compliance Ltd
Unit G1
Main Avenue
Treforest Industrial Estate
Pontypridd
CF37 5BF

Customer Contact: Mr Sam Brookes

Customer Job Reference: P3334
Customer Purchase Order: E7497
Date Job Received at Concept: 15-Jan-2018
Date Analysis Started: 15-Jan-2018
Date Analysis Completed: 24-Jan-2018

The results reported relate to samples received in the laboratory and may not be representative of a whole batch.

Opinions and interpretations expressed herein are outside the scope of UKAS accreditation

This report should not be reproduced except in full without the written approval of the laboratory

Tests covered by this certificate were conducted in accordance with Concept Life Sciences SOPs

All results have been reviewed in accordance with Section 25 of the Concept Life Sciences, Analytical Services Quality Manual



Report checked
and authorised by :
Kathryn Gleaves
Customer Service Advisor

Issued by :
Emma Spear
Customer Service Advisor

Page 1 of 4
708572-1

Environmental Compliance Limited

Potters Waste
Permit No
Variation No
Report Ref

: BU77661C
: EPR/BU77661C/V004
: P3334 : R002

Installation Name : Flare Stack
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Concept Reference: 708572					
Customer Reference: P3334					
Impinger(peroxide) Analysed as Impinger(peroxide)					
Sulphur Dioxide & Volume					
Concept Reference	708572 001	708572 002	708572 003	708572 004	708572 005
Customer Sample Reference	ECL/18/0070	ECL/18/0071	ECL/18/0072	ECL/18/0073	ECL/18/0074
Test Sample	AR	AR	AR	AR	AR
Date Sampled	10-JAN-2018	10-JAN-2018	10-JAN-2018	10-JAN-2018	10-JAN-2018
Determinand	Method	LOD	Units	Symbol	
Sulphur Dioxide	IC	0.05	mg/l	U	(13) 64
Volume	Vol	1	ml	U	460

Concept Reference: 708572					
Customer Reference: P3334					
Impinger(peroxide) Analysed as Impinger(peroxide)					
Sulphur Dioxide & Volume					
Concept Reference	708572 006	708572 007	708572 008	708572 009	
Customer Sample Reference	ECL/18/0075	ECL/18/0076	ECL/18/0077	ECL/18/0078	
Test Sample	AR	AR	AR	AR	
Date Sampled	10-JAN-2018	11-JAN-2018	11-JAN-2018	11-JAN-2018	
Determinand	Method	LOD	Units	Symbol	
Sulphur Dioxide	IC	0.05	mg/l	U	(13) 0.43
Volume	Vol	1	ml	U	380

Concept Reference: 708572					
Customer Reference: P3334					
Tube (Charcoal 228-09) Analysed as Tube (Charcoal 225-09)					
VOC (Total)					
Concept Reference	708572 011	708572 012	708572 013	708572 014	708572 015
Customer Sample Reference	ECL/18/0080	ECL/18/0081	ECL/18/0082	ECL/18/0083	ECL/18/0084
Test Sample	AR	AR	AR	AR	AR
Date Sampled	10-JAN-2018	10-JAN-2018	10-JAN-2018	11-JAN-2018	11-JAN-2018
Determinand	Method	LOD	Units	Symbol	
Volatile Organic Compounds (Total)	GC/MS	1	µg	N	58

Environmental Compliance Limited

Potters Waste
Permit No
Variation No
Report Ref

: BU77661C
: EPR/BU77661C/V004
: P3334 : R002

Installation Name : Flare Stack
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Concept Reference: 708572						
Customer Reference: F3334						
Tube (Tenax/Carbon/Molecular Sieve) Analysed as Tube (Tenax/Carbon/Molecular Sieve)						
Trace Landfill Gas Suite						
Concept Reference		708572 018		708572 021		708572 022
Customer Sample Reference		ECL/18/0088		ECL/18/0089		ECL/18/0090
Test Sample		AR		AR		AR
Date Sampled		11-JAN-2018		11-JAN-2018		11-JAN-2018
Determinand	Method	LOD	Units	Symbol		
1-Pentene	GC/MS (TD SIR)	10	ng	U	(66) 46	(66) 30
1,1-Dichloroethane	GC/MS (TD SIR)	10	ng	U	<10	<10
1,1-Dichloroethylene	GC/MS (TD SIR)	10	ng	U	280	240
1,2-Dichloroethane	GC/MS (TD SIR)	10	ng	N	(175) 1800	<10
1,2-Dichloroethylene	GC/MS (TD SIR)	30	ng	U	<30	<30
1,3-Butadiene	GC/MS (TD SIR)	10	ng	U	(66) <10	(66) <10
1,4-epoxy 1,3-butadiene	GC/MS (TD SIR)	10	ng	N	<10	<10
1-Propanethiol	GC/MS (TD SIR)	10	ng	U	<10	<10
2-butoxyethanol	GC/MS (TD SIR)	10	ng	N	<10	<10
Benzene	GC/MS (TD SIR)	10	ng	U	(175) 6800	(175) 2100
Butyric acid	GC/MS (TD SIR)	10	ng	N	<10	<10
Carbon disulphide	GC/MS (TD SIR)	10	ng	N	440	<10
Carbon tetrachloride	GC/MS (TD SIR)	10	ng	U	<10	<10
Chloroethane	GC/MS (TD SIR)	30	ng	N	<30	<30
Dichloromethane	GC/MS (TD SIR)	10	ng	N	(175) 6800	<10
Dimethyl disulphide	GC/MS (TD SIR)	10	ng	N	320	<10
Dimethyl sulphide	GC/MS (TD SIR)	10	ng	U	760	12
Ethyl butyrate	GC/MS (TD SIR)	25	ng	N	<25	<25
Ethyl Mercaptan	GC/MS (TD SIR)	10	ng	N	<10	<10
Hydrogen sulphide	GC/MS (TD SIR)	60	ng	N	<60	<60
Methyl Mercaptan	GC/MS (TD SIR)	30	ng	N	<30	<30
N-Butyl Mercaptan	GC/MS (TD SIR)	10	ng	U	<10	<10
Styrene	GC/MS (TD SIR)	10	ng	N	280	<10
Toluene	GC/MS (TD SIR)	10	ng	N	(17) 12000	31
Trichloroethylene	GC/MS (TD SIR)	10	ng	U	730	260
Vinyl chloride monomer	GC/MS (TD SIR)	10	ng	U	(66) <10	(66) <10

Concept Reference: 708572						
Customer Reference: F3334						
Tube (Charcoal) Analysed as Tube (Charcoal 225-01)						
Siloxanes						
Concept Reference		708572 026		708572 028		
Customer Sample Reference		ECL/18/0088		ECL/18/0084		
Test Sample		AR		AR		
Date Sampled		11-JAN-2018		11-JAN-2018		
Determinand	Method	LOD	Units	Symbol		
Decamethylcyclotrisiloxane	GC/MS (Solvent Desorption)	1	µg	U	<1	<1
Decamethyltetrasiloxane	GC/MS (Solvent Desorption)	1	µg	U	<1	<1
Hexamethylcyclotrisiloxane	GC/MS (Solvent Desorption)	1	µg	U	<1	<1
Hexamethyldisiloxane	GC/MS (Solvent Desorption)	1	µg	U	<1	<1
Octamethylcyclotrisiloxane	GC/MS (Solvent Desorption)	1	µg	U	<1	<1
Octamethyltrisiloxane	GC/MS (Solvent Desorption)	1	µg	U	<1	<1

Index to symbols used in 708572-1

Value	Description
AR	As Received
27	Result should be considered as a minimum due to detector saturation.
13	Results have been blank corrected.
68	Outside scope of UKAS accreditation
175	Results should be viewed with caution due to being outside of the instrument calibration range.
U	Analysis is UKAS accredited
N	Analysis is not UKAS accredited

Environmental Compliance Limited

Potters Waste

Permit No : BU77661C
Variation No : EPR/BU77661C/V004
Report Ref : P3334 : R002

Installation Name

: Flare Stack
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Notes

The results for 1-Pentene, 1,3-Butadiene & Vinyl Chloride Monomer are outside the scope of our UKAS accreditation as the standards expired on the 13/01/18.



Environmental Compliance Limited

Potters Waste

Permit No

Variation No

Report Ref

: BU77661C

: EPR/BU77661C/V004

: P3334 : R002

Installation Name

Visit Details

Survey Dates

Report Issue Date

: Flare Stack

: Annual Compliance

: 10th & 11th January 2018

: 31st January 2018

UNCERTAINTY CALCULATIONS

Potters Waste
Permit No
Variation No
Report Ref

: BU77661C
: EPR/BU77661C/V004
: P3334 : R002

Installation Name : Flare Stack
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Volumetric Flowrate Uncertainty

Measurement Uncertainty Calculations - Velocity at Stack Conditions

Contribution From	Standard u/c (Pa)	
Pitot Calibration Uncertainty Contribution	0.06	A
Manometer Calibration Uncertainty Contribution	0.056833333	B
Variation in Actual Pitot reading at sample points	1.40	C
Combined u/c (Pa) =	Combined u/c (Pa)	
$\text{SQRT } (A/\sqrt{3})^2 + (B/\sqrt{3})^2 + (C/\sqrt{3})^2$	0.81	
Expanded Uncertainty of Flow Measurements Pa	1.62	
	Standard u/c (K)	
Temperature Calibration (K)	5.98	D
Variation in Actual Temp reading at sample points	0.00	E
Combined u/c of Temp (K)	Combined u/c (K)	
$\text{SQRT } ((D/\sqrt{3})^2 + (E/\sqrt{3})^2)$	3.45	
Expanded Uncertainty of Temp Measurements (K)	6.91	
Measured Average Velocity (m/s) at Stack Conds	8.71	
Maximum Average Velocity (m/s) at Stack Conds	9.33	
Standard Uncertainty Velocity at Stack Conditions (%)	7.19	
Expanded Uncertainty Velocity (at Stack Conditions)	14.39 (%)	

Measurement Uncertainty Calculations - Flowrate at Stack Conditions

Contribution From	Standard u/c (m ²)
Area (m ²)	0.04155
Measured Average Flowrate (m ³ /s) at Stack Conds	36.17
Maximum Average Flowrate (m ³ /s) at Stack Conds	39.16
Standard Uncertainty Flowrate (m ³ /s) at Stack Conditions (%)	8.27
Expanded Uncertainty Flowrate (m³/s) at Stack Conditions	16.53 (%)

Measurement Uncertainty Calculations - Flowrate at STP & Wet Gas

Contribution From	Standard u/c (%)
Temperature Calibration (K)	0.5
Barometer Calibration	0.5
Measured Average Flowrate (m ³ /s) at STP Wet	7.99
Maximum Average Flowrate (m ³ /s) at STP Wet	8.66
Standard Uncertainty Flowrate (m ³ /s) at STP Wet	8.39
Expanded Uncertainty Flowrate (m³/s) at STP Wet	16.78 (%)

Measurement Uncertainty Calculations - Flowrate at STP & Dry Gas

Contribution From	Standard u/c (%)
Moisture Uncertainty (% v/v)	0.33
Measured Average Flowrate (m ³ /s) at STP Dry	7.62
Maximum Average Flowrate (m ³ /s) at STP Dry	8.29
Standard Uncertainty Flowrate (m ³ /s) at STP Dry	8.76
Expanded Uncertainty Flowrate (m³/s) at STP Dry	17.53 (%)

Measurement Uncertainty Calculations - Flowrate at STP, Dry Gas & Ref Oxygen

Contribution From	Standard u/c (%)
Oxygen Uncertainty (% v/v)	0.141
Measured Average Flowrate (m ³ /s) at STP Dry & Ref Oxygen	4.91
Maximum Average Flowrate (m ³ /s) at STP Dry & Ref Oxygen	5.41
Standard Uncertainty Flowrate (m ³ /s) at STP Dry & Ref Oxygen	10.09
Expanded Uncertainty Flowrate (m³/s) at STP Dry & Ref O₂	20.17 (%)

Environmental Compliance Limited

Potters Waste
Permit No : BU77661C
Variation No : EPR/BU77661C/V004
Report Ref : P3334 : R002

Installation Name : Flare Stack
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Combustion Gases Measurement Uncertainty

Uncertainty of Measurement Results - Calculations Part 1

Horiba PG 250 Performance Characteristics	Standard Uncertainty (% of Range)	Distribution	Divisor	Minimum Certified Range (R _i)			
				NO 0 - 125 mg/m ³	CO 0 - 95 mg/m ³	O ₂ 0 - 25 %Vol	CO ₂ 0 - 20 %Vol
Lack of fit ⁽¹⁾	u_{lof}	Rectangular	$\sqrt{3}$	0.40	0.40	0.13	0.60
Span drift ⁽²⁾	$u_{d,s}$			0.27	0.29	0.029	0.24
Losses / leakage in the sample system ⁽⁴⁾	u_{loss}			4.15	0.78	0.11	0.30
Temperature dependant span drift ⁽³⁾	u_t			0.18	0.050	0.070	0.040

Notes:

For rectangular distributions, $u(x_i) = \frac{u \times R_i}{\sqrt{3}}$

For $u(x_i) = \Delta x_i \sqrt{\frac{(x_{i,max} - x_{i,adj})^2 + (x_{i,min} - x_{i,adj})(x_{i,max} - x_{i,adj}) + (x_{i,min} - x_{i,adj})^2}{3}}$, when $|x_{i,max} - x_{i,adj}| = |x_{i,min} - x_{i,adj}|$, then $u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$

Where $u(x_i) = \frac{\sigma}{\sqrt{n}}$ (See note 6 below), $\sigma = \sqrt{\frac{\sum_{i=1}^n (x_i - \bar{x})^2}{n-1}}$

Horiba PG 250 Performance Characteristics	Uncertainty (Units of final measurement)	Distribution	Divisor	NO 0 - 125 mg/m ³	CO 0 - 95 mg/m ³	O ₂ 0 - 25 %Vol	CO ₂ 0 - 20 %Vol
Lack of fit	u_{lof}	Rectangular	$\sqrt{3}$	0.29	0.22	0.019	0.069
Span drift	$u_{d,s}$			0.20	0.16	0.0041	0.028
Temperature dependant span drift	u_t			0.26	0.055	0.020	0.0092
Interferents	u_i			0.87	1.59	0.081	...

Uncertainty of Measurement Results - Calculations Part 2

Horiba PG 250 Performance Characteristics	Uncertainty (Units of final measurement)	Date & Time	NO 0 - 125 mg/m ³	CO 0 - 95 mg/m ³	O ₂ 0 - 25 %Vol	CO ₂ 0 - 20 %Vol
Losses / leakage in the sample system	u_{loss}	11/01/18 13:54 - 14:53	3.24	0.38	0.011	0.026
Standard Error of Measured Value	u_{SE}	11/01/18 13:54 - 14:53	0.42	1.27	0.065	0.053

Effect on Uncertainty Caused by Oxygen

$$u_{Corr^{+}O_2} = \frac{20.9\% - O_{2,ref}}{(20.9\% - O_{2,measured}) \times (20.9\% - O_{2,measured})} \times \text{Uncertainty of } O_2 \text{ Measurement} = 0.027$$

$$f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 1.8127 \quad u_{f_{O_2}} = \frac{u_{Corr^{+}O_2}}{f_{O_2}} \times 100 = 1.46\%$$

The effect of oxygen on the overall uncertainties (below) is incorporated using the following equation:-

$$u_{combined} = \sqrt{\sum (u_{f_{O_2}})^2 + (\text{Uncertainty of Measurement of Determinand})^2}$$

Where oxygen or moisture correction is required, uncertainty based on the standard error of the measured peripheral value is converted to units of final measurement using a sensitivity coefficient C,

$$\therefore u(x_i) = C_i u_i \text{ where } C_i = \frac{\partial f}{\partial x_i}$$

Uncertainty of Measurement Results - Calculations Part 3

Horiba PG 250 Uncertainty	Date & Time	NOx (as NO2) 0 - 125 mg/m ³	CO 0 - 95 mg/m ³	O ₂ 0 - 25 %Vol	CO ₂ 0 - 20 %Vol
Measured Concentration	11/01/18 13:54 - 14:53	78.19	49.12	9.87	8.67
Expanded Uncertainty as Percentage of Measured Concentration		9%	9%	3%	3%

$$\text{Combined Standard Uncertainty } u_c = \sqrt{u_{lof}^2 + u_{d,s}^2 + u_{loss}^2 + u_t^2 + u_{ref}^2 + u_{SE}^2 + u_{O_2}^2}$$

$$\text{Expanded uncertainty (at 95\% confidence)} U_{Exp} = 2 \times u_c$$

- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range as maximum drift per 24hr period
- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range per one degree centigrade
- Where the uncertainty of Moisture is taken as the standard error of the time averaged value used to correct to Dry Conditions
- If no value for uncertainty is presented above, the uncertainty is considered to be > 100%

Environmental Compliance Limited

Potters Waste
Permit No : BU77661C
Variation No : EPR/BU77661C/V004
Report Ref : P3334 : R002

Installation Name : Flare Stack
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Combustion Gases Uncertainty of Measurements

Measurement Uncertainty Calculations Part 1

Horiba PG 250 Performance Characteristics	Standard Uncertainty (% of Range)	Distributioun	Minimum Certified Range (R)									
			NO 0 - 125 mg/m ³	NO ₂ mg/m ³	N ₂ O mg/m ³	SO ₂ mg/m ³	CO 0 - 95 mg/m ³	HCl mg/m ³	NH ₃ mg/m ³	O ₂ 0 - 25 %Vol	CO ₂ 0 - 20 %Vol	H ₂ O %Vol
Lack of fit ⁽¹⁾	U_{lof}	Rectangular (Divisor = $\sqrt{3}$)	0.40				0.40			0.13	0.60	
Span drift ⁽²⁾	$U_{d,s}$	Rectangular (Divisor = $\sqrt{3}$)	0.27				0.29			0.029	0.24	
Repeatability Standard Deviation (span) ⁽³⁾	U_r	Normal (Divisor = 1)	0.58				1.16			0.42	0.20	
Losses / leakage in the sample system ⁽⁴⁾	U_{loss}	Rectangular (Divisor = $\sqrt{3}$)	4.15				0.78			0.11	0.30	
Temperature dependant span drift ⁽⁵⁾	U_t	Rectangular (Divisor = $\sqrt{3}$)	0.18				0.050			0.070	0.040	
Interferents ⁽⁶⁾	U_i	Rectangular (Divisor = $\sqrt{3}$)	1.20				2.90			0.56	0.010	
Uncertainty of Reference Gas ⁽⁶⁾	U_{ref}	Rectangular (Divisor = $\sqrt{3}$)	9.12				4.38			0.15	0.31	
Effect of Voltage Fluctuation ⁽⁷⁾	U_v	Rectangular (Divisor = $\sqrt{3}$)	
Effect of Sample Gas Flow/ Pressure ⁽⁷⁾	U_{sg}	Rectangular (Divisor = $\sqrt{3}$)	

Note:

$$\text{when } (x_{i,max} - x_{i,adj}) = (x_{i,min} - x_{i,adj}), \text{ then } u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$$

- 1 Expressed as a percentage of the certified range
- 2 Expressed as a percentage of the certified range as maximum drift per 24hr period
- 3 Expressed as a percentage of the certified range
- 4 Expressed as a percentage of the certified range
- 5 Expressed as a percentage of the certified range per one degree centigrade
- 6 Expressed as standard uncertainty in units of measurement i.e. mg/m³ / %Vol inc additional uncertainty of 2% for gas blending
- 7 Data not available so not included

Measurement Uncertainty Calculations Part 2

Horiba PG 250 Performance Characteristics	Uncertainty	Value of Standard Uncertainty	NO 0 - 125 mg/m ³	NO ₂ mg/m ³	N ₂ O mg/m ³	SO ₂ 0 - 460 mg/m ³	CO 0 - 95 mg/m ³	HCl mg/m ³	NH ₃ mg/m ³	O ₂ 0 - 25 %Vol	CO ₂ 0 - 20 %Vol	H ₂ O %Vol	*TOC mgC/m ³
			0 - 125 mg/m ³	mg/m ³	mg/m ³	0 - 460 mg/m ³	0 - 95 mg/m ³	mg/m ³	mg/m ³	0 - 25 %Vol	0 - 20 %Vol	%Vol	mgC/m ³
Lack of fit	U_{lof}	$u(x_i) = \frac{u_{lof} \times R_i}{\sqrt{3}} =$	0.29				0.22			0.019	0.07		
Span drift	$U_{d,s}$	$u(x_i) = \frac{u_{d,s} \times R_i}{\sqrt{3}} =$	0.20				0.16			0.0041	0.0280		
Repeatability Standard Deviation (span)	U_r	$\sigma = \sqrt{\frac{\sum_{i=1}^n (x_i - \bar{x})^2}{n-1}} =$	0.58				1.16			0.42	0.20		
Losses / leakage in the sample system	U_{loss}	$u(x_i) = \frac{u_{loss} \times R_i}{\sqrt{3}} =$	3.00				0.43			0.016	0.03		
Temperature dependant span drift	U_t	$u(x_i) = \frac{u_{sg} \times R_i}{100} \sqrt{\frac{(x_{i,max} - x_{i,adj})^2 + (x_{i,min} - x_{i,adj})^2 + (x_{i,max} - x_{i,min})^2}{3}} =$	0.13				0.027			0.010	0.005		
Interferents	U_i	$u(x_i) = \frac{u_i \times R_i}{\sqrt{3}} =$	0.87				1.59			0.081	0.01		
Uncertainty of Reference Gas	U_{ref}	$u(x_i) = \frac{u_{ref}}{\sqrt{3}} =$	5.26				2.53			0.086	0.18		
Effect of Voltage Fluctuation ⁽⁷⁾	U_v	$u(x_i) = \frac{u_v \times R_i}{\sqrt{3}} =$		
Effect of Sample Gas Flow/ Pressure ⁽⁷⁾	U_{sg}	$u(x_i) = \frac{u_{sg} \times R_i}{\sqrt{3}} =$		
Combined Standard Uncertainty		$u_c = \sqrt{u_{lof}^2 + u_{d,s}^2 + u_r^2 + u_{loss}^2 + u_t^2 + u_i^2 + u_{ref}^2}$	6.16				3.24			0.44	0.28		
Expanded measurement uncertainty (at 95% confidence)		$U_{EXP} = 2 \times u_c$	12.31				6.49			0.87	0.56		
Applied Span Concentration			526.44				252.75			14.84	17.73		
Measured Span Concentration, STP Dry Gas			520.59				252.50			14.79	17.70		
Expanded measurement uncertainty as % of Applied Span			2%				3%			6%	3%		

Environmental Compliance Limited

Potters Waste
Permit No : BU77661C
Variation No : EPR/BU77661C/V004
Report Ref : P3334 : R002

Installation Name : Flare Stack
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

TVOCs Measurement Uncertainty

Flare - TVOC - Measurement Uncertainty - Uncertainty Calculations Table 1

Performance Characteristics	Standard Uncertainty (% of Range)	Distribution	Min Certified Ranges
			TVOC 0 - 15 mgC/m ³
Lack of fit ⁽¹⁾	u_{lof}	Rectangular (Divisor = $\sqrt{3}$)	0.73
Span drift ⁽²⁾	$u_{d,s}$	Rectangular (Divisor = $\sqrt{3}$)	0.35
Repeatability Standard Deviation (span) ⁽³⁾	u_r	Normal (Divisor = 1)	5.50
Losses / leakage in the sample system ⁽⁴⁾	u_{loss}	Rectangular (Divisor = $\sqrt{3}$)	0.29
Temperature dependant span drift ⁽⁵⁾	u_t	Rectangular (Divisor = $\sqrt{3}$)	0.30
Interferents ⁽¹⁾	u_i	Rectangular (Divisor = $\sqrt{3}$)	4.39
Uncertainty of Reference Gas ⁽⁶⁾	u_{ref}	Rectangular (Divisor = $\sqrt{3}$)	0.83
Effect of Voltage Fluctuation ⁽⁷⁾	u_v	Rectangular (Divisor = $\sqrt{3}$)	1.80
Effect of Oxygen Synergism ⁽⁷⁾	u_{syn}	Rectangular (Divisor = $\sqrt{3}$)	4.60

Note:

$$\text{when } |(x_{i,max} - x_{i,adj})| = |(x_{i,min} - x_{i,adj})|, \text{ then } u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$$

- 1 Expressed as a percentage of the certified range
- 2 Expressed as maximum drift per 24hr period as percentage of the certified range
- 3 Expressed as a percentage of the certified range
- 4 Expressed as a percentage of the certified range
- 5 Expressed as a percentage of the certified range per one degree centigrade
- 6 Expressed as standard uncertainty in units of measurement i.e. mg/m³ / %Vol taking account of an additional uncertainty of 2% for gas blending
- 7 Expressed as a percentage of the certified range

Flare - TVOC - Measurement Uncertainty - Uncertainty Calculations Table 2

Performance Characteristics	Uncertainty	Value of Standard Uncertainty	*TVOC 0 - 15 mgC/m ³
Lack of fit	u_{lof}	$u(x_i) = \frac{u_{lof} \times R_i}{\sqrt{3}} =$	0.064
Span drift	$u_{d,s}$	$u(x_i) = \frac{u_{d,s} \times R_i}{\sqrt{3}} =$	0.031
Repeatability Standard Deviation (span)	u_r	$\sigma = \sqrt{\frac{\sum_{i=1}^n (x_i - \bar{x})^2}{n-1}} =$	0.82
Losses / leakage in the sample system	u_{loss}	$u(x_i) = \frac{u_{loss} \times R_i}{\sqrt{3}} =$	0.025
Temperature dependant span drift	u_t	$u(x_i) = \frac{u_t}{100} \times R_i \times \sqrt{\frac{(x_{i,max} - x_{i,adj})^2 + (x_{i,min} - x_{i,adj})^2 + (x_{i,max} - x_{i,adj})(x_{i,min} - x_{i,adj})}{3}}$	0.026
Interferents	u_i	$u(x_i) = \frac{u_i \times R_i}{\sqrt{3}} =$	0.38
Uncertainty of Reference Gas	u_{ref}	$u(x_i) = \frac{u_{ref}}{\sqrt{3}} =$	0.48
Effect of Voltage Fluctuation	u_v	$u(x_i) = \frac{u_v \times R_i}{\sqrt{3}} =$	0.16
Effect of Oxygen Synergism	u_{syn}	$u(x_i) = \frac{u_{syn} \times R_i}{\sqrt{3}} =$	0.40
Combined Standard Uncertainty		$u_c = \sqrt{u_{lof}^2 + u_{d,s}^2 + u_r^2 + u_{loss}^2 + u_t^2 + u_i^2 + u_{ref}^2}$	1.12
Expanded measurement uncertainty (at 95% confidence)		$U_{EXP} = 2 \times u_c$	2.23
Applied Span Concentration			48.07
Measured Span Concentration, STP Dry Gas			48.19
Expanded measurement uncertainty as % of Applied Span			5 %

* Signal 3030 FID

Environmental Compliance Limited

Potters Waste
Permit No
Variation No
Report Ref

: BU77661C
: EPR/BU77661C/V004
: P3334 : R002

Installation Name : Flare Stack
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

TVOCs Uncertainty of Measurements

Flare - TVOC - Uncertainty of Measurement Results - Calculations Part 1

Performance Characteristics	Standard Uncertainty (% of Range)	Distribution	Divisor	Min Certified Range	
				O ₂ 0 - 25 %Vol	TVOC 0 - 15 mgC/m ³
Lack of fit ⁽¹⁾	u_{lof}	Rectangular	$\sqrt{3}$	0.13	0.73
Span drift ⁽²⁾	$u_{d,s}$			0.029	0.35
Losses / leakage in the sample system ⁽⁴⁾	u_{loss}			1.00	0.15
Temperature dependant span drift ⁽⁵⁾	u_t			0.070	0.30
Interferents ⁽¹⁾	u_i			0.56	4.39
Effect of Voltage Fluctuation ⁽⁷⁾	u_v			...	1.80
Effect of Oxygen Synergism ⁽⁷⁾	u_{syn}			...	

Notes:

For rectangular distributions, $u(x_i) = \frac{u \times R_i}{\sqrt{3}}$

For $u(x_i) = \Delta x_i \sqrt{\frac{(x_{i,max} - x_{i,adj})^2 + (x_{i,min} - x_{i,adj})^2 + (x_{i,max} - x_{i,adj})^2}{3}}$, when $|x_{i,max} - x_{i,adj}| = |x_{i,min} - x_{i,adj}|$ then $u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$

Where $u(x_i) = \frac{\sigma}{\sqrt{n}}$ (See note 6 below), $\sigma = \sqrt{\frac{\sum (x_i - \bar{x})^2}{n-1}}$

Performance Characteristics	Uncertainty (Units of final measurement)	Distribution	Divisor	O ₂ 0 - 25 %Vol	TVOC 0 - 15 mgC/m ³
Lack of fit	u_{lof}	Rectangular	$\sqrt{3}$	0.019	0.064
Span drift	$u_{d,s}$			0.0041	0.031
Temperature dependant span drift	u_t			0.020	0.052
Interferents	u_i			0.081	0.38
Effect of Voltage Fluctuation (See Note)	u_v			...	0.16

Flare - TVOC - Uncertainty of Measurement Results - Calculations Part 2

Performance Characteristics	Uncertainty (Units of final measurement)	Date & Time	O ₂ 0 - 25 %Vol	TVOC 0 - 15 mgC/m ³
Losses / leakage in the sample system	u_{loss}	11/01/18 13:38 - 14:37	0.096	0.0066
Standard Error of Measured Value	u_{SE}	11/01/18 13:38 - 14:37	0.068	0.21

Effect on Uncertainty Caused by Oxygen

$$u_{Corr_{O_2}} = \frac{(20.9\% - O_{2,ref})}{(20.9\% - O_{2,measured})} \times \text{Uncertainty of } O_2 \text{ Meas} =$$

$$f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 1.5792$$

$$u_{f_{O_2}} = \frac{u_{Corr_{O_2}} \times f_{O_2} \times 100}{f_{O_2}} = 1.59\%$$

The effect of oxygen on the overall uncertainties (below) is incorporated using the following equation:-

$$u_{combined} = \sqrt{\sum (u_{f_{O_2}})^2 + (\text{Uncertainty of Measurement of Determinand})^2}$$

Where oxygen or moisture correction is required, uncertainty based on the standard error of the measured peripheral value is converted to units of final measurement using a sensitivity coefficient C,

$$\therefore u(x_i) = C_i u_i \text{ where } C_i = \frac{\partial f}{\partial x_i}$$

Flare - TVOC - Uncertainty of Measurement Results - Calculations Part 3

Uncertainty	Date & Time	O ₂ 0 - 25 %Vol	*TVOC 0 - 15 mgC/m ³
Measured Concentration	11/01/18 13:38 - 14:37	9.57	4.46
Expanded Uncertainty as Percentage of Measured Concentration		3 %	20 %

$$\text{Combined Standard Uncertainty } u_c = \sqrt{u_{lof}^2 + u_{d,s}^2 + u_{loss}^2 + u_t^2 + u_i^2 + u_{v_{ref}}^2 + u_v^2 + u_{syn}^2}$$

$$\text{Expanded uncertainty (at 95% confidence)} U_{Exp} = 2 \times u_c$$

- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range as maximum drift per 24hr period
- Expressed as a percentage of the certified range
- Expressed as a percentage of the applied span concentration
- Expressed as a percentage of the certified range per one degree centigrade
- Where the uncertainty of moisture is taken from the manual extract test calculations.
- Expressed as a percentage of the certified range
- Where no uncertainty is presented above, the uncertainty is > 100%

Environmental Compliance Limited

Potters Waste
Permit No
Variation No
Report Ref

: BU77661C
: EPR/BU77661C/V004
: P3334 : R002

Installation Name : Flare Stack
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

SO₂ Uncertainty

Site: Brynposteg
Location: Flare

$$u_{\text{mass}} = \sqrt{\sum (u_{\text{filter}})^2 + (u_{\text{solution}})^2}$$

Determinand	Filter mg	Solution mg	Recovered Mass mg	LAB Method Uncert (%) K=2 Filter mg	Solution mg	Standard Uncertainty Filter mg	Standard Uncertainty Solution mg	Combined Uncertainty mg
One								
...
Sulphur Dioxide	...	0.40	0.40	...	0.0524	...	0.0262	0.0262
...
...
...
...

	One		Standard Uncertainty @ 95%
Sampled Volume (V _s)	0.24	m ³	uV _m 0.001 m ³
Meter Correction Factor (Y _d)	0.97
Meter Temperature (T _m)	281.00	k	uT _m 1.5 k
Average Differential Pressure (ΔH)	3.00	mmH ₂ O	uΔH 0.25 mmH ₂ O
Barometric Pressure (p _b)	735.06	mmHg	uP _b 3.8 mmHg
ΔH + p _s (p _{sd})	98.03	kPa	...
Oxygen content (O _{2,m})	9.40	% by volume	uO _{2,m} = σ/√n 0.0639 % by volume
Moisture Content (H ₂ O)	7.55	% by volume	uH ₂ O 0.66 % by volume

Note: In the following calculations, the sensitivity coefficient (C) is estimated using: $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by $C_i u_i$ where C_i is the sensitivity coefficient, u_i is the standard uncertainty and i is the index identifying the contributing factor e.g. $i = uV_m, uT_m$ etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

One:

$$f_{s, \text{wet}} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured ΔH uncertainty component (uΔH), measured stack pressure uncertainty component (uP_b) & measured temperature of dry gas uncertainty component (uT_{m, dry})

One:

$$f_s = \frac{273}{760} \times \frac{P_b + \frac{\Delta H}{13.6}}{T_m} \times Y_d = 0.916$$

	Maximum	Minimum	Sensitivity	u _{stp}
uΔH	0.92	0.92	0.0000916	0.0000229
uP _b	0.92	0.91	0.00125	0.00467
uT _m	0.92	0.91	0.00326	0.00489
H ₂ O

$$u_{f_s} = \sqrt{\left(\frac{u(\Delta H)^2 + (uP_b)^2}{(P_b/101.3)} \right) + \left(\frac{uT_m}{(T_m/273.15)} \right)^2 + \left(\frac{uH_2O}{(100/(100-H_2O))} \right)^2} = 0.00621$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV_{ad}) & volume uncertainty component (uV_m)

One:

$$V_{std} = V_{measured} \times f_s = 0.223$$

	Maximum m ³	Minimum m ³	Sensitivity	Standard Uncertainty (m ³)
Effect of uV _{ad}	0.22	0.22	0.24	0.00151
Effect of uV _m	0.22	0.22	0.92	0.000916

Combined Standard Uncertainty

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uV_{std}}{f_s} \right)^2 + \left(\frac{uV_m}{V_m} \right)^2} = 0.000916$$

Uncertainty of Oxygen Correction Factor (%):-

One:

$$f_{O_2} = \frac{20.9\% - O_{2, \text{ref}}}{20.9\% - O_{2, \text{measured}}} = 1.56$$

$$u_{\text{Corr } O_2} = \frac{20.9\% - O_{2, \text{ref}}}{(20.9\% - O_{2, \text{measured}}) \times (20.9\% - O_{2, \text{measured}})} \times \text{Uncertainty of } O_2 \text{ Measurement} = 0.0244$$

$$u_{f_{O_2}} = \frac{u_{\text{Corr } O_2}}{f_{O_2}} \times 100 = 1.57\%$$

Environmental Compliance Limited

Potters Waste

Permit No : BU77661C

Variation No : EPR/BU77661C/V004

Report Ref : P3334 : R002

Installation Name : Flare Stack

Visit Details : Annual Compliance

Survey Dates : 10th & 11th January 2018

Report Issue Date : 31st January 2018

Uncertainty in final measurement @ reference conditions due to mass uncertainty component (uM)

Determinand	One:			
	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	uM mg/Nm ³
...
...
Sulphur Dioxide	3.00	2.63	6.99	0.18
...

Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

Determinand	One:	
	uL mg/Nm ³	
...	...	
...	...	
Sulphur Dioxide	0.0325	
...	...	

Uncertainty in final measurement @ Reference Conditions due to uVstp

Determinand	One:			
	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	uVstp mg/Nm ³
...
...
Sulphur Dioxide	2.83	2.81	12.65	0.0116
...

Combined Uncertainty excluding oxygen contribution

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (uV_{stp})^2}$$

Determinand	One:			
	Combined Uncertainty mg/Nm ³	Expanded Uncertainty mg/Nm ³	Measured Concentration mg/Nm ³	Percent of Measured Concentration
...
...
Sulphur Dioxide	0.19	0.37	2.82	13.23
...

Combined Uncertainty including oxygen contribution

$$u_{combined} = \sqrt{\sum (uf_{O_2})^2 + (Uncertainty\ of\ Measurement\ of\ Determinand)^2}$$

Determinand	Measurement Uncertainty of Determinand	Measurement Uncertainty of Oxygen Corr Factor	Overall Measurement Uncertainty inc O ₂ Corr factor (Ucombined)
...
...
Sulphur Dioxide	13.23	1.57	13.32
...

Environmental Compliance Limited

Potters Waste		Installation Name	: Flare Stack
Permit No	: BU77661C	Visit Details	: Annual Compliance
Variation No	: EPR/BU77661C/V004	Survey Dates	: 10th & 11th January 2018
Report Ref	: P3334 : R002	Report Issue Date	: 31st January 2018

Non-methane VOCs Uncertainty

Site: Potters Waste, Brynposteg
Location: Landfill, Stack ID:Flare

				Standard Uncertainty @ 95%		
Sampled Volume	V_m	0.05856	m^3	uV_m	0.000	m^3
Meter Correction Factor or ml/count	Y_d	0.9746
Meter Temperature	T_m	286.25	K	uT_m	1.5	K
Barometric Pressure	P_b	980.00	mBar		10.0	mBar
Oxygen content	$O_{2,m}$	9.82	% Vol	$uO_{2,m}$	0.59	% Vol
Moisture	H_2O	9.20	% Vol	uH_2O	1.66	% Vol

Tubes					
Determinand	Recovered Mass		Standard Uncertainty		
Flare	3.00	μg	uM	0.30	μg

Environmental Compliance Limited

Potters Waste
Permit No : BU77661C
Variation No : EPR/BU77661C/V004
Report Ref : P3334 : R002

Installation Name : Flare Stack
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

Note: In the following calculations, the sensitivity coefficient (C) is estimated using: $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by $C_i u_i$ where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. $i = uV_m, uT_m$ etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from meter:

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (uP_b), measured temperature of dry gas uncertainty component (uT_m) & measured moisture (uH_2O) where required

$$f_s = \frac{273}{T_m} \times \frac{P}{101.3} = 0.92$$

	Maximum	Minimum	Sensitivity	ufstp
uP_b	0.48	0.47	0.000482	0.00482
uT_m	0.93	0.92	0.00322	0.00483
uH_2O

$$\frac{uf_s}{f_s} = \sqrt{\left(\frac{uP_b}{(P_b/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{(100/(100 - H_2O))}\right)^2} = 0.00626$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV_{std}) & volume uncertainty component (uV_m)

$$V_{std} = V_{measured} \times f_s = 0.0527$$

	Maximum m ³	Minimum m ³	Sensitivity	Standard Uncertainty m ³
Effect of uf_s	0.0530	0.0523	0.0571	0.000357
Effect of uV_m	0.0527	0.0526	0.90	8.992E-06

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uf_s}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.00300$$

Uncertainty of correction factor to reference conditions (excluding oxygen contribution) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

$$uL = \frac{Conc \times \frac{2}{100}}{\sqrt{3}}$$

Flare

Tubes uL mg/Nm ³	Condensate uL mg/Nm ³
0.000658	...

Environmental Compliance Limited

Potters Waste

Permit No : BU77661C
Variation No : EPR/BU77661C/V004
Report Ref : P3334 : R002

Installation Name : Flare Stack
Visit Details : Annual Compliance
Survey Dates : 10th & 11th January 2018
Report Issue Date : 31st January 2018

$$Conc = \frac{M_{Recovered}}{V_m \times f_s \times f_{O_2}}$$

Uncertainty in final measurement @ Reference Conditions due to $uM_{Recovered}$

Charcoal Tube Results				
	Maximum	Minimum	Sensitivity	Standard Uncertainty
	mg/Nm ³	mg/Nm ³		mg/Nm ³
Non Methane VOC	0.0598	0.0541	18.99	0.00285
Condensate Results				
	Maximum	Minimum	Sensitivity	Standard Uncertainty
	mg/Nm ³	mg/Nm ³		mg/Nm ³
Non Methane VOC				


Uncertainty in final measurement @ Reference Conditions due to uV_{STD}

Charcoal Tube Results				
	Maximum	Minimum	Sensitivity	Standard Uncertainty
	mg/Nm ³	mg/Nm ³		mg/Nm ³
Non Methane VOC	0.0604	0.0539	1.09	0.00326

Combined Uncertainty (excluding Oxygen contribution)

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (uV_{stp})^2}$$

Charcoal Tubes: Determinand	Combined Uncertainty mg/Nm ³	Expanded Uncertainty mg/Nm ³	Measured Concentration mg/Nm ³	Percent of Measured Concentration
Non Methane VOC	0.00438	0.0088	0.0921	9.52



Appendix 3

APPENDIX 3 – GROUNDWATER








Figure 1 – Weekly level data (measured as metres above ordnance datum)

Table 1: Groundwater Monthly monitoring data

LOCATION	DATE	Ammoniacal Nitrogen	Chloride	Cyanide	Electrical Conductivity	pH	Sulphate
		2	69	-	-	-	-
		mg/l	mg/l	mg/l	µS/cm	pH units	mg/l
W1	MIN	0.41	105.0	0.009	461.00	5.9	5.30
	MAX	0.62	257.0	0.009	890.00	6.3	28.80
	AV	0.43	203.0	0.009	728.83	6.1	16.35
W2	MIN	0.41	28.1	0.009	171.00	6.9	<4.4
	MAX	0.60	32.9	0.009	182.00	7.8	<4.4
	AV	0.43	30.8	0.009	176.25	7.3	<4.4
W3	MIN	0.41	4.7	0.009	105.00	5.8	<4.4
	MAX	0.41	18.8	0.009	319.00	7.4	59.80
	AV	0.41	13.5	0.009	214.83	6.4	28.11
W4	MIN	1.21	20.1	0.009	303.00	6.4	8.20
	MAX	3.13	31.5	0.009	362.00	6.9	31.50
	AV	1.77	23.9	0.009	331.25	6.6	21.17
W5	MIN	0.41	11.5	0.009	157.00	5.5	24.80
	MAX	0.46	27.0	0.009	239.00	6.0	45.70
	AV	0.42	18.7	0.009	192.50	5.7	37.09
W6	MIN	0.41	4.2	0.009	58.80	5.7	<4.4
	MAX	0.41	15.4	0.009	112.00	6.4	6.30
	AV	0.41	9.5	0.009	83.29	6.0	4.57
W7	MIN	0.41	11.8	0.009	307.00	7.0	21.40
	MAX	0.41	16.3	0.009	326.00	7.6	31.70
	AV	0.41	13.7	0.009	316.25	7.2	27.85
W8	MIN	0.41	13.1	0.009	281.00	5.9	18.00
	MAX	0.41	30.7	0.009	386.00	7.1	31.40
	AV	0.41	17.7	0.009	301.58	6.6	23.53
W9	MIN	0.77	11.1	0.009	96.30	6.0	11.60
	MAX	0.41	17.9	0.009	175.00	6.6	27.60
	AV	0.41	13.5	0.009	150.28	6.2	23.33









Table 2: Groundwater Quarterly monitoring data (EP limit exceedances highlighted)

PARAMETER	Unit	EP Limit	Quarter	GW1	GW2	GW3	GW4	GW5
2,4 - D	ug/l	0.1	Q1	<0.10	<0.05	<0.05	<0.10	<0.05
			Q2	<0.05	<0.05	<0.05	<0.10	<0.05
			Q3	<0.50	<0.05	<0.05	<0.05	<0.05
			Q4	<0.05	<0.05	<0.05	<0.05	<0.05
Ammoniacal Nitrogen	mg/l	2	Q1	<0.41	<0.41	<0.41	1.21	<0.41
			Q2	<0.41	<0.41	<0.41	1.21	<0.41
			Q3	<0.41	<0.41	<0.41	1.93	<0.41
			Q4	<0.41	0.6	<0.41	1.84	0.46
Cadmium	mg/l	0.0056	Q1	<0.0006	<0.0006	<0.0006	<0.0006	<0.0006
			Q2	<0.0006	<0.0006	<0.0006	<0.0006	<0.0006
			Q3	0.0022	<0.0006	<0.0006	<0.0006	<0.0006
			Q4	0.0011	<0.0006	<0.0006	<0.0006	<0.0006
Ethyl Benzene	ug/l	1	Q1	<0.10	<0.10	<0.10	<0.10	<0.10
			Q2	<0.10	<0.10	<0.10	<0.10	<0.10
			Q3	<0.10	<0.10	<0.10	<0.10	<0.10
			Q4	<0.10	<0.10	<0.10	<0.10	<0.10
Mecoprop	ug/l	0.1	Q1	<0.08	<0.04	<0.04	<0.08	<0.04
			Q2	<0.04	<0.04	<0.04	<0.08	<0.04
			Q3	<0.40	<0.04	<0.04	0.06	0.11
			Q4	<0.04	<0.04	<0.04	0.06	0.07
Nickel	mg/l	0.12	Q1	0.009	<0.003	0.010	0.009	0.014
			Q2	0.004	<0.003	0.005	0.009	0.017
			Q3	0.016	<0.003	0.008	0.008	0.020
			Q4	0.006	<0.003	0.005	0.005	0.017
Toluene	ug/l	4	Q1	<0.10	0.2	<0.10	<0.10	<0.10
			Q2	<0.10	0.13	<0.10	<0.10	<0.10
			Q3	<0.10	0.41	0.28	<0.10	<0.10
			Q4	<0.10	0.27	<0.10	<0.10	<0.10
Total Xylenes	ug/l	3	Q1	<0.20	<0.20	<0.20	<0.20	<0.20
			Q2	<0.20	<0.20	<0.20	<0.20	<0.20
			Q3	<0.20	<0.20	<0.20	<0.20	<0.20
			Q4	<0.20	<0.20	<0.20	<0.20	<0.20
Zinc	mg/l	0.85	Q1	0.020	<0.018	0.060	0.040	0.090
			Q2	0.03	<0.018	0.03	0.03	0.1
			Q3	0.08	<0.018	0.05	0.03	0.106
			Q4	0.03	<0.018	0.05	0.07	0.111

PARAMETER	Unit	EP Limit	Quarter	GW6	GW7	GW8	GW9
2,4 - D	ug/l	0.1	Q1	<0.05	<0.05	<0.05	<0.05
			Q2	<0.05	<0.05	<0.05	<0.05
			Q3	<0.05	<0.05	<0.05	<0.05
			Q4	<0.05	<0.05	<0.05	<0.05
Ammoniacal Nitrogen	mg/l	2	Q1	<0.41	<0.41	<0.41	<0.41
			Q2	<0.41	<0.41	<0.41	<0.41
			Q3	<0.41	<0.41	<0.41	<0.41
			Q4	<0.41	<0.41	<0.41	<0.41
Cadmium	mg/l	0.0056	Q1	<0.0006	<0.0006	<0.0006	<0.0006
			Q2	<0.0006	<0.0006	<0.0006	<0.0006
			Q3	<0.0006	<0.0006	<0.0006	<0.0006
			Q4	<0.0006	<0.0006	<0.0006	<0.0006
Ethyl Benzene	ug/l	1	Q1	<0.10	<0.10	<0.10	<0.10
			Q2	<0.10	<0.10	<0.10	<0.10
			Q3	<0.10	<0.10	<0.10	<0.10
			Q4	<0.10	<0.10	<0.10	<0.10
Mecoprop	ug/l	0.1	Q1	<0.04	<0.04	<0.04	<0.04
			Q2	<0.04	<0.04	<0.04	<0.04
			Q3	<0.04	<0.04	<0.04	<0.04
			Q4	<0.04	<0.04	<0.04	<0.04
Nickel	mg/l	0.12	Q1	0.005	<0.003	<0.003	<0.003
			Q2	<0.003	<0.003	<0.003	<0.003
			Q3	0.004	<0.003	0.004	<0.003
			Q4	0.003	<0.003	0.003	<0.003
Toluene	ug/l	4	Q1	<0.10	<0.10	<0.10	<0.10
			Q2	<0.10	<0.10	<0.10	<0.10
			Q3	<0.10	<0.10	<0.10	<0.10
			Q4	<0.10	<0.10	<0.10	<0.10
Total Xylenes	ug/l	3	Q1	<0.20	<0.20	<0.20	<0.20
			Q2	<0.20	<0.20	<0.20	<0.20
			Q3	<0.20	<0.20	<0.20	<0.20
			Q4	<0.20	<0.20	<0.20	<0.20
Zinc	mg/l	0.85	Q1	0.030	<0.018	0.020	0.070
			Q2	0.04	<0.018	0.03	0.02
			Q3	0.07	<0.018	<0.018	0.03
			Q4	0.09	0.03	0.03	0.07

Table 3: Groundwater Quarterly monitoring data (No EP Limits), Quarter 1

Reference	Unit	W1	W2	W3	W4	W5	W6	W7	W8	W9	W10
Acenaphthene	ug/l	<0.02	<0.01	<0.01	<0.04	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Acenaphthylene	ug/l	<0.02	<0.01	<0.01	<0.04	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Alkalinity as CaCO3	mg/l	28.2	42.4	9.8	108	11.4	24	123	106	19.9	118
Anthracene	ug/l	<0.02	<0.01	<0.01	<0.04	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Antimony Ultra Low Total as Sb	mg/l	<0.0012	<0.0012	<0.0012	<0.0012	<0.0012	<0.0012	<0.0012	<0.0012	<0.0012	<0.0012
Arsenic, Ultra Low Total as As	mg/l	0.0061	0.001	0.0059	0.018	0.0016	0.0098	0.0011	0.0025	<0.0010	<0.0010
Benzene	ug/l	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10
Benzo (a) anthracene	ug/l	<0.02	<0.01	<0.01	<0.04	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Benzo (a) pyrene	ug/l	<0.02	<0.01	<0.01	<0.04	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Benzo (b) fluoranthene	ug/l	<0.02	<0.01	<0.01	<0.04	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Benzo (g,h,i) perylene	ug/l	<0.02	<0.01	<0.01	<0.04	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Benzo (k) fluoranthene	ug/l	<0.02	<0.01	<0.01	<0.04	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Bicarbonate Alkalinity	mg/l	28	39.2	8.8	102	12	23.2	122	106	19.9	118
Calcium , Total as Ca	mg/l	10.7	9.7	21.8	36.7	11.3	9.31	37.9	36.3	10.8	19.4
Chloride as Cl	mg/l	252	30.8	18.3	22.7	13.8	13.2	14.9	15.6	14.3	11.7
Chromium , Total as Cr	mg/l	<0.002	<0.002	0.003	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002
Chrysene	ug/l	<0.02	<0.01	<0.01	<0.04	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Conductivity- Electrical 20C	uS/cm	890	171	218	303	157	99.9	307	290	150	278
Copper, Total as Cu	mg/l	<0.009	<0.009	0.014	<0.009	0.044	<0.009	<0.009	<0.009	<0.009	<0.009
Cyanide, Total as CN	mg/l	<0.009	<0.009	<0.009	<0.009	<0.009	<0.009	<0.009	<0.009	<0.009	<0.009
Dibenz (a,h) anthracene	ug/l	<0.02	<0.01	<0.01	<0.04	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Dissolved Oxygen, Fixed	mg/l	<0.5	1.7	6.5	<0.5	4	10	1.5	1.9	8.5	12.8
Fluoranthene	ug/l	<0.02	<0.01	<0.01	<0.04	<0.04	<0.01	<0.01	<0.01	0.011	<0.01
Fluorene	ug/l	<0.02	<0.01	<0.01	<0.04	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Indeno (1,2,3) cd pyrene	ug/l	<0.02	<0.01	<0.01	<0.04	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Iron , Total as Fe	mg/l	3.03	<0.23	2.63	8	0.66	3.42	0.35	0.86	<0.23	<0.23
Lead , Total as Pb	mg/l	<0.006	<0.006	0.035	<0.006	<0.006	<0.006	0.011	0.007	<0.006	<0.006
m&p Xylene	ug/l	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20
Magnesium, Total as Mg	mg/l	3.7	1.1	5.9	8.3	2.9	2.1	5.9	8.9	2.9	5.9
Manganese , Total as Mn	mg/l	2.27	0.012	0.596	3.53	0.788	1.04	0.617	0.912	0.03	0.623
Mercury, Total as Hg	mg/l	0.00001	<0.00001	<0.00001	<0.00001	<0.00001	<0.00001	<0.00001	<0.00001	<0.00001	<0.00001
Naphthalene	ug/l	<0.02	<0.01	<0.01	<0.04	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Nitrate as N	mg/l	<0.7	<0.7	5.3	<0.7	3.5	0.9	<0.7	<0.7	<0.7	<0.7
o-Xylene	ug/l	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10
PAH, Total	ug/l	<0.02	<0.01	<0.01	<0.04	<0.04	<0.01	<0.01	<0.01	0.037	<0.01
pH	pH units	6	7	5.8	6.4	5.7	6	7.1	7	6.5	7.5
Phenanthrene	ug/l	<0.02	<0.01	<0.01	<0.04	<0.04	<0.01	<0.01	<0.01	0.011	<0.01
Phenols Mono (Phenol Index)	mg/l	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10

Reference	Unit	W1	W2	W3	W4	W5	W6	W7	W8	W9	W10
Potassium , Total as K	mg/l	1.32	2	2.91	1.82	1.72	0.51	2.43	1.1	0.99	2.43
Pyrene	ug/l	<0.02	<0.01	<0.01	<0.04	<0.04	<0.01	<0.01	<0.01	0.015	<0.01
Selenium Ultra Low Total as Se	mg/l	<0.0008	<0.0008	<0.0008	<0.0008	<0.0008	<0.0008	<0.0008	<0.0008	<0.0008	<0.0008
Silver , Total as Ag	mg/l	<0.0007	<0.0007	<0.0007	<0.0007	<0.0007	<0.0007	0.0007	<0.0007	<0.0007	<0.0007
Sodium , Total as Na	mg/l	137	20.6	8.98	10.2	8.94	5.78	18.2	8.53	10.6	28.7
Sulphate as SO4	mg/l	13.4	<4.4	59.8	26.9	31.3	<4.4	29.4	25.2	26.3	10.1

Table 4: Groundwater Quarterly and Six Monthly monitoring data (No EP Limits), Quarter 2

Reference	Unit	W1	W2	W3	W4	W5	W6	W7	W8	W9
Acenaphthene	ug/l	<0.04	<0.02	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Acenaphthylene	ug/l	<0.04	<0.02	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Alkalinity as CaCO3	mg/l	45.4	43.2	147	110	14.6	16.4	122	105	26.8
Anthracene	ug/l	<0.04	<0.02	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Antimony Ultra Low Total as Sb	mg/l	<0.0012	<0.0012	<0.0012	<0.0012	<0.0012	<0.0012	<0.0012	<0.0012	<0.0012
Arsenic, Ultra Low Total as As	mg/l	0.01	0.0011	0.013	0.016	0.0019	0.0019	0.011	0.002	<0.0010
Benzene	ug/l	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10
Benzo (a) anthracene	ug/l	<0.04	<0.02	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Benzo (a) pyrene	ug/l	<0.04	<0.02	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Benzo (b) fluoranthene	ug/l	<0.04	<0.02	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Benzo (g,h,i) perylene	ug/l	<0.04	<0.02	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Benzo (k) fluoranthene	ug/l	<0.04	<0.02	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Bicarbonate Alkalinity	mg/l	45.4	43.2	147	110	14.6	16.4	122	105	26.8
Calcium , Total as Ca	mg/l	13.3	9.74	39.2	36.6	12.8	9.41	39.7	36	11.6
Chloride as Cl	mg/l	248	30.3	10.9	20.2	14.6	14.2	12.7	13.1	11.1
Chromium , Total as Cr	mg/l	<0.002	<0.002	0.003	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002
Chrysene	ug/l	<0.04	<0.02	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Conductivity- Electrical 20C	uS/cm	867	180	315	319	177	112	312	284	160
Copper, Total as Cu	mg/l	<0.009	<0.009	0.019	<0.009	0.041	<0.009	<0.009	<0.009	<0.009
Cyanide, Total as CN	mg/l	<0.009	<0.009	<0.009	<0.009	<0.009	<0.009	<0.009	<0.009	<0.009
Dibenz (a,h) anthracene	ug/l	<0.04	<0.02	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Dissolved Oxygen, Fixed	mg/l	<0.5	0.9	0.8	0.6	2.4	4.2	<0.5	3	2.5
Ethyl Benzene	ug/l	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10
Fluoranthene	ug/l	<0.04	<0.02	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Fluorene	ug/l	<0.04	<0.02	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Indeno (1,2,3) cd pyrene	ug/l	<0.04	<0.02	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Iron , Total as Fe	mg/l	2.58	0.33	3.76	8.82	0.76	0.71	4.1	0.73	<0.23
Lead , Total as Pb	mg/l	<0.006	<0.006	0.099	<0.006	<0.006	<0.006	0.146	0.009	<0.006
m&p Xylene	ug/l	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20
Magnesium, Total as Mg	mg/l	4.5	1.1	9.3	8.4	3.4	2	6.2	8.9	3.4
Manganese , Total as Mn	mg/l	1.89	0.015	3.18	3.41	1.52	0.189	1.03	0.874	0.039
Mercury, Total as Hg	mg/l	<0.00005	<0.00005	<0.00005	<0.00005	<0.00005	<0.00005	<0.00005	<0.00005	<0.00005
Naphthalene	ug/l	<0.04	<0.02	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Nitrate as N	mg/l	<0.7	<0.7	<0.7	<0.7	2.6	1.4	<0.7	<0.7	1.2
o-Xylene	ug/l	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10
PAH, Total	ug/l	<0.04	<0.02	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
pH	pH units	6.3	7.4	7.4	6.9	6	6.4	7.6	7.1	6.6
Phenanthrene	ug/l	<0.04	<0.02	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01

Reference	Unit	W1	W2	W3	W4	W5	W6	W7	W8	W9
Phenols Mono (Phenol Index)	mg/l	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10
Potassium , Total as K	mg/l	1.47	2.33	2.1	2.19	2.03	0.56	2.9	1.21	0.94
Pyrene	ug/l	<0.04	<0.02	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Selenium Ultra Low Total as Se	mg/l	<0.0008	<0.0008	0.0017	<0.0008	<0.0008	<0.0008	<0.0008	<0.0008	<0.0008
Silver , Total as Ag	mg/l	<0.0007	<0.0007	<0.0007	<0.0007	<0.0007	<0.0007	<0.0007	<0.0007	<0.0007
Sodium , Total as Na	mg/l	139	20	9.09	10.5	9.22	6.44	17.8	8.08	10.4
Sulphate as SO4	mg/l	11.8	<4.4	11.9	30.1	36	<4.4	27.9	26.4	26.4

Table 5: Groundwater Quarterly monitoring data (No EP Limits), Quarter 3

Reference	Unit	W1	W2	W3	W4	W5	W6	W7	W8	W9
Acenaphthene	ug/l	<0.10	<0.01	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Acenaphthylene	ug/l	<0.10	<0.01	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Alkalinity as CaCO3	mg/l	57.6	42.4	162	136	24	9.6	125	110	33.6
Anthracene	ug/l	<0.41	<0.41	<0.41	1.93	<0.41	<0.41	<0.41	<0.41	<0.41
Antimony Ultra Low Total as Sb	mg/l	<0.0012	<0.0012	<0.0012	<0.0012	<0.0012	<0.0012	<0.0012	<0.0012	<0.0012
Arsenic, Ultra Low Total as As	mg/l	0.042	<0.0010	0.059	0.013	0.0014	0.0034	0.006	0.0019	<0.0010
Benzene	ug/l	<0.10	0.1	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10
Benzo (a) anthracene	ug/l	<0.10	<0.01	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Benzo (a) pyrene	ug/l	<0.10	<0.01	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Benzo (b) fluoranthene	ug/l	<0.10	<0.01	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Benzo (g,h,i) perylene	ug/l	<0.10	<0.01	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Benzo (k) fluoranthene	ug/l	<0.10	<0.01	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Bicarbonate Alkalinity	mg/l	57.6	42.4	162	136	24	9.6	125	110	33.6
Calcium , Total as Ca	mg/l	13.3	9.74	39.2	36.6	12.8	9.41	39.7	36	11.6
Chloride as Cl	mg/l	6.21	10.4	42.3	43.7	17.2	4.4	40.6	39.4	13.4
Chromium , Total as Cr	mg/l	107	31.2	11.4	27.2	24.3	4.2	14.1	16.5	12.8
Chrysene	ug/l	<0.10	<0.01	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Conductivity- Electrical 20C	uS/cm	461	177	305	357	230	58.8	326	290	164
Copper, Total as Cu	mg/l	0.059	<0.009	0.036	<0.009	0.037	0.01	<0.009	<0.009	<0.009
Cyanide, Total as CN	mg/l	<0.009	<0.009	<0.009	<0.009	<0.009	<0.009	<0.009	<0.009	<0.009
Dibenz (a,h) anthracene	ug/l	<0.10	<0.01	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Dissolved Oxygen, Fixed	mg/l	<0.5	0.6	4	2.6	<0.5	6.2	2.2	0.6	4.1
Ethyl Benzene	ug/l	N/S	N/S	N/S	N/S	N/S	N/S	N/S	N/S	N/S
Fluoranthene	ug/l	<0.10	<0.01	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Fluorene	ug/l	<0.10	<0.01	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Indeno (1,2,3) cd pyrene	ug/l	<0.10	<0.01	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Iron , Total as Fe	mg/l	10.9	0.35	10	7.22	0.44	0.63	2.04	0.74	<0.23
Lead , Total as Pb	mg/l	0.025	<0.006	0.278	<0.006	<0.006	<0.006	0.092	<0.006	<0.006
m&p Xylene	ug/l	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20
Magnesium, Total as Mg	mg/l	1.6	1.2	8.9	9.5	4.3	0.9	6.3	9.4	3.8
Manganese , Total as Mn	mg/l	1.48	0.013	1.83	3.99	2.08	0.114	0.479	0.9	0.062
Mercury, Total as Hg	mg/l	<0.00010	<0.00010	<0.00010	<0.00010	<0.00010	<0.00010	<0.00010	<0.00010	<0.00010
Naphthalene	ug/l	<0.10	<0.01	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Nitrate as N	mg/l	<0.7	<0.7	<0.7	<0.7	1.2	1.2	<0.7	<0.7	<0.7
o-Xylene	ug/l	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10
PAH, Total	ug/l	<0.10	<0.01	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
pH	pH units	6.2	6.9	7.1	6.7	5.9	5.9	7.3	6.9	6.4

Reference	Unit	W1	W2	W3	W4	W5	W6	W7	W8	W9
Phenanthrene	ug/l	<0.10	<0.01	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Phenols Mono (Phenol Index)	mg/l	<0.10	<0.10	<0.10	<0.10	0.1	<0.10	<0.10	<0.10	<0.10
Potassium , Total as K	mg/l	1.06	2.04	1.92	2.07	2.25	0.34	2.49	1.11	0.79
Pyrene	ug/l	<0.10	<0.01	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Selenium Ultra Low Total as Se	mg/l	0.0036	<0.0008	0.0014	<0.0008	0.0011	<0.0008	<0.0008	<0.0008	<0.0008
Silver , Total as Ag	mg/l	<0.0007	<0.0007	<0.0007	<0.0007	<0.0007	<0.0007	<0.0007	<0.0007	<0.0007
Sodium , Total as Na	mg/l	57.1	21.1	8.9	12.4	14	4.4	22.6	9.04	11.2
Sulphate as SO4	mg/l	5.3	<4.4	<4.4	14.1	43.6	<4.4	31.7	21.5	21.2

Table 6: Groundwater Quarterly monitoring data (No EP Limits), Quarter 4

Reference	Unit	W1	W2	W3	W4	W5	W6	W7	W8	W9
Acenaphthene	ug/l	<0.04	<0.01	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Acenaphthylene	ug/l	<0.04	<0.01	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Alkalinity as CaCO3	mg/l	24.4	42.8	10.4	113	19.6	7.4	125	111	33.2
Anthracene	ug/l	<0.04	<0.01	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Antimony Ultra Low Total as Sb	mg/l	<0.0012	<0.0012	<0.0012	<0.0012	<0.0012	<0.0012	<0.0012	<0.0012	<0.0012
Arsenic, Ultra Low Total as As	mg/l	0.0097	<0.0010	0.014	0.02	0.0014	0.0056	0.0013	0.0024	<0.0010
Benzene	ug/l	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10
Benzo (a) anthracene	ug/l	<0.04	<0.01	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Benzo (a) pyrene	ug/l	<0.04	<0.01	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Benzo (b) fluoranthene	ug/l	<0.04	<0.01	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Benzo (g,h,i) perylene	ug/l	<0.04	<0.01	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Benzo (k) fluoranthene	ug/l	<0.04	<0.01	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Bicarbonate Alkalinity	mg/l	24.4	42.8	10.4	113	19.6	7.4	125	111	33.2
Calcium , Total as Ca	mg/l	11.9	10.2	17.6	45	14.7	4.91	40.9	37.9	13.2
Chloride as Cl	mg/l	255	32.1	18.8	31.5	26.3	8.5	12.3	20.3	15.5
Chromium , Total as Cr	mg/l	0.003	<0.002	0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002
Chrysene	ug/l	<0.04	<0.01	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Conductivity- Electrical 20C	uS/cm	845	176	178	362	210	70.6	314	290	162
Copper, Total as Cu	mg/l	0.018	<0.009	0.021	<0.009	0.036	0.009	<0.009	<0.009	<0.009
Cyanide, Total as CN	mg/l	<0.009	<0.009	<0.009	<0.009	<0.009	<0.009	<0.009	<0.009	<0.009
Dibenz (a,h) anthracene	ug/l	<0.04	<0.01	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Dissolved Oxygen, Fixed	mg/l	1	2	7.5	<0.5	<0.5	8.8	2.3	1.4	10.3
Ethyl Benzene	ug/l	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10
Fluoranthene	ug/l	<0.04	<0.01	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Fluorene	ug/l	<0.04	<0.01	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Indeno (1,2,3) cd pyrene	ug/l	<0.04	<0.01	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Iron , Total as Fe	mg/l	4.48	0.28	3.56	8.96	0.59	1.12	0.42	0.97	<0.23
Lead , Total as Pb	mg/l	0.007	<0.006	0.141	<0.006	<0.006	0.008	0.016	0.008	<0.006
m&p Xylene	ug/l	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20
Magnesium, Total as Mg	mg/l	3.9	1.1	4.7	9.8	3.7	1	6.3	9.1	3.7
Manganese , Total as Mn	mg/l	1.25	0.014	0.462	4.22	1.94	0.118	0.29	0.941	0.1
Mercury, Total as Hg	mg/l	<0.00010	<0.00010	<0.00010	<0.00010	0.00012	<0.00010	<0.00010	<0.00010	<0.00010
Naphthalene	ug/l	<0.04	<0.01	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Nitrate as N	mg/l	<0.7	<0.7	4.1	<0.7	<0.7	1.3	<0.7	<0.7	<0.7
o-Xylene	ug/l	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10
PAH, Total	ug/l	<0.04	0.039	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
pH	pH units	6	7.1	6.1	6.6	5.8	5.8	7.2	6.5	6.2

Reference	Unit	W1	W2	W3	W4	W5	W6	W7	W8	W9
Phenanthrene	ug/l	<0.04	0.023	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Phenols Mono (Phenol Index)	mg/l	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10
Potassium , Total as K	mg/l	1.7	2.11	2.23	2.26	2.18	0.4	2.65	1.26	0.85
Pyrene	ug/l	<0.04	0.016	<0.02	<0.04	<0.01	<0.01	<0.01	<0.01	<0.01
Selenium Ultra Low Total as Se	mg/l	0.0009	<0.0008	0.0023	<0.0008	<0.0008	<0.0008	<0.0008	<0.0008	<0.0008
Silver , Total as Ag	mg/l	<0.0007	<0.0007	<0.0007	<0.0007	<0.0007	<0.0007	<0.0007	<0.0007	<0.0007
Sodium , Total as Na	mg/l	131	20.9	7.3	14.4	13.5	5.14	19.8	8.78	11.4
Sulphate as SO4	mg/l	17.4	<4.4	36.9	27.3	41.4	<4.4	30.7	21.9	23.2

Table 7: Groundwater Annual Hazardous Substances Suite (No EP Limits) Detected Parameters Highlighted


Parameter	Units	GW 1	GW 2	GW 3	GW 4	GW 5	GW 6	GW 7	GW 8	GW 9
SVOC										
Phenol	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
Bis(2-chloroethyl)ether	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
2-Chlorophenol	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
1,3-Dichlorobenzene	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
1,4-Dichlorobenzene	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
2-Methylphenol	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
3&4-Methylphenol	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
Dibenzofuran	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
1,2-Dichlorobenzene	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
Bis(2-chloroisopropyl)ether	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
n-Nitrosodi-n-propylamine	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
Hexachloroethane	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
Nitrobenzene	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
Isophorone	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
2,4-Dimethylphenol	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
2-Nitrophenol	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
Bis(2-chloroethoxy)methane	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
2,4-Dichlorophenol	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
1,2,4-Trichlorobenzene	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
Naphthalene	ug/l	<4.0	<2.0	<4.0	<8.0	<2.0	<2.0	<2.0	<2.0	<2.0
Hexachlorobutadiene	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
4-Chloro-3-methylphenol	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
2-Methylnaphthalene	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
2,4,6-Trichlorophenol	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
2,4,5-Trichlorophenol	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
2-Chloronaphthalene	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
Dimethylphthalate	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
2,6-Dinitrotoluene	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
Acenaphthylene	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
Acenaphthene	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
2,4-Dinitrotoluene	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
Diethylphthalate	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
4-Nitrophenol	ug/l	<10.0	<5.0	<10.0	<20.0	<5.0	<5.0	<5.0	<5.0	<5.0
4-Chlorophenyl phenyl ether	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
Fluorene	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
Diphenylamine	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0

Parameter	Units	GW 1	GW 2	GW 3	GW 4	GW 5	GW 6	GW 7	GW 8	GW 9
SVOC										
4-Bromophenyl Phenyl Ether	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
Hexachlorobenzene	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
Pentachlorophenol	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
Phenanthrene	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
Anthracene	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
di-n-Butylphthalate	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
Fluoranthene	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
Pyrene	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
Benzyl Butyl Phthalate	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
Benzo(a)anthracene	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
Chrysene	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
Bis(2-ethylhexyl)phthalate	ug/l	<10.0	<5.0	<10.0	<20.0	<5.0	<5.0	<5.0	<5.0	<5.0
Di-n-octylphthalate	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
Benzo(b)fluoranthene	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
Benzo(k)fluoranthene	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
Benzo(a)pyrene	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
Indeno(1,2,3-c,d)pyrene	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
Dibenz(a,h)anthracene	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0
Benzo(g,h,i)perylene	ug/l	<2.0	<1.0	<2.0	<4.0	<1.0	<1.0	<1.0	<1.0	<1.0

Customer Sample Ref.	units	GW 1	GW 2	GW 3	GW 4	GW 5	GW 6	GW 7	GW 8	GW 9
VOC										
Dichlorodifluoromethane	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
Chloromethane	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
Chloroethane	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
Bromomethane	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
Trichlorofluoromethane	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
1,1-Dichloroethene	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
Dichloromethane	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
1,1-Dichloroethane	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
cis-1,2-Dichloroethene	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
2,2-Dichloropropane	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
Chloroform	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
Bromochloromethane	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
1,1,1-Trichloroethane	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
1,1-Dichloropropene	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
1,2-Dichloroethane	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
Benzene	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0

Customer Sample Ref.	units	GW 1	GW 2	GW 3	GW 4	GW 5	GW 6	GW 7	GW 8	GW 9
VOC										
1,2-Dichloropropane	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
Trichloroethene	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
Bromodichloromethane	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
Dibromomethane	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
cis-1,3-Dichloropropene	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
Toluene	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
trans-1,3-Dichloropropene	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
1,1,2-Trichloroethane	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
Carbon Tetrachloride	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
Vinyl Chloride	ug/l	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
1,3-Dichloropropane	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
Tetrachloroethene	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
Dibromochloromethane	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
1,2-Dibromoethane	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
Chlorobenzene	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
1,1,1,2-Tetrachloroethane	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
Ethyl Benzene	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
m&p-Xylene	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
o-Xylene	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
Styrene	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
Bromoform	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
Isopropylbenzene	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
trans-1,2-Dichloroethene	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
1,1,2,2-Tetrachloroethane	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
1,2,3-Trichloropropane	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
n-Propylbenzene	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
Bromobenzene	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
2-Chlorotoluene	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
1,3,5-Trimethylbenzene	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
4-Chlorotoluene	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
tert-Butylbenzene	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
1,2,4-Trimethylbenzene	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
sec-Butylbenzene	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
p-Isopropyltoluene	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
1,3-Dichlorobenzene	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
1,4-Dichlorobenzene	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
n-Butylbenzene	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
1,2-Dichlorobenzene	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
1,2-Dibromo-3-chloropropane	ug/l	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0

Customer Sample Ref.	units	GW 1	GW 2	GW 3	GW 4	GW 5	GW 6	GW 7	GW 8	GW 9
VOC										
1,2,4-Trichlorobenzene	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
Hexachlorobutadiene	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
Naphthalene	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
1,2,3-Trichlorobenzene	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
MTBE	ug/l	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0



Appendix 4

APPENDIX 4 – LEACHATE**Table 1** – Monthly leachate level data

	Leachate Head (m)							
	LCP 1	LCP 2	LCP 3	LCP7	LCP8	RMLP9C	RMLP9D	EP Limit
Min	-0.06	0.3	0.6	0.25	0.65	0.6	0.5	1
Max	0.98	2.1	1.5	1.05	1.65	10.11	10.36	1
Average	0.80	0.72	1.01	0.60	1.04	2.90	2.9	1
Count	13	13	13	13	13	13	13	1




Table 2 – Monthly monitoring data

Location		pH	Ammoniacal Nitrogen
		pH units	mg/l
LCP1	Min	6.8	82.5
	Max	7.8	827.0
	Average	7.3	304.0
	Count	12	12
LCP2	Min	7.3	21.7
	Max	8.5	3690.0
	Average	8.2	2373.9
	Count	12.0	12.0
LCP3	Min	6.8	1.1
	Max	6.8	1.1
	Average	6.8	1.1
	Count	1	1
LCP7	Min	7.4	630.0
	Max	8.0	1210.0
	Average	7.6	999.4
	Count	12	12
LCP8	Min	7.3	225.0
	Max	7.9	1490.0
	Average	7.6	974.7
	Count	12	12
RMLP9C	Min	6.9	87.3
	Max	8.0	391.0
	Average	7.6	209.7
	Count	5	5
RMLP9D	Min	5.2	3.6
	Max	7.7	690.3
	Average	6.7	174.1
	Count	7	7




Table 3: Final discharge monthly monitoring data (EP exceedances highlighted)

LOCATION	DATE	pH	Ammoniacal Nitrogen as N	Suspended Solids	COD (1 hr settled)	Total TPH (EH>C6 - C40)	Sulphate as SO4	Dissolved Methane
		pH units	mg/l	mg/l	mg/l	µg/l	mg/l	mg/l
Compliance Limit		6 - 10	150	500	1000	nil	1000	N/A
Treated Leachate	27/01/2017	7.6	108	356	2660	714	115	0.01
	27/03/2017	7.1	1	18	897	603	203	<0.010
	24/04/2017	6.2	21	90	613	6100	133	<0.010
	30/05/2017	5.2	38	1310	1440	1820	<4.4	<0.010
	27/06/2017	6.3	146	1400	1910	2220	128	<0.010
	31/07/2017	6.2	84	548	962	3510	92	<0.010
	29/08/2017	7.9	148	7650	2460	-	-	-
	29/09/2017	6.0	2	130	513	2090	140	<0.010
	31/10/2017	5.9	11.2	230	518	1950	89.4	<0.010
	29/11/2017	7.1	138	31	815	1380	69.1	<0.010
	16/12/2017	3.2	112	194	374	301	86.2	<0.010
	MIN	3.2	1.2	18.0	374.0	301.0	69.1	0.0
	MAX	7.9	148.0	7650.0	2660.0	6100.0	203.0	0.0
	AVRG	6.2	73.5	1087.0	1196.5	2068.8	117.3	0.0

Table 4: Final discharge six monthly monitoring data, June

Sample Matrix		Treated Leachate
2,3,6 - TBA	ug/l	<5.00
2,4 - D	ug/l	<5.00
2,4 - DB	ug/l	<5.00
2,4,5 - T	ug/l	<5.00
Bromoxynil	ug/l	<5.00
Cadmium , Total as Cd	mg/l	<0.0006
Chromium , Total as Cr	mg/l	0.391
Copper, Total as Cu	mg/l	0.131
Cyanide, Total as CN	mg/l	0.85
Dicamba	ug/l	<5.00
Dichlorprop	ug/l	<5.00
EH >C10 - C16	ug/l	2220
EH >C16 - C24	ug/l	<100
EH >C24 - C40	ug/l	<100
EH >C6 - C40	ug/l	2220
EH >C6 - C8	ug/l	<100
EH >C8 - C10	ug/l	<100
Fenthion	ug/l	<0.192
Hexachlorobenzene	ng/l	<155
Ioxynil	ug/l	<5.00
Lead , Total as Pb	mg/l	0.046
MCPA	ug/l	<5.00
MCPB	ug/l	<5.00
Mecoprop	ug/l	<4.00
Mercury, Total as Hg	mg/l	0.00019
Methane, Dissolved	mg/l	<0.010
Nickel, Total as Ni	mg/l	0.256
Zinc, Total as Zn	mg/l	0.418

Sample Matrix	Units	Treated Leachate
SVOC		
Phenol	ug/l	<200
Bis(2-chloroethyl)ether	ug/l	<200
2-Chlorophenol	ug/l	<200
1,3-Dichlorobenzene	ug/l	<200
1,4-Dichlorobenzene	ug/l	<200
2-Methylphenol	ug/l	<200
3&4-Methylphenol	ug/l	<200
Dibenzofuran	ug/l	<200
1,2-Dichlorobenzene	ug/l	<200
Bis(2-chloroisopropyl)ether	ug/l	<200
n-Nitrosodi-n-propylamine	ug/l	<200
Hexachloroethane	ug/l	<200
Nitrobenzene	ug/l	<200
Isophorone	ug/l	<200
2,4-Dimethylphenol	ug/l	<200
2-Nitrophenol	ug/l	<200
Bis(2-chloroethoxy)methane	ug/l	<200
2,4-Dichlorophenol	ug/l	<200
1,2,4-Trichlorobenzene	ug/l	<200
Naphthalene	ug/l	<400
Hexachlorobutadiene	ug/l	<200
4-Chloro-3-methylphenol	ug/l	<200

Sample Matrix	Units	Treated Leachate
SVOC		
2-Methylnaphthalene	ug/l	<200
2,4,6-Trichlorophenol	ug/l	<200
2,4,5-Trichlorophenol	ug/l	<200
2-Chloronaphthalene	ug/l	<200
Dimethylphthalate	ug/l	<200
2,6-Dinitrotoluene	ug/l	<200
Acenaphthylene	ug/l	<200
Acenaphthene	ug/l	<200
2,4-Dinitrotoluene	ug/l	<200
Diethylphthalate	ug/l	<200
4-Nitrophenol	ug/l	<1000
4-Chlorophenyl phenyl ether	ug/l	<200
Fluorene	ug/l	<200
Diphenylamine	ug/l	<200
4-Bromophenyl Phenyl Ether	ug/l	<200
Hexachlorobenzene	ug/l	<200
Pentachlorophenol	ug/l	<200
Phenanthrene	ug/l	<200
Anthracene	ug/l	<200
di-n-Butylphthalate	ug/l	<200
Fluoranthene	ug/l	<200
Pyrene	ug/l	<200
Benzyl Butyl Phthalate	ug/l	<200
Benzo(a)anthracene	ug/l	<200
Chrysene	ug/l	<200
Bis(2-ethylhexyl)phthalate	ug/l	<1000
Di-n-octylphthalate	ug/l	<200
Benzo(b)fluoranthene	ug/l	<200
Benzo(k)fluoranthene	ug/l	<200
Benzo(a)pyrene	ug/l	<200
Indeno(1,2,3-c,d)pyrene	ug/l	<200
Dibenz(a,h)anthracene	ug/l	<200
Benzo(g,h,i)perylene	ug/l	<200

Sample Matrix	Units	Treated Leachate
VOC		
Dichlorodifluoromethane	ug/l	<10.0
Chloromethane	ug/l	22
Chloroethane	ug/l	<10.0
Bromomethane	ug/l	17.2
Trichlorofluoromethane	ug/l	<10.0
1,1-Dichloroethene	ug/l	<10.0
Dichloromethane	ug/l	<10.0
1,1-Dichloroethane	ug/l	<10.0
cis-1,2-Dichloroethene	ug/l	<10.0
2,2-Dichloropropane	ug/l	<10.0
Chloroform	ug/l	<10.0
Bromochloromethane	ug/l	<10.0
1,1,1-Trichloroethane	ug/l	<10.0
1,1-Dichloropropene	ug/l	<10.0
1,2-Dichloroethane	ug/l	<10.0
Benzene	ug/l	<10.0
1,2-Dichloropropane	ug/l	<10.0
Trichloroethene	ug/l	<10.0

Sample Matrix	Units	Treated Leachate
VOC		
Bromodichloromethane	ug/l	<10.0
Dibromomethane	ug/l	<10.0
cis-1,3-Dichloropropene	ug/l	<10.0
Toluene	ug/l	<10.0
trans-1,3-Dichloropropene	ug/l	<10.0
1,1,2-Trichloroethane	ug/l	<10.0
Carbon Tetrachloride	ug/l	<10.0
Vinyl Chloride	ug/l	<5.0
1,3-Dichloropropane	ug/l	<10.0
Tetrachloroethene	ug/l	<10.0
Dibromochloromethane	ug/l	<10.0
1,2-Dibromoethane	ug/l	<10.0
Chlorobenzene	ug/l	<10.0
1,1,1,2-Tetrachloroethane	ug/l	<10.0
Ethyl Benzene	ug/l	<10.0
m&p-Xylene	ug/l	<10.0
o-Xylene	ug/l	<10.0
Styrene	ug/l	<10.0
Bromoform	ug/l	<10.0
Isopropylbenzene	ug/l	<10.0
trans-1,2-Dichloroethene	ug/l	<10.0
1,1,2,2-Tetrachloroethane	ug/l	<10.0
1,2,3-Trichloropropane	ug/l	<10.0
n-Propylbenzene	ug/l	<10.0
Bromobenzene	ug/l	<10.0
2-Chlorotoluene	ug/l	<10.0
1,3,5-Trimethylbenzene	ug/l	<10.0
4-Chlorotoluene	ug/l	<10.0
tert-Butylbenzene	ug/l	<10.0
1,2,4-Trimethylbenzene	ug/l	<10.0
sec-Butylbenzene	ug/l	<10.0
p-Isopropyltoluene	ug/l	<10.0
1,3-Dichlorobenzene	ug/l	<10.0
1,4-Dichlorobenzene	ug/l	<10.0
n-Butylbenzene	ug/l	<10.0
1,2-Dichlorobenzene	ug/l	<10.0
1,2-Dibromo-3-chloropropane	ug/l	<20.0
1,2,4-Trichlorobenzene	ug/l	<10.0
Hexachlorobutadiene	ug/l	<10.0
Naphthalene	ug/l	<10.0
1,2,3-Trichlorobenzene	ug/l	<10.0
MTBE	ug/l	<10.0

Table 5: Final discharge six monthly monitoring data, December


Sample Matrix	Units	Treated Leachate
2,3,6 - TBA	ug/l	<0.20
2,4 - D	ug/l	<0.20
2,4 - DB	ug/l	<0.20
2,4,5 - T	ug/l	<0.20
Bromoxynil	ug/l	<0.20
Cadmium , Total as Cd	mg/l	0.0014
Chromium , Total as Cr	mg/l	0.068
Copper, Total as Cu	mg/l	0.088
Cyanide, Total as CN	mg/l	<0.009
Dicamba	ug/l	0.32
Dichlorprop	ug/l	<0.20
EH >C10 - C16	ug/l	232
EH >C16 - C24	ug/l	69
EH >C24 - C40	ug/l	<40
EH >C6 - C40	ug/l	301
EH >C6 - C8	ug/l	<40
EH >C8 - C10	ug/l	<40
Fenthion	ug/l	<0.011
Hexachlorobenzene	ng/l	<9
Ioxynil	ug/l	<0.20
Lead , Total as Pb	mg/l	0.011
MCPA	ug/l	<0.20
MCPB	ug/l	<0.20
Mecoprop	ug/l	<0.16
Mercury, Total as Hg	mg/l	<0.00010
Methane, Dissolved	mg/l	<0.010
Nickel, Total as Ni	mg/l	0.063
Zinc, Total as Zn	mg/l	0.556

Sample Matrix	units	Treated Leachate
SVOC		
Phenol	ug/l	<200
Bis(2-chloroethyl)ether	ug/l	<200
2-Chlorophenol	ug/l	<200
1,3-Dichlorobenzene	ug/l	<200
1,4-Dichlorobenzene	ug/l	<200
2-Methylphenol	ug/l	<200
3&4-Methylphenol	ug/l	<200
Dibenzofuran	ug/l	<200
1,2-Dichlorobenzene	ug/l	<200
Bis(2-chloroisopropyl)ether	ug/l	<200
n-Nitrosodi-n-propylamine	ug/l	<200
Hexachloroethane	ug/l	<200
Nitrobenzene	ug/l	<200
Isophorone	ug/l	<200
2,4-Dimethylphenol	ug/l	<200
2-Nitrophenol	ug/l	<200
Bis(2-chloroethoxy)methane	ug/l	<200
2,4-Dichlorophenol	ug/l	<200
1,2,4-Trichlorobenzene	ug/l	<200
Naphthalene	ug/l	<400
Hexachlorobutadiene	ug/l	<200
4-Chloro-3-methylphenol	ug/l	<200
2-Methylnaphthalene	ug/l	<200
2,4,6-Trichlorophenol	ug/l	<200

Sample Matrix	units	Treated Leachate
SVOC		
2,4,5-Trichlorophenol	ug/l	<200
2-Chloronaphthalene	ug/l	<200
Dimethylphthalate	ug/l	<200
2,6-Dinitrotoluene	ug/l	<200
Acenaphthylene	ug/l	<200
Acenaphthene	ug/l	<200
2,4-Dinitrotoluene	ug/l	<200
Diethylphthalate	ug/l	<200
4-Nitrophenol	ug/l	<1000
4-Chlorophenyl phenyl ether	ug/l	<200
Fluorene	ug/l	<200
Diphenylamine	ug/l	<200
4-Bromophenyl Phenyl Ether	ug/l	<200
Hexachlorobenzene	ug/l	<200
Pentachlorophenol	ug/l	<200
Phenanthrene	ug/l	<200
Anthracene	ug/l	<200
di-n-Butylphthalate	ug/l	<200
Fluoranthene	ug/l	<200
Pyrene	ug/l	<200
Benzyl Butyl Phthalate	ug/l	<200
Benzo(a)anthracene	ug/l	<200
Chrysene	ug/l	<200
Bis(2-ethylhexyl)phthalate	ug/l	<1000
Di-n-octylphthalate	ug/l	<200
Benzo(b)fluoranthene	ug/l	<200
Benzo(k)fluoranthene	ug/l	<200
Benzo(a)pyrene	ug/l	<200
Indeno(1,2,3-c,d)pyrene	ug/l	<200
Dibenz(a,h)anthracene	ug/l	<200
Benzo(g,h,i)perylene	ug/l	<200

Sample Matrix	units	Treated Leachate
VOC		
Dichlorodifluoromethane	ug/l	<20.0
Chloromethane	ug/l	<20.0
Chloroethane	ug/l	<20.0
Bromomethane	ug/l	<20.0
Trichlorofluoromethane	ug/l	<20.0
1,1-Dichloroethene	ug/l	<20.0
Dichloromethane	ug/l	<20.0
1,1-Dichloroethane	ug/l	<20.0
cis-1,2-Dichloroethene	ug/l	<20.0
2,2-Dichloropropane	ug/l	<20.0
Chloroform	ug/l	<20.0
Bromochloromethane	ug/l	<20.0
1,1,1-Trichloroethane	ug/l	<20.0
1,1-Dichloropropene	ug/l	<20.0
1,2-Dichloroethane	ug/l	<20.0
Benzene	ug/l	<20.0
1,2-Dichloropropane	ug/l	<20.0
Trichloroethene	ug/l	<20.0
Bromodichloromethane	ug/l	<20.0
Dibromomethane	ug/l	<20.0

Sample Matrix	units	Treated Leachate
VOC		
cis-1,3-Dichloropropene	ug/l	<20.0
Toluene	ug/l	<20.0
trans-1,3-Dichloropropene	ug/l	<20.0
1,1,2-Trichloroethane	ug/l	<20.0
Carbon Tetrachloride	ug/l	<20.0
Vinyl Chloride	ug/l	<10.0
1,3-Dichloropropane	ug/l	<20.0
Tetrachloroethene	ug/l	<20.0
Dibromochloromethane	ug/l	<20.0
1,2-Dibromoethane	ug/l	<20.0
Chlorobenzene	ug/l	<20.0
1,1,1,2-Tetrachloroethane	ug/l	<20.0
Ethyl Benzene	ug/l	<20.0
m&p-Xylene	ug/l	<20.0
o-Xylene	ug/l	<20.0
Styrene	ug/l	<20.0
Bromoform	ug/l	<20.0
Isopropylbenzene	ug/l	<20.0
trans-1,2-Dichloroethene	ug/l	<20.0
1,1,2,2-Tetrachloroethane	ug/l	<20.0
1,2,3-Trichloropropane	ug/l	<20.0
n-Propylbenzene	ug/l	<20.0
Bromobenzene	ug/l	<20.0
2-Chlorotoluene	ug/l	<20.0
1,3,5-Trimethylbenzene	ug/l	<20.0
4-Chlorotoluene	ug/l	<20.0
tert-Butylbenzene	ug/l	<20.0
1,2,4-Trimethylbenzene	ug/l	<20.0
sec-Butylbenzene	ug/l	<20.0
p-Isopropyltoluene	ug/l	<20.0
1,3-Dichlorobenzene	ug/l	<20.0
1,4-Dichlorobenzene	ug/l	<20.0
n-Butylbenzene	ug/l	<20.0
1,2-Dichlorobenzene	ug/l	<20.0
1,2-Dibromo-3-chloropropane	ug/l	<40.0
1,2,4-Trichlorobenzene	ug/l	<20.0
Hexachlorobutadiene	ug/l	<20.0
Naphthalene	ug/l	<20.0
1,2,3-Trichlorobenzene	ug/l	<20.0
MTBE	ug/l	<20.0







Appendix 5

APPENDIX 5 – SURFACE WATER

Table 1: Monthly monitoring data

LOCATION		pH	Conductivity- Electrical 20C	Ammoniacal Nitrogen as N (LL)	Chloride as Cl	Total Suspended Solids	BOD + ATU (5 day)	EH >C6 - C40	EH >C6 - C8	EH >C8 - C10	EH >C16 - C24	EH >C24 - C40	EH >C10 - C16
		pH units	µS/cm	mg/l	mg/l	mg/l	mg/l	µg/l	µg/l	µg/l	µg/l	µg/l	µg/l
EP Limit		6 - 9	N/A	0.25	N/A	50	N/A	N/A	N/A	N/A	N/A	N/A	N/A
SW 1	Min	6.5	95.4	0.1	7.9	1	1	10	10	10	10	10	10
	Max	7.8	459.0	13.6	55.3	30	10	100	100	100	100	100	100
	Average	7.1	133.7	1.2	14.3	8	2	24	20	20	20	24	20
	Count	12	12	12	12	12	12	12	12	12	12	12	12
SW 2	Min	7.0	101.0	0.1	11.7	5	1	10	10	10	10	10	10
	Max	8.6	2060.0	17.0	236.0	320	21	743	100	100	421	200	122
	Average	7.9	920.8	4.2	103.3	108	5	133	26	26	72	68	37
	Count	12	12	12	12	12	12	12	12	12	12	12	12









Table 2: Six monthly monitoring data, June

Parameters	Units	SW1	SW2
2,3,6 - TBA	ug/l	<0.05	<0.05
2,4 - D	ug/l	0.15	0.11
2,4 - DB	ug/l	<0.05	<0.05
2,4,5 - T	ug/l	0.1	<0.05
Bromoxynil	ug/l	<0.05	<0.05
Cadmium , Total as Cd	mg/l	<0.0006	<0.0006
COD (Total)	mg/l	36	63
Cyanide, Total as CN	mg/l	<0.009	<0.009
Dicamba	ug/l	<0.05	<0.05
Dichlorprop	ug/l	<0.05	<1.00
Dissolved Oxygen, Fixed	mg/l	7.7	4.4
Ioxynil	ug/l	<0.05	<0.05
MCPA	ug/l	<0.05	<0.05
MCPB	ug/l	<0.05	<0.05
Mecoprop	ug/l	<0.04	0.18

Parameter	Units	SW 1	SW 2
SVOC			
Phenol	ug/l	<2.0	<1.0
Bis(2-chloroethyl)ether	ug/l	<2.0	<1.0
2-Chlorophenol	ug/l	<2.0	<1.0
1,3-Dichlorobenzene	ug/l	<2.0	<1.0
1,4-Dichlorobenzene	ug/l	<2.0	<1.0
2-Methylphenol	ug/l	<2.0	<1.0
3&4-Methylphenol	ug/l	<2.0	<1.0
Dibenzofuran	ug/l	<2.0	<1.0
1,2-Dichlorobenzene	ug/l	<2.0	<1.0
Bis(2-chloroisopropyl)ether	ug/l	<2.0	<1.0
n-Nitrosodi-n-propylamine	ug/l	<2.0	<1.0
Hexachloroethane	ug/l	<2.0	<1.0
Nitrobenzene	ug/l	<2.0	<1.0
Isophorone	ug/l	<2.0	<1.0
2,4-Dimethylphenol	ug/l	<2.0	<1.0
2-Nitrophenol	ug/l	<2.0	<1.0
Bis(2-chloroethoxy)methane	ug/l	<2.0	<1.0
2,4-Dichlorophenol	ug/l	<2.0	<1.0
1,2,4-Trichlorobenzene	ug/l	<2.0	<1.0
Naphthalene	ug/l	<4.0	<2.0
Hexachlorobutadiene	ug/l	<2.0	<1.0
4-Chloro-3-methylphenol	ug/l	<2.0	<1.0
2-Methylnaphthalene	ug/l	<2.0	<1.0
2,4,6-Trichlorophenol	ug/l	<2.0	<1.0
2,4,5-Trichlorophenol	ug/l	<2.0	<1.0
2-Chloronaphthalene	ug/l	<2.0	<1.0
Dimethylphthalate	ug/l	<2.0	<1.0
2,6-Dinitrotoluene	ug/l	<2.0	<1.0
Acenaphthylene	ug/l	<2.0	<1.0
Acenaphthene	ug/l	<2.0	<1.0
2,4-Dinitrotoluene	ug/l	<2.0	<1.0
Diethylphthalate	ug/l	<2.0	<1.0
4-Nitrophenol	ug/l	<10.0	<5.0
4-Chlorophenyl phenyl ether	ug/l	<2.0	<1.0
Fluorene	ug/l	<2.0	<1.0
Diphenylamine	ug/l	<2.0	<1.0
4-Bromophenyl Phenyl Ether	ug/l	<2.0	<1.0

Parameter	Units	SW 1	SW 2
SVOC			
Hexachlorobenzene	ug/l	<2.0	<1.0
Pentachlorophenol	ug/l	<2.0	<1.0
Phenanthrene	ug/l	<2.0	<1.0
Anthracene	ug/l	<2.0	<1.0
di-n-Butylphthalate	ug/l	<2.0	<1.0
Fluoranthene	ug/l	<2.0	<1.0
Pyrene	ug/l	<2.0	<1.0
Benzyl Butyl Phthalate	ug/l	<2.0	<1.0
Benzo(a)anthracene	ug/l	<2.0	<1.0
Chrysene	ug/l	<2.0	<1.0
Bis(2-ethylhexyl)phthalate	ug/l	<10.0	<5.0
Di-n-octylphthalate	ug/l	<2.0	<1.0
Benzo(b)fluoranthene	ug/l	<2.0	<1.0
Benzo(k)fluoranthene	ug/l	<2.0	<1.0
Benzo(a)pyrene	ug/l	<2.0	<1.0
Indeno(1,2,3-c,d)pyrene	ug/l	<2.0	<1.0
Dibenz(a,h)anthracene	ug/l	<2.0	<1.0
Benzo(g,h,i)perylene	ug/l	<2.0	<1.0

Parameter	Units	SW 1	SW 2
SVOC			
Phenol	ug/l	<2.0	<1.0
Bis(2-chloroethyl)ether	ug/l	<2.0	<1.0
2-Chlorophenol	ug/l	<2.0	<1.0
1,3-Dichlorobenzene	ug/l	<2.0	<1.0
1,4-Dichlorobenzene	ug/l	<2.0	<1.0
2-Methylphenol	ug/l	<2.0	<1.0
3&4-Methylphenol	ug/l	<2.0	<1.0
Dibenzofuran	ug/l	<2.0	<1.0
1,2-Dichlorobenzene	ug/l	<2.0	<1.0
Bis(2-chloroisopropyl)ether	ug/l	<2.0	<1.0
n-Nitrosodi-n-propylamine	ug/l	<2.0	<1.0
Hexachloroethane	ug/l	<2.0	<1.0
Nitrobenzene	ug/l	<2.0	<1.0
Isophorone	ug/l	<2.0	<1.0
2,4-Dimethylphenol	ug/l	<2.0	<1.0
2-Nitrophenol	ug/l	<2.0	<1.0
Bis(2-chloroethoxy)methane	ug/l	<2.0	<1.0
2,4-Dichlorophenol	ug/l	<2.0	<1.0
1,2,4-Trichlorobenzene	ug/l	<2.0	<1.0
Naphthalene	ug/l	<4.0	<2.0
Hexachlorobutadiene	ug/l	<2.0	<1.0
4-Chloro-3-methylphenol	ug/l	<2.0	<1.0
2-Methylnaphthalene	ug/l	<2.0	<1.0
2,4,6-Trichlorophenol	ug/l	<2.0	<1.0
2,4,5-Trichlorophenol	ug/l	<2.0	<1.0
2-Chloronaphthalene	ug/l	<2.0	<1.0
Dimethylphthalate	ug/l	<2.0	<1.0
2,6-Dinitrotoluene	ug/l	<2.0	<1.0
Acenaphthylene	ug/l	<2.0	<1.0
Acenaphthene	ug/l	<2.0	<1.0
2,4-Dinitrotoluene	ug/l	<2.0	<1.0
Diethylphthalate	ug/l	<2.0	<1.0
4-Nitrophenol	ug/l	<10.0	<5.0
4-Chlorophenyl phenyl ether	ug/l	<2.0	<1.0

Parameter	Units	SW 1	SW 2
SVOC			
Fluorene	ug/l	<2.0	<1.0
Diphenylamine	ug/l	<2.0	<1.0
4-Bromophenyl Phenyl Ether	ug/l	<2.0	<1.0
Hexachlorobenzene	ug/l	<2.0	<1.0
Pentachlorophenol	ug/l	<2.0	<1.0
Phenanthrene	ug/l	<2.0	<1.0
Anthracene	ug/l	<2.0	<1.0
di-n-Butylphthalate	ug/l	<2.0	<1.0
Fluoranthene	ug/l	<2.0	<1.0
Pyrene	ug/l	<2.0	<1.0
Benzyl Butyl Phthalate	ug/l	<2.0	<1.0
Benzo(a)anthracene	ug/l	<2.0	<1.0
Chrysene	ug/l	<2.0	<1.0
Bis(2-ethylhexyl)phthalate	ug/l	<10.0	<5.0
Di-n-octylphthalate	ug/l	<2.0	<1.0
Benzo(b)fluoranthene	ug/l	<2.0	<1.0
Benzo(k)fluoranthene	ug/l	<2.0	<1.0
Benzo(a)pyrene	ug/l	<2.0	<1.0
Indeno(1,2,3-c,d)pyrene	ug/l	<2.0	<1.0
Dibenz(a,h)anthracene	ug/l	<2.0	<1.0
Benzo(g,h,i)perylene	ug/l	<2.0	<1.0
Dichlorodifluoromethane	ug/l	<1.0	<1.0
Chloromethane	ug/l	<1.0	<1.0
Chloroethane	ug/l	<1.0	<1.0
Bromomethane	ug/l	<1.0	<1.0
Trichlorofluoromethane	ug/l	<1.0	<1.0
1,1-Dichloroethene	ug/l	<1.0	<1.0
Dichloromethane	ug/l	<1.0	<1.0
1,1-Dichloroethane	ug/l	<1.0	<1.0
cis-1,2-Dichloroethene	ug/l	<1.0	<1.0
2,2-Dichloropropane	ug/l	<1.0	<1.0
Chloroform	ug/l	<1.0	<1.0
Bromochloromethane	ug/l	<1.0	<1.0
1,1,1-Trichloroethane	ug/l	<1.0	<1.0
1,1-Dichloropropene	ug/l	<1.0	<1.0
1,2-Dichloroethane	ug/l	<1.0	<1.0
Benzene	ug/l	<1.0	<1.0
1,2-Dichloropropane	ug/l	<1.0	<1.0
Trichloroethene	ug/l	<1.0	<1.0
Bromodichloromethane	ug/l	<1.0	<1.0
Dibromomethane	ug/l	<1.0	<1.0
cis-1,3-Dichloropropene	ug/l	<1.0	<1.0
Toluene	ug/l	<1.0	<1.0
trans-1,3-Dichloropropene	ug/l	<1.0	<1.0
1,1,2-Trichloroethane	ug/l	<1.0	<1.0
Carbon Tetrachloride	ug/l	<1.0	<1.0
Vinyl Chloride	ug/l	<0.5	<0.5
1,3-Dichloropropane	ug/l	<1.0	<1.0
Tetrachloroethene	ug/l	<1.0	<1.0
Dibromochloromethane	ug/l	<1.0	<1.0
1,2-Dibromoethane	ug/l	<1.0	<1.0
Chlorobenzene	ug/l	<1.0	<1.0
1,1,1,2-Tetrachloroethane	ug/l	<1.0	<1.0
Ethyl Benzene	ug/l	<1.0	<1.0
m&p-Xylene	ug/l	<1.0	<1.0
o-Xylene	ug/l	<1.0	<1.0
Styrene	ug/l	<1.0	<1.0

Parameter	Units	SW 1	SW 2
SVOC			
Bromoform	ug/l	<1.0	<1.0
Isopropylbenzene	ug/l	<1.0	<1.0
trans-1,2-Dichloroethene	ug/l	<1.0	<1.0
1,1,2,2-Tetrachloroethane	ug/l	<1.0	<1.0
1,2,3-Trichloropropane	ug/l	<1.0	<1.0
n-Propylbenzene	ug/l	<1.0	<1.0
Bromobenzene	ug/l	<1.0	<1.0
2-Chlorotoluene	ug/l	<1.0	<1.0
1,3,5-Trimethylbenzene	ug/l	<1.0	<1.0
4-Chlorotoluene	ug/l	<1.0	<1.0
tert-Butylbenzene	ug/l	<1.0	<1.0
1,2,4-Trimethylbenzene	ug/l	<1.0	<1.0
sec-Butylbenzene	ug/l	<1.0	<1.0
p-Isopropyltoluene	ug/l	<1.0	<1.0
1,3-Dichlorobenzene	ug/l	<1.0	<1.0
1,4-Dichlorobenzene	ug/l	<1.0	<1.0
n-Butylbenzene	ug/l	<1.0	<1.0
1,2-Dichlorobenzene	ug/l	<1.0	<1.0
1,2-Dibromo-3-chloropropane	ug/l	<2.0	<2.0
1,2,4-Trichlorobenzene	ug/l	<1.0	<1.0
Hexachlorobutadiene	ug/l	<1.0	<1.0
Naphthalene	ug/l	<1.0	<1.0
1,2,3-Trichlorobenzene	ug/l	<1.0	<1.0
MTBE	ug/l	<1.0	<1.0

Table 3: Six monthly monitoring data, December


Parameters	Units	SW1	SW2
2,3,6 - TBA	ug/l	<0.05	<0.05
2,4 - D	ug/l	<0.05	<0.05
2,4 - DB	ug/l	<0.05	<0.05
2,4,5 - T	ug/l	<0.05	<0.05
Bromoxynil	ug/l	<0.05	<0.05
Cadmium , Total as Cd	mg/l	<0.0006	<0.0006
COD (Total)	mg/l	35	37
Cyanide, Total as CN	mg/l	<0.009	<0.009
Dicamba	ug/l	<0.05	<0.05
Dichlorprop	ug/l	<0.05	<0.05
Dissolved Oxygen, Fixed	mg/l	8.3	11.4
Ioxynil	ug/l	<0.05	<0.05
MCPA	ug/l	<0.05	<0.05
MCPB	ug/l	<0.05	<0.05
Mecoprop	ug/l	<0.04	0.05

Parameter	Units	SW 1	SW 2
SVOC			
Phenol	ug/l	<1.0	<2.0
Bis(2-chloroethyl)ether	ug/l	<1.0	<2.0
2-Chlorophenol	ug/l	<1.0	<2.0
1,3-Dichlorobenzene	ug/l	<1.0	<2.0
1,4-Dichlorobenzene	ug/l	<1.0	<2.0
2-Methylphenol	ug/l	<1.0	<2.0
3&4-Methylphenol	ug/l	<1.0	<2.0
Dibenzofuran	ug/l	<1.0	<2.0
1,2-Dichlorobenzene	ug/l	<1.0	<2.0
Bis(2-chloroisopropyl)ether	ug/l	<1.0	<2.0
n-Nitrosodi-n-propylamine	ug/l	<1.0	<2.0
Hexachloroethane	ug/l	<1.0	<2.0
Nitrobenzene	ug/l	<1.0	<2.0
Isophorone	ug/l	<1.0	<2.0
2,4-Dimethylphenol	ug/l	<1.0	<2.0
2-Nitrophenol	ug/l	<1.0	<2.0
Bis(2-chloroethoxy)methane	ug/l	<1.0	<2.0
2,4-Dichlorophenol	ug/l	<1.0	<2.0
1,2,4-Trichlorobenzene	ug/l	<1.0	<2.0
Naphthalene	ug/l	<2.0	<4.0
Hexachlorobutadiene	ug/l	<1.0	<2.0
4-Chloro-3-methylphenol	ug/l	<1.0	<2.0
2-Methylnaphthalene	ug/l	<1.0	<2.0
2,4,6-Trichlorophenol	ug/l	<1.0	<2.0
2,4,5-Trichlorophenol	ug/l	<1.0	<2.0
2-Chloronaphthalene	ug/l	<1.0	<2.0
Dimethylphthalate	ug/l	<1.0	<2.0
2,6-Dinitrotoluene	ug/l	<1.0	<2.0
Acenaphthylene	ug/l	<1.0	<2.0
Acenaphthene	ug/l	<1.0	<2.0
2,4-Dinitrotoluene	ug/l	<1.0	<2.0
Diethylphthalate	ug/l	<1.0	<2.0
4-Nitrophenol	ug/l	<5.0	<10.0
4-Chlorophenyl phenyl ether	ug/l	<1.0	<2.0
Fluorene	ug/l	<1.0	<2.0
Diphenylamine	ug/l	<1.0	<2.0
4-Bromophenyl Phenyl Ether	ug/l	<1.0	<2.0

Parameter	Units	SW 1	SW 2
SVOC			
Hexachlorobenzene	ug/l	<1.0	<2.0
Pentachlorophenol	ug/l	<1.0	<2.0
Phenanthrene	ug/l	<1.0	<2.0
Anthracene	ug/l	<1.0	<2.0
di-n-Butylphthalate	ug/l	<1.0	<2.0
Fluoranthene	ug/l	<1.0	<2.0
Pyrene	ug/l	<1.0	<2.0
Benzyl Butyl Phthalate	ug/l	<1.0	<2.0
Benzo(a)anthracene	ug/l	<1.0	<2.0
Chrysene	ug/l	<1.0	<2.0
Bis(2-ethylhexyl)phthalate	ug/l	<5.0	<10.0
Di-n-octylphthalate	ug/l	<1.0	<2.0
Benzo(b)fluoranthene	ug/l	<1.0	<2.0
Benzo(k)fluoranthene	ug/l	<1.0	<2.0
Benzo(a)pyrene	ug/l	<1.0	<2.0
Indeno(1,2,3-c,d)pyrene	ug/l	<1.0	<2.0
Dibenz(a,h)anthracene	ug/l	<1.0	<2.0
Benzo(g,h,i)perylene	ug/l	<1.0	<2.0

Parameter	Units	SW 1	SW 2
VOC			
Dichlorodifluoromethane	ug/l	<1.0	<1.0
Chloromethane	ug/l	<1.0	<1.0
Chloroethane	ug/l	<1.0	<1.0
Bromomethane	ug/l	<1.0	<1.0
Trichlorofluoromethane	ug/l	<1.0	<1.0
1,1-Dichloroethene	ug/l	<1.0	<1.0
Dichloromethane	ug/l	<1.0	<1.0
1,1-Dichloroethane	ug/l	<1.0	<1.0
cis-1,2-Dichloroethene	ug/l	<1.0	<1.0
2,2-Dichloropropane	ug/l	<1.0	<1.0
Chloroform	ug/l	<1.0	<1.0
Bromochloromethane	ug/l	<1.0	<1.0
1,1,1-Trichloroethane	ug/l	<1.0	<1.0
1,1-Dichloropropene	ug/l	<1.0	<1.0
1,2-Dichloroethane	ug/l	<1.0	<1.0
Benzene	ug/l	<1.0	<1.0
1,2-Dichloropropane	ug/l	<1.0	<1.0
Trichloroethene	ug/l	<1.0	<1.0
Bromodichloromethane	ug/l	<1.0	<1.0
Dibromomethane	ug/l	<1.0	<1.0
cis-1,3-Dichloropropene	ug/l	<1.0	<1.0
Toluene	ug/l	<1.0	<1.0
trans-1,3-Dichloropropene	ug/l	<1.0	<1.0
1,1,2-Trichloroethane	ug/l	<1.0	<1.0
Carbon Tetrachloride	ug/l	<1.0	<1.0
Vinyl Chloride	ug/l	<0.5	<0.5
1,3-Dichloropropane	ug/l	<1.0	<1.0
Tetrachloroethene	ug/l	<1.0	<1.0
Dibromochloromethane	ug/l	<1.0	<1.0
1,2-Dibromoethane	ug/l	<1.0	<1.0
Chlorobenzene	ug/l	<1.0	<1.0
1,1,1,2-Tetrachloroethane	ug/l	<1.0	<1.0
Ethyl Benzene	ug/l	<1.0	<1.0
m&p-Xylene	ug/l	<1.0	<1.0
o-Xylene	ug/l	<1.0	<1.0
Styrene	ug/l	<1.0	<1.0

Parameter	Units	SW 1	SW 2
VOC			
Bromoform	ug/l	<1.0	<1.0
Isopropylbenzene	ug/l	<1.0	<1.0
trans-1,2-Dichloroethene	ug/l	<1.0	<1.0
1,1,2,2-Tetrachloroethane	ug/l	<1.0	<1.0
1,2,3-Trichloropropane	ug/l	<1.0	<1.0
n-Propylbenzene	ug/l	<1.0	<1.0
Bromobenzene	ug/l	<1.0	<1.0
2-Chlorotoluene	ug/l	<1.0	<1.0
1,3,5-Trimethylbenzene	ug/l	<1.0	<1.0
4-Chlorotoluene	ug/l	<1.0	<1.0
tert-Butylbenzene	ug/l	<1.0	<1.0
1,2,4-Trimethylbenzene	ug/l	<1.0	<1.0
sec-Butylbenzene	ug/l	<1.0	<1.0
p-Isopropyltoluene	ug/l	<1.0	<1.0
1,3-Dichlorobenzene	ug/l	<1.0	<1.0
1,4-Dichlorobenzene	ug/l	<1.0	<1.0
n-Butylbenzene	ug/l	<1.0	<1.0
1,2-Dichlorobenzene	ug/l	<1.0	<1.0
1,2-Dibromo-3-chloropropane	ug/l	<2.0	<2.0
1,2,4-Trichlorobenzene	ug/l	<1.0	<1.0
Hexachlorobutadiene	ug/l	<1.0	<1.0
Naphthalene	ug/l	<1.0	<1.0
1,2,3-Trichlorobenzene	ug/l	<1.0	<1.0
MTBE	ug/l	<1.0	<1.0



Appendix 6

Appendix 6. Dust Monitoring Results

	Dust Monitoring 2017		1	2	3
Q2	Number of Days Exposed		13	13	13
	Mass of Undissolved Solids	mg	13.7	21.8	16.1
	Deposited Dust, Total, Calc.	mg/m ² /day	26	41	31
	Frisbee Diameter	mm	227	227	227
Q3	Number of Days Exposed		34	34	34
	Mass of Undissolved Solids	mg	62.8	95.2	51.3
	Deposited Dust, Total, Calc.	mg/m ² /day	46	69	37
	Frisbee Diameter	mm	227	227	227
Q4	Number of Days Exposed		34	34	34
	Mass of Undissolved Solids	mg	1.9	4.7	32.3
	Deposited Dust, Total, Calc.	mg/m ² /day	<10	<10	23
	Frisbee Diameter	mm	230	230	230



Caulmert Limited

InTec, Parc Menai, Bangor, Gwynedd, LL57 4FG

Tel: 01248 672671

Fax: 01248 672601

Email: contact@caulmert.com

Web: www.caulmert.com

