

Permit Number: PP3238LX Operator: Hexion UK Limited

Installation: Barry Thermosets Plant Form Number: Air1 / 25/04/2013

Reporting of emissions to air for the period from 01/01/2014 to 31/12/2014

Emission Point	Substance / Parameter	Emission Limit Value	Reference Period	Result	Test Method ^[1]	Sample Date and Times ^[2]	Uncertainty ^[3]
A1	Oxides of nitrogen (NO and NO ₂ expressed as NO ₂)	Gas: 180mg/m ³	Spot sample	112.2	BS EN 14792 (A44)	24/03/2014	24.2
A1	Oxides of nitrogen (NO and NO ₂ expressed as NO ₂)	Oil: 220mg/m ³	Spot sample		-	Not in use on sample date	
A1	Carbon monoxide	140 mg/m ³	Spot sample	6.6	BS EN 15058 (A44)	24/03/2014	11.6
A2	Phenol	10 mg/m ³	Spot sample	<1.7 <1.7 <1.8 <1.7	BS13649	24/03/2014 11/06/2014 11/08/2014 08/12/2014	50
A2	Formaldehyde	2 mg/m ³	Spot sample	<0.02 0.07 0.23 0.05	BS13649	As above	50 50 30 30
A2	Styrene mg/m ³	NA	Spot sample	<0.05 <0.05 <0.05 <0.05	BS13649	As above	50

1. Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated, e.g. gas chromatography.
2. For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.
3. The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

A handwritten signature in dark ink, appearing to read 'J. Beatty', with a stylized flourish extending from the end.

Signed
(Authorised to sign as representative of Operator)

Date.....27th January 2015.....