

Permit Number: PP3238LX Operator: Momentive Specialty Chemicals Limited
 Installation: Barry Thermosets Plant Form Number: E1 / 25/04/2013

Reporting of emissions to water (other than to sewer) for the period from 02/07/2015 to 24/09/2015

Emission Point	Substance / Parameter	Reference Period	Result ^[1]	Average Result ^[5]	Test Method	Sample Date and Times ^[2]	Uncertainty ^[3]
E1	Total suspended solids		86	73		02/07/2015 09/07/2015 16/07/2015 23/07/2015 30/07/2015 06/08/2015 13/08/2015 20/08/2015 27/08/2015 03/09/2015 10/09/2015 17/09/2015 24/09/2015	
W1	Free formaldehyde		4	0.8		As above	
E1	Monohydric phenol		48	7		As above	
E1	Methanol		122	23		As above	
E1	Chemical Oxygen Demand		1522	838		As above	

1. The result given is the maximum value obtained during the reporting period (3 months), expressed in the same terms as the emission limit value.
2. For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.
3. The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.
4. An average of the samples taken over the reporting period (every 3 months).

A handwritten signature in dark ink, appearing to read 'J. Beatty', with a long horizontal stroke extending to the right.

Signed
(Authorised to sign as representative of Operator)

Date.....6th October 2015