

Permit Number: PP3238LX Operator: Hexion UK Limited  
 Installation: Barry Thermosets Plant Form Number: Water1 / 25/04/2013

**Reporting of emissions to water (other than to sewer) for the period from 30/03/2018 to 28/06/2018**

Emission Point	Substance / Parameter	Emission Limit Value	Reference Period	Result <sup>[1]</sup>	Average Result <sup>[5]</sup>	Test Method <sup>[2]</sup>	Sample Date and Times <sup>[3]</sup>	Uncertainty <sup>[4]</sup>
W1	Daily discharge. Maximum volume of effluent discharged under dry conditions determined by no significant rainfall over the previous 48 hours on the Barry site. discharged.	6800m <sup>3</sup>	Instantaneous	3570	584		05/04/2018 12/04/2018 19/04/2018 26/04/2018 03/05/2018 10/05/2018 17/05/2018 24/05/2018 31/05/2018 07/06/2018 14/06/2018 21/06/2018 28/06/2018	
W1	Daily discharge. Maximum volume of effluent	15900m <sup>3</sup>	Instantaneous	3570	584		As above	
W1	Flow	0.19m <sup>3</sup> /s	Instantaneous	0.0413	0.00676		As above	
W1	Monohydric phenol	10mg/l	24-hour flow proportional sample	8	2.8	BS6068-2.12 1990 ISO6439:1990	As above	1.64

Emission Point	Substance / Parameter	Emission Limit Value	Reference Period	Result <sup>[1]</sup>	Average Result <sup>[5]</sup>	Test Method <sup>[2]</sup>	Sample Date and Times <sup>[3]</sup>	Uncertainty <sup>[4]</sup>
W1	Total suspended solids	150mg/l	24-hour flow proportional sample	91.6	43.3	BS EN 872 2005 /BS6068-2.54 2005	As above	13.6
W1	Chemical Oxygen Demand	1000mg/l	24-hour flow proportional sample	779	522	BS ISO 15705-2002/BS6068-2.80 2002	As above	122
W1	Methanol	50mg/l	24-hour flow proportional sample	17	2.2	BS EN ISO 15680 2003	As above	2.73
W1	Acrylonitrile	50mg/l	24-hour flow proportional sample	0	0	BS 6068 2.85:2003	As above	0
W1	Free formaldehyde	10mg/l	24-hour flow proportional sample	1	0.1	BS 2942 App D	As above	0.154
W1	Styrene	None	24-hour flow proportional sample	n/a	n/a	n/a		
W1	pH	6-9	Instantaneous	7.9	7.5	BS6068-2.50	As above	0.0923
W1	Monohydric phenol	10950 kg/year	Annual mass release		-	-	-	
W1	Methanol	43800 kg/year	Annual mass release		-	-	-	
W1	Acrylonitrile	51000 kg/year	Annual mass release		-	-	-	
W1	Free formaldehyde	10950 kg/year	Annual mass release		-	-	-	

1. The result given is the maximum value obtained during the reporting period (3 months), expressed in the same terms as the emission limit value.
2. Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated, e.g. gas chromatography.
3. For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.
4. The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

5. An average of the samples taken over the reporting period (every 3 months). This figure is for information only.



Signed .....  
(Authorised to sign as representative of Operator)

Date.....10<sup>th</sup> July 2018