

Permit Number: PP3238LX Operator: Hexion UK Limited
 Installation: Barry Thermosets Plant Form Number: Water1 / 25/04/2013

Reporting of emissions to water (other than to sewer) for the period from 31/03/2017 to 29/06/2017

Emission Point	Substance / Parameter	Emission Limit Value	Reference Period	Result ^[1]	Average Result ^[5]	Test Method ^[2]	Sample Date and Times ^[3]	Uncertainty ^[4]
W1	Daily discharge. Maximum volume of effluent discharged under dry conditions determined by no significant rainfall over the previous 48 hours on the Barry site. discharged.	6800m ³	Instantaneous	2180	760		06/04/2017 13/04/2017 20/04/2017 27/04/2017 04/05/2017 11/05/2017 18/05/2017 25/05/2017 01/06/2017 08/06/2017 15/06/2017 22/06/2017 29/06/2017	
W1	Daily discharge. Maximum volume of effluent	15900m ³	Instantaneous	2180	760		As above	
W1	Flow	0.19m ³ /s	Instantaneous	0.0252	0.0088		As above	
W1	Monohydric phenol	10mg/l	24-hour flow proportional sample	6	3.6	BS6068-2.12 1990 ISO6439:1990	As above	1.03

Emission Point	Substance / Parameter	Emission Limit Value	Reference Period	Result ^[1]	Average Result ^[5]	Test Method ^[2]	Sample Date and Times ^[3]	Uncertainty ^[4]
W1	Total suspended solids	150mg/l	24-hour flow proportional sample	38.4	21.8	BS EN 872 2005 /BS6068-2.54 2005	As above	6.38
W1	Chemical Oxygen Demand	1000mg/l	24-hour flow proportional sample	936	423	BS ISO 15705-2002/BS6068-2.80 2002	As above	108
W1	Methanol	50mg/l	24-hour flow proportional sample	6	0.9	BS EN ISO 15680 2003	As above	1.05
W1	Acrylonitrile	50mg/l	24-hour flow proportional sample	0	0	BS 6068 2.85:2003	As above	0
W1	Free formaldehyde	10mg/l	24-hour flow proportional sample	0	0	BS 2942 App D	As above	0
W1	Styrene	None	24-hour flow proportional sample	n/a	n/a	n/a		
W1	pH	6-9	Instantaneous	7.9	7.4	BS6068-2.50	As above	0.159
W1	Monohydric phenol	10950 kg/year	Annual mass release		-	-	-	
W1	Methanol	43800 kg/year	Annual mass release		-	-	-	
W1	Acrylonitrile	51000 kg/year	Annual mass release		-	-	-	
W1	Free formaldehyde	10950 kg/year	Annual mass release		-	-	-	

1. The result given is the maximum value obtained during the reporting period (3 months), expressed in the same terms as the emission limit value.
2. Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated, e.g. gas chromatography.
3. For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.
4. The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.
5. An average of the samples taken over the reporting period (every 3 months). This figure is for information only.

A handwritten signature in black ink, appearing to read "J. Bealby". The signature is written in a cursive style with a long horizontal stroke extending to the right.

Signed
(Authorised to sign as representative of Operator)

Date.....25th July 2017