

- 5 JAN 2016

Schedule 1 – Notification of abnormal emissions

This page outlines the information that the Operator must provide to satisfy conditions 5.1.1 and 5.1.2 of this Permit.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the PPC Regulations.

Part A

Permit Number	UP3237CP
Name of Operator	RF Brookes Ltd
Location of Installation	Rogerstone Park, Azalea Road, Rogerstone, Newport, Gwent, NP10 9SA
Location of the emission	Oven in Yorkshire Pudding Plant (Low Risk side)
Time and date of the emission	Sunday 20 th December (12:03pm)

Substance(s) emitted	Media	Best estimate of the quantity or the rate of emission	Time during which the emission took place
None	N/A	Fire was active for approx 10-20 seconds.	12:03 pm
Measures taken, or intended to be taken, to stop the emission	Operators noticed a fire had started in the Yorkshire pudding oven. The fire suppression system was operated by the operator on duty – his estimation was approximately 10 seconds after he noticed the fire. The suppression system was operated manually, and it is known the fire was extinguished immediately (steam). The operator called Fire Brigade as a precaution, but no measures were taken. No extra water was generated within the suppression process. No fugitive emissions were created (all contained within room).		

Alica Thomas

* Authorised to sign on behalf of RF Brookes