


**(c) In the event of a breach of permit condition which poses an immediate danger to human health or threatens to cause an immediate significant adverse effect on the environment:**

To be notified immediately	
Description of where the effect on the environment was detected	
Substances(s) detected	
Concentrations of substances detected	
Date of monitoring/sampling	

**Part B - to be submitted as soon as practicable**

Any more accurate information on the matters for notification under Part A.	Gap in SLAB leads below to A waterproof membrane
Measures taken, or intended to be taken, to prevent a recurrence of the incident	Contractor applied the correct seal on 17/03/17
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	Inspection of all slab sealant within bund.
The dates of any unauthorised emissions from the facility in the preceding 24 months.	N/A

Name*	CARL THOMAS
Post	LEAD OPERATOR
Signature	C. Thomas
Date	20/03/17

\* authorised to sign on behalf of the operator