

Permit Number: EPR/SP3537VQ
Facility: Bryn Pica Anaerobic Digestion Facility

Operator: Biogen Bryn Pica Ltd
Form Number: Performance1 10/12/14

Reporting of other performance indicators for the period 10/12/2014 to 31/12/2015

Parameter	Units
Power output – Electricity	5,184.99 MWh
Energy efficiency	0.002 MWh/m ³ Biogas
Electrical energy exported to the grid	4,474.78 MWh
Electrical energy drawn from the grid	195 MWh
Water usage	1,643 M ³
Operational time of emergency flare	5.5% of operational time
Amount of biogas combusted in the CHP unit per day	9,540 M ³ /day

Operator's comments :

The site does not yet benefit from a mains water connection and therefore potable water is either tankered in or collected from rainfall. The volume of biogas combusted on a daily basis is an average figure since the plant became operational.

Signed
(Authorised to sign as representative of Operator)

Date: 22/1/16