

Schedule 5 – Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

Part A

Permit Number	EPR/LP3131SW
Name of operator	Simec Uskmouth Power Limited
Location of Facility -	Uskmouth Power Plant
Time and date of the detection	17 October 2016

(a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or emission of a substance not controlled by an emission limit which has caused, is causing or may cause significant pollution	
To be notified immediately	
Date and time of the event –	22 nd September 2016 to 17 October 2016
Reference or description of the location of the event –	Unit 13 line 10 and 20 Dust monitors
Description of where any release into the environment took place –	A4 common chimney
Substances(s) potentially released -	Dust
Best estimate of the quantity or rate of release of substances –	0.5 tonnes
Measures taken, or intended to be taken, to stop any emission	Refurbished DR800 dust monitors are ready for delivery once payment has been made.
Description of the failure or accident.	Continuous monitoring requirement not met.

(b) Notification requirements for the breach of a limit	
To be notified immediately unless otherwise specified below	
Emission point reference/ source	
Parameter(s)	
Limit	
Measured value and uncertainty	
Date and time of monitoring	

Permit number


LP3131SW 31

(b) Notification requirements for the breach of a limit	
To be notified immediately unless otherwise specified below	
Measures taken, or intended to be taken, to stop the emission	
Time periods for notification following detection of a breach of a limit	
Parameter	Notification period

(c) Notification requirements for the detection of any significant adverse environmental effect	
To be notified immediately	
Description of where the effect on the environment was detected	
Substances(s) detected	
Concentrations of substances detected	
Date of monitoring/sampling	

Part B – to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	
Measures taken, or intended to be taken, to prevent a recurrence of the incident	
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	
The dates of any unauthorised emissions from the facility in the preceding 24 months.	

Name* M JAMES	
Post ENVIRONMENTAL OFFICER	
Signature 	
Date 17 10 2016	

* authorised to sign on behalf of the operator

Permit number

LP3131SW 32