

RELEASES TO CONTROLLED WATER

Reporting of emissions to Water (other than sewer) for the period from:

01/12/2017 to 31/12/2017

OPERATOR: Uskmouth Power Company FORM: W1

LOCATION: Newport

PERMIT/VARIATION NUMBER: LP3131SW

Emission Point	Substance/Parameter	ELY	Result (1)	Test Method (2)	Sample date and time(3)	Accreditation/ Certification(4)	Uncertainty(5)
W1a	Total Suspended Solids	75 mg/l	7.65	EIWC05	29/12/2017 (11:30)	UKAS 1314 STL	19.70%
W1a	pH	6 - 9	7.63	EIWC02	29/12/2017 (11:30)	"	5.60%
W1a	Cadmium	0.01 mg/l		EIWC09		"	6.60%
W1a	Mercury	0.005 mg/l					7.70%
W1b	Total Suspended Solids	75 mg/l	8	EIWC05	29/12/2017 (11:40)	UKAS 1314 STL	19.70%
W1b	pH	6 - 9	7.51	EIWC02	29/12/2017 (11:40)	"	5.60%
W1b	Cadmium	0.01 mg/l		EIWC09			6.60%
W1b	Mercury	0.005 mg/l					7.70%
W2	Total Suspended Solids	150 mg/l		EIWC05			19.70%
W2	pH	6 - 9		EIWC02			5.60%
W2	Temperature	30°C		ISO, BS EN or SCA Blue book method			+/- 1°C
W2	Biological Oxygen Demand	100 mg/l		BS EN 1899-1			20.10%
W2	Zinc	2 mg/l		EIWC09			6.30%
W2	Copper	0.8 mg/l		EIWC09			8.00%
W2	Nickel	0.4 mg/l		EIWC09			7.10%
W2	Lead	0.8 mg/l		EIWC09			7.00%
W2	Chromium	0.8 mg/l		EIWC09			7.60%
W2	Flow	19872 second		ISO, BS EN or SCA Blue book method			0.50%
W2	Flow	0.01 mg/l		ISO, BS EN or SCA Blue book method			0.50%
W2	Cadmium	0.01 mg/l		EIWC09			6.60%
W2	Mercury	0.005 mg/l					7.70%

- (1) The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the minimum - maximum measured values.
- (2) Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated, e.g. colorimetry.
- (3) For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements, or flow/time proportional samples, the percentage of the process operating time covered by the monitoring is given.
- (4) The accreditation status of the equipment and/or the monitoring organisation, as appropriate, for the methods used for both sampling and analysis.
- (5) The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.
- (6) The emission limit values for all substances is expressed as a maximum individual value
- (7) W2 no sample taken due to ponds emptied and systems offline. No blowdown from ponds till further notice.
- (8) Awaiting confirmation of UKAS accreditation for BOD and Mercury testing

Signed

(authorised to sign as representative of the Operator)

Date.....

26/01/2018