

EMISSIONS MONITORING SURVEY

Prepared for:

Biotage GB Ltd
Distribution Way, Dyffryn Industrial Estate
Ystard Mynach
CF82 7TS

Permit Number	: EPR/DP3832EF
Variation Number	: N/A
Installation	: Ystrad Mynach
Visit Details	: Annual Emissions Compliance
Job Number	: P2251
Report Number	: R001
Report Issue Date	: 29 th April 2015
Survey Dates	: 31 st March – 1 st April 2015

Prepared by:

Environmental Compliance Limited
 Unit G1
 Main Avenue
 Treforest Industrial Estate
 Pontypridd
 CF37 5BF.
 Tel: 01443 841760
 Fax: 01443 841761

Report Issue:		FINAL	
Report Prepared by:		Report Reviewed & Approved by MCERTS Level Two Technical Endorsements TE1, TE2, TE3 & TE4	
Name:	Sam Brookes	Name:	Craig Lewis
		MCERTS No:	MM 11 1148
		Signature:	
Date:	28/04/2015	Date:	11/05/2015

This report is not to be used for contractual or engineering purposes unless this approval sheet is signed where indicated by the approver and the report is designated "FINAL".



Environmental Compliance Limited

Biotage GB Ltd		Installation Name	: Ystrad Mynach
Permit No	: EPR/DP3832EF	Visit Details	: Annual Compliance Emissions
Variation No	: N/A	Survey Dates	: 31 st March – 1 st April 2015
Report Ref	: P2251 : R001	Report Issue Date	: 29th April 2015

This report has been prepared by Environmental Compliance Limited (ECL) in their professional capacity as Environmental Consultants. The contents of the report reflect the conditions that prevailed and the information available or supplied at the time of its preparation. The report, and the information contained therein, is provided by ECL solely for use and reliance by the Client in performance of ECLs duties and liabilities under its contract with the Client. Until ECL has received payment in full as detailed in the quotation or contract the contents of this report remain the legal property of ECL. The contents of the report do not, in any way, purport to include any manner of legal advice or opinion.

Should the Client wish to release this report to a Third Party for the party's reliance, Environmental Compliance Ltd may, at its discretion, agree to such release provided that:

- Environmental Compliance Ltd gives written agreement prior to such release and ECL has received payment in full for all works/services undertaken;
- By release of the report to the Third Party, that Third Party does not acquire any rights, contractual or otherwise, whatsoever against Environmental Compliance Ltd and, accordingly, Environmental Compliance Ltd assume no duties, liabilities or obligations to that Third Party;
- Environmental Compliance Ltd accepts no responsibility for any loss or damage incurred by the Client or for any conflict of Environmental Compliance Ltd interests arising out of the Clients' release of this report to the Third Party.

In the event that a report is revised and re-issued, the client shall ensure that any earlier versions of the report, and any copies thereof, are void and such copies should be marked with the words "superseded and revised".

Opinions and Interpretation expressed within this report are outside the scope of the UKAS accreditation.

MCERTS requirements mean that comparison of results with emissions limit values is not permitted within this report.

TABLE OF CONTENTS

Section	Description	Page Number
	Document Control Sheet	
PART 1	EXECUTIVE SUMMARY	4
1	MONITORING OBJECTIVES	4
1.1	Monitoring Results	5
1.2	Operating Information	7
2	MONITORING DEVIATIONS	8
PART 2	SUPPORTING INFORMATION	9
3	SAMPLING STAFF DETAILS	9
4	SAMPLING PROTOCOLS / METHODOLOGIES	10
5	SAMPLE POINT DESCRIPTIONS	13
	EQUIPMENT IDs	15
	FIGURES	17
	TABLES	19
	VELOCITY TRAVERSE PROFILES	26
	FIELD CALIBRATION AND SAMPLING DATA	31
	LABORATORY ANALYSIS RESULTS	39
	UNCERTAINTY CALCULATIONS	43

PART 1 - EXECUTIVE SUMMARY

1 Monitoring Objectives

Environmental Compliance Ltd (ECL) was commissioned by **Biotage Ltd** to undertake an emission monitoring survey at their **Ystard Mynach installation**. This report presents the findings of the study.

The monitoring at this installation was carried out in accordance with our quotation reference **dhfb/P2251/Q001** for compliance check monitoring of emissions to air. The substances requested for monitoring at each emissions point are listed below:

Substances to be monitored	Emission Point Identification			
	A1	A2	A3	A4
Velocity / Flowrate	● U	● U	● U	● U
Oxides of Nitrogen (as NO ₂)			● U	
Hydrogen Chloride	● U	● U		
Hydrogen Bromide				● U*
Methanol	● U*	● U*	● U*	

● Denotes the substances to be monitored.

U

Denotes UKAS accreditation is held for monitoring that substance, but does not mean that it has been claimed which will depend on whether the testing could be completed in accordance with the Standard Reference Method.

* External laboratory does not hold UKAS accreditation for Hydrogen Bromide and Methanol

Special Requirements: *"Under normal operating conditions."*

Environmental Compliance Limited

Biotage GB Ltd
 Permit No : EPR/DP3832EF
 Variation No : N/A
 Report Ref : P2251 : R001

Installation Name : Ystrad Mynach
 Visit Details : Annual Compliance Emissions
 Survey Dates : 31st March – 1st April 2015
 Report Issue Date : 29th April 2015

1.1 Monitoring Results

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty %	Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation for use of Method	Tick if non-conforming test (see Sections 2 & 5)	Operating Status
A1 Main Building EP1	Volumetric Flowrate	N/A	0.42	m³/sec	4	Stack Conditions	31/03/15	09:00 – 09:12	BS EN 16911-1	UKAS / MCERTS		Normal
	Volumetric Flowrate	N/A	0.39	m³/sec	5	Wet Gas						
	Hydrogen Chloride \$	10	106.08	mg/m³	13	09:34 – 10:34		BS EN 1911	UKAS / MCERTS			
	Methanol \$	2700	< 1.78	mg/m³	10	09:30 – 10:30		BS EN 13649: 2002	NU			

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty %	Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation for use of Method	Tick if non-conforming test (see Sections 2 & 5)	Operating Status
A2 Main Building EP2	Volumetric Flowrate	N/A	0.47	m³/sec	4	Stack Conditions	01/04/15	06:30 – 06:42	BS EN 16911-1	UKAS / MCERTS		Normal
	Volumetric Flowrate	N/A	0.45	m³/sec	5	Wet Gas						
	Hydrogen Chloride \$	29	33.40	mg/m³	13	06:51 – 07:51		BS EN 1911	UKAS / MCERTS			
	Methanol \$	27	< 1.81	mg/m³	10	06:53 – 07:53		BS EN 13649: 2002	NU			

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty %	Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation for use of Method	Tick if non-conforming test (see Sections 2 & 5)	Operating Status
A3 Main Building EP3	Volumetric Flowrate	N/A	0.38	m³/sec	4	Stack Conditions	01/04/15	11:55 – 12:07	BS EN 16911-1	UKAS / MCERTS		Normal
	Volumetric Flowrate	N/A	0.36	m³/sec	5	Wet Gas				UKAS / MCERTS		
	Oxides of Nitrogen (as NO₂)	35.7	56.71	mg/m³	4			12:48 – 13:47	BS EN 14792: 2005	UKAS / MCERTS		
	Methanol \$	260	10.69	mg/m³	10			12:14 – 13:14	BS EN 13649: 2002	NU		

Environmental Compliance Limited

Biotage GB Ltd
Permit No : EPR/DP3832EF
Variation No : N/A
Report Ref : P2251 : R001

Installation Name : Ystrad Mynach
Visit Details : Annual Compliance Emissions
Survey Dates : 31st March – 1st April 2015
Report Issue Date : 29th April 2015

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty %	Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation for use of Method	Tick if non-conforming test (see Sections 2 & 5)	Operating Status
A4 Resin Shed EP4	Volumetric Flowrate	N/A	0.87	m³/sec	5	Stack Conditions	01/04/15	08:30 – 08:42	BS EN 16911-1	UKAS / MCERTS		Normal
	Volumetric Flowrate	N/A	0.80	m³/sec	5	Wet Gas				UKAS / MCERTS		
	Hydrogen Bromide \$	0.2	57.63	mg/m³	13			09:04 – 10:04	US EPA Method 26	NU	✓	

The volumetric flowrate shown above is that from the initial pitot traverse. Any other flow measurements made during isokinetic sampling and/ or repeat traverses are shown later in the tables section.

Notes

Emission Limit Value
Periodic Monitoring Result
Uncertainty
Reference Conditions
Monitoring Method Reference
Accreditation for use of Method
Operating Status
\$
NU
NA

The emission limit value is that stated in the permit and will be expressed as a concentration or a mass emission.
The result given is expressed in the same terms and units as the emission limit value.
The uncertainty associated with the quoted result is at the 95% confidence interval. The Uncertainty results **DO NOT** take into account the effect of the sample location limitations.
All results are expressed at 273 K and 101.3kPa. The oxygen and moisture corrections are stated.
The method stated is in accordance with the Environment Agency Technical Guidance Note M2, or other method approved by the Environment Agency.
The details indicate the accreditation for the use of the complete monitoring method, e.g. MCERTs, UKAS. If use of the method is not accredited "NA" is stated.
The details indicate the feedstock and the loading rate of the plant during monitoring.
Chemical Analysis on sample reagents was performed by an External Laboratory as detailed in Section 4
UKAS Accreditation Held but UKAS Accreditation cannot be claimed for the test as sampling did not comply with the Standard Reference Method (SRM), see section 2 & 5
Method is NOT UKAS Accredited.

Environmental Compliance Limited

Biotage GB Ltd
 Permit No : EPR/DP3832EF
 Variation No : N/A
 Report Ref : P2251 : R001

Installation Name : Ystrad Mynach
 Visit Details : Annual Compliance Emissions
 Survey Dates : 31st March – 1st April 2015
 Report Issue Date : 29th April 2015

1.2 Operating Information

Emission Point Reference	Process Type	Process Duration	Fuel	Feedstock	Abatement	Load	Comparison of Operator CEMS and Periodic Monitoring Results					
							Parameter	Date	Time	CEMS Results	Periodic Monitoring Results	Units
A1	Batch	Early morning	N/A	N/A	None	N/A	...	...	...	NP	...	...
A2	Continuous	N/A	N/A	N/A	None	N/A	...	...	...	NP	...	...
A3	Continuous	N/A	N/A	N/A	None	N/A	...	...	...	NP	...	...
A4	Batch	Early morning	N/A	N/A	None	N/A	...	...	...	NP	...	...

Notes:

Process Type State whether the process is a continuous or batch process.
 Process Duration If a batch process, state the duration, frequency and details of the portion of the batch sampled. If continuous state "NA"
 Fuel If applicable, state the fuel type If not applicable state "NA"
 Feedstock State the feedstock type
 Abatement State the type and whether operational during monitoring. If not applicable state "NA"
 Load State the normal load, throughput or rating of the plant
 CEMS Data Enter this data for each CEM installed if it has been provided by operator otherwise state "NP" (NOT PROVIDED)

2 Monitoring Deviations

The objective of the survey was to measure the concentrations of pollutants from the processes / locations as detailed in Section 1. This survey meets the requirements of the site's **PPC Permit Number: EPR/DP3832EF**, where UKAS and MCERTS accreditation has and could be claimed for the testing in the monitoring results table.

There were no modifications to the sampling procedures (TPDs) listed in Section 4.

There were no substance deviations from the original and agreed emissions monitoring schedule.

Non-conforming tests are as follows:

- The blank concentration for Hydrogen Bromide on A4 was greater than 10% of the ELV. Consequently, UKAS/MCERTS cannot be claimed and the result shall be reported as "NU".
- The analytical laboratory is not accredited for the analysis of Hydrogen Bromide. Consequently, UKAS/MCERTS cannot be claimed and the result shall be reported as "NU".
- The analytical laboratory is not accredited for the analysis of Methanol. Consequently, UKAS/MCERTS cannot be claimed and the result shall be reported as "NU".

The Uncertainty of the reported concentrations for these pollutant results DOES NOT take into account the effect of non-conformities or sample location limitations.

Homogeneity tests have not been completed for pollutants at the following locations:

- A1, A2, A3 & A4 - Such tests are not applicable to these locations as the duct area is < 1m² and they were not requested by the client.

PART 2 – SUPPORTING INFORMATION

3 SAMPLING STAFF DETAILS

Site Sampling Team

Names of Site Team	Dates on Site	MCERTS No.	LEVEL	Technical Endorsements
Craig Lewis	31/03/2015 and 01/04/2015	MM 11 1148	2	TE1, TE2, TE3, TE4
Ian Hick		MM 12 1192	1	...

Report Reviewer

Name	MCERTS No.	LEVEL	Technical Endorsements
Craig Lewis	MM 11 1148	2	TE1, TE2, TE3, TE4

Technical Endorsement Key:-

TE1 – Isokinetic Particulates, Temperature & Velocity Profiles, Oxygen.

TE2 – Isokinetic Extractive Pollutants:- Metals, Dioxin & Furans, PAHs, PCBs, HCl, HF.

TE3 – Non-Isokinetic Extractive Pollutants:- Speciated VOCs, HF, HCl, Cyanide.

TE4 – Continuous Analysers (Combustion Gases):- TVOC, CO, NO_x, SO₂.

4 SAMPLING PROTOCOLS / METHODOLOGIES

Any required modifications to the Technical Procedure Documents (TPDs) specified below will be detailed in section 2 of this report.

Pressure, Temperature and Velocity

Testing was carried out using a sampling system in accordance with **BS EN ISO 16911-1 & MID** and In-house technical procedure **ECL/TPD/022**.

Temperature was recorded using a thermocouple and digital temperature reader.

Velocity and pressure were recorded using an “L” type pitot and digital manometer, data being recorded in mm H₂O.

Combustion Gases (NO_x)

Measurements of combustion gases were carried out using an MCERTS Certified **Horiba PG 250** stack gas analyser. Continuous monitoring of emissions was undertaken over each test period recording minute averaged data (one measurement every 60 seconds). The measurement techniques for each determinand are as follows:

<u>Determinand</u>	<u>Technique</u>	<u>SRM</u>
• NO _x	Chemiluminescence	BS EN 14792: 2005

The analyser was set up with reference to the manufacturers operator handbook and the in-house technical procedure **ECL/TPD/033c**. The analyser was calibrated on site using certified gases which are traceable to ISO 17025. (with uncertainty <2%). Zero measurements were performed using Nitrogen. The analyser was calibrated directly into the sample inlet and then checked through the entire sampling system (including sampling probe, heated & unheated gas transport lines and gas drying/conditioning system).

Data is presented graphically in the Figures Section, and the minute averaged data is given in the Tables Section.

Halogen Halides & Halogens (Hydrogen Bromide Only)

Testing was carried out isokinetically using a Universal Stack Sampling system in accordance with **US EPA Method 26** and In-house technical procedure **ECL/TPD/035**. Non-isokinetic sampling can only take place if there are no droplets present in the stack gas.

In this method the stack gases are filtered to remove particulate matter then the gases are passed through a series of impingers. The first two impingers each containing 100ml of 0.1N Sulphuric Acid (0.1N H₂SO₄) the second set of impingers each containing 100ml of 0.1N Sodium Hydroxide (0.1N NaOH) and finally through an impinger containing a measured quantity of silica gel.

The first two impingers containing the 0.1N Sulphuric Acid are analysed for concentrations of Hydrogen Bromide.

Scientific Analysis Laboratories Ltd (SAL) who is situated in Manchester carried out the analysis of the samples. **SAL is not UKAS accredited** for this analysis. In addition to the survey samples, appropriate field blanks and efficiency checks are submitted as part of the technical procedure.

Hydrogen Chloride

Testing was carried out isokinetically using a Universal Stack Sampling system in accordance with **BS EN 1911** and In-house technical procedure **ECL/TPD/036**. Non-isokinetic sampling can only take place if there are no droplets present in the stack gas.

In this method the stack gases are filtered to remove particulate matter then the gases are passed through a series of impingers. The first two or three impingers each containing 100ml of De-ionised Water and finally through an impinger containing a measured quantity of silica gel.

The impingers containing the de-ionised water are analysed for concentrations of Hydrogen Chloride by IC (Ion Chromatography).

Scientific Analysis Laboratories Ltd (SAL) who is situated in Manchester carried out the analysis of the samples. **SAL is UKAS accredited** for this analysis. In addition to the survey samples, appropriate field blanks and efficiency checks are submitted as part of the technical procedure.

Speciated VOC (Methanol Only)

Non-continuous sampling for **Speciated VOC (Methanol)** was carried out in accordance with **BS EN 13649** and In-house technical procedure **ECL/TPD/084**. In this method a metered volume of stack gas is extracted through a standard charcoal sorbent tube.

Scientific Analysis Laboratories Ltd (SAL) who is situated in Manchester carried out the analysis of the samples. **SAL is not UKAS accredited** for the analysis of Methanol. In addition to the survey samples, appropriate field blanks and efficiency checks are submitted as part of the technical procedure.

Due to restrictions set out in BS EN 13649, MCERTS/UKAS accreditation can only be claimed when the target parameters are organic compounds, the sorbent tube used is a standard charcoal tube and when laboratory analysis is UKAS accredited and carried out by GC. If other tubes are used, or if analysis is by other means than GC, then usually only UKAS accreditation can be claimed, as long as the laboratory analysis is UKAS accredited. (MCERTS accreditation may still be claimed if prior approval is given for the modifications by the Environment Agency – details will be given in section 2 of this report).

Laboratory analysis **cannot** be UKAS accredited for “Total VOC” or “TOP 10 compounds”.

For the subcontract laboratory to claim UKAS accreditation for analysis, the internal recovery of a spiking compound (desorption efficiency from tube) needs to be above 80%. If it falls below 80% this will be noted on the analysis certificate.

Water Vapour

Testing was carried out using a Universal Stack Sampling system in accordance with **BS EN 14790** and In-house technical procedure **ECL/TPD/082**.

In this method the stack gases are filtered (in-stack unheated filter or out-stack heated filter) to remove particulate matter. The gases are then passed through a **heated probe** and then to a cooled moisture trapping unit. All unheated parts of the sample train (outside the sample port) which come into contact with stack gas are weighed pre and post sampling in order to determine the weight gain.

After each test, a visual inspection of the last impinger is made to confirm that at least 50% of the silica gel column has not changed colour. This indicates satisfactory collection of water vapour.

5 SAMPLE POINT DESCRIPTIONS

The homogeneity test is applicable to combustion processes. This includes but is not restricted to, those regulated under the Waste Incineration Directive (**WID**) and the Large Combustion Plant Directive (**LCPD**).

Homogeneity testing has not been completed at these locations in accordance with the mandatory requirements of the regulatory authority.

The test is not usually required for stacks with sampling plane areas of $< 1\text{m}^2$ (below 1.13m in diameter for circular ducts).

The sample locations that were monitored are detailed below:-

A1

The sampling platform does meet the requirements detailed in *Technical Guidance Note (Monitoring) M1 "Sampling requirements for stack-emission monitoring"* Environment Agency, and BS EN 13284-1.

The stack diameter is 200mm and the sample platform width back from the sample port is 2m.

There is one sample port but this is adequate for a duct of this size.

These sample ports is located at a height of approximately 0.75m from the working sample platform

All sampling was carried out non-isokinetically.

A2

The sampling platform does meet the requirements detailed in *Technical Guidance Note (Monitoring) M1 "Sampling requirements for stack-emission monitoring"* Environment Agency, and BS EN 13284-1.

The stack diameter is 200mm and the sample platform width back from the sample port is 2m.

There is one sample port.

These sample port is located at a height of approximately 0.75m from the working sample platform

All sampling was carried out non-isokinetically.

Biotage GB Ltd
Permit No
Variation No
Report Ref

: EPR/DP3832EF
: N/A
: P2251 : R001

Installation Name : Ystrad Mynach
Visit Details : Annual Compliance Emissions
Survey Dates : 31st March – 1st April 2015
Report Issue Date : 29th April 2015

A3

The sampling platform does meet the requirements detailed in *Technical Guidance Note (Monitoring) M1* "Sampling requirements for stack-emission monitoring" Environment Agency, and BS EN 13284-1.

The stack diameter is 200mm and the sample platform width back from the sample port is 2m.

There is one sample port.

These sample port is located at a height of approximately 0.75m from the working sample platform

All sampling was carried out non-isokinetically.

A4

The sampling platform does meet the requirements detailed in *Technical Guidance Note (Monitoring) M1* "Sampling requirements for stack-emission monitoring" Environment Agency, and BS EN 13284-1.

The stack diameter is 350mm and the sample platform width back from the sample port is 2.5m.

There is one sample port.

These sample port is located at a height of approximately 1.2m from the working sample platform

All sampling was carried out non-isokinetically.

Environmental Compliance Limited

Biotage GB Ltd

Permit No : EPR/DP3832EF

Variation No : N/A

Report Ref : P2251 : R001

Installation Name

: Ystrad Mynach

Visit Details

: Annual Compliance Emissions

Survey Dates

: 31st March – 1st April 2015

Report Issue Date

: 29th April 2015

EQUIPMENT IDs
(Pre site checklist from SSP)

Biotage GB Ltd
 Permit No : EPR/DP3832EF
 Variation No : N/A
 Report Ref : P2251 : R001

Installation Name : Ystrad Mynach
 Visit Details : Annual Compliance Emissions
 Survey Dates : 31st March – 1st April 2015
 Report Issue Date : 29th April 2015

PRE SITE EQUIPMENT CHECKLIST/ EQUIPMENT USED

(Completed before departure to site and when on site in full)

Equipment	Equip. Type	ID No:	ID No:	ID No:	ID No:	ID No:	ID No:	ID No:	ID No:
MST console/pump	E001	U011							
MST Nozzle set		...							
MST "S" Type Pitot		...							
MST Probe		141							
MST Hot Box		977							
MST Impinger Arm		657							
		980							
Barometer		629							
Site Balance		368							
Site Check weights		598							
		599							
Horiba	E002	511							
Heated Probe / Filter		806							
Chiller		970							
Sonimix / MFC		934	761						
Heated Line		1013	1014						
FID	E003								
Heated Line									
Heated Probe / Filter									
Testo	E004								
FTIR	E005								
Heated Probe / Filter									
Heated Line									
Stackmite	E006	...							
"L" Type Pitot		491							
Digital Manometer		506	421						
Stack Thermocouple		464							
Thermocouple Reader		431							
Nozzle Set		...							
Workhorse Pumps	E007	164							
Low Flow Pumps									

Quantity of Ice Required / Used for Survey	4	Bags (2kg bags)
--	---	-----------------

Environmental Compliance Limited

Biotage GB Ltd		Installation Name	: Ystrad Mynach
Permit No	: EPR/DP3832EF	Visit Details	: Annual Compliance Emissions
Variation No	: N/A	Survey Dates	: 31 st March – 1 st April 2015
Report Ref	: P2251 : R001	Report Issue Date	: 29th April 2015


FIGURES

Biotage GB Ltd
 Permit No : EPR/DP3832EF
 Variation No : N/A
 Report Ref : P2251 : R001

Installation Name : Ystrad Mynach
 Visit Details : Annual Compliance Emissions
 Survey Dates : 31st March – 1st April 2015
 Report Issue Date : 29th April 2015

Figure 1

Data Recorded From Biotage GB Ltd, Ystrad Mynach, A3, EP3,
 on 31/03/2015 Between 12:48 and 13:47
 Data Presented at 273K, 101.3kPa, Wet Gas and No Correction for Oxygen



Environmental Compliance Limited

Biotage GB Ltd		Installation Name	: Ystrad Mynach
Permit No	: EPR/DP3832EF	Visit Details	: Annual Compliance Emissions
Variation No	: N/A	Survey Dates	: 31 st March – 1 st April 2015
Report Ref	: P2251 : R001	Report Issue Date	: 29th April 2015

TABLES

Biotage GB Ltd
 Permit No : EPR/DP3832EF
 Variation No : N/A
 Report Ref : P2251

: R001

Installation Name : Ystrad Mynach
 Visit Details : Annual Compliance Emissions
 Survey Dates : 31st March – 1st April 2015
 Report Issue Date : 29th April 2015

Table 1 – HCl

Data Recorded from A1 - Main Building EP1

Emission Parameter	Units	HCl-1	Blank
Stack Diameter	metres	0.20	
Area of Sample Plane	m ²	0.031	
Moisture Content	%	1.01	
Oxygen Content	%	20.90	
Stack Temperature	°C	13	
Gas Velocity (as Measured)	m/sec	12.53	
Gas Velocity (Reference Conditions)	m/sec*	11.75	
Volumetric Flowrate (as Measured)	m ³ /sec	0.39	
Volumetric Flowrate (Reference Conditions)	m ³ /sec*	0.37	
Dry Gas Molecular Weight	g/gmole	28.856	
Sample Date	...	31/03/2015	
Sample Period	...	09:34 - 10:34	
Sample Volume (reference Conditions)	m ³ *	0.566	0.566
Sample Reference (ECL ID)	ECL/15/	1546/1547	1548
Mass of Hydrogen Chloride Collected	mg	60.04	0.01
Concentration of Hydrogen Chloride	mg/m ³ *	106.08	0.02
Emission Rate of Hydrogen Chloride	g/hr	140.97	...
Expanded Uncertainty (% Relative)	%	13	...
Emission Limit Value (ELV)	mg/m ³ *	10	...
Impinger Collection Efficiency	%	100	...
Blank Concentration as Percentage of ELV	%	...	<1.00%

*Reference Conditions (273K, 101.3kPa, Wet Gas)

Biotage GB Ltd
 Permit No : EPR/DP3832EF
 Variation No : N/A
 Report Ref : P2251 : R001

Installation Name : Ystrad Mynach
 Visit Details : Annual Compliance Emissions
 Survey Dates : 31st March – 1st April 2015
 Report Issue Date : 29th April 2015

Table 2 – Methanol

Biotage GB LTD Ystrad Mynach Main building EP1 A1

Emission Parameter	Units	Value		
Stack Diameter	mm	200		
Area of Sample Plane	m ²	0.031		
Meter Temperature	°C	11.83		
Stack Temperature	°C	13.10		
Sample Date	...	31.03.15		
Sample Period	...	09:30 - 10:30		
Sample Volume (as Measured)	m ³	0.0059		
Sample Volume (reference Conditions)	m ³ *	0.0056		
Sample Tube Results		Speciated VOCs 1		Blank
Sample Reference ECL/15/1549	Units	Concentration*	Uncertainty	Concentration
Concentration of Methanol	mg/m ³	1.78	10.33%	1.78

*Reference Conditions: 273 K, 101.3 kPa, Wet Gas

Biotage GB Ltd
 Permit No : EPR/DP3832EF
 Variation No : N/A
 Report Ref : P2251

: R001

Installation Name : Ystrad Mynach
 Visit Details : Annual Compliance Emissions
 Survey Dates : 31st March – 1st April 2015
 Report Issue Date : 29th April 2015

Table 3 – HCl

Data Recorded from A2 - Main Building EP2

Emission Parameter	Units	HCl-1	Blank
Stack Diameter	metres	0.20	
Area of Sample Plane	m ²	0.031	
Moisture Content	%	0.02	
Oxygen Content	%	20.90	
Stack Temperature	°C	13	
Gas Velocity (as Measured)	m/sec	14.27	
Gas Velocity (Reference Conditions)	m/sec*	13.53	
Volumetric Flowrate (as Measured)	m ³ /sec	0.45	
Volumetric Flowrate (Reference Conditions)	m ³ /sec*	0.42	
Dry Gas Molecular Weight	g/gmole	28.856	
Sample Date	...	01/04/2015	
Sample Period	...	06:51 - 07:51	
Sample Volume (reference Conditions)	m ³ *	0.577	0.577
Sample Reference (ECL ID)	ECL/15/	1553/1554	1555
Mass of Hydrogen Chloride Collected	mg	19.28	0.01
Concentration of Hydrogen Chloride	mg/m ³ *	33.40	0.02
Emission Rate of Hydrogen Chloride	g/hr	51.10	...
Expanded Uncertainty (% Relative)	%	13	...
Emission Limit Value (ELV)	mg/m ³ *	29	...
Impinger Collection Efficiency	%	100	...
Blank Concentration as Percentage of ELV	%	...	<1.00%

*Reference Conditions (273K, 101.3kPa, Wet Gas)

Biotage GB Ltd
 Permit No : EPR/DP3832EF
 Variation No : N/A
 Report Ref : P2251 : R001

Installation Name : Ystrad Mynach
 Visit Details : Annual Compliance Emissions
 Survey Dates : 31st March – 1st April 2015
 Report Issue Date : 29th April 2015

Table 4 – Methanol

Biotage GB LTD
Ystrad Mynach Main Building EP2 A2

Emission Parameter	Units	Value		
Stack Diameter	mm	200		
Area of Sample Plane	m ²	0.031		
Meter Temperature	°C	6.17		
Stack Temperature	°C	12.55		
Sample Date	...	01.04.15		
Sample Period	...	06:53 - 07:53		
Sample Volume (as Measured)	m ³	0.0057		
Sample Volume (reference Conditions)	m ³ *	0.0055		
Sample Tube Results		Methanol 1		Blank
Sample Reference ECL/15/1556	Units	Concentration*	Uncertainty	Concentration
Concentration of Methanol	mg/m ³	1.81	10.33%	1.81

*Reference Conditions: 273 K, 101.3 kPa, Wet Gas

Table 5 – Moisture

Data Recorded from A3 - Main Building EP3

Emission Parameter	Units	Moisture-1	Blank
Stack Diameter	metres	0.20	
Area of Sample Plane	m ²	0.031	
Moisture Content	%	0.03	
Oxygen Content	%	20.90	
Stack Temperature	°C	15	
Gas Velocity (as Measured)	m/sec	12.25	
Gas Velocity (Reference Conditions)	m/sec*	11.50	
Volumetric Flowrate (as Measured)	m ³ /sec	0.38	
Volumetric Flowrate (Reference Conditions)	m ³ /sec*	0.36	
Dry Gas Molecular Weight	g/gmole	28.856	
Sample Date	...	31/03/2015	
Sample Period	...	12:13 - 12:43	
Sample Volume (reference Conditions)	m ³ *	0.447	0.447

*Reference Conditions (273K, 101.3kPa, Wet Gas)

Biotage GB Ltd
 Permit No : EPR/DP3832EF
 Variation No : N/A
 Report Ref : P2251 : R001

Installation Name : Ystrad Mynach
 Visit Details : Annual Compliance Emissions
 Survey Dates : 31st March – 1st April 2015
 Report Issue Date : 29th April 2015

Table 6 – NO_x
Data Recorded from A3 – Main Building EP3
Sample Period: 12:48 – 13:47 on the 1st April 2015

Volumetric Flowrate (Reference Conditions) = **0.36 m³/sec ***

	Average	Emission Rate
	mg/m ³	Kg/hr
Oxides of Nitrogen (as NO ₂) *	56.71	0.073

* Reference Conditions (273K, 101.3 kPa & Wet Gas)

Table 7 – Methanol

Biotage GB LTD
Ystrad Mynach Main Building EP3 A3

Emission Parameter	Units	Value			
Stack Diameter	mm	200			
Area of Sample Plane	m ²	0.031			
Meter Temperature	°C	16.17			
StackTemperature	°C	14.58			
Sample Date	...	31.03.15			
Sample Period	...	12:14 - 13:14			
Sample Volume (as Measured)	m ³	0.0061			
Sample Volume (reference Conditions)	m ³ *	0.0057			
Sample Tube Results		Methanol 1		Blank	
Sample Reference ECL/15/1551		Units	Concentration*	Uncertainty	Concentration
Concentration of Methanol		mg/m ³	10.69	10.34%	1.75

*Reference Conditions: 273 K, 101.3 kPa, Wet Gas

Biotage GB Ltd
 Permit No : EPR/DP3832EF
 Variation No : N/A
 Report Ref : P2251

: R001

Installation Name : Ystrad Mynach
 Visit Details : Annual Compliance Emissions
 Survey Dates : 31st March – 1st April 2015
 Report Issue Date : 29th April 2015

Table 8 – HBr

Data Recorded from A4 - Resin Shed

Emission Parameter	Units	Hydrogen Bromide 1	Blank
Stack Diameter	metres	0.20	
Area of Sample Plane	m ²	0.031	
Moisture Content	%	2.02	
Oxygen Content	%	20.90	
Stack Temperature	°C	23	
Gas Velocity (as Measured)	m/sec	9.04	
Gas Velocity (Reference Conditions)	m/sec*	8.30	
Volumetric Flowrate (as Measured)	m ³ /sec	0.28	
Volumetric Flowrate (Reference Conditions)	m ³ /sec*	0.26	
Dry Gas Molecular Weight	g/gmole	28.856	
Sample Date	...	01/04/2015	
Sample Period	...	09:04 - 10:04	
Sample Volume (reference Conditions)	m ³ *	0.610	0.610
Sample Reference	ECL/15/	1558 & 1559	1562
Mass of Hydrogen Bromide Collected	mg	35.14	1.15
Concentration of Hydrogen Bromide	mg/m ³ *	57.63	1.89
Emission Rate of Hydrogen Bromide	g/hr	54.11	...
Expanded Uncertainty (% Relative)	%	13	...
Emission Limit Value (ELV)	mg/m ³ *	0.2	...
Impinger Collection Efficiency	%	97	...
Blank Concentration as Percentage of ELV	%	...	943.09

*Reference Conditions (273K, 101.3kPa, Wet Gas)

Environmental Compliance Limited

Biotage GB Ltd

Permit No : **EPR/DP3832EF**

Variation No : **N/A**

Report Ref : **P2251** : **R001**

Installation Name

: **Ystrad Mynach**

Visit Details

: **Annual Compliance Emissions**

Survey Dates

: **31st March – 1st April 2015**

Report Issue Date

: **29th April 2015**

VELOCITY TRAVERSE PROFILES

Biotage GB Ltd
Permit No
Variation No
Report Ref

: EPR/DP3832EF

: N/A

: P2251 : R001

Installation Name : Ystrad Mynach

Visit Details	: Annual Compliance Emissions
---------------	-------------------------------

Survey Dates : 31st March – 1st April 2015

Report Issue Date : 29th April 2015

Company	Biotage GB LTD	Stack Diameter Port A (mm)	200	Average Stack Diameter (mm)	200	Pitot tube coefficient	1.00
Site	Ystrad Mynach	Stack Diameter Port B (mm)		Port Length (mm)	0	Pitot Id	491
Location	Main Building EP1	Duct Length Port A (mm)		Average Duct Length (mm) L		Stack Thermocouple ID	464
Stack	A1	Duct Length Port B (mm)		Duct width (mm) B		Stack Temp Reader ID	431
Job No	P2251	Duct Length Port C (mm)		Barometric Pressure. (mb)	1001	Manometer ID	506
Operators	CL + JH	Duct Length Port D (mm)		Ave Static Press. (mm H ₂ O)	8.65	Barometer ID	629

Pre - Traverse Checks Carried Out	Time	Pass/ Fail
Pre - Traverse Visual Inspection	09:00:00	Pass
Pre - Traverse Pitot Leak Check	09:02:00	Pass

Smooth Walls

Static Pressure Readings (mm H ₂ O)			
Port A	Port B	Port C	Port D
8.65			

Port/ Point	Distance to Point (mm)	Time	Temperature Readings (°C)			(ΔP) Pitot Readings (mm H ₂ O)			Average Temp. (°C)	Average (ΔP) (mm H ₂ O)	Swirl Test ° From Reference
			1	2	3	1	2	3			
A1	100	09:04:00	15.0	14.8	14.9	11.2	11.0	10.9	14.9	11.0	3
Blockage Check @ A1 (L-Type Pitot Only)		09:10:00	14.9	14.9	14.8	11.1	11.2	11.1	14.9	11.0	Total
			Mean		14.9	Mean		11.1	14.9	11.0	Max
			Difference <5% from Initial ?		-0.01	Difference <5% from Initial ?		0.97	14.9	11.0	Min
									14.9	11.0	Average

Post - Traverse Checks Carried Out	Time	Pass/ Fail
Post - Traverse Visual Inspection	09:12:00	Pass

Stagnation Check (S-type Pitot Only)	Time	Reading
Static Pressure Via Positive Leg (mm H ₂ O)	n/a	.
Static Pressure Via Negative Leg (mm H ₂ O)	n/a	.
Difference (Pa) < 1 mm H ₂ O ?		#VALUE!




Average temp (K)	287.900
------------------	---------

Suitability of Sampling Position	Actual Stack Conditions
Highest:lowest flow pressure ratio < 9:1?	1.01:1
Maximum deviation of flow from axis <15°?	3
X-sectional area for stacks = πr^2	0.03 m ²
X-sectional area for ducts = L x B	m ²
Suitability of Position for Sampling	Ok

Stack Moisture	1.01	%	Gas Velocity (as Measured) Adjusted for Smooth Walls	13.33820	m/sec
Measured Oxygen	20.9	%	Gas Velocity (Reference Conditions) Adjusted for Smooth Walls	12.50865	m/sec *
Measured Carbon Dioxide	0.1	%	Volumetric Flowrate (as Measured) Adjusted for Smooth Walls	0.41903	m ³ /sec
Dry Gas Molecular Weight	28.85200	g/g mole	Volumetric Flowrate (Ref Cond) Adjusted for Smooth Walls	0.39297	m ³ /sec *

*Reference Conditions: 273K, 101.3kPa, Wet Gas

NOTE: Velocity / volume flowrate calculations exclude contributions from the measurement point(s) where swirl $> 15^\circ$



Notes

Including expected or actual deviations from procedures / non-conformities

Only one port, but stack $< 0.357\text{m}$ so ok

Compliance With Positional Requirements?

Height of sample ports from Platform

Number of sample ports

Width of platform (port back to handrail)

0.75m

1

 $2m$

Nearest downstream disturbance	Exit	3m
Nearest upstream disturbance	Bend	2.5m

Disturbances are classed as bends, fans or diameter variations

Nearest upstream disturbance	bend
Disturbances are classed as bends, fans or diameter variations	

Biotage GB Ltd
Permit No : **EPR/DP3832EF**
Variation No : **N/A**
Report Ref : **P2251** : **R001**

Installation Name : Ystrad Mynach
Visit Details : Annual Compliance Emissions
Survey Dates : 31st March – 1st April 2015
Report Issue Date : 29th April 2015

Company	Biotage GB LTD	Stack Diameter Port A (mm)	200	Average Stack Diameter (mm)	200	Pitot tube coefficient	1.00
Site	Ystrad Mynach	Stack Diameter Port B (mm)		Port Length (mm)	0	Pitot Id	491
Location	Main Building EP2	Duct Length Port A (mm)		Average Duct Length (mm) L		Stack Thermocouple ID	464
Stack	A2	Duct Length Port B (mm)		Duct width (mm) B		Stack Temp Reader ID	431
Job No	P2251	Duct Length Port C (mm)		Barometric Pressure. (mb)	1005	Manometer ID	506
Operators	CL + IH	Duct Length Port D (mm)		Ave Static Press. (mm H-0)	10.00	Barometer ID	629

Pre - Traverse Checks Carried Out	Time	Pass/ Fail
Pre - Traverse Visual Inspection	06:30:00	Pass
Pre - Traverse Pitot Leak Check	06:32:00	Pass

Smooth Walls

Static Pressure Readings (mm H ₂ O)			
Port A	Port B	Port C	Port D
10.00			

Port/ Point	Distance to Point (mm)	Time	Temperature Readings (°C)			(ΔP) Pitot Readings (mm H ₂ O)			Average Temp. (°C)	Average (ΔP) (mm H ₂ O)	Swirl Test ° From Reference
			1	2	3	1	2	3			
A2	100	06:34:00	13.4	12.9	12.8	14.3	14.0	14.2	13.0	14.2	3
Blockage Check @ A1 (I-Type Pitot Only)		06:40:00	13.1	13.0	13.1	14.2	14.0	14.2	13.0	14.2	Total
			Mean		13.1	Mean		14.1	13.0	14.2	Max
			Difference <5% from Initial ?		0.01	Difference <5% from Initial ?		-0.26	13.0	14.2	Min
									13.0	14.2	Average

Post - Traverse Checks Carried Out	Time	Pass/ Fail
Post - Traverse Visual Inspection	06:42:00	Pass

Stagnation Check (S-type Pitot Only)	Time	Reading
Static Pressure Via Positive Leg (mm H ₂ O)	n/a	.
Static Pressure Via Negative Leg (mm H ₂ O)	n/a	.
Difference (Pa) < 1 mm H ₂ O?		#VALUE!


Average temp (K)	286.033
------------------	---------

Suitability of Sampling Position	Actual Stack Conditions
Highest:lowest flow pressure ratio < 9:1?	1.0:1
Maximum deviation of flow from axis < 15°?	3
X-sectional area for stacks = πr^2	0.03 m ²
X-sectional area for ducts = L x B	m ²
Suitability of Position for Sampling	Ok

Stack Moisture	0.02	%	Gas Velocity (as Measured) Adjusted for Smooth Walls	15.00511	m/sec
Measured Oxygen	20.9	%	Gas Velocity (Reference Conditions) Adjusted for Smooth Walls	14.22214	m/sec*
Measured Carbon Dioxide	0.1	%	Volumetric Flowrate (as Measured) Adjusted for Smooth Walls	0.47140	m ³ /sec
Dry Gas Molecular Weight	28.85200	g/g mole	Volumetric Flowrate (Ref Cond) Adjusted for Smooth Walls	0.44680	m ³ /sec*

*Reference Conditions: 273K, 101.3kPa, Wet Gas

NOTE: Velocity / volume flowrate calculations exclude contributions from the measurement point(s) where swirl $\geq 15^\circ$



Notes
Including expected or actual deviations from procedures / non-conformities

Only one port but stack $< 0.357\text{m}$, ok

Compliance With Positional Requirements?

Height of sample ports from Platform	0.75m
Number of sample ports	1
Width of platform (port back to handrail)	2m

Nearest downstream disturbance	Exit	3m
Nearest upstream disturbance	Bend	2.5m



Disturbances are classed as bends, fans or diameter variations

Biotage GB Ltd
Permit No
Variation No
Report Ref

Installation Name : Ystrad Mynach
Visit Details : Annual Compliance Emissions
Survey Dates : 31st March – 1st April 2015
Report Issue Date : 29th April 2015

Company	Biotage GB LTD	Stack Diameter Port A (mm)	200	Average Stack Diameter (mm)	200	Pitot tube coefficient	1.00
Site	Ystrad Mynach	Stack Diameter Port B (mm)		Port Length (mm)	0	Pitot Id	491
Location	Main Building EP3	Duct Length Port A (mm)		Average Duct Length (mm) L		Stack Thermocouple ID	464
Stack	A3	Duct Length Port B (mm)		Duct width (mm) B		Stack Temp Reader ID	431
Job No	P2251	Duct Length Port C (mm)		Barometric Pressure. (mb)	1001	Manometer ID	506
Operators	CL + JH	Duct Length Port D (mm)		Ave Static Press. (mm H ₂ O)	7.48	Barometer ID	629

Smooth Walls

Diagram/ Description of Cross Section of Stack/Duct

Notes
Including expected or actual deviations from procedures / non-conformities

Average temp (K)	287.533
------------------	---------

Suitability of Sampling Position	Actual Stack Conditions
Highest:lowest flow pressure ratio < 9:1?	1:1
Maximum deviation of flow from axis < 15°?	4
X-sectional area for stacks = πr^2	0.03 m ²
X-sectional area for ducts = L x B	m ²
Suitability of Position for Sampling	Ok

Stack Moisture	0.03	%	Gas Velocity (as Measured) Adjusted for Smooth Walls	12.25257	m/sec
Measured Oxygen	20.9	%	Gas Velocity (Reference Conditions) Adjusted for Smooth Walls	11.50387	m/sec*
Measured Carbon Dioxide	0.1	%	Volumetric Flowrate (as Measured) Adjusted for Smooth Walls	0.38493	m ³ /sec
Dry Gas Molecular Weight	28.85200	g/g mole	Volumetric Flowrate (Ref Cond) Adjusted for Smooth Walls	0.36140	m ³ /sec*

*Reference Conditions: 273K, 101.3kPa, Wet Gas

NOTE: Velocity / volume flowrate calculations exclude contributions from the measurement point(s) where swirl $> 15^\circ$

Compliance With Positional Requirements?

Height of sample ports from Platform	0.75
Number of sample ports	1
Width of platform (port back to handrail)	2

Nearest downstream disturbance	Exit	3m
Nearest upstream disturbance	Bend	2.5m

Disturbances are classed as bends, fans or diameter variations

Biotage GB Ltd
Permit No
Variation No
Report Ref

: N/A

: P225

: P2251 : R001


Visit Details : Annual Compliance Emissions

Survey Dates : 31st March – 1st April 2015

Report Issue Date : 29th April 2015

Company	Biotage GB LTD	Stack Diameter Port A (mm)	350	Average Stack Diameter (mm)	350	Pitot tube coefficient	1.00
Site	Ystrad Mynach	Stack Diameter Port B (mm)		Port Length (mm)	0	Pitot Id	491
Location	Resin Shed	Duct Length Port A (mm)		Average Duct Length (mm) L		Stack Thermocouple ID	464
Stack	A4	Duct Length Port B (mm)		Duct width (mm) B		Stack Temp Reader ID	431
Job No	P2251	Duct Length Port C (mm)		Barometric Pressure. (mb)	1005	Manometer ID	506
Operators	CL + JH	Duct Length Port D (mm)		Ave Static Press. (mm H ₂ O)	3.64	Barometer ID	629

Smooth Walls

Diagram/ Description of Cross Section of Stack/Duct

Notes
Including expected or actual deviations from procedures / non-conformities

Only one port but stack $< 0.357\text{m}$, ok

Average temp (K)	295.200
--------------------	---------

Suitability of Sampling Position	Actual Stack Conditions
Highest:lowest flow pressure ratio < 9:1?	1:1
Maximum deviation of flow from axis < 15°?	3
X-sectional area for stacks = πr^2	0.10 m ²
X-sectional area for ducts = L x B	m ²
Suitability of Position for Sampling	Ok

Compliance With Positional Requirements?

Height of sample ports from Platform	1.2M
Number of sample ports	1
Width of platform (port back to handrail)	2.5M

Nearest downstream disturbance	Exit	2m
Nearest upstream disturbance	Fan	2m

Disturbances are classed as bends, fans or diameter variations

*Reference Conditions: 273K, 101.3kPa, Wet Gas

NOTE: Velocity / volume flowrate calculations exclude contributions from the measurement point(s) where swirl $> 15^\circ$

Environmental Compliance Limited

Biotage GB Ltd

Permit No : EPR/DP3832EF

Variation No : N/A

Report Ref : P2251 : R001

Installation Name

: Ystrad Mynach

Visit Details

: Annual Compliance Emissions

Survey Dates

: 31st March – 1st April 2015

Report Issue Date

: 29th April 2015

FIELD CALIBRATION AND SAMPLING DATA

Environmental Compliance Limited

Biotage GB Ltd
Permit No
Variation No
Report Ref

: EPR/DP3832EF
: N/A
: P2251 : R001

Installation Name : Ystrad Mynach
Visit Details : Annual Compliance Emissions
Survey Dates : 31st March – 1st April 2015
Report Issue Date : 29th April 2015

A1 Methanol Sampling Data

Environmental Compliance Limited				SAMPLE TUBE DATA SAMPLING PROFORMA																																											
Client	Biotage GB LTD	Stack Diameter (mm)	200	Barometer ID	629	Date of Test	31.03.15																																								
Site	Ystrad Mynach	Stack Area (m ²)	0.031	Balance ID	N/A	Sample Start Time	09:30																																								
Location	Main building EP1	Barometric Pressure (mb)	1001	Pump ID	164	Sample End Time	10:30																																								
Stack ID	A1	Heated Line ID	N/A	Meter ID	164	Duration	60																																								
Test No.	Methanol 1	Impinger ID	N/A	DGM Yd or ml/count	0.41	Measured O2																																									
Job No	P2251			was sampler train upstream or sorbent tube condensation free for entire sample (y/n)	Y	O2 Uncertainty %Vol																																									
ECL Site Staff	CL + IH																																														
Meter Units ☐ m3 ☒ litres <table border="1"> <thead> <tr> <th>Sample</th> <th>Leak 1</th> <th>Time (start/ end) (minimum 1 minute)</th> <th>Leak 2</th> <th>Time (start/ end) (minimum 1 minute)</th> <th>Total</th> </tr> </thead> <tbody> <tr> <td>Start Volume</td> <td>830249.0</td> <td>09:20:00</td> <td>844794.0</td> <td>10:33:00</td> <td></td> </tr> <tr> <td>Final Volume</td> <td>844755.0</td> <td>09:21:00</td> <td>844794.0</td> <td>10:34:00</td> <td></td> </tr> <tr> <td>Total Volume</td> <td>14506.0</td> <td>0.0</td> <td>0.0</td> <td></td> <td>14506.0</td> </tr> </tbody> </table>								Sample	Leak 1	Time (start/ end) (minimum 1 minute)	Leak 2	Time (start/ end) (minimum 1 minute)	Total	Start Volume	830249.0	09:20:00	844794.0	10:33:00		Final Volume	844755.0	09:21:00	844794.0	10:34:00		Total Volume	14506.0	0.0	0.0		14506.0																
Sample	Leak 1	Time (start/ end) (minimum 1 minute)	Leak 2	Time (start/ end) (minimum 1 minute)	Total																																										
Start Volume	830249.0	09:20:00	844794.0	10:33:00																																											
Final Volume	844755.0	09:21:00	844794.0	10:34:00																																											
Total Volume	14506.0	0.0	0.0		14506.0																																										
<table border="1"> <thead> <tr> <th>Time Point</th> <th>0-10</th> <th>10-20 mins</th> <th>20-30</th> <th>30-40</th> </tr> </thead> <tbody> <tr> <td>Heated Line Temp °C</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> <tr> <td>Tube Temp °C</td> <td>17.2</td> <td>18.5</td> <td>19.7</td> <td>20.2</td> </tr> <tr> <td>Stack Temp °C</td> <td>14.8</td> <td>12.9</td> <td>13</td> <td>12.6</td> </tr> <tr> <td>Meter Temp In °C</td> <td>8</td> <td>9</td> <td>13</td> <td>13</td> </tr> <tr> <td>Meter Temp Out °C</td> <td>8</td> <td>9</td> <td>13</td> <td>13</td> </tr> </tbody> </table>						Time Point	0-10	10-20 mins	20-30	30-40	Heated Line Temp °C	N/A	N/A	N/A	N/A	Tube Temp °C	17.2	18.5	19.7	20.2	Stack Temp °C	14.8	12.9	13	12.6	Meter Temp In °C	8	9	13	13	Meter Temp Out °C	8	9	13	13	<table border="1"> <thead> <tr> <th>Impinger 1</th> <th></th> </tr> </thead> <tbody> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </tbody> </table>		Impinger 1		Start Weight (g)		End Weight (g)		Total weight (g)	0		
Time Point	0-10	10-20 mins	20-30	30-40																																											
Heated Line Temp °C	N/A	N/A	N/A	N/A																																											
Tube Temp °C	17.2	18.5	19.7	20.2																																											
Stack Temp °C	14.8	12.9	13	12.6																																											
Meter Temp In °C	8	9	13	13																																											
Meter Temp Out °C	8	9	13	13																																											
Impinger 1																																															
Start Weight (g)																																															
End Weight (g)																																															
Total weight (g)	0																																														
<table border="1"> <thead> <tr> <th>Time Point</th> <th>40-50</th> <th>50-60</th> <th></th> <th></th> </tr> </thead> <tbody> <tr> <td>Heated Line Temp °C</td> <td>N/A</td> <td>N/A</td> <td></td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td>20.6</td> <td>21</td> <td></td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td>13</td> <td>12.3</td> <td></td> <td></td> </tr> <tr> <td>Meter Temp In °C</td> <td>14</td> <td>14</td> <td></td> <td></td> </tr> <tr> <td>Meter Temp Out °C</td> <td>14</td> <td>14</td> <td></td> <td></td> </tr> </tbody> </table>						Time Point	40-50	50-60			Heated Line Temp °C	N/A	N/A			Tube Temp °C	20.6	21			Stack Temp °C	13	12.3			Meter Temp In °C	14	14			Meter Temp Out °C	14	14			<table border="1"> <thead> <tr> <th>Impinger 2</th> <th></th> </tr> </thead> <tbody> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </tbody> </table>		Impinger 2		Start Weight (g)		End Weight (g)		Total weight (g)	0		
Time Point	40-50	50-60																																													
Heated Line Temp °C	N/A	N/A																																													
Tube Temp °C	20.6	21																																													
Stack Temp °C	13	12.3																																													
Meter Temp In °C	14	14																																													
Meter Temp Out °C	14	14																																													
Impinger 2																																															
Start Weight (g)																																															
End Weight (g)																																															
Total weight (g)	0																																														
<table border="1"> <thead> <tr> <th>Time Point</th> <th></th> <th></th> <th></th> <th></th> </tr> </thead> <tbody> <tr> <td>Heated Line Temp °C</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Meter Temp In °C</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Meter Temp Out °C</td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>						Time Point					Heated Line Temp °C					Tube Temp °C					Stack Temp °C					Meter Temp In °C					Meter Temp Out °C					<table border="1"> <thead> <tr> <th>Impinger 3</th> <th></th> </tr> </thead> <tbody> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </tbody> </table>		Impinger 3		Start Weight (g)		End Weight (g)		Total weight (g)	0		
Time Point																																															
Heated Line Temp °C																																															
Tube Temp °C																																															
Stack Temp °C																																															
Meter Temp In °C																																															
Meter Temp Out °C																																															
Impinger 3																																															
Start Weight (g)																																															
End Weight (g)																																															
Total weight (g)	0																																														
<table border="1"> <thead> <tr> <th>Time Point</th> <th></th> <th></th> <th></th> <th></th> </tr> </thead> <tbody> <tr> <td>Heated Line Temp °C</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Meter Temp In °C</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Meter Temp Out °C</td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>						Time Point					Heated Line Temp °C					Tube Temp °C					Stack Temp °C					Meter Temp In °C					Meter Temp Out °C					<table border="1"> <thead> <tr> <th>Silica</th> <th>(IF USED)</th> </tr> </thead> <tbody> <tr> <td>< 50% Spent at end?</td> <td>YES</td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </tbody> </table>		Silica	(IF USED)	< 50% Spent at end?	YES	Start Weight (g)		End Weight (g)		Total weight (g)	0
Time Point																																															
Heated Line Temp °C																																															
Tube Temp °C																																															
Stack Temp °C																																															
Meter Temp In °C																																															
Meter Temp Out °C																																															
Silica	(IF USED)																																														
< 50% Spent at end?	YES																																														
Start Weight (g)																																															
End Weight (g)																																															
Total weight (g)	0																																														
<table border="1"> <thead> <tr> <th>Total</th> <th></th> </tr> </thead> <tbody> <tr> <td></td> <td>0</td> </tr> </tbody> </table>						Total			0																																						
Total																																															
	0																																														

Installation Name : Ystrad Mynach
Visit Details : Annual Compliance Emissions
Survey Dates : 31st March – 1st April 2015
Report Issue Date : 29th April 2015

Environmental Compliance Limited		NON ISOKINETIC SAMPLING PROFORMA				Date of Measurement		01/04/2015		If moisture was not measured see detailed notes below.	
ECL/TPD:		36 B		Time taken to change Ports:		0		Start Time		06:51	
								End Time		07:51	
Client	Biotage GB LTD	Stack Profile	Circular	Console id	u011	Barometer id	629		Impinger 1	D1 H2O	Item Name
Site	Ystrad Mynach	Stack Area (m ²)	0.83	Pump id	u011	Nozzle size	n/a		SOL/	2714	Start Weight (g)
Location	Main Building EP2	Barometric Pressure (mb)	1006	Probe id	141	Nozzle size	n/a		Start Weight (g)	710	End Weight (g)
Stack ID	A-2	Static Pres. (mm H ₂ O)	10	DCM Yd	1.0321	Filter Id	n/a		End Weight (g)	607.6	Total weight (g)
Test No.	HG13	Phos coefficient	n/a	APB	42.88	Pilot ID	n/a		Total weight (g)	-192.4	0
Job No	P2251	Probe Heater Setting (°C)	n/a	Impinger Id	657	Hot Box ID	977				Item Name
ECL Site Staff	CL + IH	Hot Box Settings (°C)	160	Balance Id	368				Impinger 2	D1 H2O	Start Weight (g)
									SOL/	2714	End Weight (g)
									Start Weight (g)	697.2	Total weight (g)
									End Weight (g)	696.6	0
									Total weight (g)	-0.6	Item Name
Sample	315230.5	Leak 1	Leak 2	Leak 3	Leak 4	Leak 5	Total		Impinger 3	D1 H2O	Start Weight (g)
Final Volume	315806.7								SOL/	2714	End Weight (g)
Total Volume	576.2	0.0	0.0	0.0	0.0	0.0	576.2		Start Weight (g)	711.4	Total weight (g)
Leak Check	First	Second	Third	Fourth	Fifth				End Weight (g)	710.5	0
Leak rate Lim	0								Total weight (g)	-0.9	Item Name
Vacuum "Hg"	10										Start Weight (g)
Time of Check	06:33										End Weight (g)
Set Rate Limit	10										Total weight (g)
Leak < 2%	YES										0
Traverse Point	A1	A1	A1	A1	A1	A1	A1	Total	Impinger 4	Empty	Item Name
Time/Point (mins)	0 - 10	10 - 20	20 - 30	30 - 40	40 - 50	50 - 60			SOL/	---	Start Weight (g)
AP (mm H2O)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	Start Weight (g)	599.6	End Weight (g)
K factor	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	End Weight (g)	560	Total weight (g)
ΔH (Orifice)	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00		-39.6	0
Meter (Im in)	3.60	4.80	5.80	7.50	8.30	9.70	6.62	6.62	Impinger 5	Silica	Item Name
Meter (Im out)	3.60	4.80	5.80	7.50	8.30	9.70	6.62	6.62	SOL/	---	Start Weight (g)
Stack Temp (Ft)	12.70	12.50	12.20	12.80	12.50	12.60	12.55	12.55	Start Weight (g)	768.8	End Weight (g)
Impinger Outlet	2.00	2.00	3.00	3.00	3.00	4.00	2.83	2.83	End Weight (g)	770.2	Total weight (g)
Vacuum (" Hg)	2.00	2.00	2.00	2.00	2.00	2.00	2.00	2.00	Total weight (g)	1.4	0
Traverse Point							Total		Impinger 6		Item Name
Time/Point(mins)									SOL/	---	Start Weight (g)
AP (mm H2O)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	Start Weight (g)	---	End Weight (g)
K factor	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	End Weight (g)	-39.6	Total weight (g)
ΔH (Orifice)										0	0
Meter (Im in)											Item Name
Meter (Im out)											Start Weight (g)
Stack Temp (Ft)											End Weight (g)
Impinger Outlet											

Environmental Compliance Limited

Biotage GB Ltd
Permit No
Variation No
Report Ref

: EPR/DP3832EF
: N/A
: P2251 : R001

Installation Name : Ystrad Mynach
Visit Details : Annual Compliance Emissions
Survey Dates : 31st March – 1st April 2015
Report Issue Date : 29th April 2015

A2 Methanol Sampling Data

Environmental Compliance Limited						SAMPLE TUBE DATA SAMPLING PROFORMA																															
Client	Biotage GB LTD	☒ Circular ☐ Rectangular ☐ Hose	Barometer ID	629	Date of Test	01.04.15																															
Site	Ystrad Mynach	Stack Diameter (mm)	200	Balance ID	N/a	Sample Start Time	06:53																														
Location	Main Building EP2	Pump ID	164	Pump ID	164	Sample End Time	07:53																														
Stack ID	A2	Stack Area (m ²)	0.031	Meter ID	164	Duration	60																														
Test No.	Methanol 1	Barometric Pressure (mb)	1005	DGM Yd or ml/count	0.41	Measured O2																															
Job No	P2251	Heated Line ID	N/A	(was sample main significant or present tube condensation free for entire sample (y/n))	Y	O2 Uncertainty %Vol																															
ECL Site Staff	CL + IH	Impinger ID	N/A																																		
<table border="1"> <thead> <tr> <th>Meter Units</th> <th>Sample</th> <th>Leak 1</th> <th>Time (start/end) (minimum 1 minute)</th> <th>Leak 2</th> <th>Time (start/end) (minimum 1 minute)</th> <th>Total</th> </tr> </thead> <tbody> <tr> <td>Start Volume</td> <td>861179.0</td> <td>861168.0</td> <td>06:28:00</td> <td>875084.0</td> <td>07:35:00</td> <td></td> </tr> <tr> <td>Final Volume</td> <td>875074.0</td> <td>861168.0</td> <td>06:29:00</td> <td>875084.0</td> <td>07:36:00</td> <td></td> </tr> <tr> <td>Total Volume</td> <td>13895.0</td> <td>0.0</td> <td></td> <td>0.0</td> <td></td> <td>13895.0</td> </tr> </tbody> </table>								Meter Units	Sample	Leak 1	Time (start/end) (minimum 1 minute)	Leak 2	Time (start/end) (minimum 1 minute)	Total	Start Volume	861179.0	861168.0	06:28:00	875084.0	07:35:00		Final Volume	875074.0	861168.0	06:29:00	875084.0	07:36:00		Total Volume	13895.0	0.0		0.0		13895.0		
Meter Units	Sample	Leak 1	Time (start/end) (minimum 1 minute)	Leak 2	Time (start/end) (minimum 1 minute)	Total																															
Start Volume	861179.0	861168.0	06:28:00	875084.0	07:35:00																																
Final Volume	875074.0	861168.0	06:29:00	875084.0	07:36:00																																
Total Volume	13895.0	0.0		0.0		13895.0																															
<table border="1"> <thead> <tr> <th>Time Point</th> <th>0-10</th> <th>10-20 mins</th> <th>20-30</th> <th>30-40</th> </tr> </thead> <tbody> <tr> <td>Heated Line Temp °C</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> <tr> <td>Tube Temp °C</td> <td>12.4</td> <td>13.2</td> <td>13.7</td> <td>14.1</td> </tr> <tr> <td>Stack Temp °C</td> <td>12.7</td> <td>12.4</td> <td>12.6</td> <td>12.2</td> </tr> <tr> <td>Meter Temp In °C</td> <td>3</td> <td>3</td> <td>5</td> <td>7</td> </tr> <tr> <td>Meter Temp Out °C</td> <td>3</td> <td>3</td> <td>5</td> <td>7</td> </tr> </tbody> </table>								Time Point	0-10	10-20 mins	20-30	30-40	Heated Line Temp °C	N/A	N/A	N/A	N/A	Tube Temp °C	12.4	13.2	13.7	14.1	Stack Temp °C	12.7	12.4	12.6	12.2	Meter Temp In °C	3	3	5	7	Meter Temp Out °C	3	3	5	7
Time Point	0-10	10-20 mins	20-30	30-40																																	
Heated Line Temp °C	N/A	N/A	N/A	N/A																																	
Tube Temp °C	12.4	13.2	13.7	14.1																																	
Stack Temp °C	12.7	12.4	12.6	12.2																																	
Meter Temp In °C	3	3	5	7																																	
Meter Temp Out °C	3	3	5	7																																	
<table border="1"> <thead> <tr> <th>Time Point</th> <th>40-50</th> <th>50-60</th> <th></th> <th></th> </tr> </thead> <tbody> <tr> <td>Heated Line Temp °C</td> <td>N/A</td> <td>N/A</td> <td></td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td>14.9</td> <td>15.3</td> <td></td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td>12.5</td> <td>12.9</td> <td></td> <td></td> </tr> <tr> <td>Meter Temp In °C</td> <td>9</td> <td>10</td> <td></td> <td></td> </tr> <tr> <td>Meter Temp Out °C</td> <td>9</td> <td>10</td> <td></td> <td></td> </tr> </tbody> </table>								Time Point	40-50	50-60			Heated Line Temp °C	N/A	N/A			Tube Temp °C	14.9	15.3			Stack Temp °C	12.5	12.9			Meter Temp In °C	9	10			Meter Temp Out °C	9	10		
Time Point	40-50	50-60																																			
Heated Line Temp °C	N/A	N/A																																			
Tube Temp °C	14.9	15.3																																			
Stack Temp °C	12.5	12.9																																			
Meter Temp In °C	9	10																																			
Meter Temp Out °C	9	10																																			
<table border="1"> <thead> <tr> <th>Time Point</th> <th></th> <th></th> <th></th> <th></th> </tr> </thead> <tbody> <tr> <td>Heated Line Temp °C</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Meter Temp In °C</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Meter Temp Out °C</td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>								Time Point					Heated Line Temp °C					Tube Temp °C					Stack Temp °C					Meter Temp In °C					Meter Temp Out °C				
Time Point																																					
Heated Line Temp °C																																					
Tube Temp °C																																					
Stack Temp °C																																					
Meter Temp In °C																																					
Meter Temp Out °C																																					
<table border="1"> <thead> <tr> <th>Impinger 1</th> <th></th> </tr> </thead> <tbody> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </tbody> </table>								Impinger 1		Start Weight (g)		End Weight (g)		Total weight (g)	0																						
Impinger 1																																					
Start Weight (g)																																					
End Weight (g)																																					
Total weight (g)	0																																				
<table border="1"> <thead> <tr> <th>Impinger 2</th> <th></th> </tr> </thead> <tbody> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </tbody> </table>								Impinger 2		Start Weight (g)		End Weight (g)		Total weight (g)	0																						
Impinger 2																																					
Start Weight (g)																																					
End Weight (g)																																					
Total weight (g)	0																																				
<table border="1"> <thead> <tr> <th>Impinger3</th> <th></th> </tr> </thead> <tbody> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </tbody> </table>								Impinger3		Start Weight (g)		End Weight (g)		Total weight (g)	0																						
Impinger3																																					
Start Weight (g)																																					
End Weight (g)																																					
Total weight (g)	0																																				
<table border="1"> <thead> <tr> <th>Silica</th> <th>(IF USED)</th> </tr> </thead> <tbody> <tr> <td><50% Spent at endf</td> <td>YES</td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </tbody> </table>								Silica	(IF USED)	<50% Spent at endf	YES	Start Weight (g)		End Weight (g)		Total weight (g)	0																				
Silica	(IF USED)																																				
<50% Spent at endf	YES																																				
Start Weight (g)																																					
End Weight (g)																																					
Total weight (g)	0																																				
<table border="1"> <thead> <tr> <th>Total</th> <th></th> </tr> </thead> <tbody> <tr> <td></td> <td>0</td> </tr> </tbody> </table>								Total			0																										
Total																																					
	0																																				

Biotage GB Ltd
Permit No
Variation No
Report Ref

: EPR/DP3832EF
: N/A
: P2251 : R001

Installation Name
Visit Details
Survey Dates
Report Issue Date

: Ystrad Mynach
: Annual Compliance Emissions
: 31st March – 1st April 2015
: 29th April 2015

A3 NO_x Field Calibration

Units

Mean Initial Direct Zero
Mean Confirmation Direct Zero
Difference in Direct Zero
Repeatability at Zero
<2 x Repeatability at Zero?

Mean Pre Test Zero
% of Measurement Range?
Detection Limit (LOD)

Actual Applied Span Concentration

Mean Pre Test System Zero
Difference $\leq \pm 2\%$ of Span Value (5% for SO₂)?

Mean Post Test Zero
% of Certified Range?

Mean Pre Test System Span
Difference $\leq \pm 2\%$ of Span Value (5% for SO₂)?

Mean Post Test System Span
Span Drift $\leq \pm 5\%$ Span Value?

Horiba PG 250 Measurement Ranges:		
NO as NO ₂	O ₂	CO ₂
205 mg/m ³	25 %Vol	20 %Vol
Zero Values (Direct)		
-0.03	-0.01	0.00
0.96	-0.04	0.00
0.99	0.03	0.00
2.05	0.20	0.20
YES	YES	YES
Pre Zero Values (System)		
0.04	0.19	0.00
0.02%	0.77%	0.00%
0.08	0.20	0.00

Applied Span:		
NO	O ₂	CO ₂
102.40	15.03	5.06
Pre Test System Zero Values		
0.04	0.19	0.00
0.04%	1.28%	0.00%
Post Zero Values (System)		
0.21	0.06	0.00
0.10%	0.23%	0.00%
Pre Test System Span Values		
100.43	15.25	4.97
1.92%	1.47%	1.73%
Post Test System Span Values		
99.87	15.14	5.05
0.56%	0.72%	1.64%
0.56%	0.89%	1.64%
See Note 3	See Note 3	See Note 3

NOTE 1: Data Invalid! Contact Quality Manager!

NOTE 2: Correct test data for drift!

NOTE 3: No drift correction required.

Environmental Compliance Limited

Biotage GB Ltd
Permit No
Variation No
Report Ref

: EPR/DP3832EF
: N/A
: P2251 : R001

Installation Name : Ystrad Mynach
Visit Details : Annual Compliance Emissions
Survey Dates : 31st March – 1st April 2015
Report Issue Date : 29th April 2015

A4 HBr Sampling Data

Environmental Compliance Limited		NON ISOKINETIC SAMPLING PROFORMA				Date of Measurement		01/04/2015	
ECL/TPD		35 B		Time taken to change Ports		0		Start Time	
09:04		End Time		10:04		Test Duration		60 mins	
Client	Biotage GB LTD	Stack Profile	Circular	Console id	u011	Barometer id	629	Impinger 1	H2SO4
Site	Ystrad Mynach	Stack Area (m ²)	0.03	Pump id	u011	Nozzle id	n/a	SOL	2713
Location	Resin Shed	Barometric Pressure (mb)	1006	Probe id	141	Nozzle size	n/a	Start Weight (g)	727.1
Stack ID	A4	Static Pres. (mm Hg)	10	DGM Yd.	1.8321	Filter id	n/a	End Weight (g)	726.7
Test No.	Hydrogen Bromide 1	Pilot coefficient	n/a	APB	42.88	Pilot ID	n/a	Total weight (g)	0
Job No	P2251	Probe Heater Setting (°C)	160	Impinger id	657	Hot Box ID	977	Impinger 2	H2SO4
ECL Site Staff	CL + IH	Hot Box Setting (°C)	160	Balance id	368			SOL	2713
								Start Weight (g)	716.9
								End Weight (g)	718.4
								Total weight (g)	1.5
								Impinger3	NaOH
								SOL	2719
								Start Weight (g)	709.4
								End Weight (g)	710.6
								Total weight (g)	1.2
								Impinger 4	NaOH
								SOL	2719
								Start Weight (g)	773.9
								End Weight (g)	775.1
								Total weight (g)	1.2
								Impinger 5	Silica
								SOL	2770.1
								Start Weight (g)	2770.1
								End Weight (g)	2773.9
								Total weight (g)	3.8
								Impinger 6	
								SOL	
								Start Weight (g)	
								End Weight (g)	
								Total weight (g)	0
								Impinger 7	
								SOL	
								Start Weight (g)	
								End Weight (g)	
								Total weight (g)	0
								Impinger 8	
								SOL	
								Start Weight (g)	
								End Weight (g)	
								Total weight (g)	0
								Total (g)	9.90
								Silica < 30% used at End of Test Y/N	YES
								Rinse Solutions used	
								Solution	SOL NO
								DI Water	2714
								Acetone	...

Environmental Compliance Limited

Biotage GB Ltd

Permit No : EPR/DP3832EF

Variation No : N/A

Report Ref : P2251 : R001

Installation Name

Visit Details

Survey Dates

Report Issue Date

: Ystrad Mynach

: Annual Compliance Emissions

: 31st March – 1st April 2015

: 29th April 2015

LABORATORY ANALYSIS RESULTS

Environmental Compliance Limited

Biotage GB Ltd
Permit No
Variation No
Report Ref

: EPR/DP3832EF
: N/A
: P2251 : R001

Installation Name : Ystrad Mynach
Visit Details : Annual Compliance Emissions
Survey Dates : 31st March – 1st April 2015
Report Issue Date : 29th April 2015



Scientific Analysis Laboratories is a
limited company registered in England and
Wales (No 2514788) whose address is at
Hadfield House, Hadfield Street, Manchester M16 9FE

Scientific Analysis Laboratories Ltd Certificate of Analysis

Hadfield House
Hadfield Street
Cornbrook
Manchester
M16 9FE
Tel : 0161 874 2400
Fax : 0161 874 2404

Report Number: 468613-1

Date of Report: 20-Apr-2015

Customer: Environmental Compliance Ltd
Unit G1
Main Avenue
Treforest Industrial Estate
Pontypridd
CF37 5BF

Customer Contact: Mr Craig Lewis

Customer Job Reference: P2251
Customer Purchase Order: E3898
Date Job Received at SAL: 08-Apr-2015
Date Analysis Started: 16-Apr-2015
Date Analysis Completed: 20-Apr-2015

The results reported relate to samples received in the laboratory
Opinions and interpretations expressed herein are outside the scope of UKAS accreditation
This report should not be reproduced except in full without the written approval of the laboratory
Tests covered by this certificate were conducted in accordance with SAL SOPs
All results have been reviewed in accordance with QP22



Report checked
and authorised by :
Michael Goodman
Project Management

Issued by :
Kayleigh McCann
Project Manager

Signature valid

Digitally signed by Kayleigh
McCann
Date: 2015.04.29 17:03:01 BST
Reason: Issue
Location: SAL

Page 1 of 3
468613-1

Environmental Compliance Limited

Biotage GB Ltd
Permit No
Variation No
Report Ref

: EPR/DP3832EF
: N/A
: P2251 : R001

Installation Name : Ystrad Mynach
Visit Details : Annual Compliance Emissions
Survey Dates : 31st March – 1st April 2015
Report Issue Date : 29th April 2015

SAL Reference: 468613							
Customer Reference: P2251							
Impinger (sodium hydroxide)		Analysed as Impinger (sodium hydroxide)					
Miscellaneous							
SAL Reference		468613 019		468613 020		468613 022	
Customer Sample Reference		ECL/15/1560		ECL/15/1561		ECL/15/1563	
Test Sample		AR		AR		AR	
Date Sampled		01-APR-2015		01-APR-2015		01-APR-2015	
Determinand	Method	LOD	Units	Symbol			
Hydrogen Bromide	IC	0.05	mg/l	U	(13) 2.8	(13) 0.30	(13) <0.05
Volume	Vol	1	ml	N	160	140	230

SAL Reference: 468613							
Customer Reference: P2251							
Impinger (0.1N Sulphuric Acid)		Analysed as Impinger (0.1N Sulphuric Acid)					
Miscellaneous							
SAL Reference		468613 017		468613 018		468613 021	
Customer Sample Reference		ECL/15/1558		ECL/15/1559		ECL/15/1562	
Test Sample		AR		AR		AR	
Date Sampled		01-APR-2015		01-APR-2015		01-APR-2015	
Determinand	Method	LOD	Units	Symbol			
Hydrogen Bromide	IC	0.5	mg/l	N	(13) 180	(13) 5.2	(9) <5.0
Volume	Vol	1	ml	N	190	180	250

SAL Reference: 468613									
Customer Reference: P2251									
Impinger(DI water)		Analysed as Impinger(DI water)							
Miscellaneous									
SAL Reference		468613 001	468613 002	468613 003	468613 011	468613 012			
Customer Sample Reference		ECL/15/1546	ECL/15/1547	ECL/15/1548	ECL/15/1553	ECL/15/1554			
Test Sample		AR	AR	AR	AR	AR			
Date Sampled		31-MAR-2015	31-MAR-2015	31-MAR-2015	01-APR-2015	01-APR-2015			
Determinand	Method	LOD	Units	Symbol					
Hydrogen Chloride	IC	0.05	mg/l	U	(195,13) 200	(13) 0.32	(13) <0.05	(13,195) 74	(13) 0.29
Volume	Vol	1	ml	U	300	120	260	260	130

SAL Reference: 468613					
Customer Reference: P2251					
Impinger(DI water)		Analysed as Impinger(DI water)			
Miscellaneous					
SAL Reference				468613 013	
Customer Sample Reference				EOL/15/1555	
Test Sample				AR	
Date Sampled				01-APR-2015	
Determinand	Method	LOD	Units	Symbol	
Hydrogen Chloride	IC	0.05	mg/l	U	(13) <0.05
Volume	Vol	1	ml	U	240

Environmental Compliance Limited

Biotage GB Ltd
Permit No
Variation No
Report Ref

: EPR/DP3832EF
: N/A
: P2251 : R001

Installation Name : Ystrad Mynach
Visit Details : Annual Compliance Emissions
Survey Dates : 31st March – 1st April 2015
Report Issue Date : 29th April 2015

SAL Reference: 468613												
Customer Reference: P2251												
Tube (Charcoal 226-09) Analysed as Tube (Charcoal 226-09)												
Miscellaneous												
SAL Reference			468613 004		468613 005		468613 006		468613 007		468613 008	
Customer Sample Reference			ECL/15/1540 FRONT		ECL/15/1540 MIDDLE		ECL/15/1540 BACK		ECL/15/1550		ECL/15/1551 FROM	
Test Sample			AR		AR		AR		AR		AR	
Date Sampled			31-MAR-2015		31-MAR-2015		31-MAR-2015		31-MAR-2015		31-MAR-2015	
Determinand		Method	LOD	Units	Symbol							
Methanol		GC/MS	10	µg	N	<10	<10	<10	<10	<10	(37) 61	

SAL Reference: 468613											
Customer Reference: P2251											
Tube (Charcoal 226-09) Analysed as Tube (Charcoal 226-09)											
Miscellaneous											
SAL Reference		468613 009		468613 010		468613 014		468613 015		468613 016	
Customer Sample Reference		ECL/15/1551 BACK		ECL/15/1552		ECL/15/1556 FRONT		ECL/15/1556 BACK		ECL/15/1557	
Test Sample		AR		AR		AR		AR		AR	
Date Sampled		31-MAR-2015		31-MAR-2015		01-APR-2015		01-APR-2015		01-APR-2015	
Determinand	Method	LOD	Units	Symbol							
Methanol	GC/MS	10	ug	N	<10	<10	<10	<10	<10	<10	<10

Index to symbols used in 468613-1

Value	Description
AR	As Received
195	Due to levels found in the sample that are outside of the normal calibration range of the instrument, analysis was conducted on a diluted sample
37	There was >10% found on the back section of the tube
13	Results have been blank corrected.
9	LOD raised due to dilution of sample
U	Analysis is UKAS accredited
N	Analysis is not UKAS accredited

Environmental Compliance Limited

Biotage GB Ltd

Permit No : EPR/DP3832EF

Variation No : N/A

Report Ref : P2251 : R001

Installation Name

Visit Details

Survey Dates

Report Issue Date

: Ystrad Mynach

: Annual Compliance Emissions

: 31st March – 1st April 2015

: 29th April 2015

UNCERTAINTY CALCULATIONS

Biotage GB Ltd
 Permit No : EPR/DP3832EF
 Variation No : N/A
 Report Ref : P2251 : R001

Installation Name : Ystrad Mynach
 Visit Details : Annual Compliance Emissions
 Survey Dates : 31st March – 1st April 2015
 Report Issue Date : 29th April 2015

A1 Volumetric Flowrate Uncertainty

Stack Reference A1

Measurement Uncertainty Calculations - Velocity at Stack Conditions

Contribution From	Standard u/c (mm H ₂ O)	
Pitot Calibration Uncertainty Contribution	0.055	A
Manometer Calibration Uncertainty Contribution	0.055	B
Variation in Actual Pitot reading at sample points	0.12	C
Combined u/c (mm H ₂ O) =	Combined u/c (mm H ₂ O)	
$\text{SQRT } (A/\sqrt{3})^2 + (B/\sqrt{3})^2 + (C/\sqrt{3})^2$	0.08	
Expanded Uncertainty of Flow Measurements (mm H₂O)	0.16	
	Standard u/c (K)	
Temperature Calibration (K)	1.44	D
Variation in Actual Temp reading at sample points	0.10	E
Combined u/c of Temp (K)	Combined u/c (K)	
$\text{SQRT } ((D/\sqrt{3})^2 + (E/\sqrt{3})^2)$	0.83	
Expanded Uncertainty of Temp Measurements (K)	1.67	
Measured Average Velocity (m/s) at Stack Conds	13.41	
Maximum Average Velocity (m/s) at Stack Conds	13.54	
Standard Uncertainty Velocity at Stack Conditions (%)	1.02	
Expanded Uncertainty Velocity (at Stack Conditions)	2.03 (%)	

Measurement Uncertainty Calculations - Flowrate at Stack Conditions

Contribution From	Standard u/c (m ²)
Area (m ²)	0.00031
Measured Average Flowrate (m ³ /s) at Stack Conds	0.42
Maximum Average Flowrate (m ³ /s) at Stack Conds	0.43
Standard Uncertainty Flowrate (m ³ /s) at Stack Conditions (%)	2.03
Expanded Uncertainty Flowrate (m³/s) at Stack Conditions	4.05 (%)

Measurement Uncertainty Calculations - Flowrate at STP & Wet Gas

Contribution From	Standard u/c (%)
Temperature Calibration (K)	0.5
Barometer Calibration	0.5
Measured Average Flowrate (m ³ /s) at STP Wet	0.39
Maximum Average Flowrate (m ³ /s) at STP Wet	0.40
Standard Uncertainty Flowrate (m ³ /s) at STP Wet	2.51
Expanded Uncertainty Flowrate (m³/s) at STP Wet	5.02 (%)

Environmental Compliance Limited

Biotage GB Ltd

Permit No : EPR/DP3832EF

Variation No : N/A

Report Ref : P2251 : R001

Installation Name : Ystrad Mynach

Visit Details : Annual Compliance Emissions

Survey Dates : 31st March – 1st April 2015

Report Issue Date : 29th April 2015

A1 HCl Uncertainty

Site: Ystrad Mynach
Location: A1

$$u_{\text{mass}} = \sqrt{\sum (u_{\text{filter}})^2 + (u_{\text{solution}})^2}$$

Determinand	Filter mg	Solution mg	Recovered Mass mg	LAB Method Uncert (%) K=2 Filter mg	Solution mg	Standard Uncertainty Filter mg	Solution mg	Combined Uncertainty mg
HCl-1								
Hydrogen Chloride	...	60.04	60.04	...	7.80	...	3.90	3.90
...	...	...	...	...	...	...	...	...
...	...	...	...	...	...	...	...	...
...	...	...	...	...	...	...	...	...

HCl-1			Standard Uncertainty @ 95%		
Sampled Volume (V _m)	0.58	m ³	uV _m	0.001	m ³
Meter Correction Factor (Y _d)	1.03	...	...	...	...
Meter Temperature (T _m)	286.55	k	uT _m	1.5	k
Average Differential Pressure (ΔH)	10.00	mmH ₂ O	uΔH	0.25	mmH ₂ O
Barometric Pressure (P _b)	750.81	mmHg	uP _b	3.8	mmHg
ΔH + P _s (P _m)	100.20	kPa	...	...	...
Oxygen content (O _{2,m})	21.00	% by volume	uO _{2,m} = σ/√n	0.00	% by volume
Moisture Content (H ₂ O)	1.01	% by volume	uH ₂ O	0.27	% by volume

Note: In the following calculations, the sensitivity coefficient (C) is estimated using: $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by $C_i u_i$ where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. i = uV_m, uT_m etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

HCl-1:

$$f_{s,\text{wet}} = \frac{100}{(100 - H_2O)} = 1.01$$

Uncertainty in correction factor to STP due to measured ΔH uncertainty component (uΔH), measured stack pressure uncertainty component (uP_b) & measured temperature of dry gas uncertainty component (uT_{m D₉₅})

HCl-1:

$$f_s = \frac{273}{760} \times \frac{P_b + \frac{\Delta H}{13.6}}{T_m} \times Y_d = 0.982$$

	Maximum	Minimum	Sensitivity	u _{fstp}
uΔH	0.98	0.98	0.0000961	0.0000240
uP _b	0.99	0.98	0.00131	0.00490
uT _m	0.99	0.98	0.00343	0.00514
H ₂ O	0.98	0.98	0.00992	0.00269

$$\frac{u f_s}{f_s} = \sqrt{\left(\frac{\sqrt{(u\Delta H)^2 + (uP_b)^2}}{(P_m/101.3)} \right)^2 + \left(\frac{uT_m}{(T_m/273.15)} \right)^2 + \left(\frac{uH_2O}{(100/(100-H_2O))} \right)^2} = 0.00733$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV_{std}) & volume uncertainty component (uV_m)

HCl-1:

$$V_{std} = V_{measured} \times f_s = 0.566$$

	Maximum m ³	Minimum m ³	Sensitivity	Standard Uncertainty (m ³)
Effect of uV _{std}	0.57	0.56	0.58	0.00422
Effect of uV _m	0.57	0.57	0.98	0.000982

Combined Standard Uncertainty

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uV_{std}}{f_s} \right)^2 + \left(\frac{uV_m}{V_m} \right)^2} = 0.00262$$

Uncertainty of Oxygen Correction Factor (%):-

HCl-1:

$$f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 1.00$$

$$uCorr^{O_2} = \frac{20.9\% - O_{2,ref}}{(20.9\% - O_{2,measured}) \times (20.9\% - O_{2,measured})} \times \text{Uncertainty of } O_2 \text{ Measurement} = 1.00$$

$$u f_{O_2} = \frac{uCorr^{O_2}}{f_{O_2}} \times 100 = 0.00\%$$

Environmental Compliance Limited

Biotage GB Ltd

Permit No : EPR/DP3832EF

Variation No : N/A

Report Ref : P2251 : R001

Installation Name : Ystrad Mynach

Visit Details : Annual Compliance Emissions

Survey Dates : 31st March – 1st April 2015

Report Issue Date : 29th April 2015

Uncertainty in final measurement @ reference conditions due to mass uncertainty component (uM)

Determinand	HCl-1:			
	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	uM mg/Nm ³
...	...	...	...	...
Hydrogen Chloride	112.97	99.18	1.77	6.89
...	...	...	...	...
...	...	...	...	...

Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

Determinand	HCl-1:
	uL mg/Nm ³
...	...
Hydrogen Chloride	1.22
...	...
...	...

Uncertainty in final measurement @ Reference Conditions due to uVstp

Determinand	HCl-1:			
	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	uVstp mg/Nm ³
...	...	...	...	...
Hydrogen Chloride	106.57	105.59	187.42	0.49
...	...	...	...	...
...	...	...	...	...

Combined Uncertainty excluding oxygen contribution

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (u_{Vstp})^2}$$

Determinand	HCl-1:			
	Combined Uncertainty mg/Nm ³	Expanded Uncertainty mg/Nm ³	Measured Concentration mg/Nm ³	Percent of Measured Concentration
...	...	...	...	...
Hydrogen Chloride	7.02	14.04	106.08	13.24
...	...	...	...	...
...	...	...	...	...

Combined Uncertainty including oxygen contribution

$$u_{combined} = \sqrt{\sum (u_{f_{O_2}})^2 + (Uncertainty\ of\ Measurement\ of\ Determinand)^2}$$

Determinand	Measurement Uncertainty of Determinand	Measurement Uncertainty of Oxygen Corr Factor	Overall Measurement Uncertainty inc O ₂ Corr ⁿ factor (U _{combined})
...	...	...	...
Hydrogen Chloride	13.24	0.00	13.24
...	...	...	...
...	...	...	...

Environmental Compliance Limited

Biotage GB Ltd

Permit No : EPR/DP3832EF

Variation No : N/A

Report Ref : P2251 : R001

Installation Name

Visit Details

Survey Dates

Report Issue Date

: Ystrad Mynach

: Annual Compliance Emissions

: 31st March – 1st April 2015

: 29th April 2015

A1 Methanol Uncertainty

Site: Biotage GB LTD, Ystrad Mynach

Location: Main building EP1, Stack ID:A1

				Standard Uncertainty @ 95%		
Sampled Volume	V _m	0.01451	m ³	uV _m	0.000	m ³
Meter Correction Factor or ml/count	Y _d	0.41	...	...	...	...
Meter Temperature	T _m	284.83	K	uT _m	1.5	K
Barometric Pressure	P _b	1001.00	mBar		10.0	mBar
Oxygen content	O _{2,m}	0.00	% Vol	uO _{2,m}	0.00	% Vol
Moisture	H ₂ O	0.00	% Vol	uH ₂ O		% Vol

Tubes					
Determinand	Recovered Mass		Standard Uncertainty		
Methanol	10.00	µg	uM	0.50	µg

Note: In the following calculations, the sensitivity coefficient (C) is estimated using: $C_i = \frac{\partial I}{\partial x_i}$

For each factor, uncertainty is then calculated by $C_i u_i$ where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. $i = uV_m, uT_m$ etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from meter:

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (uP_b), measured temperature of dry gas uncertainty component (uT_m) & measured moisture (uH₂O) where required

$f_s = \frac{273}{T_m} \times \frac{P}{101.3} = 0.95$				
	Maximum	Minimum	Sensitivity	uf _{stp}
uP _b	0.49	0.48	0.000483	0.00483
uT _m	0.95	0.94	0.00333	0.00499
uH ₂ O	...	...	...	...
$\frac{uf_s}{f_s} = \sqrt{\left(\frac{uP_b}{(P_b/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{(100/(100 - H_2O))}\right)^2} = 0.00648$				

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV_{std}) & volume uncertainty component (uV_m)

$V_{std} = V_{measured} \times f_s = 0.00563$				
	Maximum	Minimum	Sensitivity	Standard Uncertainty
	m ³	m ³		m ³
Effect of uf _s	0.00567	0.00559	0.00595	0.0000385
Effect of uV _m	0.00564	0.00563	0.39	3.883E-06
$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uf_s}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.0000335$				

Uncertainty of correction factor to reference conditions (excluding oxygen contribution) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

$uL = \frac{Conc \times \frac{2}{100}}{\sqrt{3}}$		
	Tubes	Condensate
	uL	uL
	mg/Nm ³	mg/Nm ³
Methanol	0.0205	...

Environmental Compliance Limited

Biotage GB Ltd

Permit No : EPR/DP3832EF

Variation No : N/A

Report Ref : P2251 : R001

Installation Name : Ystrad Mynach

Visit Details : Annual Compliance Emissions

Survey Dates : 31st March – 1st April 2015

Report Issue Date : 29th April 2015

$$Conc = \frac{M_{Recovered}}{V_m \times f_s \times f_{O_2}}$$

Uncertainty in final measurement @ Reference Conditions due to $uM_{Recovered}$

Charcoal Tube Results				
	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	Standard Uncertainty mg/Nm ³
Methanol	1.86	1.69	177.53	0.0888
Condensate Results				
	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	Standard Uncertainty mg/Nm ³
Methanol				

Uncertainty in final measurement @ Reference Conditions due to uV_{STD}

Charcoal Tube Results				
	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	Standard Uncertainty mg/Nm ³
Methanol	1.79	1.76	315.18	0.0106

Combined Uncertainty (excluding Oxygen contribution)

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (uV_{sp})^2}$$

Charcoal Tubes: Determinand	Combined Uncertainty mg/Nm ³	Expanded Uncertainty mg/Nm ³	Measured Concentration mg/Nm ³	Percent of Measured Concentration
Methanol	0.0917	0.18	1.78	10.33

Biotage GB Ltd
 Permit No : EPR/DP3832EF
 Variation No : N/A
 Report Ref : P2251 : R001

Installation Name : Ystrad Mynach
 Visit Details : Annual Compliance Emissions
 Survey Dates : 31st March – 1st April 2015
 Report Issue Date : 29th April 2015

A2 Volumetric Flowrate Uncertainty

Stack Reference A2

Measurement Uncertainty Calculations - Velocity at Stack Conditions

Contribution From	Standard u/c (mm H ₂ O)	
Pitot Calibration Uncertainty Contribution	0.071	A
Manometer Calibration Uncertainty Contribution	0.071	B
Variation in Actual Pitot reading at sample points	0.14	C
Combined u/c (mm H ₂ O) = SQRT (A/√3) ² + (B/√3) ² + (C/√3) ²	0.10	
Expanded Uncertainty of Flow Measurements (mm H₂O)	0.20	
	Standard u/c (K)	
Temperature Calibration (K)	1.43	D
Variation in Actual Temp reading at sample points	0.30	E
Combined u/c of Temp (K) SQRT ((D/√3) ² + (E/√3) ²)	0.84	
Expanded Uncertainty of Temp Measurements (K)	1.69	
Measured Average Velocity (m/s) at Stack Conds	15.08	
Maximum Average Velocity (m/s) at Stack Conds	15.23	
Standard Uncertainty Velocity at Stack Conditions (%)	1.00	
Expanded Uncertainty Velocity (at Stack Conditions)	1.99 (%)	

Measurement Uncertainty Calculations - Flowrate at Stack Conditions

Contribution From	Standard u/c (m ³)
Area (m ²)	0.00031
Measured Average Flowrate (m ³ /s) at Stack Conds	0.47
Maximum Average Flowrate (m ³ /s) at Stack Conds	0.48
Standard Uncertainty Flowrate (m ³ /s) at Stack Conditions (%)	2.01
Expanded Uncertainty Flowrate (m³/s) at Stack Conditions	4.01 (%)

Measurement Uncertainty Calculations - Flowrate at STP & Wet Gas

Contribution From	Standard u/c (%)
Temperature Calibration (K)	0.5
Barometer Calibration	0.5
Measured Average Flowrate (m ³ /s) at STP Wet	0.45
Maximum Average Flowrate (m ³ /s) at STP Wet	0.46
Standard Uncertainty Flowrate (m ³ /s) at STP Wet	2.49
Expanded Uncertainty Flowrate (m³/s) at STP Wet	4.99 (%)

Environmental Compliance Limited

Biotage GB Ltd

Permit No : EPR/DP3832EF

Variation No : N/A

Report Ref : P2251 : R001

Installation Name : Ystrad Mynach

Visit Details : Annual Compliance Emissions

Survey Dates : 31st March – 1st April 2015

Report Issue Date : 29th April 2015

A2 HCl Uncertainty

Site: Ystrad Mynach
Location: A2

$$u_{\text{mass}} = \sqrt{\sum (u_{\text{filter}})^2 + (u_{\text{solution}})^2}$$

Determinand	Filter mg	Solution mg	Recovered Mass mg	LAB Method Uncert (%) K=2 Filter mg	Solution mg	Standard Uncertainty Filter mg	Solution mg	Combined Uncertainty mg
HCl-1								
Hydrogen Chloride	...	19.28	19.28	...	2.51	...	1.25	1.25
...	...	...	...	...	...	...	...	...
...	...	...	...	...	...	...	...	...

HCl-1			Standard Uncertainty @ 95%		
Sampled Volume (V _m)	0.58	m ³	uV _m	0.001	m ³
Meter Correction Factor (Y _d)	1.03	...	...	...	...
Meter Temperature (T _m)	279.62	k	uT _m	1.5	k
Average Differential Pressure (ΔH)	10.00	mmH ₂ O	uΔH	0.25	mmH ₂ O
Barometric Pressure (P _b)	754.56	mmHg	uP _b	3.8	mmHg
ΔH + P _s (P _m)	100.70	kPa	...	...	...
Oxygen content (O _{2,m})	21.00	% by volume	uO _{2,m} = σ/√n	0.00	% by volume
Moisture Content (H ₂ O)	0.0216	% by volume	uH ₂ O	0.26	% by volume

Note: In the following calculations, the sensitivity coefficient (C) is estimated using: $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by $C_i u_i$ where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. i = uV_m, uT_m etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

HCl-1:

$$f_{s,\text{wet}} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured ΔH uncertainty component (uΔH), measured stack pressure uncertainty component (uP_b) & measured temperature of dry gas uncertainty component (uT_{m D₉₅})

HCl-1:

$$f_s = \frac{273}{760} \times \frac{P_b + \frac{\Delta H}{13.6}}{T_m} \times Y_d = 1.002$$

	Maximum	Minimum	Sensitivity	u _{fstp}
uΔH	1.00	1.00	0.0000975	0.0000244
uP _b	1.01	1.00	0.00133	0.00497
uT _m	1.01	1.00	0.00358	0.00537
H ₂ O	1.00	1.00	0.0100	0.00265

$$\frac{u f_s}{f_s} = \sqrt{\left(\frac{\sqrt{(u\Delta H)^2 + (uP_b)^2}}{(P_m/101.3)} \right)^2 + \left(\frac{uT_m}{(T_m/273.15)} \right)^2 + \left(\frac{uH_2O}{(100/(100-H_2O))} \right)^2} = 0.00773$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV_{std}) & volume uncertainty component (uV_m)

HCl-1:

$$V_{std} = V_{measured} \times f_s = 0.577$$

	Maximum m ³	Minimum m ³	Sensitivity	Standard Uncertainty (m ³)
Effect of uV _{std}	0.58	0.57	0.58	0.00446
Effect of uV _m	0.58	0.58	1.00	0.00100

Combined Standard Uncertainty

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uV_{std}}{f_s} \right)^2 + \left(\frac{uV_m}{V_m} \right)^2} = 0.00276$$

Uncertainty of Oxygen Correction Factor (%):-

HCl-1:

$$f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 1.00$$

$$uCorr_{O_2} = \frac{20.9\% - O_{2,ref}}{(20.9\% - O_{2,measured}) \times (20.9\% - O_{2,measured})} \times \text{Uncertainty of } O_2 \text{ Measurement} = 1.00$$

$$u f_{O_2} = \frac{uCorr_{O_2}}{f_{O_2}} \times 100 = 0.00\%$$

Environmental Compliance Limited

Biotage GB Ltd

Permit No : EPR/DP3832EF

Variation No : N/A

Report Ref : P2251 : R001

Installation Name : Ystrad Mynach

Visit Details : Annual Compliance Emissions

Survey Dates : 31st March – 1st April 2015

Report Issue Date : 29th April 2015

Uncertainty in final measurement @ reference conditions due to mass uncertainty component (uM)

Determinand	HCl-1:			
	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	uM mg/Nm ³
...	...	...	...	...
Hydrogen Chloride	35.57	31.23	1.73	2.17
...	...	...	...	...
...	...	...	...	...

Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

Determinand	HCl-1:
	uL mg/Nm ³
...	...
Hydrogen Chloride	0.39
...	...
...	...

Uncertainty in final measurement @ Reference Conditions due to uVstp

Determinand	HCl-1:			
	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	uVstp mg/Nm ³
...	...	...	...	...
Hydrogen Chloride	33.56	33.24	57.87	0.16
...	...	...	...	...
...	...	...	...	...

Combined Uncertainty excluding oxygen contribution

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (u_{Vstp})^2}$$

Determinand	HCl-1:			
	Combined Uncertainty mg/Nm ³	Expanded Uncertainty mg/Nm ³	Measured Concentration mg/Nm ³	Percent of Measured Concentration
...	...	...	...	...
Hydrogen Chloride	2.21	4.42	33.40	13.24
...	...	...	...	...
...	...	...	...	...

Combined Uncertainty including oxygen contribution

$$u_{combined} = \sqrt{\sum (u_{f_{O_2}})^2 + (Uncertainty\ of\ Measurement\ of\ Determinand)^2}$$

Determinand	Measurement Uncertainty of Determinand	Measurement Uncertainty of Oxygen Corr Factor	Overall Measurement Uncertainty inc O ₂ Corr ⁿ factor (Ucombined)
...	...	...	...
Hydrogen Chloride	13.24	0.00	13.24
...	...	...	...
...	...	...	...

Environmental Compliance Limited

Biotage GB Ltd

Permit No : EPR/DP3832EF

Variation No : N/A

Report Ref : P2251 : R001

Installation Name

Visit Details

Survey Dates

Report Issue Date

: Ystrad Mynach

: Annual Compliance Emissions

: 31st March – 1st April 2015

: 29th April 2015

A2 Methanol Uncertainty

Site: Biotage GB LTD, Ystrad Mynach

Location: Main Building EP2, Stack ID:A2

				Standard Uncertainty @ 95%		
Sampled Volume	V _m	0.01390	m ³	uV _m	0.000	m ³
Meter Correction Factor or ml/count	Y _d	0.41	...	...	...	...
Meter Temperature	T _m	279.17	k	uT _m	1.5	k
Barometric Pressure	p _b	1005.00	mBar		10.0	mBar
Oxygen content	O _{2,m}	0.00	% Vol	uO _{2,m}	0.00	% Vol
Moisture	H ₂ O	0.00	% Vol	uH ₂ O		% Vol

Tubes					
Determinand	Recovered Mass		Standard Uncertainty		
Methanol	10.00	µg	uM	0.50	µg

Note: In the following calculations, the sensitivity coefficient (C) is estimated using: $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by $C_i u_i$, where C_i is the sensitivity coefficient, u_i is the standard uncertainty and i is the index identifying the contributing factor e.g. $i = uV_m, uT_m$ etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from meter:

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (uP_b), measured temperature of dry gas uncertainty component (uT_m) & measured moisture (uH₂O) where required

$$f_s = \frac{273}{T_m} \times \frac{P_b}{101.3} = 0.97$$

	Maximum	Minimum	Sensitivity	ufstp
uP _b	0.50	0.49	0.000488	0.00488
uT _m	0.98	0.97	0.0035	0.0052
uH ₂ O	...	...	...	...

$$\frac{uf_s}{f_s} = \sqrt{\left(\frac{uP_b}{(P_b/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{(100/(100-H_2O))}\right)^2} = 0.01$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uVstd) & volume uncertainty component (uV_m)

$$V_{std} = V_{measured} \times f_s = 0.0055$$

	Maximum m ³	Minimum m ³	Sensitivity	Standard Uncertainty m ³
Effect of uf _s	0.0056	0.0055	0.00570	0.00004
Effect of uV _m	0.0055	0.0055	0.40	0.0000040

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uf_s}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.000032$$

Uncertainty of correction factor to reference conditions (excluding oxygen contribution) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

$uL = \frac{Conc \times \frac{2}{100}}{\sqrt{3}}$			
	Tubes uL mg/Nm ³	Condensate uL mg/Nm ³	
Methanol	0.02089	...	

Environmental Compliance Limited

Biotage GB Ltd

Permit No : EPR/DP3832EF

Variation No : N/A

Report Ref : P2251 : R001

Installation Name : Ystrad Mynach

Visit Details : Annual Compliance Emissions

Survey Dates : 31st March – 1st April 2015

Report Issue Date : 29th April 2015

$$Conc = \frac{M_{Recovered}}{V_m \times f_s \times f_{O_2}}$$

Uncertainty in final measurement @ Reference Conditions due to $uM_{Recovered}$

Charcoal Tube Results				
	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	Standard Uncertainty mg/Nm ³
Methanol	1.90	1.72	180.93	0.09046
Condensate Results				
	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	Standard Uncertainty mg/Nm ³
Methanol				

Uncertainty in final measurement @ Reference Conditions due to uV_{STD}

Charcoal Tube Results				
	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	Standard Uncertainty mg/Nm ³
Methanol	1.82	1.80	327.35	0.01032

Combined Uncertainty (excluding Oxygen contribution)

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (uV_{sp})^2}$$

Charcoal Tubes: Determinand	Combined Uncertainty mg/Nm ³	Expanded Uncertainty mg/Nm ³	Measured Concentration mg/Nm ³	Percent of Measured Concentration
Methanol	0.09342	0.1868	1.81	10.33

Biotage GB Ltd
 Permit No : EPR/DP3832EF
 Variation No : N/A
 Report Ref : P2251 : R001

Installation Name : Ystrad Mynach
 Visit Details : Annual Compliance Emissions
 Survey Dates : 31st March – 1st April 2015
 Report Issue Date : 29th April 2015

A3 Volumetric Flowrate Uncertainty

Stack Reference A3

Measurement Uncertainty Calculations - Velocity at Stack Conditions

Contribution From	Standard u/c (mm H ₂ O)	
Pitot Calibration Uncertainty Contribution	0.047	A
Manometer Calibration Uncertainty Contribution	0.047	B
Variation in Actual Pitot reading at sample points	0.12	C
Combined u/c (mm H ₂ O) = SQRT (A/ ³) ² + (B/ ³) ² + (C/ ³) ²	0.08	
Expanded Uncertainty of Flow Measurements (mm H₂O)	0.15	
	Standard u/c (K)	
Temperature Calibration (K)	1.44	D
Variation in Actual Temp reading at sample points	0.10	E
Combined u/c of Temp (K) SQRT ((D/ ³) ² + (E/ ³) ²)	0.83	
Expanded Uncertainty of Temp Measurements (K)	1.66	
Measured Average Velocity (m/s) at Stack Conds	12.31	
Maximum Average Velocity (m/s) at Stack Conds	12.45	
Standard Uncertainty Velocity at Stack Conditions (%)	1.11	
Expanded Uncertainty Velocity (at Stack Conditions)	2.21 (%)	

Measurement Uncertainty Calculations - Flowrate at Stack Conditions

Contribution From	Standard u/c (m ³)
Area (m ²)	0.00031
Measured Average Flowrate (m ³ /s) at Stack Conds	0.39
Maximum Average Flowrate (m ³ /s) at Stack Conds	0.40
Standard Uncertainty Flowrate (m ³ /s) at Stack Conditions (%)	2.12
Expanded Uncertainty Flowrate (m³/s) at Stack Conditions	4.24 (%)

Measurement Uncertainty Calculations - Flowrate at STP & Wet Gas

Contribution From	Standard u/c (%)
Temperature Calibration (K)	0.5
Barometer Calibration	0.5
Measured Average Flowrate (m ³ /s) at STP Wet	0.36
Maximum Average Flowrate (m ³ /s) at STP Wet	0.37
Standard Uncertainty Flowrate (m ³ /s) at STP Wet	2.60
Expanded Uncertainty Flowrate (m³/s) at STP Wet	5.21 (%)

Environmental Compliance Limited

Biotage GB Ltd

Permit No : EPR/DP3832EF

Variation No : N/A

Report Ref : P2251 : R001

Installation Name : Ystrad Mynach

Visit Details : Annual Compliance Emissions

Survey Dates : 31st March – 1st April 2015

Report Issue Date : 29th April 2015

A3 NOx Measurement Uncertainty

Measurement Uncertainty Calculations Part 1

Horiba PG 250 Performance Characteristics	Standard Uncertainty (% of Range)	Distributioun	Minimum Certified Range (R _i)		
			NO 0 - 125 mg/m ³	O ₂ 0 - 25 %Vol	CO ₂ 0 - 20 %Vol
Lack of fit ⁽¹⁾	U_{lof}	Rectangular (Divisor = $\sqrt{3}$)	0.40	0.13	0.60
Span drift ⁽²⁾	$U_{d,s}$	Rectangular (Divisor = $\sqrt{3}$)	0.27	0.029	0.24
Repeatability Standard Deviation (span) ⁽³⁾	U_r	Normal (Divisor = 1)	0.33	0.29	0.22
Losses / leakage in the sample system ⁽⁴⁾	U_{loss}	Rectangular (Divisor = $\sqrt{3}$)	1.58	0.89	0.44
Temperature dependant span drift ⁽⁵⁾	U_t	Rectangular (Divisor = $\sqrt{3}$)	0.18	0.070	0.040
Interferents ⁽¹⁾	U_i	Rectangular (Divisor = $\sqrt{3}$)	1.20	0.56	0.010
Uncertainty of Reference Gas ⁽⁶⁾	U_{ref}	Rectangular (Divisor = $\sqrt{3}$)	1.77	0.15	0.088

Note:

$$\text{when } |(x_{i,\max} - x_{i,\text{adj}})| = |(x_{i,\min} - x_{i,\text{adj}})|, \text{ then } u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$$

1 Expressed as a percentage of the certified range

2 Expressed as a percentage of the certified range as maximum drift per 24hr period

3 Expressed as a percentage of the certified range

4 Expressed as a percentage of the certified range

5 Expressed as a percentage of the certified range per one degree centigrade

6 Expressed as standard uncertainty in units of measurement i.e. mg/m³ / %Vol inc additional uncertainty of 2% for gas blending

7 Applies to TVOC only

Measurement Uncertainty Calculations Part 2

Horiba PG 250 Performance Characteristics	Uncertainty	Value of Standard Uncertainty	NO 0 - 125 mg/m ³	O ₂ 0 - 25 %Vol	CO ₂ 0 - 20 %Vol
Lack of fit	U_{lof}	$u(x_i) = \frac{u_{lof} \times R_i}{\sqrt{3}} =$	0.29	0.019	0.07
Span drift	$U_{d,s}$	$u(x_i) = \frac{u_{d,s} \times R_i}{\sqrt{3}} =$	0.20	0.0041	0.0280
Repeatability Standard Deviation (span)	U_r	$\sigma = \sqrt{\frac{\sum_{i=1}^n (x_i - \bar{x})^2}{n-1}} =$	0.33	0.29	0.22
Losses / leakage in the sample system	U_{loss}	$u(x_i) = \frac{u_{loss} \times R_i}{\sqrt{3}} =$	1.14	0.13	0.05
Temperature dependant span drift	U_t	$u(x_i) = \frac{u_t}{100} \times R_i \times \sqrt{\frac{(x_{i,\max} - x_{i,\text{adj}})^2 + (x_{i,\min} - x_{i,\text{adj}})(x_{i,\max} - x_{i,\text{adj}}) + (x_{i,\min} - x_{i,\text{adj}})^2}{3}}$	0.052	0.0040	0.002
Interferents	U_i	$u(x_i) = \frac{u_i \times R_i}{\sqrt{3}} =$	0.87	0.081	0.01
Uncertainty of Reference Gas	U_{ref}	$u(x_i) = \frac{u_{ref}}{\sqrt{3}} =$	1.02	0.087	0.05
Combined Standard Uncertainty		$u_c = \sqrt{u_{lof}^2 + u_{d,s}^2 + u_r^2 + u_{loss}^2 + u_t^2 + u_i^2 + u_{ref}^2}$	1.82	0.33	0.24
Expanded measurement uncertainty (at 95 % confidence)		$U_{EXP} = 2 \times u_c$	3.65	0.67	0.49
Applied Span Concentration			102.40	15.03	5.06
Measured Span Concentration, STP Dry Gas			100.19	15.19	5.01
Expanded measurement uncertainty as % of Applied Span			4%	4%	10%

Biotage GB Ltd

Permit No : EPR/DP3832EF

Variation No : N/A

Report Ref : P2251 : R001

Installation Name

Visit Details

Survey Dates

Report Issue Date

: Ystrad Mynach

: Annual Compliance Emissions

: 31st March – 1st April 2015

: 29th April 2015

A3 NOx Uncertainty of Measurement

Uncertainty of Measurement Results - Calculations Part 1

Horiba PG 250 Performance Characteristics	Standard Uncertainty (% of Range)	Distribution	Divisor	Minimum Certified Range (R _i)		
				NO 0 - 125 mg/m ³	O ₂ 0 - 25 %Vol	CO ₂ 0 - 20 %Vol
Lack of fit ⁽¹⁾	u_{lof}	Rectangular	$\sqrt{3}$	0.40	0.13	0.60
Span drift ⁽²⁾	$u_{d,s}$			0.27	0.029	0.24
Losses / leakage in the sample system ⁽⁴⁾	u_{loss}			1.58	0.89	0.44
Temperature dependant span drift ⁽⁵⁾	u_t			0.18	0.070	0.040

Notes:

For rectangular distributions, $u(x_i) = \frac{u \times R_i}{\sqrt{3}}$ For $u(x_i) = \Delta x_i \sqrt{\frac{(x_{i,max} - x_{i,adj})^2 + (x_{i,min} - x_{i,adj})(x_{i,max} - x_{i,adj}) + (x_{i,min} - x_{i,adj})^2}{3}}$, when $|x_{i,max} - x_{i,adj}| = |x_{i,min} - x_{i,adj}|$, then $u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$ Where $u(x_i) = \frac{\sigma}{\sqrt{n}}$ (See note 6 below), $\sigma = \sqrt{\frac{\sum_{i=1}^n (x_i - \bar{x})^2}{n-1}}$

Horiba PG 250 Performance Characteristics	Uncertainty (Units of final measurement)	Distribution	Divisor	NO 0 - 125 mg/m ³	O ₂ 0 - 25 %Vol	CO ₂ 0 - 20 %Vol
Lack of fit	u_{lof}	Rectangular	$\sqrt{3}$	0.29	0.019	0.069
Span drift	$u_{d,s}$			0.20	0.0041	0.028
Temperature dependant span drift	u_t			0.060	0.0046	0.00
Interferents	u_i			0.87	0.081	...

Uncertainty of Measurement Results - Calculations Part 1

Horiba PG 250 Performance Characteristics	Standard Uncertainty (% of Range)	Distribution	Divisor	Minimum Certified Range (R _i)		
				NO 0 - 125 mg/m ³	O ₂ 0 - 25 %Vol	CO ₂ 0 - 20 %Vol
Lack of fit ⁽¹⁾	u_{lof}	Rectangular	$\sqrt{3}$	0.40	0.13	0.60
Span drift ⁽²⁾	$u_{d,s}$			0.27	0.029	0.24
Losses / leakage in the sample system ⁽⁴⁾	u_{loss}			1.58	0.89	0.44
Temperature dependant span drift ⁽⁵⁾	u_t			0.18	0.070	0.040

Notes:

For rectangular distributions, $u(x_i) = \frac{u \times R_i}{\sqrt{3}}$ For $u(x_i) = \Delta x_i \sqrt{\frac{(x_{i,max} - x_{i,adj})^2 + (x_{i,min} - x_{i,adj})(x_{i,max} - x_{i,adj}) + (x_{i,min} - x_{i,adj})^2}{3}}$, when $|x_{i,max} - x_{i,adj}| = |x_{i,min} - x_{i,adj}|$, then $u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$ Where $u(x_i) = \frac{\sigma}{\sqrt{n}}$ (See note 6 below), $\sigma = \sqrt{\frac{\sum_{i=1}^n (x_i - \bar{x})^2}{n-1}}$

Horiba PG 250 Performance Characteristics	Uncertainty (Units of final measurement)	Distribution	Divisor	NO 0 - 125 mg/m ³	O ₂ 0 - 25 %Vol	CO ₂ 0 - 20 %Vol
Lack of fit	u_{lof}	Rectangular	$\sqrt{3}$	0.29	0.019	0.069
Span drift	$u_{d,s}$			0.20	0.0041	0.028
Temperature dependant span drift	u_t			0.060	0.0046	0.00
Interferents	u_i			0.87	0.081	...

Where oxygen or moisture correction is required, uncertainty based on the standard error of the measured

peripheral value is converted to units of final measurement using a sensitivity coefficient C_i

$$\therefore u(x_i) = C_i u_i \text{ where } C_i = \frac{\partial f}{\partial x_i}$$

Uncertainty of Measurement Results - Calculations Part 3

Horiba PG 250 Uncertainty	Date & Time	NOx (as NO2) 0 - 125 mg/m ³	O ₂ 0 - 25 %Vol	CO ₂ 0 - 20 %Vol
Measured Concentration	31/03/15 12:48 - 13:47	56.73	21.10	0.020
Expanded Uncertainty as Percentage of Measured Concentration		14%	2%	> 100%

Combined Standard Uncertainty

$$u_c = \sqrt{u_{lof}^2 + u_{d,s}^2 + u_r^2 + u_{loss}^2 + u_t^2 + u_{adj}^2 + u_i^2 + u_{syn}^2}$$

Expanded uncertainty (at 95% confidence)

$$U_{Exp} = 2 \times u_c$$

1 Expressed as a percentage of the certified range

2 Expressed as a percentage of the certified range as maximum drift per 24hr period

3 Expressed as a percentage of the certified range

4 Expressed as a percentage of the certified range

5 Expressed as a percentage of the certified range per one degree centigrade

6 Where the uncertainty of Moisture is taken from the manual extractive test calculations

7 If no value for uncertainty is presented above, the uncertainty is considered to be > 100%

Environmental Compliance Limited

Biotage GB Ltd

Permit No : EPR/DP3832EF

Variation No : N/A

Report Ref : P2251 : R001

Installation Name : Ystrad Mynach

Visit Details : Annual Compliance Emissions

Survey Dates : 31st March – 1st April 2015

Report Issue Date : 29th April 2015

A3 Moisture Uncertainty

Site: Ystrad Mynach
Location: A3

$$u_{\text{mass}} = \sqrt{(u_{\text{filter}})^2 + (u_{\text{solution}})^2}$$

Determinand	Filter mg	Solution mg	Recovered Mass mg	LAB Method Filter mg	Solution mg	Standard Uncertainty Filter mg	Solution mg	Combined Uncertainty mg
Moisture-1								
***	...	...	...	...	...	...	...	...
***	...	...	...	...	...	...	...	...
***	...	...	...	...	...	...	...	...
***	...	...	...	...	...	...	...	...

***	...	...	...	...	...	...	...	...
***	...	...	...	...	...	...	...	...
***	...	...	...	...	...	...	...	...
***	...	...	...	...	...	...	...	...

Moisture-1			Standard Uncertainty @ 95%		
Sampled Volume (V _m)	0.47	m ³	uV _m	0.001	m ³
Meter Correction Factor (Y _d)	1.03	...	...	...	...
Meter Temperature (T _m)	291.40	k	uT _m	1.5	k
Average Differential Pressure (ΔH)	10.00	mmH ₂ O	uΔH	0.25	mmH ₂ O
Barometric Pressure (P _b)	750.81	mmHg	uP _b	3.8	mmHg
ΔH + P _s (P _m)	100.20	kPa	...	...	...
Oxygen content (O _{2,m})	21.00	% by volume	uO _{2,m} = σ/√n	0.00	% by volume
Moisture Content (H ₂ O)	0.0278	% by volume	uH ₂ O	0.34	% by volume

Note: In the following calculations, the sensitivity coefficient (C) is estimated using:

$$C_i = \frac{\partial f}{\partial x_i}$$

For each factor, uncertainty is then calculated by C_iu_i where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. i = uV_m, uT_m etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{s,\text{wet}} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured ΔH uncertainty component (uΔH), measured stack pressure uncertainty component (uP_b) & measured temperature of dry gas uncertainty component (uT_{m,Dry})

Moisture-1:				
$f_s = \frac{273}{760} \times \frac{P_b + \Delta H}{T_m} \times Y_d = 0.956$				
	Maximum	Minimum	Sensitivity	u _{stp}
uΔH	0.96	0.96	0.0000936	0.0000234
uP _b	0.96	0.95	0.00127	0.00477
uT _m	0.96	0.95	0.00328	0.00492
H ₂ O	0.96	0.95	0.00957	0.00326
$\frac{u f_s}{f_s} = \sqrt{\left(\frac{(u\Delta H)^2 + (uP_b)^2}{(P_b/101.3)} \right) + \left(\frac{uT_m}{(T_m/273.15)} \right)^2 + \left(\frac{uH_2O}{100/(100-H_2O)} \right)^2} = 0.00711$				

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV_{adj}) & volume uncertainty component (uV_m)

Moisture-1:				
$V_{std} = V_{measured} \times f_s = 0.447$				
	Maximum	Minimum	Sensitivity	Standard Uncertainty (m ³)
	m ³	m ³		
Effect of uV _{adj}	0.45	0.44	0.47	0.00332
Effect of uV _m	0.45	0.45	0.96	0.000956
Combined Standard Uncertainty				
$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uV_{std}}{f_s} \right)^2 + \left(\frac{uV_m}{V_m} \right)^2} = 0.00180$				

Uncertainty of Oxygen Correction Factor (%):-

Moisture-1:				
$f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 1.00$				
$u_{Corr_{O_2}} = \frac{20.9\% - O_{2,ref}}{(20.9\% - O_{2,measured}) \times (20.9\% - O_{2,measured})} \times \text{Uncertainty of } O_2 \text{ Measurement} = 1.00$				
$u f_{O_2} = \frac{u_{Corr_{O_2}}}{f_{O_2}} \times 100 = 0.00\%$				

Environmental Compliance Limited

Biotage GB Ltd

Permit No : EPR/DP3832EF

Variation No : N/A

Report Ref : P2251 : R001

Installation Name

Visit Details

Survey Dates

Report Issue Date

: Ystrad Mynach

: Annual Compliance Emissions

: 31st March – 1st April 2015

: 29th April 2015

A3 Methanol Uncertainty

Site: Biotage GB LTD, Ystrad Mynach

Location: Main Building EP3, Stack ID:A3

				Standard Uncertainty @ 95%		
Sampled Volume	V_m	0.01491	m ³	uV_m	0.000	m ³
Meter Correction Factor or ml/count	Y_d	0.41	...	...	...	...
Meter Temperature	T_m	289.17	K	uT_m	1.5	K
Barometric Pressure	P_b	1001.00	mBar		10.0	mBar
Oxygen content	$O_{2,m}$	0.00	%Vol	$uO_{2,m}$	0.00	%Vol
Moisture	H_2O	0.00	%Vol	uH_2O		%Vol

Tubes					
Determinand	Recovered Mass		Standard Uncertainty		
Methanol	61.00	µg	uM	3.05	µg

Note: In the following calculations, the sensitivity coefficient (C) is estimated using: $C_i = \frac{\partial I}{\partial x_i}$

For each factor, uncertainty is then calculated by $C_i u_i$ where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. i = uV_m , uT_m etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from meter:

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (uP_b), measured temperature of dry gas uncertainty component (uT_m) & measured moisture (uH_2O) where required

$f_s = \frac{273}{T_m} \times \frac{P}{101.3} = 0.93$				
	Maximum	Minimum	Sensitivity	u _{stp}
uP_b	0.48	0.48	0.000479	0.00479
uT_m	0.94	0.93	0.00323	0.00484
uH_2O	...	...	...	...
$\frac{u f_s}{f_s} = \sqrt{\left(\frac{u P_b}{(P_b/101.3)}\right)^2 + \left(\frac{u T_m}{(T_m/273.15)}\right)^2 + \left(\frac{u H_2O}{(100/(100 - H_2O))}\right)^2} = 0.00622$				

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV_{std}) & volume uncertainty component (uV_m)

$V_{std} = V_{measured} \times f_s = 0.00570$				
	Maximum m ³	Minimum m ³	Sensitivity	Standard Uncertainty m ³
Effect of $u f_s$	0.00574	0.00567	0.00611	0.0000380
Effect of $u V_m$	0.00571	0.00570	0.38	3.825E-06
$\frac{u V_{std}}{V_{std}} = \sqrt{\left(\frac{u f_s}{f_s}\right)^2 + \left(\frac{u V_m}{V_m}\right)^2} = 0.0000349$				

Uncertainty of correction factor to reference conditions (excluding oxygen contribution) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

$uL = \frac{Conc \times \frac{2}{100}}{\sqrt{3}}$			Tubes uL mg/Nm ³	Condensate uL mg/Nm ³
Methanol			0.12	...

Environmental Compliance Limited

Biotage GB Ltd

Permit No : EPR/DP3832EF

Variation No : N/A

Report Ref : P2251 : R001

Installation Name : Ystrad Mynach

Visit Details : Annual Compliance Emissions

Survey Dates : 31st March – 1st April 2015

Report Issue Date : 29th April 2015

$$Conc = \frac{M_{Recovered}}{V_m \times f_s \times f_{O_2}}$$

Uncertainty in final measurement @ Reference Conditions due to $uM_{Recovered}$

Charcoal Tube Results				
	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	Standard Uncertainty mg/Nm ³
Methanol	11.23	10.16	175.32	0.53
Condensate Results				
	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	Standard Uncertainty mg/Nm ³
Methanol				

Uncertainty in final measurement @ Reference Conditions due to uV_{STD}

Charcoal Tube Results				
	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	Standard Uncertainty mg/Nm ³
Methanol	10.76	10.63	1875.12	0.0654

Combined Uncertainty (excluding Oxygen contribution)

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (uV_{sp})^2}$$

Charcoal Tubes: Determinand	Combined Uncertainty mg/Nm ³	Expanded Uncertainty mg/Nm ³	Measured Concentration mg/Nm ³	Percent of Measured Concentration
Methanol	0.55	1.11	10.69	10.34

Biotage GB Ltd
 Permit No : EPR/DP3832EF
 Variation No : N/A
 Report Ref : P2251 : R001

Installation Name : Ystrad Mynach
 Visit Details : Annual Compliance Emissions
 Survey Dates : 31st March – 1st April 2015
 Report Issue Date : 29th April 2015

A4 Volumetric Flowrate Uncertainty

Stack Reference A4

Measurement Uncertainty Calculations - Velocity at Stack Conditions

Contribution From	Standard u/c (mm H ₂ O)	
Pitot Calibration Uncertainty Contribution	0.025	A
Manometer Calibration Uncertainty Contribution	0.025	B
Variation in Actual Pitot reading at sample points	0.07	C
Combined u/c (mm H ₂ O) = SQRT (A/√3) ² + (B/√3) ² + (C/√3) ²	0.05	
Expanded Uncertainty of Flow Measurements (mm H₂O)	0.10	
	Standard u/c (K)	
Temperature Calibration (K)	1.48	D
Variation in Actual Temp reading at sample points	0.10	E
Combined u/c of Temp (K) SQRT ((D/√3) ² + (E/√3) ²)	0.85	
Expanded Uncertainty of Temp Measurements (K)	1.71	
Measured Average Velocity (m/s) at Stack Conds	9.08	
Maximum Average Velocity (m/s) at Stack Conds	9.20	
Standard Uncertainty Velocity at Stack Conditions (%)	1.25	
Expanded Uncertainty Velocity (at Stack Conditions)	2.51 (%)	

Measurement Uncertainty Calculations - Flowrate at Stack Conditions

Contribution From	Standard u/c (m ³)
Area (m ²)	0.00096
Measured Average Flowrate (m ³ /s) at Stack Conds	0.87
Maximum Average Flowrate (m ³ /s) at Stack Conds	0.89
Standard Uncertainty Flowrate (m ³ /s) at Stack Conditions (%)	2.27
Expanded Uncertainty Flowrate (m³/s) at Stack Conditions	4.53 (%)

Measurement Uncertainty Calculations - Flowrate at STP & Wet Gas

Contribution From	Standard u/c (%)
Temperature Calibration (K)	0.5
Barometer Calibration	0.5
Measured Average Flowrate (m ³ /s) at STP Wet	0.80
Maximum Average Flowrate (m ³ /s) at STP Wet	0.82
Standard Uncertainty Flowrate (m ³ /s) at STP Wet	2.74
Expanded Uncertainty Flowrate (m³/s) at STP Wet	5.48 (%)

Environmental Compliance Limited

Biotage GB Ltd

Permit No : EPR/DP3832EF

Variation No : N/A

Report Ref : P2251 : R001

Installation Name : Ystrad Mynach

Visit Details : Annual Compliance Emissions

Survey Dates : 31st March – 1st April 2015

Report Issue Date : 29th April 2015

A4 HBr Uncertainty

Site: Ystrad Mynach
Location: A4

$$u_{\text{mass}} = \sqrt{\sum (u_{\text{filter}})^2 + (u_{\text{solution}})^2}$$

Determinand	Filter mg	Solution mg	Recovered Mass mg	LAB Method Uncert (%) K=2 Filter mg	Solution mg	Standard Uncertainty Filter mg	Solution mg	Combined Uncertainty mg
Hydrogen Bromide 1								
...	...	...	...	...	...	...	...	...
Hydrogen Bromide	...	35.14	35.14	...	4.57	...	2.28	2.28
...	...	...	...	...	...	...	...	...
...	...	...	...	...	...	...	...	...
...	...	...	...	...	...	...	...	...
...	...	...	...	...	...	...	...	...

Hydrogen Bromide 1			Standard Uncertainty @ 95%		
Sampled Volume (V _m)	0.61	m ³	uV _m	0.001	m ³
Meter Correction Factor (Y _d)	1.03	...	...	...	...
Meter Temperature (T _m)	284.48	k	uT _m	1.5	k
Average Differential Pressure (ΔH)	10.00	mmH ₂ O	uΔH	0.25	mmH ₂ O
Barometric Pressure (P _b)	754.56	mmHg	uP _b	3.8	mmHg
ΔH + P _s (P _m)	100.70	kPa	...	...	...
Oxygen content (O _{2,m})	21.00	% by volume	uO _{2,m} = σ/√n	0.000698	% by volume
Moisture Content (H ₂ O)	2.02	% by volume	uH ₂ O	0.26	% by volume

Note: In the following calculations, the sensitivity coefficient (C) is estimated using: $C_i = \frac{\partial f}{\partial X_i}$

For each factor, uncertainty is then calculated by $C_i u_i$ where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. i = uV_m, uT_m etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{s,\text{wet}} = \frac{100}{(100 - H_2O)} = 1.02$$

Uncertainty in correction factor to STP due to measured ΔH uncertainty component (uΔH), measured stack pressure uncertainty component (uP_b) & measured temperature of dry gas uncertainty component (uT_{m,Dry})

Hydrogen Bromide 1:

$$f_s = \frac{273}{760} \times \frac{P_b + \frac{\Delta H}{T_m}}{13.6} \times Y_d = 1.005$$

	Maximum	Minimum	Sensitivity	ufstp
uΔH	1.00	1.00	0.0000978	0.0000245
uP _b	1.01	1.00	0.00133	0.00499
uT _m	1.01	1.00	0.00353	0.00530
H ₂ O	1.01	1.00	0.0103	0.00262

$$\frac{uf_s}{f_s} = \sqrt{\left(\frac{\sqrt{(u\Delta H)^2 + (uP_b)^2}}{(P_m/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{100/(100 - H_2O)}\right)^2} = 0.00763$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV_{std}) & volume uncertainty component (uV_m)

Hydrogen Bromide 1:

$$V_{std} = V_{measured} \times f_s = 0.610$$

	Maximum m ³	Minimum m ³	Sensitivity	Standard Uncertainty (m ³)
Effect of uV _{std}	0.61	0.61	0.61	0.00463
Effect of uV _m	0.61	0.61	1.00	0.00100

Combined Standard Uncertainty

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uV_{std}}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.00298$$

Uncertainty of Oxygen Correction Factor (%):-

Hydrogen Bromide 1:

$$f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 1.00$$

$$uCorr_{O_2} = \frac{uCorr_{O_2}^n}{f_{O_2}} \times 100 = 0.00\%$$

$$uCorr_{O_2} = \frac{20.9\% - O_{2,ref}}{(20.9\% - O_{2,measured}) \times (20.9\% - O_{2,measured})} \times \text{Uncertainty of } O_2 \text{ Measurement} = 1.00$$

Environmental Compliance Limited

Biotage GB Ltd

Permit No : EPR/DP3832EF

Variation No : N/A

Report Ref : P2251 : R001

Installation Name

Visit Details

Survey Dates

Report Issue Date

: Ystrad Mynach

: Annual Compliance Emissions

: 31st March – 1st April 2015

: 29th April 2015

Uncertainty in final measurement @ reference conditions due to mass uncertainty component (uM)

Determinand	Hydrogen Bromide 1:			
	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	uM mg/Nm ³
...	...	...	...	...
...	...	...	...	...
Hydrogen Bromide	61.37	53.88	1.64	3.75
...	...	...	...	...

Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

Determinand	Hydrogen Bromide 1:	
	uL mg/Nm ³	
...	...	
...	...	
Hydrogen Bromide	0.67	
...	...	

Uncertainty in final measurement @ Reference Conditions due to uVstp

Determinand	Hydrogen Bromide 1:			
	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	uVstp mg/Nm ³
...	...	...	...	...
...	...	...	...	...
Hydrogen Bromide	57.91	57.35	94.52	0.28
...	...	...	...	...

Combined Uncertainty excluding oxygen contribution

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (u_{Vstp})^2}$$

Determinand	Hydrogen Bromide 1:			
	Combined Uncertainty mg/Nm ³	Expanded Uncertainty mg/Nm ³	Measured Concentration mg/Nm ³	Percent of Measured Concentration
...	...	...	...	...
...	...	...	...	...
Hydrogen Bromide	3.81	7.63	57.63	13.24
...	...	...	...	...

Combined Uncertainty including oxygen contribution

$$u_{combined} = \sqrt{\sum (u_{f_{O_2}})^2 + (Uncertainty\ of\ Measurement\ of\ Determinand)^2}$$

Determinand	Measurement Uncertainty of Determinand	Measurement Uncertainty of Oxygen Corr Factor	Overall Measurement Uncertainty inc O ₂ Corr factor (Ucombined)
...	...	...	...
...	...	...	...
Hydrogen Bromide	13.24	0.00	13.24
...	...	...	...