

Schedule 1 - Notification of abnormal emissions

This page outlines the information that the Operator must provide to satisfy conditions 5.1.1 and 5.1.2 of this Permit.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the PPC Regulations.

Part A

Permit Number	NP3030BJ
Name of Operator	EnerSys Newport
Location of Installation	Stephenson Street, Newport, NP19 4XJ
Location of the emission	Stores Building
Time and date of the emission	Saturday 14 th November 2015. 00.12 fire alarm activated

Substance(s) emitted	Media	Best estimate of the quantity or the rate of emission	Time during which the emission took place
Firewater runoff	Aqueous	Unknown	00.12 onwards
Smoke	Air	Unknown	00.12 onwards

Measures taken, or intended to be taken, to stop the emission	CCTV shows smoke from the fire at 00.11 and the fire alarm activated at 00.12. The sprinklers operated and smoke within the building was clearing by 01.47. Fire brigade attended site at 00.22 and used a limited amount of water - they left at 03.10. Sprinkler water and fire brigade hose water ran to surface water drains. The Interceptor was sealed to stop any surface water drainage entering the re-en. Spill kits and drain stoppers were used to try and contain the firewater runoff. Specialist contractors brought onto site to assist the clean up. All waste placed in a dedicated skip for specialist disposal. Interceptor surface contents tankered off site.
---	---

Part B

Any more accurate information on the matters for notification under Part A.	
Measures taken, or intended to be taken, to prevent a recurrence of the incident	
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment or harm which has been or may be caused by the emission	
The dates of any unauthorised emissions from the Installation in the preceding 24 months.	

Name*	Paula Terrett
Post	ENVIRONMENTAL OFFICER
Signature	Paula J. Terrett.
Date	16/11/2015.

* authorised to sign on behalf of EnerSys Newport Ltd