

Permit Number: EPR/BL3986ID

Operator: Lafarge Tarmac Cement & Lime Ltd

Installation: Aberthaw Works

Form number: Air 9 / 31 August 2010

Annual reporting of non-kiln Particulate Matter Emissions to Air for 2014

Release point	Emission Limit Value mg/m3	Results mg/m3		Test Method	Sample Date and Times	Accreditation/ Certification	Uncertainty Method	
		Continuous Monitor	Extractive Test				Continuous Monitor	Extractive Test
A2	30	2.84	1.12	BS EN 13284-1	10/04/2014 12:57-16:09	UKAS & MCERTS	30%	0.30
		1.80	4.34		11/11/2014 09:29-12:46		30%	0.76
A3	30	1.60	1.16	BS EN 13284-1	10/04/2014 09:13-12:35	UKAS & MCERTS	30%	0.30
		3.90	5.72		11/11/2014 10:26-13:39		30%	0.51

Operator's comments:

Signed: R. Fairless

Date: 12/02/2015

(authorised to sign as representative of Lafarge Tarmac Cement & Lime Ltd)