



Element Materials Technology, Unit 37, Evans Business Centre, Western Industrial Estate, Caerphilly, CF83 1BE  
Your Element Contact: Paul Martin (07827 332 630)  
E: paul.martin@element.com

**Stack Emissions Testing Report Commissioned by**  
Vale Bio-Energy

**Installation Name & Address**

Vale Bio-Energy  
Pancross AD Plant  
Pancross Farm  
Llancarfan  
CF62 3AJ

EPR Permit: EPR/HB3935AE/V02

**Stack Reference**

Engine 1

**Dates of the Monitoring Campaign**

12th March 2021

**Job Reference Number**

EMT-00590

**Report Written by**

Darren Price  
Team Leader  
MCERTS Level 2  
MM 03 176  
TE1 TE2 TE3 TE4

**Report Approved by**

Phil Soley  
Assistant Operations Manager  
MCERTS Level 2  
MM 12 1187  
TE1 TE2 TE3 TE4

**Report Date**

30th March 2021

**Version**

Version 1

**Signature of Report Approver**

## CONTENTS

TITLE PAGE

CONTENTS

EXECUTIVE SUMMARY

Monitoring Objectives	3
Monitoring Results	4
Monitoring Dates & Times	5
Process Details	6
Monitoring & Analytical Methods	7
Summary of Sampling Deviations	7
Sampling Location	8
Plant Photos / Sample Points	9

APPENDIX 1 - Monitoring Personnel & List of Equipment

APPENDIX 2 - Raw Data, Sampling Equations & Charts

*Opinions and interpretations expressed herein are outside the scope of Element's ISO 17025 accreditation.*

*This test report shall not be reproduced, except in full, without the written approval of Element.*

## Executive Summary

(Page 1 of 7)

### MONITORING OBJECTIVES

Vale Bio-Energy, Llancarfan

Engine 1

12th March 2021

#### Overall Aim of the Monitoring Campaign

Element were commissioned by Vale Bio-Energy to carry out stack emissions testing on the Engine 1 at Llancarfan.

The aim of the monitoring campaign was to demonstrate compliance with a set of emission limit values (ELVs) as specified in the Site's Permit.

#### Special Requirements

There were no special requirements.

#### Target Parameters

Sulphur Dioxide, Total VOCs (as Carbon), Oxides of Nitrogen (as NO<sub>2</sub>), Carbon Monoxide

# Executive Summary

(Page 2 of 7)

## MONITORING RESULTS

Vale Bio-Energy, Llanccarfan  
 Engine 1  
 12th March 2021

where MU = Measurement Uncertainty associated with the Result

Parameter	Concentration				Mass Emission			
	Units	Result	MU +/-	Limit	Units	Result	MU +/-	Limit
Sulphur Dioxide	<sup>1</sup> mg/m <sup>3</sup>	223	17.8	350	g/hr	353	36.8	-
Total VOCs (as Carbon)	<sup>1</sup> mg/m <sup>3</sup>	1109	45.8	1000	g/hr	1760	138	-
Oxides of Nitrogen (as NO <sub>2</sub> )	<sup>1</sup> mg/m <sup>3</sup>	409	15.6	500	g/hr	649	50.0	-
Carbon Monoxide	<sup>1</sup> mg/m <sup>3</sup>	902	33.8	1400	g/hr	1431	110	-
Oxygen	% v/v	Dry 8.6	0.21					
Water Vapour	% v/v	15.4	0.69					
Stack Gas Temperature	°C	195						
Stack Gas Velocity	m/s	21.6	1.1					
Volumetric Flow Rate (ACTUAL)	m <sup>3</sup> /hr	4120	275					
Volumetric Flow Rate (REF)	<sup>1</sup> m <sup>3</sup> /hr	1587	106					

NOTE: VOLUMETRIC FLOW RATE & VELOCITY DATA TAKEN FROM THE PRELIMINARY VELOCITY TRAVERSE.

<sup>1</sup> Reference Conditions (REF) are: 273K, 101.3kPa, dry gas, 5% oxygen.

## Executive Summary

(Page 3 of 7)

### MONITORING DATE(S) & TIMES

Vale Bio-Energy, Llancafán

Engine 1

12th March 2021

Parameter		Units	Concentration	Units	Mass Emission	Sampling Date(s)	Sampling Times	Duration mins
Sulphur Dioxide	R1	mg/m <sup>3</sup>	223	g/hr	353	12/03/2021	11:20 - 12:20	60
Total VOCs (as Carbon)	R1	mg/m <sup>3</sup>	1109	g/hr	1760	12/03/2021	11:20 - 12:20	60
Oxides of Nitrogen (as NO <sub>2</sub> )	R1	mg/m <sup>3</sup>	409	g/hr	649	12/03/2021	11:20 - 12:20	60
Carbon Monoxide	R1	mg/m <sup>3</sup>	902	g/hr	1431	12/03/2021	11:20 - 12:20	60
Oxygen	R1	% v/v	8.6			12/03/2021	11:20 - 12:20	60
Velocity Traverse	R1					12/03/2021	10:25 - 10:30	

All results are expressed at the respective reference conditions.

**Executive Summary**  
(Page 4 of 7)

**PROCESS DETAILS**

Vale Bio-Energy, Llancafarn  
Engine 1  
12th March 2021

**Standard Operating Conditions**

Parameter	Value
Process Status	Operating
Capacity (of 100%) and Tonnes / Hour	100%
Continuous or Batch Process	Continuous
Feedstock (if applicable)	N/A
Abatement System	None
Abatement System Running Status	N/A
Fuel	Bio gas
Plume Appearance	No plume visible

# Executive Summary

(Page 5 of 7)

## MONITORING & ANALYTICAL METHODS

Vale Bio-Energy, Llanccarfan  
 Engine 1  
 12th March 2021

Parameter	Monitoring				Analysis				Overall Status	LOD (Average)
	Standard	Technical Procedure	Sampling Status	Testing Lab	Analytical Procedure	Analytical Technique	Analysis Status	Analysis Lab		
Sulphur Dioxide	EN 14791	CAT-TP-09	MCERTS	EET	CAT-AP-01	IC	MCERTS	EET	MCERTS	0.17 mg/m³
Water Vapour	EN 14790	CAT-TP-05	MCERTS	EET	CAT-TP-05	Gravimetric	MCERTS	EET	MCERTS	0.10 % v/v
Total VOCs (as Carbon)	EN 12619:2013	CAT-TP-20	MCERTS	EET	Flame Ionisation Detection by Sick 3006 FID				MCERTS	1.16 mg/m³
Oxides of Nitrogen (as NO <sub>2</sub> )	EN 14792	CAT-TP-39	MCERTS	EET	Chemiluminescence by Horiba PG-350E				MCERTS	0.41 mg/m³
Carbon Monoxide	EN 15058	CAT-TP-39	MCERTS	EET	NDIR by Horiba PG-350E				MCERTS	0.25 mg/m³
Oxygen	EN 14789	CAT-TP-39	MCERTS	EET	Dry Paramagnetic Cell by Horiba PG-350E				MCERTS	0.1 %
Velocity & Vol. Flow Rate	EN 16911-1 (MID)	CAT-TP-41	MCERTS	EET	Pitot Tube and Thermocouple				MCERTS	3.0 m/s

## ANALYSIS LABORATORIES

(with short name reference as appears in the table above)

Element Materials Technology (EET)	ISO 17025 Accreditation Number: 4279
------------------------------------	--------------------------------------

## SUMMARY OF SAMPLING DEVIATIONS

Parameter	Run	Deviation
All	All	There are no deviations associated with the sampling employed.

## Executive Summary

(Page 6 of 7)

### SUITABILITY OF SAMPLING LOCATION

#### Duct Characteristics

Parameter	Units	Value
Type	-	Circular
Depth	m	0.26
Width	m	-
Area	m <sup>2</sup>	0.05
Port Depth	cm	12
Orientation of Duct	-	Vertical
Number of Ports	-	1
Sample Port Size	-	4" Flange

#### Location of Sampling Platform

General Platform Information	Value
Permanent / Temporary Platform	On Ground
Inside / Outside	Outside

#### Platform Details

EA Technical Guidance Note M1 / EN 15259 Platform Requirements	Value
Sufficient working area to manipulate probe and operate the measuring instruments	Yes
Platform has 2 levels of handrails (approx. 0.5m & 1.0m high)	N/A
Platform has vertical base boards (approx. 0.25m high)	N/A
Platform has chains / self closing gates at top of ladders	N/A
There are no obstructions present which hamper insertion of sampling equipment	N/A
Safe Access Available	Yes
Easy Access Available	Yes

#### Sampling Location / Platform Improvement Recommendations

The sampling location meets all the requirements specified in EA Guidance Note M1 and EN 15259, and therefore there are no improvement recommendations.

#### EN 15259 Homogeneity Test Requirements

There is no requirement to perform a EN 15259 Homogeneity Test on this Stack.

#### Sampling Plane Validation Criteria (from EN 15259)

Criteria in EN 15259	Units	Traverse 1	Required	Compliant
Lowest Differential Pressure	Pa	240.0	> 5 Pa	Yes
Mean Velocity	m/s	21.55	-	-
Lowest Gas Velocity	m/s	21.55	-	-
Highest Gas Velocity	m/s	21.55	-	-
Ratio of Above	: 1	1.00	< 3 : 1	Yes
Maximum Angle of Swirl	°	0.00	< 15°	Yes
No Local Negative Flow	-	Yes	-	Yes



Executive Summary

(Page 7 of 7)

PLANT PHOTOS

Photo 1




Photo 2



Photo 3



SAMPLE POINTS



- where

○ = isokinetic point sampled at

● = isokinetic point not sampled at

● = combustion gases sample point

● = non-isokinetic sample point

## APPENDICES

### APPENDIX CONTENTS

APPENDIX 1 - Stack Emissions Monitoring Personnel, List of Equipment & Methods and Technical Procedures Used

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

## APPENDIX 1

### STACK EMISSIONS MONITORING PERSONNEL

Position	Name	MCERTS Accreditation	MCERTS Number	Technical Endorsements
Team Leader	Darren Price	MCERTS Level 2	MM 03 176	TE1 TE2 TE3 TE4
Technician	Craig Price	MCERTS Level 1	MM 20 1588	None

### LIST OF EQUIPMENT

Extractive Sampling		Instrumental Analysers		Miscellaneous Items	
Equipment Type	Equipment I.D.	Equipment Type	Equipment I.D.	Equipment Type	Equipment I.D.
Control Box DGM (1)	-	Horiba PG-250 SRM	CAT 9.14	Digital Manometer (1)	CAT 3.55
Control Box DGM (2)	-	Horiba PG-250	-	Digital Manometer (2)	-
Box Thermocouples (1)	-	Servomex 5200 MP	-	Digital Temperature Meter	CAT 3.55
Box Thermocouples (2)	-	Eco Physics CLD 822Mh	-	Stopwatch	-
Umbilical (1)	-	ABB AO2020-URAS26	-	Barometer	CAT 13.3
Umbilical (2)	-	Testo 350 XL	-	Stack Thermocouple (1)	CAT 4.919
Oven Box (1)	-	JCT JCC P1 Cooler	CAT 4.204	Stack Thermocouple (2)	-
Oven Box (2)	-	Gasmet DX4000	-	Stack Thermocouple (3)	-
Heated Probe (1)	-	Gasmet Sampling System	-	1m Heated Line (1)	-
Heated Probe (2)	-	Bernath 3006 FID	-	1m Heated Line (2)	-
Heated Probe (3)	-	M&C PSS	CAT 12.91	1m Heated Line (3)	-
S-Pitot (1)	CAT 21S.18	Mass Flow Controller (1)	CAT 6.34	5m Heated Line (1)	-
S-Pitot (2)	-	Mass Flow Controller (2)	CAT 6.35	15m Heated Line (1)	-
L-Pitot	-	Mass View (1)	CAT 25.78	20m Heated Line (1)	CAT 20.139
Site Balance	CAT 17.14	Mass View (2)	CAT 25.79	20m Heated Line (2)	-
500g / 1Kg Check Weights	CAT 17.14	Easylogger EN-EL-12 Bit	-	Dual Channel Heater Controller	-
Last Impinger Arm	CAT 4.82	Hioki 5031 (mA)	-	Single Channel Heater Controller	CAT 20.139
Callipers	-	Bioaerosols Temperature Logger	-	Laboratory Balance	-
Tubes Kit Thermocouple	-	Electronic Refrigerator	-	Tape Measure	CAT 16.144

### METHODS & TECHNICAL PROCEDURES USED

Parameter	Standard	Technical Procedure
Sulphur Dioxide	EN 14791	CAT-TP-09
Water Vapour	EN 14790	CAT-TP-05
Total VOCs (as Carbon)	EN 12619:2013	CAT-TP-20
Oxides of Nitrogen (as NO <sub>2</sub> )	EN 14792	CAT-TP-39
Carbon Monoxide	EN 15058	CAT-TP-39
Oxygen	EN 14789	CAT-TP-39
Velocity & Vol. Flow Rate	EN 16911-1 (MID)	CAT-TP-41

## PRELIMINARY STACK SURVEY: CALCULATIONS

### General Stack Details

Stack Details (from Traverse)	Units	Value
Stack Diameter / Depth, D	m	0.26
Stack Width, W	m	-
Stack Area, A	m <sup>2</sup>	0.05
Average Stack Gas Temperature, T <sub>a</sub>	°C	195.0
Average Stack Gas Pressure	Pa	240.0
Average Stack Static Pressure, P <sub>static</sub>	kPa	0.055
Average Barometric Pressure, P <sub>b</sub>	kPa	101.8
Average Pitot Tube Calibration Coefficient, C <sub>p</sub>	-	0.85

### Stack Gas Composition & Molecular Weights

Component	Conc ppm	Conc Dry % v/v	Conc Wet % v/v	Volume Fraction r	Molar Mass M	Density kg/m <sup>3</sup> p	Conc kg/m <sup>3</sup> p <sub>i</sub>
CO <sub>2</sub> (Estimated)	-	12.20	10.32	0.1220	44.01	1.9635	0.23955
O <sub>2</sub>	-	8.58	7.26	0.0858	32.00	1.4277	0.12253
N <sub>2</sub>	-	79.22	67.03	0.7922	28.01	1.2498	0.99010
Moisture (H <sub>2</sub> O)	-	-	15.39	0.1539	18.02	0.8037	0.12369

Where:  $p = M / 22.41$

$p_i = r \times p$

### Calculation of Stack Gas Densities

Determinand	Units	Result
Dry Density (STP), P <sub>STD</sub>	kg/m <sup>3</sup>	1.352
Wet Density (STP), P <sub>STW</sub>	kg/m <sup>3</sup>	1.268
Dry Density (Actual), P <sub>Actual</sub>	kg/m <sup>3</sup>	0.793
Average Wet Density (Actual), P <sub>ActualW</sub>	kg/m <sup>3</sup>	0.744

Where: P<sub>STD</sub> = sum of component concentrations, kg/m<sup>3</sup> (not including water vapour)

P<sub>STW</sub> = sum of all wet concentrations / 100 x density, kg/m<sup>3</sup> (including water vapour)

$P_{Actual} = P_{STD} \times (T_{STP} / (P_{STP})) \times ((P_{static} + P_b) / T_a)$

$P_{ActualW} \text{ (at each sampling point)} = P_{STW} \times (T_s / P_s) \times (P_a / T_a)$

### Calculation of Stack Gas Volumetric Flowrate, Q

Duct gas flow conditions	Units	Actual	REF <sup>1</sup>
Temperature	°C	195.0	0.0
Total Pressure	kPa	101.9	101.3
Moisture	%	15.39	0.00
Oxygen (Dry)	%	8.6	5.0

Gas Volumetric Flowrate (from Traverse)	Units	Result
Gas Volumetric Flowrate (Actual)	m <sup>3</sup> /hr	4120
Gas Volumetric Flowrate (STP, Wet)	m <sup>3</sup> /hr	2417
Gas Volumetric Flowrate (STP, Dry)	m <sup>3</sup> /hr	2045
Gas Volumetric Flowrate REF <sup>1</sup>	m <sup>3</sup> /hr	1587

PRELIMINARY STACK SURVEY: VELOCITY TRAVERSE TO EN 16911-1 (MID)

(1 of 1)

Parameter	Units	Value
Date of Survey	-	12/03/2021
Time of Survey	-	10:25 - 10:30
Atmospheric Pressure	kPa	101.8
Average Stack Static Pressure	Pa	55
Result of Pitot Stagnation Test	-	Pass
Are Water Droplets Present?	-	No
Device Used	S-Type Pitot with KIMO MP 200 (10000Pa)	

Parameter	Units	Value
Initial Pitot Leak Check	-	Pass
Final Pitot Leak Check	-	Pass
Orientation of Duct	-	Vertical
Pitot Tube, C <sub>p</sub>	-	0.85
Number of Lines Available	-	1
Number of Lines Used	-	1

Sampling Line A						
Traverse Point	Depth m	ΔP Pa	Temp °C	Wet Density kg/m³	Velocity m/s	Swirl °
STATIC (Units: Pa)		55.0				
Mean		240.0	195.0	0.744	21.55	
1	0.13	240.0	195.0	0.744	21.55	0.0

# PRELIMINARY STACK SURVEY: VELOCITY TRAVERSE TO EN 16911-1 (MID) - MEASUREMENT UNCERTAINTY

(1 of 1)

Performance characteristics (Uncertainty Components)	Uncertainty	Value	Units
Standard Uncertainty on the coefficient of the Pitot Tube	$u(k)$	0.005	-
Standard Uncertainty associated with the mean local dynamic pressures	$u(\Delta p_i)$	7.369	Pa
- Resolution	$u(res)$	0.08677	
- Calibration	$u(cal)$	5.998	
- Drift	$u(drift)$	33.333	
- Lack of Fit	$u(fit)$	13.879	
- Overall corrections to dynamic measurements	$u(C_f)$	53.297	
Standard uncertainty associated with the molar mass of the gas	$u(M)$	0.00010	-
- $\phi O_{2,w}$	-	7.262	
- $\phi CO_{2,w}$	-	10.323	
- Oxygen, dry	$u(\phi O_{2,d})$	0.263	
- Carbon Dioxide, dry	$u(\phi CO_{2,d})$	0.373	
- Water Vapour	$u(\phi H_2O)$	0.785	
- Oxygen, wet	$u(\phi O_{2,w})$	0.232	
- Carbon Dioxide, wet	$u(\phi CO_{2,w})$	0.330	
Standard uncertainty associated with the stack temperature	$u(T_c)$	2.388	K
Standard uncertainty associated with the absolute pressure in the duct	$u(p_c)$	175.846	Pa
- Atmospheric Pressure	$u(p_{atm})$	175.692	
- Static Pressure	$u(p_{stat})$	7.369	
Standard uncertainty associated with the density in the duct	$u(\rho)$	0.00401	-
Standard uncertainty associated with the local velocities	$u(v_i)$	0.540	Pa
Standard uncertainty associated with the mean velocity	$u(\bar{v})$	0.540	m/s
Standard uncertainty associated with the mean velocity (95% Confidence)	$U_c(v)$	1.059	m/s
Standard uncertainty associated with the mean velocity (95% Confidence), relative	$U_{c,rel}(v)$	4.91	%
Standard uncertainty associated with the volume flow rate (95% Confidence)	$U_c(qV,w)$	275.2	m <sup>3</sup> /hr
- $u^2(a)/a^2$	-	0.00053	
- $u^2(qV,w)/q^2V,w$	-	0.00116	
- $u^2(qV,w)$	-	19713	
- $u(qV,w)$	-	140.4	
Standard uncertainty associated with the volume flow rate (95% Confidence), relative	$U_{c,rel}(qV,w)$	6.68	%

# APPENDIX 2

## SULPHUR DIOXIDE: RESULTS SUMMARY

Vale Bio-Energy, Llancafarn  
Engine 1

### Sample Runs

Parameter	Units	Run 1	Mean
Concentration	mg/m <sup>3</sup>	223	223
Uncertainty	±mg/m <sup>3</sup>	17.8	17.8
Mass Emission	g/hr	353	353
Uncertainty	±g/hr	36.8	36.8

Parameter	Units	Run 1	Mean
Water Vapour	% v/v	15.4	15.4
Uncertainty	±% v/v	0.69	0.69

### Blank Runs

Parameter	Units	Blank 1	Maximum
Concentration	mg/m <sup>3</sup>	< 0.16	< 0.16

### General Sampling Information

Parameter	Value
Standard	EN 14791
Technical Procedure	CAT-TP-09
Name of Analytical Laboratory	EET
Analytical Laboratory's Procedure	CAT-AP-01
ISO 17025 Accredited Analysis?	MCERTS
Date of Sample Analysis	17/03/2021
Probe Material	Titanium
Filter Housing Material	Titanium
Impinger Material	Polyethylene
Absorption Solution	0.3% Hydrogen Peroxide
Positioning of Filter	Out Stack Heated Head
Filter Size and Material	0.1µm Glass Fibre
Number of Sampling Lines Used	1/1
Number of Sampling Points Used	1/1
Sample Point I.D.'s	A1

FORMAT: Number Used / Number Required  
FORMAT: Number Used / Number Required

### Reference Conditions

Reference Conditions are: 273K, 101.3kPa, dry gas, 5% oxygen.

## SULPHUR DIOXIDE: SAMPLING DETAILS

### Sample Runs

Parameter	Units	Run 1
Sampling Times	-	11:20 - 12:20
Sampling Dates	-	12/03/2021
Sampling Device	-	MFC / MV
Duration	mins	60
Volume Sampled (STP, Dry)	m <sup>3</sup>	0.1192
Volume Sampled (STP, Wet)	m <sup>3</sup>	0.1409
Volume Sampled (REF)	m <sup>3</sup>	0.0925
Sample Flow Rate	l/min	1.91
Laboratory Result for Front Impingers	µg/ml	96.87
Laboratory Result for Back Impinger	µg/ml	0.32
Volume in Front Impingers	ml	212.4
Volume in Back Impinger	ml	102.3
Mass in Front Impingers	µg	20575.2
Mass in Back Impinger	µg	32.7
Total Mass Collected	µg	20607.9
Calculated Concentration	mg/m <sup>3</sup>	222.70
Liquid Trap Start Mass	g	1536.1
Liquid Trap End Mass	g	1549.1
Silica Trap Start Mass	g	1441.6
Silica Trap End Mass	g	1446.0
Total Mass Of Water Vapour	g	17.4
Calculated Water Vapour	% v/v	15.39

**Where:** MFC stands for Mass Flow Controller, MV stands for Mass View Flowmeter

### Blank Runs

Parameter	Units	Blank 1
Blank Dates	-	11/12/2021
Average Volume Sampled (REF)	m <sup>3</sup>	0.0925
Laboratory Result for Impingers	µg/ml	< 0.05
Volume in Impingers	ml	304.7
Total Mass Collected	µg	< 15.2
Calculated Concentration	mg/m <sup>3</sup>	< 0.16



## SULPHUR DIOXIDE: QUALITY ASSURANCE

### Sample Runs

Leak Test Results	Units	Run 1	
Mean Sampling Rate	l/min	1.9	
Pre-Sampling Leak Rate	l/min	0.00	
Post-Sampling Leak Rate	l/min	0.00	
Allowable Leak Rate	l/min	0.04	
Leak Test Acceptable	-	Yes	
Absorption Efficiency	Units	Run 1	
Absorption Efficiency	%	99.8	
Allowable Absorption Efficiency	%	95	
Absorption Efficiency Acceptable	-	Yes	
Water Droplets	Units	Run 1	
Are Water Droplets Present	-	No	
MU (Concurrent Water Vapour)	Units	Run 1	
Measurement Uncertainty (MU)	%	4.5	
Allowable MU	%	20.0	
MU Acceptable	%	Yes	
Silica Gel (Concurrent Water Vapour)	Units	Run 1	
Less than 50% Faded	%	Yes	
Test Conditions	Units	Run 1	
Ambient Temperature Recorded?	-	Yes	

### Blank Runs

Leak Test Results	Units	Blank 1	
Expected Sampling Rate	l/min	2.0	
Pre-Sampling Leak Rate	l/min	0.00	
Post-Sampling Leak Rate	l/min	0.00	
Allowable Leak Rate	l/min	0.04	
Leak Test Acceptable	-	Yes	
Validity of Blank vs ELV	Units	Blank 1	
Allowable Blank	mg/m <sup>3</sup>	35.0	
Blank Acceptable	-	Yes	

### Method Deviations

Nature of Deviation	Run Number
(x = deviation applies to the associated run, wx = deviation also applies to the concurrent water vapour run)	1
There are no deviations associated with the sampling employed.	wx

## SULPHUR DIOXIDE: MEASUREMENT UNCERTAINTY CALCULATIONS

Measured Quantities	Value		Standard uncertainty		
	Symbol	Run 1	Symbol	Units	Run 1
Sampled Volume (STP)	$V_m$	0.1192	$uV_m$	m <sup>3</sup>	0.0024
Leak	L	0.00	$uL$	%	-
Laboratory Result	$L_r$	2.90	$uL_r$	%	-

Uncertainty as a Percentage				Requirement of Standard
Measured Quantities	Units	Run 1		
Sampled Volume (STP)	%	2.00		≤2%
Leak	%	0.00		≤2%
Laboratory Result	%	2.90		No Requirement

Uncertainty in Measurement Units				Sensitivity Coefficient	
Measured Quantities	Symbol	Units	Run 1	Run 1	
Sampled Volume (STP)	$V_m$	m <sup>3</sup>	0.1192	1868.26	
Leak	L	mg/m <sup>3</sup>	0.000	1.00	
Laboratory Result	$L_r$	mg/m <sup>3</sup>	6.458	1.00	

Uncertainty in Result			
Measured Quantities	Units	Run 1	
Sampled Volume (STP)	mg/m <sup>3</sup>	4.454	
Leak	mg/m <sup>3</sup>	0.0000	
Laboratory Result	mg/m <sup>3</sup>	6.4583	

Oxygen Correction Part of MU Budget			
Measured Quantities	Units	Run 1	
O <sub>2</sub> Correction Factor	-	1.29	
Stack Gas O <sub>2</sub> Content	% v/v	8.58	
MU for O <sub>2</sub> Correction	-	0.05	
Overall MU For O <sub>2</sub> Measurement	%	4.03	

Parameter	Units	Run 1	
Combined uncertainty	mg/m <sup>3</sup>	7.85	
Expanded uncertainty (95% confidence), without Oxygen Correction	mg/m <sup>3</sup>	15.38	
Expanded uncertainty (95% confidence), with Oxygen Correction	mg/m <sup>3</sup>	17.80	
Expanded uncertainty (95% confidence), estimated with Method Deviations	mg/m <sup>3</sup>	17.80	
Reported Uncertainty	mg/m <sup>3</sup>	17.80	
Expanded uncertainty (95% confidence), without Oxygen Correction	%	6.9	
Expanded uncertainty (95% confidence), with Oxygen Correction	%	8.0	
Expanded uncertainty (95% confidence), estimated with Method Deviations	%	8.0	
Reported Uncertainty	%	8.0	

## TOTAL VOCs (as CARBON): RESULTS SUMMARY

Vale Bio-Energy, Llancafarn  
Engine 1

### Sample Runs

Parameter	Units	Run 1		Mean
Concentration	mg/m <sup>3</sup>	1109		1109
Uncertainty	±mg/m <sup>3</sup>	45.8		45.8
Mass Emission	g/hr	1760		1760
Uncertainty	±g/hr	138		138

### General Sampling Information

Parameter	Value
Standard	EN 12619:2013
Technical Procedure	CAT-TP-20
Probe Material	Titanium
Filtration Type / Size	0.1µm Glass Fibre
Heated Head Filter Used	Yes
Heated Line Temperature	180°C
Span Gas Type	Propane in 7% O <sub>2</sub> in N <sub>2</sub> (5 Grade)
Span Gas Reference Number	12.300 in N <sub>2</sub>   1.0290a in AIR
Span Gas Expiry Date	15/05/2022   09/09/2021
Span Gas Start Pressure (bar)	95   10
Gas Cylinder Concentration (ppm)	811.4   800
Span Gas Set Point (ppm)	807.60
Span Gas Uncertainty (%)	2   2
Zero Gas Type	7% O <sub>2</sub> in N <sub>2</sub> (5 Grade)
Number of Sampling Lines Used	1/1
Number of Sampling Points Used	1/1
Sample Point I.D.'s	A1

This is the blended concentration of both propane cylinders

FORMAT: Number Used / Number Required


FORMAT: Number Used / Number Required

### Reference Conditions

Reference Conditions are: 273K, 101.3kPa, dry gas, 5% oxygen.

TOTAL VOCs (as CARBON): DATA TREND

Graphical Trend of Data



## TOTAL VOCs (as CARBON): SAMPLING DETAILS & QUALITY ASSURANCE

### Sampling Details

Parameter	Units	Run 1	
Sampling Times	-	11:20 - 12:20	
Sampling Dates	-	12/03/2021	
Instrument Range	ppm	1000	
Span Gas Value	ppm	807.6	

### Quality Assurance

	Zero Drift	Units	Run 1	
CAL 1	Zero Down Sampling Line (Pre)	ppm	2.00	
	Zero Down Sampling Line (Post)	ppm	0.00	
	Zero Drift	ppm	-2.00	
	Allowable Zero Drift	± ppm	40.38	
	Zero Drift Acceptable	-	Yes	

	Span Drift	Units	Run 1	
CAL 1	Span Down Sampling Line (Pre)	ppm	805.00	
	Span Down Sampling Line (Post)	ppm	813.00	
	Span Drift	ppm	8.00	
	Allowable Span Drift	± ppm	40.38	
	Span Drift Acceptable	-	Yes	

Test Conditions	Units	Run 1	
Run Ambient Temperature Range	°C	6 - 8	

### Method Deviations

Nature of Deviation	Run Number
(x = deviation applies to the associated run)	1
There are no deviations associated with the sampling employed.	x

## TOTAL VOCs (as CARBON): MEASUREMENT UNCERTAINTY CALCULATIONS

Performance characteristics	RUN 1	Units
Limit value	1000.0	mg/m <sup>3</sup> (REF)
Allowable MU	15.0	%
Measured concentration	860.49	mg/m <sup>3</sup> (STP, dry)
Range Used	1000.0	ppm
Range Used [A]	1606.1	mg/m <sup>3</sup>
Cal gas conc.	807.6	ppm
Conversion	1.61	ppm to mg/m <sup>3</sup>
MCERTS Range [B]	15.0	mg/m <sup>3</sup>
Lower of [A] or [B]	15.0	mg/m <sup>3</sup>
Cal gas conc.	1297.1	mg/m <sup>3</sup>

Performance characteristics	RUN 1	Units
Response time	45	seconds
Number of readings in measurement	60	-
Repeatability at zero	2.00	% full scale
Repeatability at span level	0.00	% full scale
Deviation from linearity	0.20	% of value
Zero drift	-0.25	% full scale
Span drift	0.99	% full scale
Volume or pressure flow dependence	1.60	% of full scale
Atmospheric pressure dependence	0.30	% of value/kPa
Ambient temperature dependence	1.40	% full scale/10K
Combined interference	0.45	% range
Dependence on voltage	0.50	% full scale/10V
Losses in the line (leak)	0.74	% of value
Uncertainty of calibration gas	2.83	% of value

Performance characteristic	RUN 1	Units
Standard deviation of repeatability at zero	use rep at span	mg/m <sup>3</sup>
Standard deviation of repeatability at span level	0.00	mg/m <sup>3</sup>
Lack of fit	0.02	mg/m <sup>3</sup>
Drift	0.00	mg/m <sup>3</sup>
Volume or pressure flow dependence	0.00	mg/m <sup>3</sup>
Atmospheric pressure dependence	0.01	mg/m <sup>3</sup>
Ambient temperature dependence	0.20	mg/m <sup>3</sup>
Combined interference (from MCERTS Certificate)	0.04	mg/m <sup>3</sup>
Dependence on voltage	0.06	mg/m <sup>3</sup>
Losses in the line (leak)	3.69	mg/m <sup>3</sup>
Uncertainty of calibration gas	14.05	mg/m <sup>3</sup>

Measurement uncertainty	Result	RUN 1	Units
Combined uncertainty		860.49	mg/m <sup>3</sup>
Expanded uncertainty		14.53	mg/m <sup>3</sup>
Expanded uncertainty	k = 1.96	28.48	mg/m <sup>3</sup>
Uncertainty corrected to std conds. (O <sub>2</sub> )		36.71	mg/m <sup>3</sup> (REF)

	RUN 1	Units
Expanded uncertainty (no O <sub>2</sub> ) - at 95% Confidence	3.31	% of Value
Expanded uncertainty (no O <sub>2</sub> ) - at 95% Confidence	2.85	% at ELV
Overall Allowable uncertainty (no O <sub>2</sub> ) - at 95% Confidence	15.0	% at ELV
<b>Result of Compliance with Uncertainty Requirement</b>	<b>N/A</b>	-

	RUN 1	Units
Expanded uncertainty (with O <sub>2</sub> ) - at 95% Confidence	4.12	% of Value
Expanded uncertainty (with O <sub>2</sub> ) - at 95% Confidence	4.42	% at ELV
Overall Allowable uncertainty (with O <sub>2</sub> ) - at 95% Confidence	15.2	% at ELV
<b>Result of Compliance with Uncertainty Requirement</b>	<b>COMPLIANT</b>	-

Requirement for SRM is that Uncertainty should be <15% of the value at the ELV, on a dry gas basis, or if O<sub>2</sub> correction is applied less than 15% + the uncertainty associated with the O<sub>2</sub> correction (using sqrt of sum squares to add uncertainty components).

## OXIDES OF NITROGEN (as NO<sub>2</sub>): RESULTS SUMMARY

Vale Bio-Energy, Llancafarn  
Engine 1

### Sample Runs

Parameter	Units	Run 1	Mean
Concentration	mg/m <sup>3</sup>	409	409
Uncertainty	±mg/m <sup>3</sup>	15.6	15.6
Mass Emission	g/hr	649	649
Uncertainty	±g/hr	50.0	50.0

### General Sampling Information

Parameter	Value
Standard	EN 14792
Technical Procedure	CAT-TP-39
Probe Material	Titanium
Filtration Type / Size	0.1µm Glass Fibre
Heated Head Filter Used	Yes
Heated Line Temperature	180°C
Date & Result of Last Converter Check	21/07/2020 - 95.7%
Span Gas Type	Nitrogen Monoxide
Span Gas Reference Number	12.0300
Span Gas Expiry Date	15/05/2022
Span Gas Start Pressure (bar)	100
Gas Cylinder Concentration (ppm)	2063
Span Gas Uncertainty (%)	2
Zero Gas Type	Nitrogen (5 Grade)
Number of Sampling Lines Used	1/1
Number of Sampling Points Used	1/1
Sample Point I.D.'s	A1

NOTE: Dilution performed to achieve correct span value

FORMAT: Number Used / Number Required


FORMAT: Number Used / Number Required

### Reference Conditions

Reference Conditions are: 273K, 101.3kPa, dry gas, 5% oxygen.

OXIDES OF NITROGEN (as NO<sub>2</sub>): DATA TREND

Graphical Trend of Data





## APPENDIX 2

### OXIDES OF NITROGEN (as NO<sub>2</sub>): SAMPLING DETAILS & QUALITY ASSURANCE

#### Sampling Details

Parameter	Units	Run 1
Sampling Times	-	11:20 - 12:20
Sampling Dates	-	12/03/2021
Instrument Range	ppm	500
Span Gas Value	ppm	243.6

#### Quality Assurance

Conditioning Unit Temperature	Units	Run 1
Average Temperature	°C	2.1
Allowable Temperature	< °C	4.0
Temperature Acceptable	-	Yes

Zero Drift	Units	Run 1
Zero at Analyser (Pre)	ppm	0.00
Zero at Analyser (Post)	ppm	2.00
Zero Drift	ppm	2.00
Zero Drift	%	0.82
Drift Correction Applied	2-5%	No
Allowable Zero Drift	± %	5.00
Zero Drift Acceptable	-	Yes

Span Drift	Units	Run 1
Span at Analyser (Pre)	ppm	243.60
Span at Analyser (Post)	ppm	241.20
Span Drift	ppm	-2.40
Zero Adj. Span Drift	%	1.81
Drift Correction Applied	2-5%	No
Allowable Span Drift	± %	5.00
Span Drift Acceptable	-	Yes

Test Conditions	Units	Run 1
Run Ambient Temperature Range	°C	6 - 8

#### Method Deviations

Nature of Deviation	Run Number
(x = deviation applies to the associated run)	1
There are no deviations associated with the sampling employed.	x

## OXIDES OF NITROGEN (as NO<sub>2</sub>): MEASUREMENT UNCERTAINTY CALCULATIONS

Performance characteristics	RUN 1	Units
Limit value	500.0	mg/m <sup>3</sup> (REF)
Allowable MU	10.0	%
Measured concentration	317.66	mg/m <sup>3</sup> (STP, dry)
Ratio NO / NO <sub>2</sub>	5	%
Range Used	500.0	ppm
Range Used [A]	1026.1	mg/m <sup>3</sup>
Cal gas conc.	243.6	ppm
Conversion	2.05	ppm to mg/m <sup>3</sup>
MCERTS Range [B]	205.0	mg/m <sup>3</sup>
Lower of [A] or [B]	205.0	mg/m <sup>3</sup>
Cal gas conc.	500.0	mg/m <sup>3</sup>

Performance characteristics	RUN 1	Units
Response time	31	seconds
Number of readings in measurement	60	-
Repeatability at zero	0.00	% full scale
Repeatability at span level	0.10	% full scale
Deviation from linearity	0.60	% of value
Zero drift	0.82	% full scale
Span drift	-1.81	% full scale
Volume or pressure flow dependence	0.10	% of full scale
Atmospheric pressure dependence	0.10	% of value/kPa
Ambient temperature dependence	0.04	% full scale/10K
Combined interference	0.63	% range
Dependence on voltage	-0.23	% full scale/10V
Converter efficiency	95.7	%
Losses in the line (leak)	0.45	% of value
Uncertainty of calibration gas blending	1.40	% of value
Uncertainty of calibration gas	2.00	% of value

Performance characteristic	RUN 1	Units
Standard deviation of repeatability at zero	use rep at span	mg/m <sup>3</sup>
Standard deviation of repeatability at span level	0.01	mg/m <sup>3</sup>
Lack of fit	0.71	mg/m <sup>3</sup>
Drift	0.00	mg/m <sup>3</sup>
Volume or pressure flow dependence	0.00	mg/m <sup>3</sup>
Atmospheric pressure dependence	0.06	mg/m <sup>3</sup>
Ambient temperature dependence	0.01	mg/m <sup>3</sup>
Combined interference (from MCERTS Certificate)	0.75	mg/m <sup>3</sup>
Dependence on voltage	-0.03	mg/m <sup>3</sup>
Converter efficiency	0.39	mg/m <sup>3</sup>
Losses in the line (leak)	0.83	mg/m <sup>3</sup>
Uncertainty of calibration gas blending	2.57	mg/m <sup>3</sup>
Uncertainty of calibration gas	3.67	mg/m <sup>3</sup>

Measurement uncertainty	Result	RUN 1	Units
Combined uncertainty		317.66	mg/m <sup>3</sup>
Expanded uncertainty		4.74	mg/m <sup>3</sup>
Expanded uncertainty	k = 1.96	9.30	mg/m <sup>3</sup>
Uncertainty corrected to std conds. (O <sub>2</sub> )		11.98	mg/m <sup>3</sup> (REF)

	RUN 1	Units
Expanded uncertainty (no O <sub>2</sub> ) - at 95% Confidence	2.93	% of Value
Expanded uncertainty (no O <sub>2</sub> ) - at 95% Confidence	1.86	% at ELV
Overall Allowable uncertainty (no O <sub>2</sub> ) - at 95% Confidence	10.0	% at ELV
<b>Result of Compliance with Uncertainty Requirement</b>	<b>N/A</b>	-

	RUN 1	Units
Expanded uncertainty (with O <sub>2</sub> ) - at 95% Confidence	3.82	% of Value
Expanded uncertainty (with O <sub>2</sub> ) - at 95% Confidence	3.43	% at ELV
Overall Allowable uncertainty (with O <sub>2</sub> ) - at 95% Confidence	10.3	% at ELV
<b>Result of Compliance with Uncertainty Requirement</b>	<b>COMPLIANT</b>	-

Requirement for SRM is that Uncertainty should be <10% of the value at the ELV, on a dry gas basis, or if O<sub>2</sub> correction is applied less than 10% + the uncertainty associated with the O<sub>2</sub> correction (using sqrt of sum squares to add uncertainty components).

### CARBON MONOXIDE: RESULTS SUMMARY

Vale Bio-Energy, Llancafarn  
Engine 1

#### Sample Runs

Parameter	Units	Run 1	Mean
Concentration	mg/m <sup>3</sup>	902	902
Uncertainty	±mg/m <sup>3</sup>	33.8	33.8
Mass Emission	g/hr	1431	1431
Uncertainty	±g/hr	110	109.6

#### General Sampling Information

Parameter	Value
Standard	EN 15058
Technical Procedure	CAT-TP-39
Probe Material	Titanium
Filtration Type / Size	0.1µm Glass Fibre
Heated Head Filter Used	Yes
Heated Line Temperature	180°C
Span Gas Type	Carbon Monoxide
Span Gas Reference Number	12.300
Span Gas Expiry Date	15/05/2022
Span Gas Start Pressure (bar)	100
Gas Cylinder Concentration (ppm)	4029
Span Gas Uncertainty (%)	2
Zero Gas Type	Nitrogen (5 Grade)
Number of Sampling Lines Used	1/1
Number of Sampling Points Used	1/1
Sample Point I.D.'s	A1

NOTE: Dilution performed to achieve correct span value

FORMAT: Number Used / Number Required


FORMAT: Number Used / Number Required

#### Reference Conditions

Reference Conditions are: 273K, 101.3kPa, dry gas, 5% oxygen.

CARBON MONOXIDE: DATA TREND

Graphical Trend of Data



## APPENDIX 2

### CARBON MONOXIDE: SAMPLING DETAILS & QUALITY ASSURANCE

#### Sampling Details

Parameter	Units	Run 1
Sampling Times	-	11:20 - 12:20
Sampling Dates	-	12/03/2021
Instrument Range	ppm	2000
Span Gas Value	ppm	1120.7

#### Quality Assurance

Conditioning Unit Temperature	Units	Run 1
Average Temperature	°C	2.1
Allowable Temperature	< °C	4.0
Temperature Acceptable	-	Yes

Zero Drift	Units	Run 1
Zero at Analyser (Pre)	ppm	0.00
Zero at Analyser (Post)	ppm	1.00
Zero Drift	ppm	1.00
Zero Drift	%	0.09
Drift Correction Applied	2-5%	No
Allowable Zero Drift	± %	5.00
Zero Drift Acceptable	-	Yes

Span Drift	Units	Run 1
Span at Analyser (Pre)	ppm	1121.00
Span at Analyser (Post)	ppm	1105.00
Span Drift	ppm	-16.00
Zero Adj. Span Drift	%	1.52
Drift Correction Applied	2-5%	No
Allowable Span Drift	± %	5.00
Span Drift Acceptable	-	Yes

Test Conditions	Units	Run 1
Run Ambient Temperature Range	°C	6 - 8

#### Method Deviations

Nature of Deviation	Run Number
(x = deviation applies to the associated run)	1
There are no deviations associated with the sampling employed.	x

## CARBON MONOXIDE: MEASUREMENT UNCERTAINTY CALCULATIONS

Performance characteristics	RUN 1	Units
Limit value	1400.0	mg/m <sup>3</sup> (REF)
Allowable MU	6.0	%
Measured concentration	700.18	mg/m <sup>3</sup> (STP, dry)
Range Used	2000.0	ppm
Range Used [A]	2498.4	mg/m <sup>3</sup>
Cal gas conc.	1120.7	ppm
Conversion	1.25	ppm to mg/m <sup>3</sup>
MCERTS Range [B]	75.0	mg/m <sup>3</sup>
Lower of [A] or [B]	75.0	mg/m <sup>3</sup>
Cal gas conc.	1400.0	mg/m <sup>3</sup>

Performance characteristics	RUN 1	Units
Response time	28	seconds
Number of readings in measurement	60	-
Repeatability at zero	0.10	% full scale
Repeatability at span level	0.20	% full scale
Deviation from linearity	0.77	% of value
Zero drift	0.09	% full scale
Span drift	-1.52	% full scale
Volume or pressure flow dependence	0.10	% of full scale
Atmospheric pressure dependence	0.22	% of value/kPa
Ambient temperature dependence	-0.20	% full scale/10K
Combined interference	-0.48	% range
Dependence on voltage	-0.35	% full scale/10V
Losses in the line (leak)	0.54	% of value
Uncertainty of calibration gas blending	1.40	% of value
Uncertainty of calibration gas	2.00	% of value

Performance characteristic	RUN 1	Units
Standard deviation of repeatability at zero	use rep at span	mg/m <sup>3</sup>
Standard deviation of repeatability at span level	0.03	mg/m <sup>3</sup>
Lack of fit	0.33	mg/m <sup>3</sup>
Drift	0.00	mg/m <sup>3</sup>
Volume or pressure flow dependence	0.00	mg/m <sup>3</sup>
Atmospheric pressure dependence	0.05	mg/m <sup>3</sup>
Ambient temperature dependence	-0.03	mg/m <sup>3</sup>
Combined interference (from MCERTS Certificate)	-0.21	mg/m <sup>3</sup>
Dependence on voltage	-0.04	mg/m <sup>3</sup>
Losses in the line (leak)	2.16	mg/m <sup>3</sup>
Uncertainty of calibration gas blending	5.66	mg/m <sup>3</sup>
Uncertainty of calibration gas	8.09	mg/m <sup>3</sup>

Measurement uncertainty	Result	RUN 1	Units
Combined uncertainty		700.18	mg/m <sup>3</sup>
Expanded uncertainty		10.11	mg/m <sup>3</sup>
Expanded uncertainty	k = 1.96	19.82	mg/m <sup>3</sup>
Uncertainty corrected to std conds. (O <sub>2</sub> )		25.53	mg/m <sup>3</sup> (REF)

	RUN 1	Units
Expanded uncertainty (no O <sub>2</sub> ) - at 95% Confidence	2.83	% of Value
Expanded uncertainty (no O <sub>2</sub> ) - at 95% Confidence	1.42	% at ELV
Overall Allowable uncertainty (no O <sub>2</sub> ) - at 95% Confidence	6.0	% at ELV
<b>Result of Compliance with Uncertainty Requirement</b>	<b>N/A</b>	-

	RUN 1	Units
Expanded uncertainty (with O <sub>2</sub> ) - at 95% Confidence	3.75	% of Value
Expanded uncertainty (with O <sub>2</sub> ) - at 95% Confidence	3.06	% at ELV
Overall Allowable uncertainty (with O <sub>2</sub> ) - at 95% Confidence	6.5	% at ELV
<b>Result of Compliance with Uncertainty Requirement</b>	<b>COMPLIANT</b>	-

Requirement for SRM is that Uncertainty should be <6% of the value at the ELV, on a dry gas basis, or if O<sub>2</sub> correction is applied less than 6% + the uncertainty associated with the O<sub>2</sub> correction (using sqrt of sum squares to add uncertainty components).

OXYGEN: RESULTS SUMMARY

Vale Bio-Energy, Llanccarfan  
Engine 1

Sample Runs

Parameter	Units	Run 1	Mean
Concentration	% v/v	8.6	8.6
Uncertainty	±% v/v	0.21	0.21

General Sampling Information

Parameter	Value
Standard	EN 14789
Technical Procedure	CAT-TP-39
Probe Material	Titanium
Filtration Type / Size	0.1µm Glass Fibre
Heated Head Filter Used	Yes
Heated Line Temperature	180°C
Span Gas Type	Synthetic Air (5 Grade)
Span Gas Reference Number	11.0427
Span Gas Expiry Date	#####
Span Gas Start Pressure (bar)	120
Gas Cylinder Concentration (% v/v)	21.25
Span Gas Uncertainty (%)	2
Zero Gas Type	Nitrogen (5 Grade)
Number of Sampling Lines Used	1/1
Number of Sampling Points Used	1/1
Sample Point I.D.'s	A1


NOTE: Dilution performed to achieve correct span value

FORMAT: Number Used / Number Required

FORMAT: Number Used / Number Required

OXYGEN: DATA TREND

Graphical Trend of Data





## APPENDIX 2

### OXYGEN: SAMPLING DETAILS & QUALITY ASSURANCE

#### Sampling Details

Parameter	Units	Run 1
Sampling Times	-	11:20 - 12:20
Sampling Dates	-	12/03/2021
Instrument Range	% v/v	25.0
Span Gas Value	% v/v	5.0

#### Quality Assurance

Conditioning Unit Temperature	Units	Run 1
Average Temperature	°C	2.1
Allowable Temperature	< °C	4.0
Temperature Acceptable	-	Yes

Zero Drift	Units	Run 1
Zero at Analyser (Pre)	% v/v	0.00
Zero at Analyser (Post)	% v/v	0.20
Zero Drift	% v/v	0.20
Zero Drift	%	3.98
Drift Correction Applied	2-5%	Yes
Allowable Zero Drift	± %	5.00
Zero Drift Acceptable	-	Yes

Span Drift	Units	Run 1
Span at Analyser (Pre)	% v/v	5.02
Span at Analyser (Post)	% v/v	5.08
Span Drift	% v/v	0.06
Zero Adj. Span Drift	%	2.80
Drift Correction Applied	2-5%	Yes
Allowable Span Drift	± %	5.00
Span Drift Acceptable	-	Yes

Test Conditions	Units	Run 1
Run Ambient Temperature Range	°C	6 - 8

#### Method Deviations

Nature of Deviation	Run Number
(x = deviation applies to the associated run)	1
There are no deviations associated with the sampling employed.	x

APPENDIX 2

OXYGEN: MEASUREMENT UNCERTAINTY CALCULATIONS

Performance characteristics	RUN 1	Units
Limit value	N/A	%vol
Allowable MU	6.0	%
Measured concentration	8.58	%vol
Range Used	25.0	%vol
Cal gas conc.	21.3	%vol

Performance characteristics	RUN 1	Units
Response time	41	seconds
Number of readings in measurement	60	-
Repeatability at zero	0.02	% full scale
Repeatability at span level	0.02	% full scale
Deviation from linearity	0.18	% of value
Zero drift	0.00	% full scale
Span drift	0.00	% full scale
Volume or pressure flow dependence	0.10	% of full scale
Atmospheric pressure dependence	0.19	% of value/kPa
Ambient temperature dependence	-0.21	% full scale/10K
Combined interference	0.00	% range
Dependence on voltage	0.02	% full scale/10V
Losses in the line (leak)	0.00	% of value
Uncertainty of calibration gas	2.00	% of value

Performance characteristic	RUN 1	Units
Standard deviation of repeatability at zero	use rep at span	%vol
Standard deviation of repeatability at span level	0.00	%vol
Lack of fit	0.03	%vol
Drift	0.00	%vol
Volume or pressure flow dependence	0.00	%vol
Atmospheric pressure dependence	0.01	%vol
Ambient temperature dependence	-0.03	%vol
Combined interference (from MCERTS Certificate)	0.00	%vol
Dependence on voltage	0.00	%vol
Losses in the line (leak)	0.00	%vol
Uncertainty of calibration gas	0.10	%vol

Measurement uncertainty	Result	RUN 1	Units
Combined uncertainty		8.58	%vol
Expanded uncertainty		0.11	%vol
	k = 1.96	0.21	%vol

	RUN 1	Units
Expanded uncertainty (no O <sub>2</sub> ) - at 95% Confidence	2.46	% of Value
Result of Compliance with Uncertainty Requirement	COMPLIANT	-

Requirement for SRM is that Uncertainty should be 0.3% vol absolute or 6% relative whichever is the lower, on a dry gas basis. Source, EN 14789.

Version Number	Record of changes made within this version of the document
V1	The original document issued to the client