

Permit Reference Number: BL3986ID

Operator: Tarmac Cement & Lime Ltd

Installation: Aberthaw Works

Form Number: Water 1 / 19/07/16

**Quarterly Reporting of Emissions to Surface Water – Emission Points W1 & W2  
for the period 01/01/17 to 31/01/17**

Emission Point	Parameter	Emission Limit Value	Result	Date of Measurement	Method
W1	pH (minimum)	6	8.2	12.01.2017	BS ISO10523
W1	pH (maximum)	9	-	-	BS ISO10523
W1	Total Suspended Solids (Maximum)	50 mg/l	18 mg/l	12.01.2017	BS EN 872
W1	Oil or Grease	None Present	None Visible	12.01.2017	Visual Check
W2	pH (minimum)	6	-	-	BS ISO10523
W2	pH (maximum)	9	-	-	BS ISO10523
W2	Total Suspended Solids (Maximum)	50 mg/l	-	-	BS EN 872
W2	Oil or Grease	None Present	-	-	Visual Check

Signed : K. Bennett  
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)

Date :26.04.2017

28 APR 2017

Permit Reference Number: BL3986ID

Operator: Tarmac Cement & Lime Ltd

Installation: Aberthaw Works

Form Number: Water 1 / 19/07/16

**Quarterly Reporting of Emissions to Surface Water – Emission Points W1 & W2  
for the period 01/02/17 to 28/02/17**

Emission Point	Parameter	Emission Limit Value	Result	Date of Measurement	Method
W1	pH (minimum)	6	7.9	13.02.2017	BS ISO10523
W1	pH (maximum)	9	-	-	BS ISO10523
W1	Total Suspended Solids (Maximum)	50 mg/l	7.0 mg/l	13.02.2017	BS EN 872
W1	Oil or Grease	None Present	None Visible	13.02.2017	Visual Check
W2	pH (minimum)	6	-	-	BS ISO10523
W2	pH (maximum)	9	-	-	BS ISO10523
W2	Total Suspended Solids (Maximum)	50 mg/l	-	-	BS EN 872
W2	Oil or Grease	None Present	-	-	Visual Check

Signed : K. Bennett  
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)  
Date :27.04.2017

Permit Reference Number: BL3986ID

Installation: Aberthaw Works

Operator: Tarmac Cement & Lime Ltd

Form Number: Water 1 / 19/07/16

**Quarterly Reporting of Emissions to Surface Water – Emission Points W1 & W2  
for the period 01/03/17 to 31/03/17**

Emission Point	Parameter	Emission Limit Value	Result	Date of Measurement	Method
W1	pH (minimum)	6	8.3	13.03.2017	BS ISO10523
W1	pH (maximum)	9	-	-	BS ISO10523
W1	Total Suspended Solids (Maximum)	50 mg/l	18 mg/l	13.03.2017	BS EN 872
W1	Oil or Grease	None Present	None Visible	13.03.2017	Visual Check
W2	pH (minimum)	6	8.3	13.03.2017	BS ISO10523
W2	pH (maximum)	9	-	-	BS ISO10523
W2	Total Suspended Solids (Maximum)	50 mg/l	13 mg/l	13.03.2017	BS EN 872
W2	Oil or Grease	None Present	None Visible	13.03.2017	Visual Check

Signed : K. Bennett  
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)

Date :27.04.2017