

Permit Reference Number: BL3986ID

Operator: Tarmac Cement & Lime Ltd

Installation: Aberthaw Works

Form Number: Water 1 / 19/07/16

**Quarterly Reporting of Emissions to Surface Water – Emission Points W1 & W2  
for the period 01/07/16 to 31/07/16**

<b>Emission Point</b>	<b>Parameter</b>	<b>Emission Limit Value</b>	<b>Result</b>	<b>Date of Measurement</b>	<b>Method</b>
W1	pH (minimum)	6	7.6	12.07.2016	BS ISO10523
W1	pH (maximum)	9	-	-	BS ISO10523
W1	Total Suspended Solids (Maximum)	50 mg/l	7.0 mg/l	12.07.2016	BS EN 872
W1	Oil or Grease	None Present	None Visible	12.07.2016	Visual Check
W2	pH (minimum)	6	-	-	BS ISO10523
W2	pH (maximum)	9	-	-	BS ISO10523
W2	Total Suspended Solids (Maximum)	50 mg/l	-	-	BS EN 872
W2	Oil or Grease	None Present	-	-	Visual Check

Signed : K. Bennett  
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)

Date :14.06.2017

Permit Reference Number: BL3986ID

Operator: Tarmac Cement & Lime Ltd

Installation: Aberthaw Works

Form Number: Water 1 / 19/07/16

**Quarterly Reporting of Emissions to Surface Water – Emission Points W1 & W2  
for the period 01/08/16 to 31/08/16**

<b>Emission Point</b>	<b>Parameter</b>	<b>Emission Limit Value</b>	<b>Result</b>	<b>Date of Measurement</b>	<b>Method</b>
<b>W1</b>	pH (minimum)	6	7.3	12.08.2016	BS ISO10523
<b>W1</b>	pH (maximum)	9	-	-	BS ISO10523
<b>W1</b>	Total Suspended Solids (Maximum)	50 mg/l	13 mg/l	12.08.2016	BS EN 872
<b>W1</b>	Oil or Grease	None Present	None Visible	12.08.2016	Visual Check
<b>W2</b>	pH (minimum)	6	-	-	BS ISO10523
<b>W2</b>	pH (maximum)	9	-	-	BS ISO10523
<b>W2</b>	Total Suspended Solids (Maximum)	50 mg/l	-	-	BS EN 872
<b>W2</b>	Oil or Grease	None Present	-	-	Visual Check

Signed : K. Bennett  
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)

Date :14.06.2017

Permit Reference Number: BL3986ID

Operator: Tarmac Cement & Lime Ltd

Installation: Aberthaw Works

Form Number: Water 1 / 19/07/16

**Quarterly Reporting of Emissions to Surface Water – Emission Points W1 & W2  
for the period 01/09/16 to 30/09/16**

<b>Emission Point</b>	<b>Parameter</b>	<b>Emission Limit Value</b>	<b>Result</b>	<b>Date of Measurement</b>	<b>Method</b>
<b>W1</b>	pH (minimum)	6	7.6	15.09.2016	BS ISO10523
<b>W1</b>	pH (maximum)	9	-	-	BS ISO10523
<b>W1</b>	Total Suspended Solids (Maximum)	50 mg/l	27 mg/l	15.09.2016	BS EN 872
<b>W1</b>	Oil or Grease	None Present	None Visible	15.09.2016	Visual Check
<b>W2</b>	pH (minimum)	6	-	-	BS ISO10523
<b>W2</b>	pH (maximum)	9	-	-	BS ISO10523
<b>W2</b>	Total Suspended Solids (Maximum)	50 mg/l	-	-	BS EN 872
<b>W2</b>	Oil or Grease	None Present	-	-	Visual Check

Signed : K. Bennett  
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)

Date :14.06.2017