


Permit Reference Number: BL3986ID
Installation: Aberthaw Works
Operator: Tarmac Cement & Lime Ltd
Aug-17

Kiln Report of Continuous Monitored Emissions (Emission Point A1)



Kiln	Monthly summary		Date		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
	Daily average	Monthly maximum	Daily average ELV		10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10
		Monthly minimum	Daily average Kln		3.27	3.37	3.52	3.46	3.50	3.77	4.07	3.73	5.41	5.85	5.27	3.72	3.08	3.36	3.17	3.33	3.55	3.48	3.58	3.77	3.90	3.67	3.89	3.67	3.98	3.65	3.68	3.77	3.59	4.23	4.19
		No. of invalid days	Value valid?		Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
		Total invalid 1/2 hours	No. of invalid 1/2 hours																																
	Sum of exceedances		Value exceeds ELV (Y/N)		N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed K.Bennett Date 16.10.2017
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)


FR

Permit Reference Number: BL3986ID

Operator: Tarmac Cement & Lime Ltd
Aug-17

Installation: Aberthaw Works

Kiln Report of Continuous Monitored Emissions (Emission Point A1)




Kiln																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																												
------	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--

Signed **K.Bennett** Date **16.10.2017**
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)

FR

Permit Reference Number: BL3986ID
 Installation: Aberthaw Works
 Operator: Tarmac Cement & Lime Ltd
 Aug-17
 Kiln Report of Continuous Monitored Emissions from Kiln 4 (Emission Point A8)



Kiln		Monthly summary		Date		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
Daily average						10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10
	Monthly maximum	3	1.33	1.59	1.60	1.05	1.04	0.64	0.74	0.56	2.75	1.35	0.89	3.46	0.93	1.12	1.75	1.61	2.27	1.78	1.82	1.50	1.90	1.38	2.36	1.15	1.66	1.65	1.81	1.04	1.45	2.11	2.50			
	No. of invalid days		Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y		
	Total invalid 1/2 hours																																			
	Sum of exceedances		N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	

Signed **K.Bennett** Date **16.10.2017**
 (Authorised to sign as representative of Tarmac Cement & Lime Ltd)


FR

Permit Reference Number: BL3986ID

Installation: Aberthaw Works

Operator: Tarmac Cement & Lime Ltd
Aug-17

Kiln Report of Continuous Monitored Emissions (Emission Point A1)



Kiln

Run	Monthly summary																															
	Date																															
Daily average	Daily average ELV	1500	1500	1500	1500	1500	1500	1500	1500	1500	1500	1500	1500	1500	1500	1500	1500	1500	1500	1500	1500	1500	1500	1500	1500	1500	1500	1500	1500	1500	1500	
	Monthly maximum	1314	1310	1314	1033	1123	1033	1097	1258	874	842	913	999	936	988	1090	1028	1144	1116	1184	1072	1153	1059	1190	1111	1182	1158	1166	1024	1048	1160	1078
	No. of invalid days	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Total invalid 1/2 hours																															
	Value exceeds ELV (Y/N)	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N
Sum of acceptance																																


Signed **K.Bennett** Date **16.10.2017**
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)

Permit Reference Number: BL3986ID
Installation: Aberthaw Works

Klin Report of Continuous Monitored Emissions (Emission Point A1)

Operator: Tarmac Cement & Lime Ltd

Aug-17



Klin	Monthly summary		Date		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
	Daily average	Monthly maximum	184	Daily average ELV	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400
		No. of invalid days		Daily average Klin	182	132	74	49	58	80	73	59	62	64	61	75	64	108	82	184	150	123	115	137	117	94	128	109	132	121	125	112	120	133	148
		Total invalid 1/2 hours		Value valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
		Sum of exceedances		No. of invalid 1/2 hours	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N
		Value exceeds ELV (Y/N)																																	


Signed **K.Bennett** Date **16.10.2017**
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)

FR

Permit Reference Number: BL3986ID
Operator: Tarmac Cement & Lime Ltd
Aug-17

Installation: Aberthaw Works

Kiln Report of Continuous Monitored Emissions (Emission Point A1)




Kiln

Daily average	Monthly summary		Date																																
	Monthly maximum	394	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31		
Daily average			500	500	500	500	500	500	500	500	500	500	500	500	500	500	500	500	500	500	500	500	500	500	500	500	500	500	500	500	500	500	500		
No. of invalid days			394	384	384	380	376	376	376	377	366	363	364	384	384	389	385	335	363	389	389	391	391	390	390	390	392	392	387	388	385	386	383	377	385
Total invalid 1/2 hours																																			
Sum of exceedances			N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	

Signed **K.Bennett** Date **16.10.2017**
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)

FR

Permit Reference Number: BL3986ID
 Installation: Aberthaw Works
 Operator: Tarmac Cement & Lime Ltd
 Aug-17
 Kiln Report of Continuous Monitored Emissions (Emission Point A1)



Kiln	Monthly summary		Date		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
			Daily average ELV		80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80
	Monthly maximum		Daily average Kiln		43	36	50	41	43	40	48	45	47	38	48	48	37	29	32	25	26	28	32	26	26	28	24	25	24	32	21	24	23	24	
	No. of invalid days		Value valid?		Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Total invalid 1/2 hours		No. of invalid 1/2 hours		1									1																					
Sum of exceedances		Value exceeds ELV (Y/N)		N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	


Signed: K.Bennett Date: 16.10.2017
 (Authorised to sign as representative of Tarmac Cement & Lime Ltd)

FR

Permit Reference Number: BL3986ID
Installation: Aberthaw Works

Operator: Tarmac Cement & Lime Ltd
Aug-17

Cement Mill Report of Continuous Monitored Emissions (Emission Point A2)



Cement Mill

Cement mill		Date																															
Monthly summary		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
Monthly maximum	1	0.77	0.83	1.08	1.11	1.02	1.13	0.84	1.12	1.03	1.04	0.88	0.85	0.86	0.73	0.47	0.66	0.61	0.72	0.78	0.70	0.65	0.84	0.69	0.61	0.59	0.82	0.78	0.56	0.90	0.59	0.78	
No. of invalid days		Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
Total invalid 1/2 hours																																	
Sum of exceedances		N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N
Value exceeds ELV (V/N)																																	
Value exceeds ELV (V/N)																																	

Signed: K.Bennett
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)

Date: 23.10.2017


FR

Permit Reference Number: BL3986ID

Operator: Tarmac Cement & Lime Ltd
Aug-17

Installation: Aberthaw Works

Cement Mill Separator Report of Continuous Monitored Emissions (Emission Point A3)



Cement Mill Separator

Cement Mill Separator			Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
Daily average			Daily average ELV			20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20
		6	Daily average Cement Mill Sepe			3.99	4.32	3.19	3.69	5.39	6.23	5.04	4.81	2.49	4.71	4.17	4.35	4.93	3.48	4.57	5.40	4.73	5.30	4.03	4.51	4.58	4.85	3.90	4.53	4.73	4.52	5.50	6.14	4.83	5.21	4.35	
			No. of invalid days			Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
			Total invalid 1/2 hours			No. of invalid 1/2 hours																															
			Sum of exceedances			N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed **K.Bennett** Date 23.10.2017
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)

FR