

Permit Reference Number: BL3986ID

Installation: Aberthaw Works

Operator: Tarmac Cement & Lime Ltd

Form Number: Water 1 / 19/07/16

**Quarterly Reporting of Emissions to Surface Water – Emission Points W1 & W2
for the period 01/04/17 to 30/04/17**

Emission Point	Parameter	Emission Limit Value	Result	Date of Measurement	Method
W1	pH (minimum)	6	8.2	04.04.2017	BS ISO10523
W1	pH (maximum)	9	-	-	BS ISO10523
W1	Total Suspended Solids (Maximum)	50 mg/l	<5.0 mg/l	04.04.2017	BS EN 872
W1	Oil or Grease	None Present	None Visible	04.04.2017	Visual Check
W2	pH (minimum)	6	8.2	04.04.2017	BS ISO10523
W2	pH (maximum)	9	-	-	BS ISO10523
W2	Total Suspended Solids (Maximum)	50 mg/l	<5.0 mg/l	04.04.2017	BS EN 872
W2	Oil or Grease	None Present	None Visible	04.04.2017	Visual Check

Signed : K. Bennett
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)

Date :24.07.2017

FR

Permit Reference Number: BL3986ID

Installation: Aberthaw Works

Operator: Tarmac Cement & Lime Ltd

Form Number: Water 1 / 19/07/16

**Quarterly Reporting of Emissions to Surface Water – Emission Points W1 & W2
for the period 01/05/17 to 31/05/17**

Emission Point	Parameter	Emission Limit Value	Result	Date of Measurement	Method
W1	pH (minimum)	6	8.2	17.05.2017	BS ISO10523
W1	pH (maximum)	9	-	-	BS ISO10523
W1	Total Suspended Solids (Maximum)	50 mg/l	18 mg/l	17.05.2017	BS EN 872
W1	Oil or Grease	None Present	None Visible	17.05.2017	Visual Check
W2	pH (minimum)	6	8.3	17.05.2017	BS ISO10523
W2	pH (maximum)	9	-	-	BS ISO10523
W2	Total Suspended Solids (Maximum)	50 mg/l	8.0 mg/l	17.05.2017	BS EN 872
W2	Oil or Grease	None Present	None Visible	17.05.2017	Visual Check

Signed : K. Bennett
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)

Date :24.07.2017

FR

Permit Reference Number: BL3986ID

Installation: Aberthaw Works

Operator: Tarmac Cement & Lime Ltd

Form Number: Water 1 / 19/07/16

**Quarterly Reporting of Emissions to Surface Water – Emission Points W1 & W2
for the period 01/06/17 to 30/06/17**

Emission Point	Parameter	Emission Limit Value	Result	Date of Measurement	Method
W1	pH (minimum)	6	7.8	20.06.2017	BS ISO10523
W1	pH (maximum)	9	-	-	BS ISO10523
W1	Total Suspended Solids (Maximum)	50 mg/l	14 mg/l	20.06.2017	BS EN 872
W1	Oil or Grease	None Present	None Visible	20.06.2017	Visual Check
W2	pH (minimum)	6	-	-	BS ISO10523
W2	pH (maximum)	9	-	-	BS ISO10523
W2	Total Suspended Solids (Maximum)	50 mg/l	-	-	BS EN 872
W2	Oil or Grease	None Present	-	-	Visual Check

Signed : K. Bennett
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)

Date :24.07.2017

FR