

Permit Number: EPR/BL3986ID

Operator: Tarmac Cement & Lime Ltd

Installation: Aberthaw Works

Form number: Air 9 / 31 August 2010

Annual reporting of non-kiln Particulate Matter Emissions to Air for 2017

Release point	Emission Limit Value mg/m3	Results mg/m3		Test Method	Sample Date and Times	Accreditation/ Certification	Uncertainty Method	
		Continuous Monitor	Extractive Test				Continuous Monitor	Extractive Test
A2	30	10.82	6.72	BS EN 13284-1	03/05/2017 13:33 - 16:40	UKAS & MCERTS	30%	0.47
		0.74	0.57		14/11/2017 11:41 - 14:50		30%	0.59
A3	30	2.20	16.34	BS EN 13284-1	03/05/2017 09:20 - 12:31	UKAS & MCERTS	30%	0.63
		6.21	7.60		14/11/2017 15:08 - 18:18		30%	0.59

Operator's comments:

Extractive result given at reference conditions. IED came into force on 9th April 2017 with this we saw a reduction in ELV for particulate on the mills from 30 mg/m3 to 20 mg/m3.

Signed: K. Bennett

Date: 26/01/2018

(authorised to sign as representative of Tarmac Cement & Lime Ltd)

FR