

Permit Reference Number: BL3986ID

Operator: Tarmac Cement & Lime Ltd

Installation: Aberthaw Works

Form Number: Water 1 / 19/07/16

**Quarterly Reporting of Emissions to Surface Water – Emission Points W1 & W2
for the period 01/01/18 to 31/01/18**

Emission Point	Parameter	Emission Limit Value	Result	Date of Measurement	Method
W1	pH (minimum)	6	8.1	17.01.2018	BS ISO10523
W1	pH (maximum)	9	-	-	BS ISO10523
W1	Total Suspended Solids (Maximum)	50 mg/l	30.0 mg/l	17.01.2018	BS EN 872
W1	Oil or Grease	None Present	None Visible	17.01.2018	Visual Check
W2	pH (minimum)	6	8.3	17.01.2018	BS ISO10523
W2	pH (maximum)	9	-	-	BS ISO10523
W2	Total Suspended Solids (Maximum)	50 mg/l	13.0 mg/l	17.01.2018	BS EN 872
W2	Oil or Grease	None Present	None Visible	17.01.2018	Visual Check

Signed : K. Bennett
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)

Date :26.04.2018

 26/4/18

Permit Reference Number: BL3986ID

Installation: Aberthaw Works

Operator: Tarmac Cement & Lime Ltd

Form Number: Water 1 / 19/07/16

**Quarterly Reporting of Emissions to Surface Water – Emission Points W1 & W2
for the period 01/02/18 to 28/02/18**

Emission Point	Parameter	Emission Limit Value	Result	Date of Measurement	Method
W1	pH (minimum)	6	7.9	01.02.2018	BS ISO10523
W1	pH (maximum)	9	-	-	BS ISO10523
W1	Total Suspended Solids (Maximum)	50 mg/l	28.0 mg/l	01.02.2018	BS EN 872
W1	Oil or Grease	None Present	None Visible	01.02.2018	Visual Check
W2	pH (minimum)	6	-	-	BS ISO10523
W2	pH (maximum)	9	-	-	BS ISO10523
W2	Total Suspended Solids (Maximum)	50 mg/l	-	-	BS EN 872
W2	Oil or Grease	None Present	-	-	Visual Check

Signed : K. Bennett
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)

Date :26.04.2018

[Signature]
22/4/18

Permit Reference Number: BL3986ID

Operator: Tarmac Cement & Lime Ltd

Installation: Aberthaw Works

Form Number: Water 1 / 19/07/16

**Quarterly Reporting of Emissions to Surface Water – Emission Points W1 & W2
for the period 01/03/18 to 31/03/18**

Emission Point	Parameter	Emission Limit Value	Result	Date of Measurement	Method
W1	pH (minimum)	6	8.3	21.03.2018	BS ISO10523
W1	pH (maximum)	9	-	-	BS ISO10523
W1	Total Suspended Solids (Maximum)	50 mg/l	<5.0 mg/l	21.03.2018	BS EN 872
W1	Oil or Grease	None Present	None Visible	21.03.2018	Visual Check
W2	pH (minimum)	6	-	-	BS ISO10523
W2	pH (maximum)	9	-	-	BS ISO10523
W2	Total Suspended Solids (Maximum)	50 mg/l	-	-	BS EN 872
W2	Oil or Grease	None Present	-	-	Visual Check

Signed : K. Bennett
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)

Date :26.04.2018

 26/4/18