

Form Number: W1

Permit Reference Number: BR9715

Operator: Solutia UK Ltd

Installation: Newport Chemical Works

Reporting of Emissions to Estuary for the period from1st January.....to.....31st March 2015.....

Emission Point	Substance / Parameter	Emission Limit Value (*mean weekly in the quarter)	Result ^[1] Max	Result ^[1] Mean	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]	
W1	Benzene	20 kg *	7	2	GC/MS	Weekly composite		10%	
W1	Biphenyl	20 kg *	0.2	<0.1					10%
W1	Triphenyl/kg	-	0.3	0.1					10%
W1	Formaldehyde	10 mg/l	3.5	1.8	HPLC	Weekly composite		>20%	
W1	Phenol	40 mg/l	12	4	HPLC	Weekly composite	Aquacheck	10%	
W1	COD	65000 kg / week	21469	13754	Spectrophotometric	Weekly composite	Aquacheck	4%	
W1	Max volume of process effluent discharged	25000 m ³ / week	12391	9596	Electronic counter				
W1 + W2	Cadmium	50 g	2	1	ICP/MS	Monthly; weekly composite	NAMAS		
W1 + W2	Mercury	27 g	9	3	FIMS (AA)	Weekly composite	Aquacheck	13%	
W1 + W2	PCBs	100 g	45	11			Aquacheck		
W1 + W2	PCP	250 g	226	108			Aquacheck		
W1 + W2	TCB	50 g	10	5					
W1	Mercury	1.5 µg/l	0.4	0.1	FIMS (AA)	Monthly spot	Aquacheck	13%	
W1	Cadmium	3.5 µg/l	0.1	0.1	ICP/MS		NAMAS		
W1	PCP	150 µg/l	9	5	GC/MS		Aquacheck		
W1	TCB	20 µg/l	0.4	0.2					

Form Number: W1

Permit Reference Number: **BR9715**

Operator: Solutia UK Ltd

Installation: Newport Chemical Works

- [1] The result given is the maximum value and the average value obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum - maximum' measured values.
- [2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated, e.g. colorimetry.
- [3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements, or flow/time proportional samples, the percentage of the process operating time covered by the monitoring is given.
- [4] The accreditation status of the equipment and/or the monitoring organisation, as appropriate, for the methods used for both sampling and analysis.
- [5] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

Signed
(authorised to sign as representative of the Operator)

Date:24th April 2015.....

Date of Form: 21/8/14