

Schedule 1 – 5.1.1 Notification

PART A

Permit Number:	BR9715B
Name of Operator:	Solutia UK Ltd
Location of Installation:	Corporation Road, Newport, Gwent, NP194XF
Location of the emission:	W1 Effluent Discharge
Time and date of the emission:	26/01/2016 afternoon shift

Substance(s) emitted	Media eg air /water	Best estimate of the quantity or the rate of emission	Time during which the emission took place
W1 Effluent (during 'cease discharge')	Estuary	An estimated volume of approximately 1500m ³ , including 300m ³ of process effluent	The emission took place throughout the designated 'cease discharge' i.e. the 2hours either side of low-tide

Measures taken, or intended to be taken, to stop the emission:	The issue arose due to an electrical supply failure to the discharge pump(s) in conjunction with very high rainfall. This resulted in a build-up of liquid which necessitated pumping to estuary outside of the intended times in order to protect the plant from flooding Alternative pumping arrangements were implemented on the following shift, and the electrical supplies subsequently restored. Further detail to follow in the Part B follow up
---	--

*** Signed:** 

Date: 08/02/2016

* authorised to sign on behalf of Solutia UK Ltd