

Schedule 1 – 5.1.1 Notification

PART A

Permit Number:	BR9715B
Name of Operator:	Solutia UK Ltd
Location of Installation:	Corporation Road, Newport, Gwent, NP194XF
Location of the emission:	Therminol 3 – Benzene Transfer line
Time and date of the emission:	12/08/2016, 13:22

Substance(s) emitted	Media eg air /water	Best estimate of the quantity or the rate of emission	Time during which the emission took place
Benzene	Release to made ground. Due to volatility of benzene, there would also be an associated vapour in the immediate area	Based on: flowmeter measurements, pipework volume, and position of gasket failure – the quantity is estimated to be ~14L	The emission took place during commissioning phase, and as such a team were in attendance who isolated the pipework immediately

Measures taken, or intended to be taken, to stop the emission:	<p>As mentioned above, the pipe-section was immediately isolated. The lagging was subsequently removed to identify the point of release, which was found to be a failed gasket</p> <p>An investigation will be initiated, with further information to follow in the Part B</p>
---	--

* Signed:



Date: 12/08/2016

* authorised to sign on behalf of Solutia UK Ltd