

Permit Reference Number: BR97151B
Operator: Solutia UK Ltd
Installation: Newport Chemical Complex

Form Number: W1

Reporting of Emissions to Estuary for the period from: 01/01/16 to 31/03/16

Emission Point	Substance / Parameter	Emission Limit Value	Result Max ^[1]	Result Mean ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
W1	Benzene	20 kg ^[1]	12.3	3.2	GC/MS	Weekly composite	---	10%
W1	Biphenyl	20 kg ^[1]	1.0	0.1	GC/MS		---	10%
W1	Triphenyl (kg)	-	0.7	0.4	GC/MS		---	10%
W1	Formaldehyde	10 mg/l	1.2	0.6	HPLC	Weekly composite	---	>20%
W1	Phenol ^[2]	10 mg/l ^[1]	4.4	1.7	HPLC	Weekly composite	Aquacheck	10%
W1	COD	65000 kg / week	17500	11455	Spectrophoto-metric	Weekly composite	Aquacheck	4%
W1	Max volume of effluent	25000 m ³ / week	12039	9035	Electronic counter	Quarterly Total		
W1 + W2	Cadmium	50 g	4.5	2.8	ICP/MS	Monthly (wkly composite)	NAMAS	
W1 + W2	Mercury	27 g	1.9	0.23	FIMS (AA)	Weekly composite	Aquacheck	13%
W1 + W2	PCBs	100 g	20.7	10.9	GC/MS		Aquacheck	10%
W1 + W2	PCP	250 g	230	151	GC/MS		Aquacheck	10%
W1 + W2	TCB	50 g	6.9	3.2	GC/MS		Aquacheck	10%
W1	Mercury	1.5 µg/l	0.4	0.2	FIMS (AA)		Aquacheck	13%
W1	Cadmium	3.5 µg/l	0.2	0.1	ICP/MS	Monthly spot	NAMAS	
W1	PCP ^[3]	15 µg/l	9.1	7.2	GC/MS		Aquacheck	10%
W1	TCB	20 µg/l	0.3	0.2	GC/MS		Aquacheck	10%

[1] Mean weekly in the quarter

[2] Limit change from 40 to 10 mg/l [as of Q4/2015]

[3] Limit change from 150 to 15 µg/l [as of Q4/2015]

Signed *:



Date: 13/04/2016

(* authorised to sign as representative of the Operator)

Date of Form: 31/03/11