



Schedule 1

Notification of Unauthorised Release

Operator: Tata Steel Strip Products UK

Authorisation: BS3905 **Location:** Llanwern works
Newport
South Wales
NP19 4QZ

Date Submitted: 19th November 2015

PART A
Name of the prescribed substance or other substance which might cause harm Suspended Solids in effluent
Time, date and location of the release Elevated sample solids sample results were observed over the period: 13th – 16th of November at the W1 effluent release point
Best estimate of the quantity of the substance released, or the rate of release and the time during which the release took place Concentration levels in excess of the 100 mg/l limit were recorded, with a peak of 548 mg/l. Subsequent sample(s) were within consent, although ongoing adverse weather could similarly contribute to a continued period of elevated concentration levels
Additional information Previous occurrences of a similar nature have been found to be as a result of increased rainfall. Further information to follow in the Part B follow-up
Measures taken, or intended to be taken to stop the release None proposed

Name: Stephen Thomas

Position: Lead Environment Engineer

Signature: