



Schedule 1

Notification of Unauthorised Release

Operator: Tata Steel Strip Products UK

Authorisation: BS3905 **Location:** Llanwern works
Newport
South Wales
NP19 4QZ

Date Submitted: 13/7/16

PART A
Name of the prescribed substance or other substance which might cause harm Suspended Solids in effluent
Time, date and location of the release Elevated suspended solids sample results were observed on 9/7/16 at the W1 effluent release point.
Best estimate of the quantity of the substance released, or the rate of release and the time during which the release took place Concentration levels in excess of the 100mg/l limit were recorded, with a peak of 440mg/l (resample 422mg/l) recorded on 9/7/16. Subsequent samples on 10/7/16 were recorded at 134mg/l (resample 14mg/l). 11/7/16 at 58mg/l.
Additional information Further investigation information to follow in Part B
Measures taken, or intended to be taken to stop the release W1 effluent release point and local culverts visually inspected. Reviewed outlet drain sample results. Confirmed no abnormal conditions with pumpsman collecting samples.

Name: Hayley Jeremiah

Position: Fire & Environment Manager

Signature: 