



Schedule 1

Notification of Unauthorised Release

Operator: Tata Steel Strip Products UK

Authorisation: BS3905IP **Location:** Llanwern works
Newport
South Wales
NP19 4QZ

Date Submitted: 01/05/2018

PART A
Name of the prescribed substance or other substance which might cause harm Cadmium in effluent.
Time, date and location of the release Elevated cadmium levels were recorded on 28th April 2018 at the W1 effluent release point
Best estimate of the quantity of the substance released, or the rate of release and the time during which the release took place Levels in excess of the 0.05 mg/l limit were recorded with a peak of 0.058 mg/l.
Additional information Subsequent daily results have been within permitted limit.
Measures taken, or intended to be taken to stop the release No potential process sources identified. Increased sampling program still in place on North and South drains.

Name: LAURIE JEREMY

Position: FIRE + ENVIRONMENT MANAGER
LLANWERN.

Signature: 