

Permit Number: EA/EPR/BK3638IF/V002

Operator:

Hydro Aluminium Deeside

Facility: Wrexham Aluminium Processing

Form Number: Air1a

Reporting of emissions to air for the quarter from 01/01/19 to 31/03/19

Emission Point	Substance / Parameter	Emission Limit Value	Month 1 Maximum Daily average value	Month 2 Maximum Daily average value	Month 3 Maximum Daily average value
A1	Particulate Matter	10 mg/m ³ (daily average)	0.58	7.71 ^{Note 1}	0.67
A12	Particulate Matter	10 mg/m ³ (daily average)	0.88	0.43	1.43
A13	Particulate Matter	10 mg/m ³ (daily average)	0.35	0.22	0.29

Emission Point	Substance / Parameter	Emission Limit Value	Month 1 Average of daily average values	Month 2 Average of daily average values	Month 3 Average of daily average values
A1	Particulate Matter	5 mg/m ³ (monthly average)	0.17	1.32	0.47
A12	Particulate Matter	5 mg/m ³ (monthly average)	0.34	0.25	0.25
A13	Particulate Matter	-	0.12	0.15	0.19

Note 1: A breakdown of the screwfeed to the new waste lime silo occurred on 23/02/19, causing a blockage in the system and an elevated daily average result.

Signed Joel Priest.....
(Authorised to sign as representative of Operator)

Date.....30/04/19.....

Results have been corrected as per condition 3.1.4