



No 1181

**Report for the Periodic Monitoring  
of Emissions to Air  
Permit Number - BR8212  
Knauf Insulation  
Cwmbran Site**

**23-Jan-15**

Part 1 Executive Summary

Contract Reference:	Knaufin-02291
Client:	Knauf Insulation
Address:	Chapel Lane, Croesyceiliog, Cwmbran, Gwent, NP44 2YQ
Site Contact:	Warren Christy
Monitoring Organisation:	NWSS Northubrian Water Scientific Services Unit 40 Court Road Industrial Estate, Cwmbran Torfaen. NP44 3AS <a href="http://www.nw-ss.co.uk">www.nw-ss.co.uk</a>

This report relates to tested items only


Opinions and interpretations expressed herein are outside the scope of UKAS accreditation

Report written by  
Designation

Craig Harley  
Air Quality Test Engineer

Date: 02 February 2015

Report Approved by  
Designation  
MCERTS Registration Number  
MCERTS Qualifications

Darren Price   
Air Quality Senior Project Manager  
MM03 176  
Level 2; Technical Endorsements 1, 2, 3 & 4

Date: 02 February 2015

# CONTENTS

<b>1</b>	<b>Part 1: Executive Summary</b>	<b>Page</b>
1.1	Monitoring Objectives.....	3
1.2	Monitoring Results.....	4
1.3	Operating Information.....	5
1.4	Monitoring Deviations.....	6
<b>2</b>	<b>Part 2: Supporting Information</b>	
2.1	Appendix 1: General Information	
2.1.1	Monitoring organisation staff details	
2.1.2	Monitoring organisation method details	
2.1.3	Monitoring organisation equipment check list references	
2.2	Appendix 2: Furnace Stack	
	Stack Diagrams & Flows	
	Calculation Sheets	
	Analytical Results (2 Pages Numbered separately)	

### 1.1 Monitoring Objectives

The scope of work of the monitoring as shown in the following table was required to demonstrate emission concentrations.

Location	Determinand	Number of Samples	Sampling Time	Comments
Furnace Stack	Oxides of Sulphur as SO <sub>2</sub>	3 & Field Blank	1 Hour	None

## 1.2 Monitoring Results

**Location** Furnace Stack  
**Process Status During Monitoring** Operating as normal  
**Reference Conditions** 273K, 101.3 Kpa, Dry Gas

Substance to be Monitored	Run	Units	Emission Limit Value	Date of Sampling	Start and End Times	Periodic Monitoring Result	Uncertainty ( $\pm$ )	Mass Emission Kg/hr	Vol. Flow (Nm <sup>3</sup> /min)	Monitoring Method Reference	Accreditation for use of Method
Oxides of Sulphur as SO <sub>2</sub>	1	mg/Nm <sup>3</sup>	100	23-Jan-15	10:27-11:27	35.4	4.3	0.81	381	BS EN 14791	MCERTS
	2			23-Jan-15	11:32-12:32	42.1	5.1	0.92	363		
	3			23-Jan-15	12:38-13:38	36.3	4.4	0.76	350		
	Blank			23-Jan-15	10:10	0.16	0.02	-	-		

**Note 1** Subcontracted analysis - RPS Laboratories Ltd : UKAS Number 0605

**Note 2** Uncertainty of measurement stated at 95% confidence level

### 1.3 Operating Information

Emission Point Reference	Date	Process Type	Process Duration	Fuel	Feedstock	Abatement	Load	Comparison of Operator CEMS and Periodic Monitoring Results			
								Substance	CEMS Results	Periodic Monitoring Results	Units
Furnace Stack	23-Jan-15	Combustion	Continuous	Gas/Oxygen	Sand, soda ash, bottle/plate cullet	Electrostatic Precipitator	As per production requirements	SO <sub>2</sub>	Not Required by operator		

#### 1.4 Monitoring Deviations

Emission Point Reference	Substance Deviations	Monitoring Deviations	Other Relevant Issues
Furnace Stack	None	None	None

## **Part 2: Supporting Information**

### **2.1 Appendix 1: General Information**

2.1.1 Monitoring Organisation Staff Details

2.1.2 Monitoring Organisation Method Details

2.1.3 Monitoring Organisation Equipment Checklist Reference

### 2.1.1 Monitoring organisation staff details

Name	Position	MCERTS Level	TE1	TE2	TE3	TE4	TE5	MCERTS registration No.
Sampling Team								
Craig Harley	Air Quality Test Engineer	II	✓	✓	✓	✓		MM05 670
Dale Padfield	Air Quality Air Technician	I	✓	✓	✓			MM13 1224
Report writing								
Craig Harley	Air Quality Test Engineer	II	✓	✓	✓	✓		MM05 670
Report Authorisation								
Darren Price	Air Quality Senior Project Manager	II	✓	✓	✓	✓		MM03 176

### 2.1.2 Monitoring organisation method details

Determinand	NWSS In House Method ID	NWSS Reference Standard	Analytical Laboratory
Oxides of Sulphur	A62	BS EN 14791	RPS (UKAS Number 0605)

### Nov Monitoring organisation equipment check list references

Equipment Checklist Ref: KNAUFIN-02767, Jan 2015
--

**2.2 Appendix 2: Furnace Stack**  
Stack Diagrams & Flows  
Calculation Sheets  
Analytical Results (2 Pages Numbered separately)

**NWSS**

Velocity and Temperature Data

DATE: 23/01/2015

JOB REF.: 2767

Client:	Knauf		Operators:	CH/DPd			
Location:	Cwmbran		Test For:	SO2			
Stack:	Furnace		In-house method:	A62			
Pitot Type:	S	Pitot Cp:	0.81	Probe ID:	3371	Meter ID:	1046
Bar. Pressure:	102	Static:	1.8	Duct Shape : Circle (C) or Square (S)	C		
Ambient Temp.:	15	Stack Diameter (mm):	1000	by			
Stack O2 (%):		Port Length (mm):			80		
Stack CO2 (%):		Area (m2):			0.79		
Stack Moisture (%):							


Traverse Point Number	Distance (mm)	Sample Port 1			Sample Port 2		
		Temp. °C	ΔP cm H2O	Sq.root ΔP	Temp. °C	ΔP cm H2O	Sq.root ΔP
1	148	157	1.2	1.1	157	1.2	1.1
2	854	157	1.25	1.1	157	1.1	1.0
3							
4							
5							
6							
7							
8							
9							
10							
<b>Total</b>	TA=	314		TB=	8		
<b>Average</b>		157	1.23	1.11	157.00	1.15	1.07

**Flow-stability criteria for periodic sampling of particulates**

Criteria	Requirement	Actual
Angle of gas flow	<±15° from stack longitudinal axis	<±15°
Flow direction	No local negative flow	Positive flow
Minimum velocity	5 Pa for pitot tubes	107.8 Pa
Gas velocity variation	Ratio of highest to lowest less than 3:1 (9:1 Pitot)	1.0 :1
Temperature variatio	≤ ±5% of mean temperature in Kelvin	0.0 %

Permit Number	Operator Name	Installation Name	Installation Address
BR8212	Knauf Cwmbra	Pont-y-Felin Works	Chapel Lane, Croesyceiliog, Cwmbra, Gwent, NP44 2YQ

### Furnace Stack





CLIENT: Knauf  
 LOCATION: Cwmbran  
 STACK: A1 Furnace

Sulphur Dioxide Uncertainty Calculations		CEN SO2 1	Blank	
Sampling Uncertainty (@ 95% confidence level)	%	10	10	
Sample Volume @ Reference Conditions	m3	0.159	0.159	
Volume Impinger 1	ml	126	103	
Volume Impinger 2	ml	136	118	
Concentration @ Reference Conditions	mg/Nm3	35.4	0.2	
NWSS have calculated total sampling uncertainty at a 95 % confidence level for different sampling conditions. The results were between 6 and 9 %. NWSS have decided to quote a 'worst case' sampling uncertainty of 10% to cover all sampling procedures.				
	Unit	Source	Value	Value
Analytical Uncertainty	%	From AQC data	7	7
Impinger 1 1/2 LOD	mg/l	From AQC data	0.026	0.026
Impinger 2 1/2 LOD	mg/l	From AQC data	0.026	0.026
mass Sulphate collected in Impinger 1	mg	Lab result	8.3	0.0
mass Sulphate collected in Impinger 2	mg	Lab result	0.1	0.0
Maximum Sulphate Collected	mg	Calculation	8.43	0.04
Impinger 1 Analytical Uncertainty as Sulphate	mg	Calculation	0.58	0.00
Impinger 2 Analytical Uncertainty as Sulphate	mg	Calculation	0.01	0.00
Total Analytical Uncertainty as Sulphate	mg	Calculation	0.58	0.00
Sampling Uncertainty as Sulphate	mg	Calculation	0.84	0.00
Total Uncertainty as Sulphur Dioxide	mg	Calculation	0.683	0.004
Total Uncertainty as Sulphur Dioxide	mg/Nm3	Calculation	4.30	0.02
Total Uncertainty as Sulphur Dioxide	%	Calculation	12	15



CLIENT: Knauf  
LOCATION: Cwmbran  
STACK: A1 Furnace

Sulphur Dioxide Uncertainty Calculations		CEN SO2 2	Blank	
Sampling Uncertainty (@ 95% confidence level)	%	10	10	
Sample Volume @ Reference Conditions	m3	0.157	0.157	
Volume Impinger 1	ml	109	103	
Volume Impinger 2	ml	123	118	
Concentration @ Reference Conditions	mg/Nm3	42.1	0.2	
NWSS have calculated total sampling uncertainty at a 95 % confidence level for different sampling conditions. The results were between 6 and 9 %. NWSS have decided to quote a 'worst case' sampling uncertainty of 10% to cover all sampling procedures.				
	Unit	Source	Value	Value
Analytical Uncertainty	%	From AQC data	7	7
Impinger 1 1/2 LOD	mg/l	From AQC data	0.026	0.026
Impinger 2 1/2 LOD	mg/l	From AQC data	0.026	0.026
mass Sulphate collected in Impinger 1	mg	Lab result	9.8	
mass Sulphate collected in Impinger 2	mg	Lab result	0.1	0.0
Maximum Sulphate Collected	mg	Calculation	9.93	0.03
Impinger 1 Analytical Uncertainty as Sulphate	mg	Calculation	0.69	0.00
Impinger 2 Analytical Uncertainty as Sulphate	mg	Calculation	0.01	0.00
Total Analytical Uncertainty as Sulphate	mg	Calculation	0.69	0.00
Sampling Uncertainty as Sulphate	mg	Calculation	0.99	0.00
Total Uncertainty as Sulphur Dioxide	mg	Calculation	0.806	0.003
Total Uncertainty as Sulphur Dioxide	mg/Nm3	Calculation	5.12	0.02
Total Uncertainty as Sulphur Dioxide	%	Calculation	12	13



CLIENT: Knauf  
 LOCATION: Cwmbran  
 STACK: A1 Furnace

Sulphur Dioxide Uncertainty Calculations		CEN SO2 3	Blank	
Sampling Uncertainty (@ 95% confidence level)	%	10	10	
Sample Volume @ Reference Conditions	m3	0.170	0.170	
Volume Impinger 1	ml	114	103	
Volume Impinger 2	ml	106	118	
Concentration @ Reference Conditions	mg/Nm3	36.3	0.2	
NWSS have calculated total sampling uncertainty at a 95 % confidence level for different sampling conditions. The results were between 6 and 9 %. NWSS have decided to quote a 'worst case' sampling uncertainty of 10% to cover all sampling procedures.				
	Unit	Source	Value	Value
Analytical Uncertainty	%	From AQC data	7	7
Impinger 1 1/2 LOD	mg/l	From AQC data	0.026	0.026
Impinger 2 1/2 LOD	mg/l	From AQC data	0.026	0.026
mass Sulphate collected in Impinger 1	mg	Lab result	9.2	0.0
mass Sulphate collected in Impinger 2	mg	Lab result	0.1	0.0
Maximum Sulphate Collected	mg	Calculation	9.26	0.04
Impinger 1 Analytical Uncertainty as Sulphate	mg	Calculation	0.64	0.00
Impinger 2 Analytical Uncertainty as Sulphate	mg	Calculation	0.01	0.00
Total Analytical Uncertainty as Sulphate	mg	Calculation	0.64	0.00
Sampling Uncertainty as Sulphate	mg	Calculation	0.93	0.00
Total Uncertainty as Sulphur Dioxide	mg	Calculation	0.751	0.004
Total Uncertainty as Sulphur Dioxide	mg/Nm3	Calculation	4.42	0.02
Total Uncertainty as Sulphur Dioxide	%	Calculation	12	15



### Test Certificate

Date 30/01/2015

**Client** Northumbrian Water Ltd  
Northumberland Dock Road  
Wallsend  
Tyne & Wear  
NE28 0QD

**Order No.** -  
**Certificate No.** WK15-0413  
**Issue No.** 1

**Contact** Craig Harley

**Date Received** 27/01/2015

**Description** 8 solutions for SO2

**Technique** IC Stack

Sample No.	823962	A1 Furnace Stack-Run 1 Imp 1	Method
<b>Sulphur dioxide</b>	44.0 µg/ml	126 ml	C27(U)
Sample No.	823963	A1 Furnace Stack-Run 1 Imp 2	Method
<b>Sulphur dioxide</b>	0.57 µg/ml	136 ml	C27(U)
Sample No.	823964	A1 Furnace Stack-Run 2 Imp 1	Method
<b>Sulphur dioxide</b>	60.2 µg/ml	109 ml	C27(U)
Sample No.	823965	A1 Furnace Stack-Run 2 Imp 2	Method
<b>Sulphur dioxide</b>	0.48 µg/ml	123 ml	C27(U)
Sample No.	823966	A1 Furnace Stack-Run 3 Imp 1	Method
<b>Sulphur dioxide</b>	53.5 µg/ml	114 ml	C27(U)
Sample No.	823967	A1 Furnace Stack-Run 3 Imp 2	Method
<b>Sulphur dioxide</b>	0.68 µg/ml	106 ml	C27(U)
Sample No.	823968	A1 Furnace Stack-Blank Imp 1	Method
<b>Sulphur dioxide</b>	0.11 µg/ml	103 ml	C27(U)
Sample No.	823969	A1 Furnace Stack-Blank Imp 2	Method
<b>Sulphur dioxide</b>	0.12 µg/ml	118 ml	C27(U)




## Test Certificate

Date 30/01/2015

---

<b>Client</b>	Northumbrian Water Ltd	<b>Certificate No.</b>	WK15-0413
		<b>Issue No.</b>	1

<b>Tested By</b>	Nicholas Lynch Lora McKerracher	<b>Date</b>	29/01/2015
------------------	------------------------------------	-------------	------------

<b>Approved By</b>	 Joanne Dewhurst Laboratory Manager	<b>Date</b>	30/01/2015
--------------------	--	-------------	------------

For and on authority of RPS Laboratories Ltd.

Method Symbols (U) Analysis is UKAS Accredited  
(N) Analysis is not UKAS Accredited

Concentration values (mg/m<sup>3</sup> and ppm) are calculated on the basis of information provided by the customer.  
Results stated as ml are referring to the sample volume.

RPS Laboratories terms and conditions apply - a copy is available on request.

Analysis carried out on samples 'as received'

This document may not be reproduced other than in full, except with the written approval of the issuing laboratory.