

Permit Number: RP3133LD

Operator:

RWE Generation UK plc

Installation: Aberthaw Power Station

Form Number:

AIr1 / 30/11/07

Reporting of emissions to air for the period from ... 1st January 2017 to ... 31st December 2017

Emission Point	Substance / Parameter	Emission Limit Value	Reference Period	Result ⁽¹⁾	Test Method ⁽²⁾	Sample Date and Times ⁽³⁾	Uncertainty ⁽⁴⁾
A5	Ammonia	2 mg/m ³	Annual monitoring for 2017	0.04 mg/Nm ³	BS EN 14791	9th February 2017	+/-0.005

[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.

[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated, e.g. gas chromatography.

[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.

[4] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

* Emissions results are reported at reference conditions of 273 K and 101.3 kPa without correction for moisture content or oxygen.

Signed 
(Authorised to sign as representative of Operator)

Date... 26 January 2018.....