

Transitional National Plan Annual Verification Report (v1.0)				TNP YEAR	1 (2016)
STACK FLOW		ELV¹: (m³/s)	576	LCP: (TNP ref.)	283
Process Operator: RWE Generation UK plc			Permit No:	RP3133LD	
Address: Aberthaw Power Station, The Leys, Aberthaw, Near Barry, Vale of Glamorgan, CF62 4ZW			TNP Contact:	Amy Lavisher	
			Tel No:	01446 752270	
			Email:	amy.lavisher@rwe.com	
EN 15259 (Representative Sampling)⁹					
EN 15259: (PASS/FAIL)		Test Date(s):			
Non-Compliances: (Including stratification factors if applied in addition to QAL2 factors)		N/A, type 2 calibration, pre-investigation has not been performed			
QAL1 (Instrument Suitability)					
Make/Model: n/a			MCERTS: (Y/N) n/a		
Manufacturer: n/a			Sample Type ² : n/a		
QAL2 (Calibration)³					
LCP unit within windshield or Instrument number:	-	Unit 7	Unit 8	Unit 9	
QAL2 Factors: b (gradient) ⁴	-	0.98			
a (offset)	m ³ /s	0.00			
Test date	-	01/03/2017			
Date applied ⁵	-	n/a			
Variability ⁶	m ³ /s	22.54			
VCR from test data ^{7a}	m ³ /s	576.46			
VCR extended (if applicable) ^{7b}	m ³ /s	n/a			
Second QAL2 (Calibration) (if applicable)					
QAL2 Factors: b (gradient) ⁴	-				
a (offset)	m ³ /s				
Test date	-				
Date applied ⁵	-				
Variability ⁶	m ³ /s				
VCR from test data ^{7a}	m ³ /s				
VCR extended (if applicable) ^{7b}	m ³ /s				
AST (Annual Surveillance Test)					
LCP units within windshield:	-	Unit 7	Unit 8	Unit 9	Unit 7
Test date	-				
Variability ⁶	m ³ /s				
Validity (Mean Deviation) ⁶	m ³ /s				
VCR extended (if applicable) ^{7c}	m ³ /s				
QAL3 (Ongoing Drift Checks)					
Frequency ⁸ :	Every				
Alarm (Action) Limit:	m ³ /s				
Warning Limit:	m ³ /s				
Signature: A. Lavisher					Date: 29/06/2017