

Permit Number:

RP3133LD

Installation:

Aberthaw Power Station

Operator:

RWE Generation UK plc

Form Number:

Process1 / 30/11/07

Reporting of process monitoring for the period from ...

01/03/2018

...to... 31/03/2018

Emission Point	Substance / Parameter	Emission Limit Value	Reference Period	Result [1]	Test Method [2]	Sample Date and Times [3]	Uncertainty [4]
A13 (unit 7 absorber inlet)	Particulate Matter (mg/m3) (maximum hourly average value)	-	Continuous	734		01 - 31/03/18	MCERT monitor
A13 (unit 7 absorber inlet)	Particulate Matter (mg/m3) (monthly average value)	-	Continuous	235		01 - 31/03/18	MCERT monitor
A14 (unit 8 absorber inlet)	Particulate Matter (mg/m3) (maximum hourly average value)	-	Continuous	248		01 - 31/03/18	MCERT monitor
A14 (unit 8 absorber inlet)	Particulate Matter (mg/m3) (monthly average value)	-	Continuous	141		01 - 31/03/18	MCERT monitor
A15 (unit 9 absorber inlet)	Particulate Matter (mg/m3) (maximum hourly average value)	-	Continuous	247		01 - 31/03/18	MCERT monitor
A15 (unit 9 absorber inlet)	Particulate Matter (mg/m3) (monthly average value)	-	Continuous	111		01 - 31/03/18	MCERT monitor

[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum - maximum' measured values.

[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated, e.g. gas chromatography. To be confirmed upon completion of permit improvement condition reference IC20.

[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.

[4] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

Signed *R. Powell*

Date *27/4/18*

(Authorised to sign as representative of Operator)

Reporting of deposited particulate matter for the period from 13/03/2018 to 04/04/2018

Operator: RWE Generation UK plc

Form:

Deposition1 /30/11/07

Location: Aberthaw

Permit/Variation Number: RP3133LD

Monitoring Point	Substance / Parameter	Guidance Value (mg/m ³ /day)	Result (1) (mg/m ³ /day)	Test Method (2)	Sample Date and Times (3)	Accreditation/ Certification (4)	Uncertainty (5)
Font-y-gary	Total deposited particulate matter	80-100	34.1	BS 1747-1:1969 and best practice guidelines	Continuous	-	-
East Aberthaw Sidings	Total deposited particulate matter	80-100	52.9	BS 1747-1:1969 and best practice guidelines	Continuous	-	-
Rail Bend	Total deposited particulate matter	80-100	240.9	BS 1747-1:1969 and best practice guidelines	Continuous	-	-
Quarry North	Total deposited particulate matter	80-100	98.7	BS 1747-1:1969 and best practice guidelines	Continuous	-	-
Quarry South	Total deposited particulate matter	80-100	87.1	BS 1747-1:1969 and best practice guidelines	Continuous	-	-

[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum - maximum' measured values.

[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated, e.g. colorimetry.

[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements, or flow/time proportional samples, the percentage of the process operating time covered by the monitoring is given.

[4] The accreditation status of the equipment and/or the monitoring organisation, as appropriate, for the methods used for both sampling and analysis.

[5] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

Signed R. Powell
(authorised to sign as representative of the Operator)

Date: 27/4/18

Reporting of Emissions to Water (other than to Sewer) for the period from ...1st March 2018...to....31st March 2018.

Operator: RWE Generation UK plc

Form:

Water1 /25/01/2013

Location: Aberthaw

Version:

V.8 Jan 2013

Permit/Variation Number: EPR/RP3133LD

Emission Point	Substance / Parameter	Emission Limit Value	Result ⁽¹⁾	Test Method ⁽²⁾	Sample Date and Times ⁽³⁾	Accreditation/ Certification ⁽⁴⁾	Uncertainty ⁽⁵⁾
W1	Total suspended solids	100 mg/l	12.8	BS EN 872:2005			
W1	Ammoniacal nitrogen	2 mg/l	0.045	BS 6068-2:11			
W1	Cadmium and its compounds, expressed as cadmium (Total Cd)	0.01 mg/l	<0.0001	BS 6068-2:89			
W1	Total hydrocarbon oil	3 mg/l	<0.2	EN ISO 9377-2			
W1	pH (minimum daily value)	6	7.46	BS 6068-2:50:1995			
W1	pH (maximum daily value)	9	8.15	BS 6068-2:50:1995			
W1	pH (average daily value)	-	7.83	BS 6068-2:50:1995			
W2	Differential total suspended solids	50 mg/l	0.00 mg/l	BS EN 872:2005			
W2	Ammoniacal nitrogen	0.1 mg/l (above background)	0.014 mg/l (above background)	BS 6068-2:11			
W2	Differential temperature (rolling 98th percentile)	13.5°C	10.1 °C	ISO, BS EN or SCA Blue Book Method			
W2	Differential temperature (average daily value)	-	0.9 °C	ISO, BS EN or SCA Blue Book Method			
W2	Differential temperature (maximum daily value)	-	12.9 °C	ISO, BS EN or SCA Blue Book Method			
W2	Total hydrocarbon oil	3 mg/l	0.200 mg/l	EN ISO 9377-2			
W2	pH (minimum value)	5.6	5.9	BS 6068-2:50:1995			
W2	pH (maximum 95%ile value)	8.5	8.3	BS 6068-2:50:1995			
W2	pH (minimum 95%ile value)	5.8	5.9	BS 6068-2:50:1995			
W2	pH (average value)	-	7.5	BS 6068-2:50:1995			

Emission Point	Substance / Parameter	Emission Limit Value	Result ⁽¹⁾	Test Method ⁽²⁾	Sample Date and Times ⁽³⁾	Accreditation/ Certification ⁽⁴⁾	Uncertainty ⁽⁵⁾
SWTP1	Mercury and its compounds, expressed as mercury (Total Hg) (monthly average of daily samples)	0.0005 mg/l (above background)	0.0002 mg/l (above background)	BS EN 17852			
SWTP1	Cadmium and its compounds, expressed as cadmium (Total Cd) (monthly average of daily samples)	0.0002 mg/l (above background)	0.0006 mg/l (above background)	BS 6068-2.89			
SWTP2	Mercury and its compounds, expressed as mercury (Total Hg) (monthly average of daily samples)	0.0005 mg/l (above background)	0.0002 mg/l (above background)	BS EN 17852			
SWTP2	Cadmium and its compounds, expressed as cadmium (Total Cd) (monthly average of daily samples)	0.0002 mg/l (above background)	0.0006 mg/l (above background)	BS 6068-2.89			
SWTP3	Mercury and its compounds, expressed as mercury (Total Hg) (monthly average of daily samples)	0.0005 mg/l (above background)	0.0003 mg/l (above background)	BS EN 17852			
SWTP3	Cadmium and its compounds, expressed as cadmium (Total Cd) (monthly average of daily samples)	0.0002 mg/l (above background)	0.0007 mg/l (above background)	BS 6068-2.89			

Emission Point	Substance / Parameter	Emission Limit Value	Result ⁽¹⁾	Test Method ⁽²⁾	Sample Date and Times ⁽³⁾	Accreditation/ Certification ⁽⁴⁾	Uncertainty ⁽⁵⁾
W2	Dissolved oxygen (minimum value)	-	0.0 mg/l	EN 25814			
W2	Dissolved oxygen (maximum value)	-	10.8 mg/l	EN 25814			
W2	Dissolved oxygen (average value)	-	8.6 mg/l	EN 25814			
SWTP1	pH (average value)	-	3.6	BS 6068-2.50:1995			
SWTP1	Flow (average daily value)	-	16618 m ³ /h	BS3680			
SWTP1	Flow (Total Monthly Volume)	-	3183596 m ³	BS3680			
SWTP1	Arsenic and its compounds, expressed as arsenic (Total As)	-	0.0063 mg/l	BS 6068			
SWTP1	Lead and its compounds, expressed as lead (Total Pb) (monthly average of daily samples)	0.004 mg/l (above background)	0.0076 mg/l (above background)	BS 6068			suspect intermittent running has caused settlement and re-entrainment
SWTP1	Chromium and its compounds, expressed as chromium (Total Cr VI)	-	0.0300 mg/l	BS 6068			
SWTP1	Zinc and its compounds, expressed as zinc (Total Zn) (monthly average of daily samples)	0.01 mg/l (above background)	0.020 mg/l (above background)	BS 6068			suspect intermittent running has caused settlement and re-entrainment
SWTP1	Selenium and its compounds, expressed as selenium (Total Se)	-	0.0001 mg/l	BS 6068			

Emission Point	Substance / Parameter	Emission Limit Value	Result ⁽³⁾	Test Method ⁽²⁾	Sample Date and Times ⁽³⁾	Accreditation/ Certification ⁽⁴⁾	Uncertainty ⁽⁵⁾
SWTP2	pH (average value)	-	3.6	BS 6068-2.50:1995			
SWTP2	Flow (average daily value)	-	4283 m ³ /h	BS3660			
SWTP2	Flow (Total Monthly Volume)	-	2680665 m ³	BS3660			
SWTP2	Arsenic and its compounds, expressed as arsenic (Total As)	-	0.0087 mg/l	BS 6068			
SWTP2	Lead and its compounds, expressed as lead (Total Pb) (monthly average of daily samples)	0.004 mg/l (above background)	0.0070 mg/l (above background)	BS 6068			suspect intermittent running has caused settlement and re-entrainment
SWTP2	Chromium and its compounds, expressed as chromium (Total Cr VI)	-	0.0300 mg/l	BS 6068			
SWTP2	Zinc and its compounds, expressed as zinc (Total Zn) (monthly average of daily samples)	0.01 mg/l (above background)	0.018 mg/l (above background)	BS 6068			suspect intermittent running has caused settlement and re-entrainment
SWTP2	Selenium and its compounds, expressed as selenium (Total Se)	-	0.0003 mg/l	BS 6068			

Emission Point	Substance / Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
SWTP3	pH (average value)	-	3.9	BS 6068-2.50:1995			
SWTP3	Flow (average daily value)	-	5740 m ³ /h	BS3680			
SWTP3	Flow (Total Monthly Volume)	-	3467178 m ³	BS3680			
SWTP3	Arsenic and its compounds, expressed as arsenic (Total As)	-	0.0062 mg/l	BS 6068			
SWTP3	Lead and its compounds, expressed as lead (Total Pb) (monthly average of daily samples)	0.004 mg/l (above background)	0.0047 mg/l (above background)	BS 6068			suspect intermittent running has caused settlement and re-entrainment
SWTP3	Chromium and its compounds, expressed as chromium (Total Cr VI)	-	0.0300 mg/l	BS 6068			
SWTP3	Zinc and its compounds, expressed as zinc (Total Zn) (monthly average of daily samples)	0.01 mg/l (above background)	0.059 mg/l (above background)	BS 6068			suspect intermittent running has caused settlement and re-entrainment
SWTP3	Selenium and its compounds, expressed as selenium (Total Se)	-	0.0006 mg/l	BS 6068			

[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum - maximum' measured values.

[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated, e.g. colorimetry.

[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements, or flow/time proportional samples, the percentage of the process operating time covered by the monitoring is given.

[4] The accreditation status of the equipment and/or the monitoring organisation, as appropriate, for the methods used for both sampling and analysis.

[5] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

[6] The emission limit values for all substances is expressed as a maximum individual value, unless otherwise stated.

Signed 

Date 27/4/18

(authorised to sign as representative of the Operator)

Reporting of Surface Water Monitoring for the period from ...1st March 2018...to...31st March 2018.

Operator: RWE Generation UK plc

Form: Water2 /25/01/2013

Location: Aberthaw

Version: V.7 Jan 2013

Permit/Variation Number: EPR/RP3133LD/V006

Emission Point	Substance / Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
Seawater intake from Bristol Channel	Total suspended solids	-	128.00 mg/l	BS EN 872:2005			
Seawater intake from Bristol Channel	pH (average value)	-	8.1	BS 6068-2:50:1995			
Seawater intake from Bristol Channel	Mercury and its compounds, expressed as mercury (Total Hg)	-	0.00002 mg/l	BS EN 17852			
Seawater intake from Bristol Channel	Mercury (on filtered sample)	-	0.00001 mg/l	BS EN 17852			
W2	Mercury and its compounds, expressed as mercury (Total Hg) (monthly cumulative mass)	60kg/yr	1.1 kg	BS EN 17852			

- [1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum - maximum' measured values.
- [2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated, e.g. colorimetry.
- [3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements, or flow/time proportional samples, the percentage of the process operating time covered by the monitoring is given.
- [4] The accreditation status of the equipment and/or the monitoring organisation, as appropriate, for the methods used for both sampling and analysis.
- [5] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.
- [6] The emission limit values for all substances is expressed as a maximum individual value, unless otherwise stated.

Signed *R. Powell* Date: *27/4/18*

(authorised to sign as representative of the Operator)

RP3133LD

1 of 1

Water2

