


Permit Number: BM3965 / NP3235MQ Operator: Airbus UK Ltd
 Installation: Broughton Aircraft Factory Form Number: Water1 / 11/01/07

Reporting of emissions to water (other than to sewer) for the period from ...01/07/2018..... to ...30/09/2018.....

Emission Point	Substance / Parameter	Emission Limit Value	Reference Period	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Uncertainty ^[4]
SW16	Suspended Solids	50 mg/l	01/07/2018 – 30/09/2018	24.8 mg/l	Method 2540D	20/08/2018 @ 13:38	<2mg/l
SW16	Chromium	-	01/07/2018 – 30/09/2018	5.56 ug/l	Standard Methods ICP-MS	03/09/2018 @ 13:48	<3ug/l

- [1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.
- [2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated, e.g. gas chromatography.
- [3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.
- [4] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

Signed
 (Authorised to sign as representative of Operator)

 Date 10/10/2018.....