



Dŵr Cymru
Welsh Water

Martyn Grant
Environmental Manager
The Royal Mint Limited
Llantrisant
Pontyclun
CF72 8YT

Date 19th March 2015

Dear Mr Grant,

Ref:- Authorisation for Disposal of additional Trade Effluent resulting from Dilution to the Public Foul Sewer

Further to the site meeting today regarding the proposal by the Royal Mint to continue to use dilution water (originating from river abstraction) to correct marginally non-compliant pre-treated wastewater effluent, for an agreed period of an additional 6 months. The dilution will bring the non-compliant wastewater within acceptable limits under the current trade effluent consent TE409, and therefore allow for disposal as normal to the public foul sewer. The dilution process is to compromise an additional procedure over and above the normal trade effluent treatment process.

Based on the information provided, I can confirm that authorisation is given to discharge the additional trade effluent into the public foul sewer, subject to the following conditions and not otherwise:

1. The maximum volume of diluted or undiluted trade effluent that may be discharged shall not exceed the current consented discharge rates, that is, 673 cubic metres per day at a flow rate of no more than 36 cubic metres per hour.
2. The additional trade effluent to be discharged is to be derived from dilution of the pre-treated trade effluent using river water from abstraction.
3. The additional volumes of trade effluent to be discharged will be subject to the normal trade effluent charges according to Dwr Cymru's current Scheme of Charges.
4. All trade effluent flows, diluted or undiluted, must pass through the existing trade effluent flow meter installed after the pretreatment plant, and prior to discharge to the public foul sewer.

glas
Glas Cymru Cyfyngedig

Welsh Water is owned by Glas Cymru - a 'not-for-profit' company.
Mae Dŵr Cymru yn eiddo i Glas Cymru - cwmni 'nid-er-elw'.

We welcome correspondence
in Welsh and English.

Dŵr Cymru Cyf, a limited company registered in
Wales no. 2366777. Registered office: Pentwyn Road,
Nelson, Treharris, Mid Glamorgan CF46 6LY.

Rydym yn croesawu gohebiaeth yn
y Gymraeg neu yn Saesneg.


Dŵr Cymru Cyf, cwmni cyfyngedig wedi'i gofrestru yng
Nghymru rhif 2366777. Swyddfa gofrestredig: Heol Pentwyn,
Nelson, Treharris, Morgannwg Ganol CF46 6LY.

5. This permission is given on the understanding that:
 - a) it may be reviewed from time to time in accordance with the frequency applying in respect of a trade effluent consent issued under the Water Industry Act 1991, section 124.
 - b) Dwr Cymru-Welsh Water may review its Trade Effluent Policy and require a review of this permission subject to the restrictions in a) above.
 - c) If the nature of the discharge is changed then Dwr Cymru-Welsh Water must be informed of this and shall be entitled to review the permission.

6. This permission is valid until 30th September 2015. Prior to this date a review meeting will be required, to provide an update on progress with measures to reduce incidences of non-compliance leading to the requirement for dilution.

In the meantime, if you have any queries on this authorisation or should the operation change in any way so as to affect the nature and/or volume of wastewater for disposal, please contact me by phone or e-mail using the contact details given below.

Yours sincerely



Heather Pepper
TRADE EFFLUENT OFFICER

Tel (029) 20 478822

heather.pepper@dwrcymru.com