

Schedule 5 – Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

Part A

Permit Number	EPR/JP3632ZH/V002	
Name of operator	Engie FM Limited	
Location of Facility	Barry Cogeneration Plant	
Time and date of the detection	18/06/2017 15:36pm	

(a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or emission of a substance not controlled by an emission limit which has caused, is causing or may cause significant pollution

To be notified immediately

Date and time of the event	18/06/2017 15:36pm	
Reference or description of the location of the event	HRSG A black smoke from chimney	
Description of where any release into the environment took place	Main chimney stack for CHP Emission point A1	
Substance(s) potentially released	Black Smoke	
Best estimate of the quantity or rate of release of substances	unknown	
Measures taken, or intended to be taken, to stop any emission	Unit was stopped after this period as it had not come back into control.	
Description of the failure or accident.	O2 trim feature, was inactive and manual trim was unsuccessful	

(b) Notification requirements for the breach of a limit

To be notified immediately unless otherwise specified below

Emission point reference/ source	
Parameter(s)	
Limit	
Measured value and uncertainty	
Date and time of monitoring	

(b) Notification requirements for the breach of a limit	
To be notified immediately unless otherwise specified below	
Measures taken, or intended to be taken, to stop the emission	
Time periods for notification following detection of a breach of a limit	
Parameter	Notification period

(c) Notification requirements for the detection of any significant adverse environmental effect	
To be notified immediately	
Description of where the effect on the environment was detected	
Substance(s) detected	
Concentrations of substances detected	
Date of monitoring/sampling	

Part B – to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	
Measures taken, or intended to be taken, to prevent a recurrence of the incident	
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	
The dates of any unauthorised emissions from the facility in the preceding 24 months.	

Name*	HIRAM MULLAN
Post	OPERATIONS MANAGER
Signature	
Date	23/6/17

* authorised to sign on behalf of the operator