

RELEASES TO AIR
RETURN OF DISCONTINUOUS MONITORING RESULTS
Operator name: Engie FM Ltd

Location: Dow Corning CHP

Permit/Variation Number:
Form:
Version:
IED PM1
V.11 Mar 2016

Year:	LCP 60 (A2 FB-001)				
Six months to December 2016					
Measurement approach	NO _x	SO ₂	CO	Hg	Dust
Time					
Date					
Measurement 1 (mg/m ³) ^(b)					
Measurement 2 (mg/m ³) ^(b)					
Measurement 3 (mg/m ³) ^(b)					
Alternative approach ^(c)					
Method ^(d)	NF	FS	CS		DF
Calculation (mg/m ³)	95.08	0.72	1.17		0
Operational data ^(a)					
Load (%MCR)	20%	20%	20%		20%
Fuel 1 Natural Gas (%)	100	100	100		100
Fuel 2 name (%)					
Fuel 3 name (%)					
Daily Emission Limit Value					
(mg/m ³)	135	38.5	200		5.5

NOTES:


(a) Operational data for the test period (measurement approach) or the six month period to date (Alternative approach)

 (b) Reference conditions for mg/m³ are 15% O₂ CCGT, 6% O₂ solid fuels, 3% O₂ for oil and gas, dry, 0 °C, 101.325 kPa

(c) Alternative approach to discontinuous monitoring by agreement with the Competent Authority

 (d) Use abbreviation: NF for agreed NO_x factor, FS for fuel sulphur content, CS for agreed CO factor, DF for agreed dust factor

Signed on behalf of the Operator by:



Date of return:

25th February 2-18