

Schedule 1 - Notification of abnormal emissions

This page outlines the information that the Operator must provide to satisfy conditions 5.1.1 and 5.1.2 of this Permit.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the PPC Regulations.

Part A

Permit Number	NP3433BC
Name of Operator	CONVATEC LTD.
Location of Installation	UNIT 1 HEADS OF THE VALLEYS IND. EST, RHYMNEY
Location of the emission	NORTH WEST SURFACE WATER OUTFALL
Time and date of the emission	13:00 hrs 19 APR 2017. (DELUGE TEST)

Substance(s) emitted	Media	Best estimate of the quantity or the rate of emission	Time during which the emission took place
3% FOAM / 97% H ₂ O	SURFACE WATER	100L FIRE FIGHTING FOAM	13:37:28 to
SPRINKLER WATER	"	3000L SPRINKLER WATER	13:38:24 (56 sec)

Measures taken, or intended to be taken, to stop the emission	DIVERT VALVE TO INTERCEPTOR TANK ACTIVATED.
---	---

Part B

Any more accurate information on the matters for notification under Part A.	FOAM — FIRE FIGHTING AFF — AR 3%.
Measures taken, or intended to be taken, to prevent a recurrence of the incident	DIVERT VALVE TO BE ACTIVATED PRIOR TO ANY REPEAT TEST.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment or harm which has been or may be caused by the emission	NO EVIDENCE OF ENVIRONMENTAL DAMAGE TO WATERWAY OR WILD LIFE. OBSERVATIONS TO CONTINUE DAILY.
The dates of any unauthorised emissions from the installation in the preceding 24 months.	N/A.

Name*	KEVIN RICHARDS
Post	EHS MANAGER
Signature	K Richards
Date	20 APR 2017.

* authorised to sign on behalf of Convatec Limited