

Schedule 5 - Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

Part A

Permit Number	TP3639BH
Name of operator	CELSA Manufacturing (UK) Ltd
Location of Facility	Seawall Road, Tremorfa, Cardiff CF24 5TH
Time and date of the detection	19/04/2015, 23.59-00.59, 00.59-01.59, 01.59-02.59, 02.59-03.59, 04.59-05.59, 05.59-06.59, 14.59-15.59, 18.59-19.59, 20.59-21.59, 21.59-22.59.

(a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or emission of a substance not controlled by an emission limit which has caused, is causing or may cause significant pollution

To be notified within 24 hours of detection

Date and time of the event	
Reference or description of the location of the event	
Description of where any release into the environment took place	
Substances(s) potentially released	
Best estimate of the quantity or rate of release of substances	
Measures taken, or intended to be taken, to stop any emission	
Description of the failure or accident.	

(b) Notification requirements for the breach of a limit	
To be notified within 24 hours of detection unless otherwise specified below	
Emission point reference/ source	A1 Air
Parameter(s)	CO
Limit	CO = 100 mg/m³
Measured value and uncertainty	19/04/2015, 23.59-00.59, Max Hourly Av.= 176.2 mg/m ³ , Max 95%ile Av.= 169.4 mg/m ³ , 00.59-01.59, Max Hourly Av.= 163 mg/m ³ , Max 95%ile Av.= 159.64 mg/m ³ , 01.59-02.59, Max Hourly Av.= 220.1 mg/m ³ , Max 95%ile Av.= 198.34 mg/m ³ , 02.59-03.59, Max Hourly Av.= 181.3 mg/m ³ , Max 95%ile Av.= 176.71 mg/m ³ , 04.59-05.59, Max Hourly Av.= 198.9 mg/m ³ , Max 95%ile Av.= 187.7 mg/m ³ , 05.59-06.59, Max Hourly Av.= 187.7 mg/m ³ , Max 95%ile Av.= 181.62 mg/m ³ , 14.59-15.59, Max Hourly Av.= 158.2 mg/m ³ , Max 95%ile Av.= 151.31 mg/m ³ , 18.59-19.59, Max Hourly Av.= 164.5 mg/m ³ , Max 95%ile Av.= 163.38 mg/m ³ , 20.59-21.59, Max Hourly Av.= 233.5 mg/m ³ , Max 95%ile Av.= 217.98 mg/m ³ , 21.59-22.59 Max Hourly Av.= 168.2 mg/m ³ , Max 95%ile Av.= 165.24 mg/m ³ .
Date and time of monitoring	19/04/2015, 23.59-00.59, 00.59-01.59, 01.59-02.59, 02.59-03.59, 04.59-05.59, 05.59-06.59, 14.59-15.59, 18.59-19.59, 20.59-21.59, 21.59-22.59.
Measures taken, or intended to be taken, to stop the emission	

Time periods for notification following detection of a breach of a limit	
Parameter	Notification period

(c) Notification requirements for the detection of any significant adverse environmental effect	
To be notified within 24 hours of detection	
Description of where the effect on the environment was detected	
Substances(s) detected	
Concentrations of substances detected	
Date of monitoring/sampling	

Part B - to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	The process was operating normally with no plant failures. There were no engineering delays that could have attributed to the emissions. CELSA is continuing to operate with low scrap stocks in order to zero the bays for maintenance work to be undertaken during the annual shutdown which commences on the 22 nd of April 2015. This is a temporary situation and scrap levels will return to normal on the 7 th of May 2015 at the start of production. Scrap screening is undertaken to limit the amount of non-ferrous material entering the scrap bays. However, when levels in the bay become low, non ferrous material at the bottom of the bays can get picked up and be charged in the furnace. As a result, refine processes are required more frequently. High carbon and phosphorous levels have been recorded in the melts. This requires treatment by addition of oxygen.
Measures taken, or intended to be taken, to prevent a recurrence of the incident	As above.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	As above.
The dates of any unauthorised emissions from the facility in the preceding 24 months.	19 April, 9 May, 10 May, 11 May, 1 Jun, 2 Jun, 3 Jun, 4 Jun, 5 Jun, 6 Jun, 8 Jun, 9 Jun, 10 Jun, 11 Jun, 12 Jun, 13 Jun, 14 Jun, 15 Jun, 16 Jun, 17 Jun, 18 Jun, 19 Jun, 21 Jun, 22 Jun, 25 Jun, 26 Jun, 15 Jul, 18 Jul, 8 August, 9 August, 10 August, 12 August, 14 August, 15 August, 16 August, 17 August, 18 August, 19 August, 20 August, 21 August, 23 August, 24 August, 25 August, 26 August, 28 August, 29 August, 31 August, 1 September, 2 September, 3 September, 4 September, 5 September, 6 September, 19 October, 1 November, 10 November, 28 November, 9 December, 16 December, 23 December, 20 January, 21 January, 22 January, 23 January, 24 January, 6 February, 13 February, 28 February, 14 March, 19 March, 21 March, 22 March, 23 March, 24 March, 25 March, 26 March, 27 March, 28 March, 29 March, 30 March, 31 March, 1 April, 2 April, 3 April, 4 April, 5 April, 6 April, 7 April, 8 April, 9 April, 1 May, 10 May, 22 May, 23 May, 24 May, 25 May, 27 May, 28 May, 29 May, 2 June, 3 June, 5 June, 7 June, 8 June, 9 June, 19 June, 20 June, 23 June, 26 June, 11 July, 13 July, 5 August, 6 August, 7 August, 8 August, 9 August, 10 August, 11 August, 12 August, 13 August, 14 August, 15 August, 17 August, 19 August, 20 August, 21 August, 22 August, 23 August, 24 August, 29 August, 31 August, 1 September, 18 September, 23 September, 25 September, 4 October, 7 October, 8 October, 9 October, 10 October, 11 October, 4 November, 5 November, 6 November, 9 November, 10 November, 22 November, 23 November, 24 November, 25 November, 26 November, 27 November, 1 December, 2 December, 6 December, 7 December, 9 December, 11 December, 12 December, 13 December, 14 December, 15 December, 16 December, 17

	December, 18 December, 19 December, 05 January, 6 January, 7 January, 8 January, 10 January, 12 January, 14 January, 19 January, 20 January, 21 January, 22 January, 27 January, 28 January, 29 January, 31 January, 3 February, 4 February, 8 February, 10 February, 11 February, 12 February, 13 February, 14 February, 15 February, 17 February, 18 February, 20 February, 21 February, 23 February, 25 February, 26 February, 27 February, 28 February, 1 March, 4 March, 5 March, 6 March, 8 March, 11 March, 14 March, 17 March, 18 March, 19 March, 20 March, 21 March, 22 March, 24 March, 26 March, 05 April, 6 April, 7 April, 8 April, 9 April, 10 April, 11 April, 13 April, 14 April, 15 April, 16 April, 17 April, 18 April.
--	--

Name*	Sara Jones
Post	Environmental Advisor
Signature	<u>S.Jones.</u>
Date	21/04/2015

* authorised to sign on behalf of CELSA Manufacturing UK Limited