

Permit Number: EPR/VP3736EF
Operator: The BOC Group Limited
Facility: Newport Steam Reforming Plant
Reporting: 4.2.2(a)

01/01/19 – 31/12/19

Reviewing the performance monitoring data for the installation for the given reporting period, the results are:

- Within the reporting limits for all parameters.

NOx emissions have remained in control at 59.5mgm^{-3} which is well within the limit value of 140mgm^{-3} . There has been a slight increase in the hydrogen produced due to customer demand.

R Warren (SHEQ Manager Margam and Satellites)

29/01/2020