



**Cyfoeth
Naturiol
Cymru
Natural
Resources
Wales**

Natural Resources Wales permitting decisions

Rhymney Power Limited (Rhymney Energy Park) Decision Document

New bespoke permit

The application number is: PAN-013974
The Applicant / Operator is: Rhymney Power Limited
The Facility is located at: Phymney Energy Park, Unit 48, Portmanmoor Road Industrial Estate, Cardiff, South Wales, CF24 5HB

We have decided to grant the permit for Rhymney Energy Park operated by Rhymney Power Limited.

We consider in reaching that decision we have taken into account all relevant considerations and legal requirements and that the permit will ensure that the appropriate level of environmental protection is provided.

Purpose of this document

This decision document:

- explains how the application has been determined
- provides a record of the decision-making process
- shows how all relevant factors have been taken into account
- justifies the specific conditions in the permit other than those in our generic permit template.

Unless the decision document specifies otherwise we have accepted the applicant's proposals.

Structure of this document

- Table of contents
- Key issues

Table of Contents

Contents

New bespoke permit.....	2
Purpose of this document	2
Structure of this document	2
Table of Contents	3
Contents	3
Key issues of the decision	4
1 Our decision	4
2 How we reached our decision	4
2.1 Receipt of Application	4
2.2 Consultation on the Application	5
2.3 Requests for Further Information	5
3 The Legal Framework.....	5
4 The Facility	6
4.1 Description of the Facility and related issues	6
4.2 Operation of the Facility – general issues	9
5 Minimising the Facility’s environmental impact.....	11
5.1 Assessment of Impact on Air Quality	11
5.2 Impact on Habitats sites, SSSIs, non-statutory conservation sites	13
5.3 Natura 2000/Ramsar sites.....	13
HRA Overall conclusion	13
SSSI Assessment	14
6 Setting ELVs and other Permit conditions	14
6.1 Monitoring	14
6.2 Reporting	15
7 SG Charges and Subsistence Fees	16

Key issues of the decision

1 Our decision

We consider that, in reaching that decision, we have taken into account all relevant considerations and legal requirements and that the permit will ensure that a high level of protection is provided for the environment and human health.

This Application is to operate a regulated facility which is subject principally to the Environmental Permitting Regulations 2016 (EPR), and Specified Generator (SG) regulations. The plant is an existing Medium Combustion Plant therefore is not subject to the MCP Directive yet.

The permit contains many conditions taken from our standard Environmental Permit template including the relevant Annexes. We developed these conditions in consultation with industry, having regard to the legal requirements of EPR and other relevant legislation. This document does not therefore include an explanation for these standard conditions. Where they are included in the permit, we have considered the Application and accepted the details are sufficient and satisfactory to make the standard conditions appropriate. This document should be read in conjunction with the application and supporting information and permit.

2 How we reached our decision

2.1 Receipt of Application

The Application was accepted as duly made on **14/09/21**. This means we considered it was in the correct form and contained sufficient information for us to begin our determination, but not that it necessarily contained all the information we would need to complete that determination.

The Applicant made a claim for no claim for commercial confidentiality. We have not received information in relation to the Application that appears to be confidential in relation to any party.

2.2 Consultation on the Application

There was no requirement to carry out a consultation on this application because it is a standalone MCP/SG permit application.

2.3 Requests for Further Information

In order for us to be able to consider the Application duly made, we needed more information. We requested further information relating to the operator to provide an Environmental Management System, an amended Air Emissions risk assessment and proof of the application fee payment. Upon receipt of this information we were able to consider the application Duly Made.

A copy of the information notice and e-mails requesting further information were placed on our public register as were the responses when received.

3 The Legal Framework

The permit will be granted, under Regulation 13 of the EPR. The Environmental Permitting regime is a legal vehicle which delivers most of the relevant legal requirements for activities falling within its scope. In particular, the regulated facility is:

- plant as described by Schedule 25B covering the Specified Generator (SG) regulations
- subject to aspects of the Well-Being of Future Generations (Wales) Act 2015 and the Environment (Wales) Act 2016 which also have to be addressed.

We address the legal requirements directly where relevant in the body of this document. NRW is satisfied that this decision is consistent with its general purpose of pursuing the sustainable management of natural resources (SMNR) in relation to Wales, and applying the principles of SMNR. In particular, NRW acknowledges that it is a principle of sustainable management to take action to prevent significant damage to ecosystems. We consider that, in granting the Permit a high level of protection will be delivered for the environment and human health through the operation of the Facility in accordance with the permit conditions. NRW is satisfied that this decision is compatible with its general purpose of pursuing the sustainable management of natural resources in relation to Wales and applying the principles of sustainable management of natural resources.

Environment Wales Act 2016 – Biodiversity and resilience of ecosystems duty

Section 6 of the Environment Wales Act 2016 requires that we seek to maintain and enhance biodiversity in the exercise of our functions, and in so doing promote the resilience of ecosystems, in a manner that is consistent with the proper exercise of our functions. NRW is satisfied that in this case we have taken into account and had due regard to this duty in so far as it is consistent with the function of determining an application for an EPR permit.

4 The Facility

4.1 Description of the Facility and related issues

4.1.1 The permitted activities

The Facility is subject to the EPR because it carries out an activity as described in Schedule 25B of the EPR as well as an activity listed in Part 2 of Schedule 1 of the EPR:

- One combined Tranche B Specified Generator/existing Medium Combustion Plant aggregated to <50MWth at a specified location

A Generator means any combustion plant generating electricity. The regulations use the term ‘specified generator’ to encompass both individual generators and multiple generators at the same location or site, operated by the same Operator and for the same purpose. The “same purpose” means that having a different function does not stop individual generators being treated as part of a specified generator, e.g. generators with a capacity market agreement or providing a balancing service whether they are under the same contract or not would be classed as operating for the “same purpose” as they generate electricity. Similarly, generators with different fuels or technologies are also classed as operating for the “same purpose”.

The specified generator permit will apply to the site, rather than its constituent individual generators. All specified generators equal to or more than 1 MWth will also be Medium Combustion Plant (MCP) and must also meet the requirements of the MCP Directive, the engines are an existing medium combustion plant as they were operational before 20 December 2018, therefore are not subject to the requirements of the MCPD yet. The Site has entered into a Capacity Market Agreement signed post-31st October 2017 in October 2021, triggering the Site to become a Tranche B Specified Generator whereas previously it was a Tranche A Specified Generator. As it is now a Tranche B SG it requires permitting now and does not benefit from any of the transitional arrangements as stated for Tranche A specified generators.

Specified Generators are also divided into Tranche A and Tranche B sites, which will determine the relevant permitting date. A site is a Tranche A site if it meets the following criteria:

- It came into operation before 1 December 2016, or
- It is the subject of a capacity agreement arising from the 2014 or 2015 capacity auctions

A generator with a rated thermal input of less than 1MWth will be classed as Tranche A if:

- It is the subject of a capacity agreement arising from the 2014, 2015 or 2016 capacity auctions, or
- A FiT preliminary accreditation application was received by OfGEM before 1 December 2017, or
- Is the subject of an agreement to provide balancing services entered into before 31 October 2017.


Tranche B generators are all those that are not Tranche A.

The plant is classed as an existing medium combustion plant as put into operation prior to 20 December 2018, 'Put into operation' means the plant being fired up to its full load with its design fuel.

4.1.2 The Site

Rhymney Power Limited operate Rhymney Energy Park which is an aggregated 28.5 MWth natural gas fired power station located at Unit 48, Portmanmoor Road Industrial Estate, Cardiff, CF24 5HB.

The site has entered into a Capacity Market agreement sign post-31st October 2017 in October 2021, triggering the site to become a Tranche B Specified Generator.



4.1.3 What the Facility does

The site is used for balancing purposes and is made up of four containerised gas-engines that are fired on natural gas. Engines 1,2 and 3 are a J620 Gas Engine and Engine 4 is a Jenbacher J612, all four engines are fuelled on natural gas.

- Engine 1 – 3352 kW output (approximately 8.4MWth input),
- Engine 2 – 3352 kW output (approximately 8.4MWth input),
- Engine 3 – 3352 kW output (approximately 8.4MWth input),
- Engine 4 – 1320 kW output (approximately 3.3MWth input).

The engines together comprise a 'Specified Generator' used for the purpose of generating electricity. The Sites operational hours have been determined by the grid balancing requirements. Given the variability of the operational hours it has been assumed that the generators will operate continuously therefore the facility is permitted to operate for maximum 8,760 hours per year.

4.1.4 Key Issues in the Determination

Our decision includes but is not limited to the following:

- Air quality – Oxides of Nitrogen (NO and NO₂ expressed as NO₂)

This will be discussed separately in this decision document.

4.2 Operation of the Facility – general issues

4.2.1 Administrative issues

The Applicant is the sole Operator of the Facility. We are satisfied that the Applicant is the person who will have control over the operation of the Facility if the Permit were to be granted; and that the Applicant will be able to operate the Facility so as to comply with the conditions included in the Permit, if issued.

Relevant Convictions

NRW's COLINS Database has been checked to ensure that all relevant convictions have been declared. No relevant convictions were found.

Financial Provision

There is no known reason to consider that the operator will not be financially able to comply with the permit. The decision was taken in accordance with RGN 5 on Operator Competence.

4.2.2 Management

The Applicant has stated in the Application that they will implement an Environmental Management System (EMS) that will meet the requirements for an EMS in our "*How to comply with your environmental permit guidance*". The Applicant submitted a summary of the EMS with their application. The applicant has an EMS which is externally certified to ISO14001.

We are satisfied that appropriate management systems and management structures will be in place for this Facility, and that sufficient resources are available to the Operator to ensure compliance with all the Permit conditions.

4.2.3 Operating techniques

We have reviewed the operating techniques used by the Operator and compared these with the relevant guidance notes. The relevant guidance notes for this plant are:

- Technical Guidance Note (TGN) M5: Monitoring of stack emissions from medium combustion plants and specified generators

Monitoring of point source emissions to air will be carried out in line with the monitoring requirements contained within TGN M5 and will have MCERTS accreditation.

The operator has stated that they will implement the following quality assurance techniques and maintenance schedule, in order to for the generators to achieve and retain optimal performance. In order to enable each generator and the power plant in general to achieve and retain optimal performance in both efficiency and emissions, the plant will engage in the following best available operational management techniques:

- *DECC Developing Best available Techniques for combustion plants operating in the balancing market (2016)*, natural gas engines can readily comply with the 190 mg/Nm³ NO_x Emission Limit Value at 15 % O₂ content with the use of lean burn or enhanced lean burn primary abatement measures.
- Monitoring and confirmation of compliance with the NO_x Emission Limit Values will be undertaken within 4 months of the date of the permit issue.

We have reviewed the techniques used by the Operator and compared these with the relevant guidance notes. The proposed techniques are in line with benchmark techniques contained within the relevant guidance notes.

As a Specified Generator, the site must adhere to the following operating techniques specific for Specified Generator:

- Each generator must be operated in accordance with the manufacturer's instructions and records must be made and retained to demonstrate this.

- The operator must keep periods of start-up and shut down of the generators as short as possible
- There must be no persistent emission of 'dark smoke' as defined in section 3(1) of the Clean Air Act 1993.
- Where secondary abatement is required to ensure compliance with the NOx ELV it must be met within 10 minutes from when the generator commences operation or within 20 minutes when the generator was a Tranche A and is now a Tranche B generator.
- The stack must be vertical and unimpeded by cowls or caps.

We have specified the operating techniques and the operator must use the operating techniques specified Table S1.2 in the permit

5 Minimising the Facility's environmental impact

For this kind of regulated activity, the principal emissions are emissions to air. There are no permit conditions for water, land, odour or noise and BAT does not apply.

The next sections of this document explain how we have approached the critical issue of assessing the likely impact of air emissions from the Facility on human health and the environment and what measures we are requiring to ensure a high level of protection.

We have reviewed the operator's assessment of the environmental risk from the facility. The operator's risk assessment is satisfactory. The assessment shows that, applying the conservative criteria in our guidance on Environmental Risk Assessment, all emissions may be categorised as environmentally not significant.

We will discuss the operators risk assessment in more detail as follows:

5.1 Assessment of Impact on Air Quality

This section of the decision document deals primarily with the dispersion modelling of emissions to air from the stack(s) and its impact on local air quality.

The Applicant has assessed the Facility's potential emissions to air against the relevant air quality standards, and the potential impact upon human health. These assessments predict the potential effects on local air quality from the Facility's stack emission(s).

The air impact assessments, and the dispersion modelling has been based on the plant operating continuously up to 8760 hours per year at the relevant long-term or short-term emission limit values, i.e. the maximum permitted emission rate.

We are in agreement with this approach. The assumptions underpinning the model have been checked and are reasonably precautionary. The way in which the Applicant used dispersion models, its selection of input data, use of background data and the assumptions it made have been reviewed by Natural Resources Wales modelling specialists to establish the robustness of the Applicant's air impact assessment. The output from the model has then been used to inform further assessment of health impacts.

The Site itself not located within an AQMA however there are designated AQMAs situated 1.8km to the north-west and then 2.2km west-north-west of the site with designated ecological receptors located to the south.

A technical support request was sent to AQMRAT to review the modelling supplied as part of the application. The request was sent to check the impacts of NO_x on human receptors but mainly to assess the impact of short and long-term impacts on ecological receptors situated within the relevant screening distance. A response from AQMRAT broadly agrees with the conclusions stated in the application supplied by the applicant. However, the technical team did comment stating that further habitat receptors between 5 km and 10 km should be considered. As per current NRW guidance, the correct screening distance for this type of facility using natural gas as fuel is 5 km, therefore we do not consider any habitat receptors beyond 5 km.

The applicant has calculated process contributions (PC) and predicted environmental concentrations (PEC) at locations identified as sensitive receptor locations. The modelling results for NO_x will be discussed separately below.

Oxides of nitrogen (NO_x)

A long-term critical level of 40 µg/m³ (annual) and short-term critical level of 200 µg/m³ (hourly) was assumed for NO_x. At sensitive receptor locations the maximum predicted long-term PC was 1.2 µg/m³ representing >1 % of the long-term critical level and the long-term PEC was 26.2 µg/m³ representing <70 % of the long-term critical level. Therefore, in accordance with NRW guidance the long-term impacts from NO_x can be considered insignificant. At sensitive receptor locations the maximum predicted short-term PC was 31.2 µg/m³ representing >10 % of the short-term critical level and the short-term PEC was 81.2 µg/m³ representing <100 % of the short-term critical level. Therefore, in accordance with NRW guidance the short-term impacts from NO_x can be considered not significant.

5.2 Impact on Habitats sites, SSSIs, non-statutory conservation sites

The Facility is within the relevant screening distance criteria for protected conservation sites. A full assessment of the application and its potential to affect any of the sites has been carried out as part of the permit determination process. Natura 2000/Ramsar sites, SSSIs and non-statutory conservation sites will be discussed in detail separately below.

5.3 Natura 2000/Ramsar sites

The following Natura 2000/Ramsar sites are located within 5 km of the installation:

- SAC UK0013030 / SPA UK9015022 / Ramsar UK11081 Severn Estuary

An OGN 200 Form 1 (Habitats Regulation Assessment) was completed to assess the potential to affect the Natura 2000/Ramsar sites, this is available on the public register.

HRA Overall conclusion

The operational hours of the site have been will be determined and modelled by grid balancing requirements (anticipated to be between 1,500 – 2,000 hours per year).

However, given the variability in operating hours, as a precautionary approach, it has been assumed that the generators will operate 8,760 hours per year (i.e. continuously).

This modelling report is overly conservative as has modelled impact based on 8760 hours per year continuous operation whereas in reality it is expected the plant will be operational between 1,500 – 2000 hours per year. Therefore, impacts at the habitat site have been overestimated, notwithstanding this the critical loads or levels will not be exceeded even given the conservative nature of the modelling.

Therefore, in light of the conclusions of the appropriate assessment, it has been ascertained that the project will not adversely affect the integrity of any Natura 2000/Ramsar site, as documented in section 4 of OGN 200 form 1, and section 5 is applicable. The HRA was sent for consultation to the Statutory Nature Conservation Body which agreed with the conclusions.

SSSI Assessment

The following Sites of Special Scientific Interest (SSSI) are located within 2 km of the installation:

- SSSI Severn Estuary / Mor Hafren

An Appendix 4 Form was completed to assess the potential to effect the SSSI site, this is available to view on the public register. The assessment concluded the installation is not likely to damage any of the features of the SSSI site.

6 Setting ELVs and other Permit conditions

We have decided that emission limits should be set for the parameters listed in the permit. Emissions Limit Values (ELVs) are in line with those set out in the EPR Schedule 25B Regulations.

6.1 Monitoring

We have decided that monitoring should be carried out for the parameters listed in Schedule 3 of the permit using the methods and to the frequencies specified in those tables. These monitoring requirements have been imposed in order to demonstrate

compliance with the emissions limits in the permit, as per the ELV and monitoring frequency requirements specified within the EPR Schedule 25B Regulations.

For a combined Tranche B Specified Generator/existing Medium Combustion Plant, that is an engine fuelled on natural gas, the monitoring requirements are as follows:

Pollutant	Type of Specified Generator	Fuel Type	Emission Limit Value (mg/Nm³)	Monitoring Required
NOx	Gas engine	Natural Gas	190*	Periodic – every 3 years

*380 mg/Nm³ for dual fuel engines in gas mode.

Emission limit values are defined at a temperature of 273.15 K, a pressure of 101.3 kPa and after correction for the water vapour content of the waste gases and at a standardised O₂ content of 15 % for engines (and gas turbines)

For emissions to air, the methods for continuous and periodic monitoring are in accordance with the Environment Agency's Technical Guidance Note M5 for monitoring of stack gas emissions from medium combustion plants and specified generators.

Based on the information in the Application and the requirements set in the conditions of the permit we are satisfied that the monitoring techniques, personnel and equipment employed by the Operator will have either MCERTS certification or MCERTS accreditation as appropriate.

6.2 Reporting

We have specified the reporting requirements in Schedule 4 of the Permit to ensure data is reported to enable timely review by Natural Resources Wales to ensure compliance with permit conditions.

7 SG Charges and Subsistence Fees

The type of application regarding SG will have an associated charge. The SG application type and number of plant will also form the basis for ongoing subsistence fees. More information on this can be found in our charging scheme on our website.