

Compliance Report

Company:Harsco Environmental Contact:Paul Roberts

Authorisation number (s):Lancing Booth Stack Monitor Q4 2021

No exceedances

From:01 Oct 21 00:55:49 To:31 Dec 21 00:55:50

Device 1 : Stack1 Dust Cal Factor: 0.52 (constant) Average:0.284 Averaging Period:1 hrs

Emission Limit: 20.00 INDmg/m3

Date	Max Value (INDmg/m3)	Number of failures	95% Compliance	Max < 150% Limit
01 Oct 21	3.31	0	pass	pass
02 Oct 21	0.15	0	pass	pass
03 Oct 21	0.46	0	pass	pass
04 Oct 21	1.16	0	pass	pass
05 Oct 21	0.12	0	pass	pass
06 Oct 21	0.06	0	pass	pass
07 Oct 21	6.25	0	pass	pass
08 Oct 21	0.08	0	pass	pass
09 Oct 21	0.04	0	pass	pass
10 Oct 21	0.02	0	pass	pass
11 Oct 21	9.46	0	pass	pass
12 Oct 21	0.01	0	pass	pass
13 Oct 21	0.01	0	pass	pass
14 Oct 21	0.01	0	pass	pass
15 Oct 21	0.03	0	pass	pass
16 Oct 21	0.01	0	pass	pass
17 Oct 21	0.01	0	pass	pass
18 Oct 21	0.05	0	pass	pass
19 Oct 21	1.82	0	pass	pass
20 Oct 21	0.48	0	pass	pass
21 Oct 21	16.42	0	pass	pass
22 Oct 21	4.70	0	pass	pass
23 Oct 21	0.06	0	pass	pass
24 Oct 21	0.31	0	pass	pass
25 Oct 21	6.45	0	pass	pass
26 Oct 21	0.08	0	pass	pass
27 Oct 21	6.17	0	pass	pass
28 Oct 21	4.66	0	pass	pass
29 Oct 21	2.79	0	pass	pass
30 Oct 21	0.56	0	pass	pass
31 Oct 21	0.37	0	pass	pass
01 Nov 21	0.06	0	pass	pass
02 Nov 21	0.18	0	pass	pass
03 Nov 21	4.03	0	pass	pass
04 Nov 21	5.21	0	pass	pass
05 Nov 21	6.40	0	pass	pass
06 Nov 21	0.12	0	pass	pass
07 Nov 21	0.12	0	pass	pass
08 Nov 21	5.38	0	pass	pass
09 Nov 21	5.06	0	pass	pass
10 Nov 21	6.50	0	pass	pass
11 Nov 21	7.04	0	pass	pass
12 Nov 21	0.09	0	pass	pass
13 Nov 21	0.07	0	pass	pass
14 Nov 21	0.05	0	pass	pass
15 Nov 21	0.04	0	pass	pass
16 Nov 21	0.04	0	pass	pass
17 Nov 21	0.08	0	pass	pass
18 Nov 21	0.04	0	pass	pass
19 Nov 21	0.03	0	pass	pass
20 Nov 21	0.03	0	pass	pass
21 Nov 21	0.10	0	pass	pass
22 Nov 21	0.10	0	pass	pass
23 Nov 21	0.06	0	pass	pass
24 Nov 21	2.42	0	pass	pass
25 Nov 21	0.09	0	pass	pass
26 Nov 21	3.83	0	pass	pass
27 Nov 21	0.23	0	pass	pass
28 Nov 21	0.14	0	pass	pass
29 Nov 21	0.08	0	pass	pass
30 Nov 21	1.28	0	pass	pass
01 Dec 21	0.25	0	pass	pass
02 Dec 21	1.96	0	pass	pass
03 Dec 21	5.49	0	pass	pass
04 Dec 21	0.24	0	pass	pass
05 Dec 21	0.30	0	pass	pass
06 Dec 21	0.11	0	pass	pass
07 Dec 21	0.25	0	pass	pass
08 Dec 21	0.19	0	pass	pass
09 Dec 21	5.72	0	pass	pass

Date	Max Value (INDmg/m3)	Number of failures	95% Compliance	Max < 150% Limit
10 Dec 21	5.28	0	pass	pass
11 Dec 21	0.15	0	pass	pass
12 Dec 21	0.07	0	pass	pass
13 Dec 21	0.38	0	pass	pass
14 Dec 21	0.26	0	pass	pass
15 Dec 21	0.16	0	pass	pass
16 Dec 21	0.06	0	pass	pass
17 Dec 21	0.08	0	pass	pass
18 Dec 21	0.08	0	pass	pass
19 Dec 21	0.06	0	pass	pass
20 Dec 21	0.08	0	pass	pass
21 Dec 21	0.13	0	pass	pass
22 Dec 21	0.26	0	pass	pass
23 Dec 21	0.14	0	pass	pass
24 Dec 21	0.31	0	pass	pass
25 Dec 21	0.89	0	pass	pass
26 Dec 21	0.38	0	pass	pass
27 Dec 21	0.15	0	pass	pass
28 Dec 21	0.17	0	pass	pass
29 Dec 21	0.18	0	pass	pass
30 Dec 21	0.10	0	pass	pass
31 Dec 21	0.14	0	pass	pass