

Schedule 5 – Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provision of the EP Regulations.

Part A

Permit number	EPR/CB3091HY
Name of operator	Cambrian Pet Foods Ltd
Location of Facility	Tywi Valley Food Park Station Road Llangadog Carmarthenshire SA19 9LN
Time and date of the detection	

(a) Notification requirements for any activity that gives rise to an incident or accident which significantly affects or may significantly affect the environment

To be notified within 24 hours

Date and time of the event	
Reference or description of the location of the event	
Description of where any release into the environment took place	
Substance(s) potentially released	
Best estimate of the quantity of rate of release of substances	
Measures taken, or intended to be taken, to stop any emission	
Description of the failure or accident.	

(b) Notification requirements for the breach of a permit condition

To be notified within 24 hours

Emission point reference/source	Point S1 on site plan in Schedule 7 emission to Afon Tywi
Parameter(s)	Maximum daily discharge volume
Limit	1000m ³
Measured value and uncertainty	The above limit includes rainfall from the 17 acre site.
Date and time of monitoring	01.11.21 at 19.24 12.11.21 at 21.00 14.12.21 at 22.33

Measures taken, or intended to be taken, to stop the emission	We are monitoring daily water usage on site and have identified potential areas for reduction. The abstraction flowmeter has been calibrated. A weather station is being installed so we can accurately record rainfall on site, to determine accurately site rainfall data.
---	---

Time periods for notification following detection of a breach of a limit	
Parameter	Notification period

(c) in the event of a breach of permit condition which poses and immediate danger to human health or threatens to cause an immediate significant adverse effect on the environment:	
To be notified within 24 hours	
Description of where the effect on the environment was detected	
Substance(s) detected	
Concentrations of substances detected	
Date of monitoring/sampling	

Part B – to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	
Measures taken, or intended to be taken, to prevent a recurrence of the incident	The permit limit of 1000m³ per day includes both rainfall and surface waters from the 17 acre site. During periods of rainfall, we are unable to prevent surface water that is captured through site drains being directed through the ETP which is then included in our daily flow figures. Please refer to attached example graphs below showing screen grabs taken from NRW River Levels, rainfall and sea data SN7056328532 for the Afon Bran
Measures taken, or intended to be taken, to rectify limit or prevent any pollution of the environment which has been or may be caused by the emission	We have a working party established to look at practical ways we can reduce process waters. We are installing a weather station to accurately record rainfall on our site.
The dates of any unauthorised emissions from the facility in the preceding 24 months.	N/A

Name*	Philippa Stanley
Post	HS & E Manager
Signature	Philippa Stanley

Date	24.01.22

*authorised to sign on behalf of the operator

Please refer to an example graphs below to demonstrate water height in the near river Bran on the corresponding dates concerned. Please note the rainfall will enter and be processed within the ETP, so there is a lag time between rainfall and breach occurring.



