

Dec 2021

Day	Downtime	Availability	Daily Mwh	Rationale
1	0	100.00%	315	
2	0	100.00%	334	
3	0	100.00%	332	
4	0	100.00%	328	
5	0	100.00%	333	
6	0	100.00%	332	
7	0	100.00%	330	
8	0	100.00%	326	
9	0	100.00%	331	
10	0	100.00%	332	
11	0	100.00%	331	
12	0	100.00%	329	
13	0	100.00%	330	
14	0	100.00%	298	
15	0	100.00%	330	
16	0	100.00%	313	CC2 Refurb Plant online Emergency Dosing / Oil on due to log jam
17	0.5	97.92%	264	Plant trip on filter / ID Fan DP as slug of wet fuel tripped ID fan - oil on for log jam
18	0	100.00%	299	CC2 Refurb Plant online Emergency Dosing
19	0	100.00%	319	CC2 Refurb Plant online Emergency Dosing
20	0	100.00%	325	
21	0	100.00%	333	
22	0	100.00%	331	
23	0	100.00%	328	
24	0	100.00%	329	
25	0	100.00%	329	
26	3.5	85.42%	267	Lost fuel feed due to log jam in disk screen and feedback error or screen drive feedback.
27	7.5	68.75%	220	CC3 chain snapped, Replaced chain paddles & sprockets
28	24	0.00%	0	
29	20.5	14.58%	40	
30	0	100.00%	328	
31	0	100.00%	328	
Month	56	92.47%	9264	